

50-354

## Document Transmittal Form

To: NRC - WASHINGTON  
DOCUMENT CONTROL DESK  
WASHINGTON, DC 20555

ID: HECG0065

Date: 20000612

Please update your controlled set of documents with the following list of documents:

Document ID	Revision	Status	Quantity	Format	RecNo
PRC HECG-HECG-TOC-BASIS 000	7	A	1	H	70733
PRC HECG-SECT.03.1 (BASIS) 000	2	A	1	H	70553
PRC HECG-SECT.03.2 (BASIS) 000	1	A	1	H	70598
PRC HECG-SECT.03.3 (BASIS) 000	2	A	1	H	70643
PRC HECG-SECT.08.1 (BASIS) 000	1	A	1	H	70689

This acknowledgement receipt must be returned within 5 working days to:

Document Management:  
PSEG Nuclear  
BOX 236  
Hancocks's Bridge, NJ 08038

MC N04

Your signature below verifies that:

(1) the above documents have been filed and superseded documents have been removed and destroyed or clearly marked as obsolete.

(2) the mailing address and copy holder information are correct or corrections have been identified on this transmittal.

☐ Place checkmark here to remove from controlled distribution

Signature: \_\_\_\_\_

Date: \_\_\_\_\_

KRR-037

A045

HOPE CREEK GENERATING STATION  
EVENT CLASSIFICATION GUIDE  
TECHNICAL BASIS  
June 12, 2000

CHANGE PAGES FOR  
REVISION #7

PSE&G  
CONTROL  
COPY # HECG0065

The Table of Contents (T.O.C.) forms a general guide to the current revision of each section and attachment of the Hope Creek ECG Technical Basis. The changes that are made in this T.O.C. Revision #7 are shown below.

1. Check that your revision packet is complete.
2. Add the revised documents.
3. Remove and recycle the outdated material listed below.

ADD			REMOVE		
<u>Pages</u>	<u>Description</u>	<u>Rev.</u>	<u>Pages</u>	<u>Description</u>	<u>Rev.</u>
ALL	T.O.C.	7	ALL	T.O.C.	6
ALL	Section 3.1	02	ALL	Section 3.1	01
ALL	Section 3.2	01	ALL	Section 3.2	00
ALL	Section 3.3	02	ALL	Section 3.3	01
ALL	Section 8.1	01	ALL	Section 8.1	00

REVISION SUMMARY:

Sections 3.1.1, 3.2.1.b, & 3.3.1 clarifies the loss of reactor level indication paragraph.

Section 3.3.4.a clarifies "After valve closure from the main Control room has been attempted."

Section 8.1 clarifies the use of Main Steam line drains to control Reactor pressure.

**HOPE CREEK ECG TECHNICAL BASIS**  
**TABLE OF CONTENTS/SIGNATURE PAGE**

**PSE&G**  
**CONTROL**  
**COPY #**

**HECG-0065**

<u>SECTION</u>	<u>TITLE</u>	<u>REV #</u>	<u>PAGES</u>	<u>DATE</u>
T.O.C.	Table of Contents/Signature Page	07	3	06/12/00
i	Introduction and Usage	00	3	01/21/97
ii	Glossary of Acronyms & Abbreviations	00	5	01/21/97
1.0	Fuel Clad Challenge	00	9	01/21/97
2.0	RCS Challenge	00	8	01/21/97
3.0	Fission Product Barriers (Table)			
	3.1 Fuel Clad Barrier	02	13	06/12/00
	3.2 RCS Barrier	01	18	06/12/00
	3.3 Containment Barrier	02	18	06/12/00
4.0	EC Discretion	00	8	01/21/97
5.0	Failure to SCRAM	00	10	01/21/97
6.0	Radiological Releases/Occurrences			
	6.1 Gaseous Effluent Release	00	44	01/21/97
	6.2 Liquid Effluent Release	00	4	01/21/97
	6.3 In - Plant Radiation Occurrences	00	6	01/21/97
	6.4 Irradiated Fuel Event	00	8	01/21/97
7.0	Electrical Power			
	7.1 Loss of AC Power Capabilities	01	18	05/12/97
	7.2 Loss of DC Power Capabilities	00	5	01/21/97
8.0	System Malfunctions			
	8.1 Loss of Heat Removal Capability	01	8	06/12/00
	8.2 Loss of Overhead Annunciators	00	8	01/21/97
	8.3 Loss of Communications Capability	00	4	01/21/97
	8.4 Control Room Evacuation	00	4	01/21/97
	8.5 Technical Specifications	00	2	01/21/97
9.0	Hazards - Internal/External			
	9.1 Security Threats	00	8	01/21/97
	9.2 Fire	00	6	01/21/97
	9.3 Explosion	00	4	01/21/97
	9.4 Toxic/Flammable Gases	00	11	01/21/97
	9.5 Seismic Event	00	4	01/21/97
	9.6 High Winds	00	7	01/21/97
	9.7 Flooding	00	4	01/21/97
	9.8 Turbine Failure/Vehicle Crash/ Missile Impact	00	6	01/21/97
	9.9 River Level	00	4	01/21/97

**HOPE CREEK ECG TECHNICAL BASIS  
TABLE OF CONTENTS/SIGNATURE PAGE**

<u>SECTION</u>	<u>TITLE</u>	<u>REV #</u>	<u>PAGES</u>	<u>DATE</u>
10.0	Reserved for future use			
11.0	Reportable Action Levels (RALs)			
11.1	Technical Specifications	01	7	08/28/97
11.2	Design Basis/ Unanalyzed Condition	01	6	03/13/97
11.3	Engineered Safety Features (ESF)	02	7	12/29/98
11.4	Personnel Safety/Overexposure	00	8	01/21/97
11.5	Environmental	00	3	01/21/97
11.6	After-the-Fact	00	1	01/21/97
11.7	Security/Emergency Response Capabilities	02	5	12/15/99
11.8	Public Interest	00	3	01/21/97
11.9	Accidental Criticality/ Special Nuclear Material / Rad Material Shipments - Releases	01	8	02/18/00
11.10	Voluntary Notifications	00	2	01/21/97

**SIGNATURE PAGE**

Prepared By: Frank Hughes 3.1 r1, 3.2 r0, 3.3r1 & 8.1 r0 5-31-00  
 (If Editorial Revisions Only, Last Approved Revision) Date

Section/Attachments Revised: N/A  
 (List Non-Editorial Only - Section/Attachments) Date

Reviewed By: N/A  
 Station Qualified Reviewer Date

Reviewed By: N/A  
 Department Manager Date

Reviewed By: N/A  
 Manager – Licensing Date  
 (Reportable Action Level (Section 11) and associated Attachments marked by “L”)

Reviewed By: Cy W. Banner 5-31-00  
 Manager – CA, EP, & IT, Date

Reviewed By: N/A  
 Manager – Quality Assessment - NBU Date  
 (If Applicable)

**SORC Review and Station Approvals**

<u>N/A</u>	<u>N/A</u>
Mtg. No. Hope Creek Chairman	Vice President - Nuclear Operations
<u>                    </u>	<u>                    </u>
Date	Date

Effective Date of this Revision: 6/12/00  
 Date

### 3.0 Fission Product Barriers

#### 3.1 Fuel Clad Barrier

##### 3.1.1 REACTOR WATER LEVEL

###### 3.1.1.a

IC Potential Loss of Fuel Clad Barrier = 3 POINTS

EAL

PSE&G  
CONTROL  
COPY #

HECG0065

Reactor Water Level REACHES - 161" (Top of Active Fuel), EXCLUDING intentional lowering of Reactor Water Level during an ATWS

OPERATIONAL CONDITION - 1, 2, 3

BASIS

Reactor Water Level reaching -161" (Top of Active Fuel - TAF), excluding intentional lowering of Reactor Water Level during an ATWS, results in an inability to maintain adequate core cooling by core submergence, causing a Potential Loss of the Fuel Clad Barrier. Without core submergence, the integrity of the fuel clad barrier is in jeopardy. Appropriate classification under this EAL is based on reaching Reactor Water Level of -161" (instead of being able to restore and maintain above -161") due to the potentially severe consequences of a loss of core submergence. Reactor Water Level reaching this threshold results from either a LOCA exceeding available makeup capacity or a Total Loss of High Pressure injection capability.

In addition, during an Anticipated Transient Without Scram (ATWS), it is possible that operator actions will be taken to intentionally lower Reactor Water Level to between -161" and -190", for Reactor Power Control purposes. For this event, classification must be made in accordance with EAL Section 5.0

#### Barrier Analysis

Fuel Clad Barrier has been potentially lost

#### ESCALATION CRITERIA

Emergency Classification will escalate based upon the Potential Loss or Loss of additional Fission Product Barriers per EAL Section 3.0.

EAL - 3.1.1.a  
Rev. 02

## DISCUSSION

Core Submergence is the preferred method of maintaining adequate core cooling. When Reactor Water Level decreases to below TAF, the ability to effectively remove decay heat is being challenged, and as such the Fuel Clad fission product barrier can no longer be considered intact. While the Emergency Operating Procedures provide contingencies to establish adequate core cooling when Reactor Water Level drops below TAF (Steam Cooling with or without injection), these actions are designed to be an alternative method of providing adequate core cooling while actions are taken to reestablish core submergence. Sustained partial or total core uncover can result in fuel clad damage and a significant release of fission products to the Reactor coolant. Sustained core uncover can also result in a breach of the Reactor Vessel due to core melt material interaction with the RPV.

A Loss of Core Submergence will occur when the rate of inventory loss is greater than the rate of inventory makeup from High Pressure injection sources. This condition can occur as the result of the following events/sequences (excluding intentional lowering of Reactor Water Level during an ATWS).

A LOCA will cause Reactor Water Level to reach the Top of Active Fuel when the LOCA is the result of a large break (momentary core uncover is expected to occur under this condition) or when the LOCA is due to a small or intermediate break in combination with an inability of High Pressure injection sources to keep up with the leakrate.

A Loss of High Pressure injection sources without the presence of a LOCA will also result in Reactor Water Level decreasing to TAF, due to continued Reactor Steam Flow without makeup.

Either of these events/sequences results in a challenge to the Fuel Clad Barrier when Reactor Water Level reaches TAF due to core uncover, hence classification at this threshold is appropriate. However, for both these sequences, Low Pressure ECCS are designed to inject to the Reactor as Reactor Pressure decreases below the shutoff head of the pumps. Reactor Depressurization will occur either due to the LOCA or Manual initiation of Emergency Depressurization when Reactor Water Level reaches -161", provided injection systems are available. This will allow for restoration of Reactor Water Level and re-establishment of Core Submergence. Failure of these systems to restore and maintain Reactor Water Level above -200" will require escalation.

If all Reactor Level instrumentation is lost and EOP 206 or EOP 206A is entered, then a classification of a Site Area Emergency is warranted, based on EALs 3.1.1.a & 3.2.1.b (-161"). EOP 206(A) assures a level at Top of Active Fuel will be maintained when successful, "at least 4 SRVs are open and RPV press is at least 75 psig above supp chamber press, etc.", then this EAL (-161") is appropriate.

If EOP 206(A) is not successful, the process will not restore and maintain reactor level above -200" (SAG entry is required). A General Emergency is the appropriate classification based on EALs 3.1.1.b, 3.2.1.b & 3.3.1.

#### DEVIATION

None

#### REFERENCES

NUMARC NESP-007, FC2

HC.OP-EO.ZZ-0100 (Q)-FC, Reactor Scram

HC.OP-EO.ZZ-0101 (Q)-FC, Reactor Pressure Vessel (RPV) Control

HC.OP-EO.ZZ-0201 (Q)-FC, Alternate Level Control

HC.OP-EO.ZZ-0207 (Q)-FC, Level/Power Control

BWR Owner's Group Emergency Procedure Guidelines, Rev. 4

### 3.0 Fission Product Barriers

#### 3.1 Fuel Clad Barrier

##### 3.1.1 REACTOR WATER LEVEL

###### 3.1.1.b

IC Loss of Fuel Clad Barrier = 4 POINTS

EAL

Reactor Water Level **CANNOT BE RESTORED AND MAINTAINED** above -200" (Minimum Zero Injection RPV Water Level)

OPERATIONAL CONDITION - 1, 2, 3

BASIS

Inability to restore and maintain Reactor Water Level above - 200" (Minimum Zero Injection RPV Water Level), results in a loss of adequate core cooling by all mechanisms, causing a Loss of the Fuel Clad Barrier. Without adequate core cooling, the integrity of the fuel clad barrier can no longer be assured. Appropriate classification under this EAL is based on the failure of injection systems to restore and maintain Reactor Water Level above -200", following a condition that causes level to decrease below the threshold.

For example, a large break LOCA is expected to cause Reactor Water Level to momentarily decrease below -200", due to the response time of Low Pressure ECCS. As these systems initiate and commence injection to the Reactor, water level will begin to increase and should be able to be maintained above -200". In this case, classification under this EAL is not appropriate as plant systems have performed their intended design function and will eventually restore adequate core cooling by core submergence.

However, in the event that Low Pressure ECCS and alternate injection system, as defined in the EOPs are in a degraded condition (i.e., Station Blackout, ECCS Suction Strainer plugging, etc.) and Reactor Water Level can not be restored and maintained above -200", then classification under this EAL should occur due to the potential for release of energy to the containment from imminent fuel failure.

##### Barrier Analysis

Fuel Clad Barrier has been lost.

EAL 3.1.1.b

Rev. 02

## ESCALATION CRITERIA

Emergency Classification will escalate based upon the Potential Loss or Loss of additional Fission Product Barriers per EAL Section 3.0.

## DISCUSSION

Core submergence is the preferred method for maintaining adequate core cooling. The failure to reestablish Reactor Water Level above -161", the Top of Active Fuel (TAF), for an extended period of time could lead to a significant of fuel damage. With Reactor Water Level below TAF, but above the Minimum Zero Injection RPV Water Level (-200"), adequate core cooling occurs due to the cooling effects of steam generated in the covered portion of the core flowing through the uncovered portion (Steam Cooling). The Minimum Zero Injection RPV Water Level is defined in the Emergency Operating Procedures. This method of cooling precludes any fuel clad temperature in the uncovered portion of the core from exceeding 1800°F. As Reactor Water Level drops below -200" with no injection available, this method of cooling becomes inadequate.

Prolonged lack of cooling may result in severe overheating of the fuel clad, additional release of energy from accelerated clad oxidation, and eventual fuel melting. For events starting from full power operation, the failure to promptly reflood could result in some fuel melting. Even under these conditions vessel failure and containment failure with resultant release to the public would not be expected for some time. Reactor Water Level remaining below TAF for an extended amount of time represents an early indicator that significant core damage is in progress while providing sufficient time to initiate public protective actions.

Ample time should be allowed for Low Pressure ECCS and alternate injection systems to restore Reactor Water Level prior to entry into this classification. The time basis for deciding whether or not Reactor Water can be maintained > -200" should be based on the rate of reactor depressurization, the availability of low pressure injection sources, (ECCS and alternate injection systems), and the rate of Reactor coolant inventory loss. Indications such as Reactor Water Level trend, injection flow rates, containment parameter trends, and low pressure injection system operability should also be considered.

In the event, Reactor Water Level can not be restored > -200", containment flooding will be required by the EOPs. This will attempt to flood the containment as a means of flooding the RPV, and use a flooded containment as a heat sink for the nuclear fuel.

If all Reactor Level instrumentation is lost and EOP 206 or EOP 206A is entered, then a classification of a Site Area Emergency is warranted, based on EALs 3.1.1.a & 3.2.1.b (-161"). EOP 206(A) assures a level at Top of Active Fuel will be maintained when successful, "at least 4 SRVs are open and RPV press is at least 75 psig above supp chamber press, etc.", then this EAL (-200") is not appropriate. If EOP 206(A) is not successful, the process will not restore and

maintain reactor level above -200" (SAG entry is required). A General Emergency is the appropriate classification based on EALs 3.1.1.b, 3.2.1.b & 3.3.1.

**DEVIATION**

None

**REFERENCES**

NUMARC NESP-0007, FC2

HC.OP-EO.ZZ-0100 (Q)-FC, Reactor Scram

HC.OP-EO.ZZ-0101 (Q)-FC, Reactor Pressure Vessel (RPV) Control

HC.OP-EO.ZZ-0201 (Q)-FC, Alternate Level Control

HC.OP-EO.ZZ-0207 (Q)-FC, Level/Power Control

HC.OP-EO.ZZ-0208 (Q)-FC, Primary Containment Flooding

BWR Owners Group Emergency Procedure Guidelines, Revision 4

### 3.0 Fission Product Barriers

#### 3.1 Fuel Clad Barrier

##### 3.1.2 DRYWELL ATMOSPHERE POST ACCIDENT (DAPA) RADIATION LEVEL

IC Loss of Fuel Clad Barrier = 4 POINTS

EAL

DAPA Radiation Monitor reading $\geq$ 5000 R/hr
---

OPERATIONAL CONDITION - 1, 2, 3

#### BASIS

Drywell Atmosphere Post Accident (DAPA) Radiation monitors indicating 5000 R/hr or greater corresponds to an instantaneous release of Reactor Coolant with a concentration of 300  $\mu\text{Ci/gm}$  Dose Equivalent Iodine-131 (DEI-131) into the Primary Containment. This value of Reactor Coolant Activity is well above the threshold that could occur as the result of Iodine Spiking, resin/chemical intrusion transients or a HWCI System malfunction. This activity level corresponds to fuel clad damage of approximately 3.8%.

In addition, there are other events that could cause Drywell Atmosphere radiation levels to increase to this threshold, without a LOCA in the Drywell. These events involve shine from the reactor core if it is uncovered. While such events would not necessarily involve the calculated fuel clad damage percentage, they would be classifiable under other EALs as a Site Area Emergency level or higher.

#### Barrier Analysis

Fuel Clad Barrier has been lost.

#### ESCALATION CRITERIA

Emergency Classification will escalate based on the Potential Loss or Loss of additional Fission Product Barriers per EAL Section 3.0.

EAL - 3.1.2  
Rev. 02

**DISCUSSION**

EAL 3.1.3 provides a core damage analysis showing that a Reactor Coolant activity of 300  $\mu\text{Ci/gm}$  Dose Equivalent Iodine-131(DEI) is indicative of 3.8% clad damage. Using Attachment 2 of EPIP 205H, 1% clad damage is indicated by a DAPA reading of 1.4E3 R/hr at 0.1 hrs after shutdown (the most conservative). This is shown on the Attachment as the 0.1% TID line. Extrapolating to the 3.8% clad damage point gives 5.32E3 R/hr. This is rounded to 5.0E3 R/hr. Hence, the Fuel Clad Barrier is lost.

NUMARC EAL RC3 addresses the use of DAPA to assess the status of the RCS Barrier, based on the release of Reactor Coolant into the Drywell. This EAL threshold is calculated assuming the instantaneous release and dispersal of the Reactor Coolant noble gas and iodine inventory associated with normal operating concentrations (within TS limits) into the Drywell Atmosphere. The reading would be lower than the threshold for EAL 3.1.2, thus being indicative of an RCS leak only. However, due to the inability of the DAPA radiation monitors to distinguish between a cloud of released RCS gases and shine from the Reactor Vessel and adjacent piping and components, this EAL is being omitted, as permitted by the NUMARC EALs, and other indications of RCS Leakage are being used. It should be recognized that DAPA exceeding 5000 R/hr would most likely occur due to core uncover, as Reactor Water Level decreases below the Top of Active Fuel. This condition will result in appropriate escalation to a Site Area Emergency in the Fission Product Barrier Table, and hence use of DAPA exceeding 5000 R/hr is not needed to detect a Loss of the RCS Barrier.

**DEVIATION**

None

**REFERENCES**

NUMARC NESP-007, FC3

NUMARC NESP-007, RC3

EPIP 205H, TSC - Post Accident Core Damage Assessment

HC.OP-AR.SP-0001(Q), Radiation Monitoring System Alarm Response

### 3.0 Fission Product Barriers

#### 3.1 Fuel Clad Barrier

##### 3.1.3 RCS IODINE CONCENTRATION

IC Loss of Fuel Clad Barrier = 4 POINTS

EAL

Reactor Coolant Sample Activity $\geq$ 300 $\mu\text{Ci/gm}$ Dose Equivalent I-131
--

OPERATIONAL CONDITION - 1, 2, 3

##### BASIS

Reactor Coolant sample analysis with specific activity greater than or equal to 300  $\mu\text{Ci/gm}$  Dose Equivalent I-131 (DEI-131) indicates fuel clad damage due to significant clad heating or mechanical stress, causing a Loss of the Fuel Clad Barrier. This threshold is well above the activity level that could occur as the result of Iodine spiking. The use of the term "Valid" as a qualifier for event classification is not required, since Reactor Coolant Activity of this magnitude can only occur as the result of fuel clad damage. This activity level corresponds to approximately 3.8% fuel clad damage.

##### Barrier Analysis

Fuel Clad Barrier has been lost.

##### ESCALATION CRITERIA

Emergency Classification will escalate based on the Potential Loss or Loss of additional Fission Product Barriers per EAL Section 3.0.

EAL - 3.1.3  
Rev. 02

## DISCUSSION

The percentage of Fuel Damage that corresponds to an RCS Activity of  $300 \mu\text{Ci/gm}$  DEI-131 is calculated as follows (for purposes of this calculation, cc and gm are considered equivalent):

Dose Factors (RG-1.109)

$$\text{I-131} = 4.39\text{E-}3$$

$$\text{I-132} = 5.23\text{E-}5$$

$$\text{I-133} = 1.04\text{E-}3$$

$$\text{I-134} = 1.37\text{E-}5$$

$$\text{I-135} = 2.14\text{E-}4$$

Total core inventory (HCGS-UFSAR, table 12.2-135). This table gives 50% inventory, so table values are multiplied by 2.0.

$$\text{I-131} = 8.64\text{E}7 \text{ Ci}$$

$$\text{I-132} = 1.29\text{E}8 \text{ Ci}$$

$$\text{I-133} = 1.99\text{E}8 \text{ Ci}$$

$$\text{I-134} = 2.32\text{E}8 \text{ Ci}$$

$$\text{I-135} = 1.81\text{E}8 \text{ Ci}$$

Reactor Water Volume = 13000 cubic feet (HCGS-UFSAR, table 12.3-2)

Clad Release Fraction for iodines = 0.02 (Table 4.1, NUREG-1228)

The activity of each isotope in the clad would then be:

$$\text{I-131} = 8.64\text{E}7(0.02) = 1.73\text{E}6 \text{ Ci}$$

$$\text{I-132} = 1.29\text{E}8(0.02) = 2.58\text{E}6 \text{ Ci}$$

$$\text{I-133} = 1.99\text{E}8(0.02) = 3.98\text{E}6 \text{ Ci}$$

$$\text{I-134} = 2.32\text{E}8(0.02) = 4.64\text{E}6 \text{ Ci}$$

$$\text{I-135} = 1.81\text{E}8(0.02) = 3.62\text{E}6 \text{ Ci}$$

These activities are equivalent to  $2.89\text{E}6 \text{ Ci}$  DEI-131

$$\text{DEI-131} = \frac{4.39\text{E-}3(1.73\text{E}6) + 5.23\text{E-}5(2.58\text{E}6) + 1.04\text{E-}3(3.98\text{E}6) + 1.37\text{E-}5(4.64\text{E}6) + 2.14\text{E-}4(3.62\text{E}6)}{4.93\text{E-}3}$$

Calculating the equivalent concentration:

$$\text{Conc} = \frac{2.89\text{E}6 \text{ Ci}(1\text{E}6 \mu\text{Ci} / \text{Ci})}{13000 \text{ cf}(2.8\text{E}4 \text{ cc} / \text{cf})} = 7.94\text{E}3 \mu\text{Ci/cc}$$

which represents the 100% clad damage concentration.

300  $\mu\text{Ci/cc}$  DEI-131 is then equivalent to:

$$\frac{300 \mu\text{Ci} / \text{cc}}{7.94\text{E}3 \mu\text{Ci} / \text{cc}} = 3.78\%$$

This is rounded to 3.8%.

## DEVIATION

None

## REFERENCES

NUMARC NESP-007, FC1

HC.OP-AB.ZZ-0100(Q), High Reactor Coolant Activity

HC.OP-AB.ZZ-0203(Q), Main Steam Line High Radiation

HCGS Technical Specification LCO 3.4.5

NUREG 1228 - Source Term Estimation During Incident Response to Severe Nuclear Power Plant Accidents, Table 4.1

Reg. Guide 1.109, Table E-9

HCGS-UFSAR, Table 12.2-135 and Table 12.3-2

10 CFR100

### 3.0 Fission Product Barriers

#### 3.1 Fuel Clad Barrier

##### 3.1.4 EMERGENCY COORDINATOR JUDGMENT

###### 3.1.4.a/ 3.1.4.b

IC Potential Loss (= 3 POINTS) or Loss of Fuel Clad Barrier (= 4 POINTS)

EAL

ANY condition, in the opinion of the EC, that indicates EITHER  
a Potential Loss OR Loss of the Fuel Clad Barrier

OPERATIONAL CONDITION - 1, 2, 3

BASIS

This EAL allows the Emergency Coordinator (EC) to address any condition that effects the integrity of the Fuel Clad Barrier that is not already covered elsewhere in the Fission Product Barrier Table. A complete loss of the ability to monitor the Fuel Clad Barrier should be considered as a "Potential Loss" of that barrier.

Barrier Analysis

Fuel Clad Barrier has been potentially lost or lost.

ESCALATION CRITERIA

Emergency Classification will escalate based on the potential loss or loss of additional Fission Product Barriers per EAL Section 3.0.

DISCUSSION

None

DEVIATION

None

EAL - 3.1.4.a/ 3.1.4.b  
Rev. 02

**REFERENCES**

NUMARC NESP-007, FC5

### 3.0 Fission Product Barriers

#### 3.2 RCS Barrier

##### 3.2.1 REACTOR WATER LEVEL

###### 3.2.1.a

IC Potential Loss of RCS Barrier = 3 POINTS

EAL

PSE&G  
CONTROL  
COPY # HECG0065

Reactor Water Level REACHES -129", EXCLUDING intentional lowering of Reactor Water Level during an ATWS

OPERATIONAL CONDITION - 1, 2, 3

#### BASIS

Reactor Water Level reaching -129", excluding intentional lowering of Reactor Water Level during an ATWS, indicates that the inventory loss from the RCS exceeds the capacity of available High Pressure injection sources. Below this threshold, a challenge to maintaining Adequate Core Cooling by core submergence exists, based on Reactor Water Level continuing to decrease, thus a Potential Loss of the RCS Barrier exists.

Without core submergence, the integrity of the Fuel Clad would be in jeopardy. Appropriate classification under this EAL is based on reaching Reactor Water Level of -129" (instead of being able to restore and maintain above -129"), due to the challenge that exists to core submergence. Reactor Water Level reaching this threshold results from either a LOCA exceeding available makeup capacity or a Total Loss of High Pressure injection capability.

In addition, during an Anticipated Transient Without Scram (ATWS), it is possible that operator action will be taken to intentionally lower Reactor Water Level to below -129" for Reactor Power Control purposes. For this event, classification must be made in accordance with EAL Section 5.0.

#### Barrier Analysis

RCS Barrier has been potentially lost.

EAL - 3.2.1.a  
Rev. 01

## ESCALATION CRITERIA

Emergency Classification will escalate based on the Potential Loss or Loss of additional Fission Product Barriers per EAL Section 3.0.

## DISCUSSION

Core Submergence is the preferred method of maintaining adequate core cooling. When Reactor Water Level decreases to -129", a significant challenge to continued core submergence exists. The threshold for this EAL corresponds to the initiation setpoint for the low pressure Emergency Core Cooling Systems (ECCS).

Reactor Water Level reaching -129" occurs when the rate of inventory loss is greater than the rate of inventory makeup from High Pressure injection sources. This condition can occur as the result of the following events/sequences (excluding intentional lowering of Reactor Water level during an ATWS).

A LOCA will cause Reactor Water Level to reach -129" when the LOCA is the result of a large break (momentary core uncover is expected to occur under this condition) or when the LOCA is due to a small or intermediate break in combination with an inability of High Pressure injection sources to keep up with the leak rate.

A Loss of High Pressure injection sources without the presence of a LOCA will also result in Reactor Water Level decreasing to -129", due to continued Reactor Steam Flow without makeup.

Either of these events/sequences results in a potential challenge to the RCS Barrier when Reactor Water level reaches -129", hence classification at this threshold is appropriate. However, for both these sequences, low Pressure ECCS are designed to inject to the Reactor as Reactor Pressure decreases below the shutoff head of the pumps. Reactor Depressurization will occur either due to the LOCA or Manual initiation of Emergency Depressurization when Reactor Water Level reaches -161", provided injection systems are available. This will allow for restoration of Reactor Water Level and re-establishment of Core Submergence.

## DEVIATION

None

**REFERENCES**

NUMARC NESP-0007, RC5

HC.OP-SO.SM-0001(Q), Isolation Systems Operation

HC.OP-AB.ZZ-0116 (Q), Containment Isolation and Recovery From An Isolation

HC.OP-AB.ZZ-0200 (Q), Reactor Low Water Level

HC.OP.EO.ZZ-0100 (Q)-FC, Reactor Scram

HC.OP.EO.ZZ-0101 (Q)-FC, Reactor Pressure Vessel (RPV) Control

HC GS Technical Specifications LCO 3/4.3, Instrumentation

### 3.0 Fission Product Barriers

#### 3.2 RCS Barrier

##### 3.2.1 REACTOR WATER LEVEL

###### 3.2.1.b

IC Loss of RCS Barrier = 4 POINTS

EAL

Reactor Water Level REACHES -161" (Top of Active Fuel), EXCLUDING intentional lowering of Reactor Water Level during an ATWS

OPERATIONAL CONDITION - 1, 2, 3

BASIS

Reactor Water Level reaching -161" (Top of Active Fuel - TAF), excluding intentional lowering of Reactor Water Level during an ATWS, results in an inability to maintain adequate core cooling by core submergence, causing a Loss of the RCS Barrier. Without core submergence, the integrity of the fuel clad barrier is in jeopardy. Appropriate classification under this EAL is based on reaching Reactor Water Level of -161" (instead of being able to restore and maintain above -161") due to the potentially severe consequences of a loss of core submergence. Reactor Water Level reaching this threshold results from either a LOCA exceeding available makeup capacity or a Total Loss of High Pressure injection capability.

In addition, during an Anticipated Transient Without Scram (ATWS), it is possible that operator actions will be taken to intentionally lower Reactor Water Level to between -161" and -190", for Reactor Power Control purposes. For this event, classification must be made in accordance with EAL Section 5.0

##### Barrier Analysis

RCS Barrier has been lost.

##### ESCALATION CRITERIA

Emergency Classification will escalate based upon the Potential Loss or Loss of additional Fission Product Barriers per EAL Section 3.0.

EAL - 3.2.1.b

Rev. 01

## DISCUSSION

Core Submergence is the preferred method of maintaining adequate core cooling. When Reactor Water Level decreases to below TAF, the ability to effectively remove decay heat is being challenged, and as such the Fuel Clad barrier can no longer be considered intact. While the Emergency Operating Procedures provide contingencies to establish adequate core cooling when Reactor Water Level drops below TAF (Steam Cooling with or without injection), these actions are designed to be an alternative method of providing adequate core cooling while actions are taken to reestablish core submergence. Sustained partial or total core uncover can result in fuel clad damage and a significant release of fission products to the Reactor coolant. Sustained core uncover can also result in a breach of the Reactor Vessel due to core melt material interaction with the RPV.

A Loss of Core Submergence will occur when the rate of inventory loss is greater than the rate of inventory makeup from High Pressure injection sources. This condition can occur as the result of the following events/sequences (excluding intentional lowering of Reactor Water Level during an ATWS).

A LOCA will cause Reactor Water Level to reach the Top of Active Fuel when the LOCA is the result of a large break (momentary core uncover is expected to occur under this condition) or when the LOCA is due to a small or intermediate break in combination with an inability of High Pressure injection sources to keep up with the leak rate.

A Loss of High Pressure injection sources without the presence of a LOCA will also result in Reactor Water Level decreasing to TAF, due to continued Reactor Steam Flow without makeup.

Either of these events/sequences results in a challenge to the Fuel Clad Barrier when Reactor Water Level reaches TAF due to core uncover, hence classification at this threshold is appropriate. However, for both these sequences, Low Pressure ECCS are designed to inject to the Reactor as Reactor Pressure decreases below the shutoff head of the pumps. Reactor Depressurization will occur either due to the LOCA or Manual initiation of Emergency Depressurization when Reactor Water Level reaches -161", provided injection systems are available. This will allow for restoration of Reactor Water Level and re-establishment of Core Submergence.

If all Reactor Level instrumentation is lost and EOP 206 or EOP 206A is entered, then a classification of a Site Area Emergency is warranted, based on EALs 3.1.1.a & 3.2.1.b (-161"). EOP 206(A) assures a level at Top of Active Fuel will be maintained when successful, "at least 4 SRVs are open and RPV press is at least 75 psig above supp chamber press, etc.", then this EAL (-161") is appropriate.

If EOP 206(A) is not successful, the process will not restore and maintain reactor level above -200" (SAG entry is required). A General Emergency is the appropriate classification based on EALs 3.1.1.b, 3.2.1.b & 3.3.1.

#### DEVIATION

None

#### REFERENCES

NUMARC NESP-0007, RC4

HC.OP-EO.ZZ-0100 (Q)-FC, Reactor Scram

HC.OP-EO.ZZ-0101 (Q)-FC, Reactor Pressure Vessel (RPV) Control

HC.OP-EO.ZZ-0201 (Q)-FC, Alternate Level Control

HC.OP-EO.ZZ-0207 (Q)-FC, Level/Power Control

BWR Owner's Group Emergency Procedure Guidelines, Rev. 4

### 3.0 Fission Product Barriers

#### 3.2 RCS Barrier

##### 3.2.2 RCS LEAK RATE/DRYWELL PRESSURE

###### 3.2.2.a

IC Potential Loss of RCS Barrier = 3 POINTS

EAL

Unisolable RCS Leak Rate  $\geq$  50 GPM INSIDE Primary Containment

OPERATIONAL CONDITION - 1, 2, 3

#### BASIS

Unisolable RCS Leak Rate exceeding 50 GPM, inside Primary Containment is indicative of a potential loss of the RCS. An unisolable leak rate of this magnitude is significant due to the potential for further break propagation, resulting in a much higher loss of inventory with an inability to isolate the leak source. As such, this threshold is considered a Potential Loss of the RCS. Leakage just above the 50 GPM threshold is well within the capacity of normal and emergency injection systems and is not a significant concern for core uncover. However, 50 GPM is the minimum leak rate that would be classified under this EAL, with the maximum being equivalent to the leak rate that would result in either Reactor Water Level reaching - 129" or Drywell Pressure reaching 1.68 PSIG, since these two conditions are obviously more recognizable to Control Room personnel, than an existing leak rate.

Specifying an unisolable RCS leak as part of the threshold for this EAL, precludes classifying events such as an isolable Reactor Recirculation Pump dual seal failure under this EAL.

#### Barrier Analysis

RCS Barrier has been potentially lost.

#### ESCALATION CRITERIA

Emergency Classification will escalate based on the Potential Loss or Loss of additional Fission Product Barriers per EAL Section 3.0.

EAL - 3.2.2.a  
Rev. 01

## DISCUSSION

It is important to recognize that the unisolable RCS leak rate established in this EAL is inside the Primary Containment. The inability to isolate the leak would eventually lead to a High Drywell Pressure ( $> 1.68$  PSIG) actuation of RPS, ECCS and PCIS. The actuation would lead to an isolation of the Drywell Floor and Equipment Drain sumps, complicating efforts to further identify and quantify any changes in the existing leak rate. In addition, monitoring of the leak rate could be limited by reaching the upper range (50 GPM) of the Drywell Leak Detection channels (9AX313 - Equipment, 9AX314- Floor Drain).

For leakage outside Containment, since quantification of the leak rate is much more difficult due to the physical size of the Reactor Building, receipt of a Valid isolation signal has been established as the threshold for classification of this type of leakage.

## DEVIATION

None

## REFERENCES

NUMARC NESP-007, RC1

NUMARC Questions and Answers, June 1993, "Fission Product Barrier Question #11"

HC.OP-SO.SM-0001(Q), Isolation Systems Operation

HC.OP-AB.ZZ-0116(Q), Containment Isolations and Recovery from an Isolation

HC.OP-AB.ZZ-0201(Q), Drywell High Pressure/Loss of Drywell Cooling

HC.RP-AR.SP-0001(Q), Radiation Monitoring System Alarm Response

HC.OP-EO.ZZ-0100(Q)-FC, Reactor Scram

HC.OP-EO.ZZ-0101(Q)-FC, Reactor Pressure Vessel (RPV) Control

HC.OP-EO.ZZ-0102(Q)-FC, Primary Containment Control

HC.OP-EO.ZZ-0103(Q)-FC, Secondary Containment Control

HC.OP-GP.ZZ-0005(Q), Drywell Leakage Source Detection

### 3.0 Fission Product Barriers

#### 3.2 RCS Barrier

##### 3.2.2 RCS LEAK RATE/DRYWELL PRESSURE

###### 3.2.2.b

IC Loss of RCS Barrier = 4 POINTS

EAL

Valid High Drywell Pressure Condition (  $\geq 1.68$  psig)

OPERATIONAL CONDITION - 1, 2, 3

#### BASIS

A Valid High Drywell Pressure Condition ( $\geq 1.68$  PSIG) is indicative of the release of high energy Reactor Coolant from the RCS into the Drywell and hence is considered a Loss of the RCS Barrier. Valid is defined as the High Drywell Pressure condition specifically due to RCS leakage into the Drywell, ensuring that event classification under this EAL is truly reflective of a degraded RCS Barrier. This precludes unwarranted event declaration as the result of system malfunctions, including a loss of Drywell Cooling or inadvertent Drywell makeup. Indication of an RCS leak should be positively determined by observing Primary Containment parameters, including Drywell Pressure and Temperature trends, Drywell Equipment and Floor Drain sump levels, DAPA Radiation levels, atmospheric pressure, Torus Pressure, and the status of Drywell Cooling systems.

An isolable Reactor Recirculation Pump dual seal failure should not result in Drywell Pressure reaching the threshold for this EAL, hence classification under this EAL should not occur.

#### Barrier Analysis

RCS Barrier has been lost.

#### ESCALATION CRITERIA

Emergency Classification will escalate based on the Potential Loss or Loss of additional Fission Product Barriers per EAL Section 3.0.

EAL - 3.2.2.b  
Rev. 01

**DISCUSSION**

RCS Leakage into the Drywell exceeding 50 GPM is substantially greater than the RCS leakage thresholds established in EAL Section 2.1.1, and represents further degradation of the RCS barrier. Inability to isolate the RCS leakage would eventually result in a High Drywell Pressure ( $> 1.68$  PSIG) actuation of RPS, ECCS and PCIS. The actuation would lead to an isolation of the Drywell Floor and Equipment Drain sumps, complicating efforts to further identify and quantify any changes in the leak rate. In addition, monitoring of the leak rate could be limited by reaching the upper range (50 GPM) of the Drywell Leak Detection channels (9AX313 - Equipment, 9AX314 - Floor Drain).

There are multiple Control Room indicators and alarms that can be used to determine the presence of a High Drywell Pressure condition. Overhead Annunciators will alarm at 1.5 PSIG and 1.68 PSIG. Plant automatic response to a High Drywell Pressure condition includes: a reactor scram, ECCS initiation, trip of the drywell cooling fans and isolation of the cooling water to the drywell. These actuations may mask the trend in drywell pressure. For example, the scram will result in less heat being added to the containment and the cooling water isolation will result in no heat being removed.

Actions initiated as part of increasing drywell pressure condition include investigation of the source of the increased leakage into the drywell maximizing drywell cooling and venting the Drywell (if release criteria can be satisfied). These actions are designed to control and relieve increasing drywell pressure.

**DEVIATION**

None

**REFERENCES**

NUMARC NESP-0007, RC2  
 NUMARC Questions and Answers, June 1993, "Fission Product Barrier Question #11"  
 HC.OP-SO.SM-0001(Q), Isolation Systems Operation  
 HC.OP-AB.ZZ-0116 (Q), Containment Isolation and Recovery From An Isolation  
 HC.OP-AB.ZZ-0201 (Q), Drywell High Pressure/Loss of Drywell Cooling  
 HC.OP-EO.ZZ-0100 (Q)-FC, Reactor Scram  
 HC.OP-EO.ZZ-0101 (Q)-FC, Reactor Pressure Vessel (RPV) Control  
 HC.OP-EO.ZZ-0102 (Q)-FC, Primary Containment Control  
 HC.OP-GP.ZZ-0005 (Q), Drywell Leak Source Detection  
 Hope Creek Appendix A based on NEDO-2121, Supplement A to BWR Owners Group  
 Emergency Procedure Guidelines, Revision 4  
 HCGS Technical Specifications LCO 3/4.3, Instrumentation

### 3.0 Fission Product Barriers

#### 3.2 RCS Barrier

##### 3.2.3 RCS LINE BREAK/CONTAINMENT BYPASS

###### 3.2.3.a

IC Potential Loss of RCS Barrier = 3 POINTS

EAL

Main Steam Line Break OUTSIDE Primary Containment , resulting in an AUTOMATIC MSIV Isolation Signal

AND

ALL 4 Main Steam Lines have been successfully isolated based on NO indication of CONTINUING FLOW / LEAKAGE OUTSIDE the Primary Containment AFTER valve closure from the Main Control Room has been attempted

OPERATIONAL CONDITION - 1, 2, 3

BASIS

A Main Steam Line Break outside the Primary Containment, resulting in an automatic MSIV Isolation Signal, could result in dose consequences offsite from a "puff" release in excess of 10 millirem, based on design basis accident analysis, even if MSIV closure occurs within design limits. Hence this condition is classified as a Potential Loss of the RCS Barrier. Classification under this EAL is specifically for a Main Steam Line Break outside the Primary Containment, as evidenced by a rapid change in Main Steam Line Flow and Steam Tunnel Temperature, which results in automatic isolation with no indication of continuing leakage. Valve Packing leaks that result in elevated Steam Tunnel temperatures do not require classification under this EAL.

A manual actuation of NSSSS or manual MSIV closure PRIOR to exceeding the setpoints that would result in an automatic isolation of the MSIV should not result in a "puff" release exceeding 10 millirem, and thus should not be classified under this EAL. Verification that continuing leakage does not exist, ensures that any potential release will not significantly exceed the 10 CFR100 limits. This EAL is specific to a break outside the Primary Containment, since a break outside represents a potential challenge to Primary Containment

EAL - 3.2.3.a

Rev. 01

Integrity due to the Containment Bypass condition that would exist until MSIV closure occurred. Failure to completely isolate the effected Main Steam Line(s) as determined by valve position and indication of continuing leakage would result in an additional Loss of the Primary Containment Barrier.

In addition, this EAL ALLOWS for valve closure from the Main Control Room to isolate any Main Steam Line that did not completely isolate. Valve closure is defined as the closure of ANY valve from the Main Control Room associated with the effected Main Steam Line(s), that did not completely isolate. For example, if the isolation logic fails to cause valve closure, but operator actions implemented in the Main Control Room successfully isolates the effected Main Steam Line(s), then event classification under this EAL is warranted due to the consequences of the event previously discussed. This includes Motor Operated Valves that are not controlled by the isolation logic, but are manually controlled from the Main Control Room. (i.e. Main Steam Stop Valves 1ABHV-3631 A/B/C/D). In the event the effected Main Steam Line(s) can not be isolated, escalation of the classification will be required.

### Barrier Analysis

RCS Barrier has been potentially lost

### ESCALATION CRITERIA

Emergency Classification will escalate based on the Potential Loss or Loss of additional barriers per EAL section 3.0.

### DISCUSSION

The Main Steam System is associated with systems that are part of the RCS boundary and penetrate the Primary Containment. Isolation requirements for these lines are covered in 10CFR50, Appendix A, General Design Criteria 55. These systems form a closed loop outside the Primary Containment and are not open or potentially open to the environment. These systems represent an extension of the RCS Barrier beyond the Primary Containment.

Positive identification of a Main Steam Line Break outside the Primary Containment can be based on receipt of the following Overhead Annunciators:

NSSSS ISLN SIG - STM TNL TEMP HI	(C8-C4)
NSSSS ISLN SIG - MN STM FLOW HI	(C8-B4)
MSIV CLOSURE	(C5-B3)

as well as the following indications:

**MSIV TRIP LOGIC TRIPPED**

Rapid changes in Main Steam Line Flow and Steam Tunnel Temperatures

EAL - 3.2.3.a

Rev. 01

**DEVIATION**

This EAL is being maintained in the Fission Product Barrier Table for ease of use by the operators. It has been categorized as a "Potential loss" since the RCS leak is successfully isolated and an Alert classification will still be made as a result of the potential loss of RCS.

**REFERENCES**

NUMARC NESP-007, RC1

NUMARC Question and Answer, June 1983, "Fission Product Barrier- BWR" Question #4  
10 CFR50, App. A, GDC 55

10 CFR 100

HC.OP-SO.SM-0001(Q), Isolation Systems Operation

HC.OP-AB.ZZ-0114(Q), Loss of Primary Containment Integrity

HC.OP-AB.ZZ-0116(Q), Containment Isolations and Recovery from an Isolation

HC.OP-AB.ZZ-0203(Q), Main Steam Line High Radiation

HC.OP-AR.SP-0001(Q), Radiation Monitoring System Alarm Response

HC.OP-AR.ZZ-0011(Q), Annunciator Response Procedures, Window C6

HC.OP-AR.ZZ-0012(Q), Annunciator Response Procedures, Window C8

HC.OP-EO.ZZ-0100 (Q)-FC, Reactor Scram

HC.OP-EO.ZZ-0101 (Q)-FC, Reactor Pressure Vessel (RPV) Control

HC.OP-EO.ZZ-0102 (Q)-FC, Primary Containment Control

HC.OP-EO.ZZ-0103 (Q)-FC, Reactor Building Control

HC.OP-EO.ZZ-0104 (Q)-FC, Radioactive Release Control

HCGS Technical Specifications, LCO 3/4.3

HCGS UFSAR, Section 6.2.4.3.1

### 3.0 Fission Product Barriers

#### 3.2 RCS Barrier

##### 3.2.3 RCS LINE BREAK/CONTAINMENT BYPASS

###### 3.2.3.b

IC Loss of RCS Barrier = 4 POINTS

EAL

RCS Line Break OUTSIDE Primary Containment, resulting in a Valid Isolation Signal for ANY one of the following systems:

- NSSSS
- HPCI
- RCIC

AND

Indication of CONTINUING FLOW / LEAKAGE OUTSIDE the Primary Containment through the effected system AFTER valve closure from the Main Control Room has been attempted

OPERATIONAL CONDITION - 1, 2, 3

BASIS

An RCS Line Break outside Primary Containment that results in a Valid Isolation Signal for any of the systems listed in the EAL requires closure of the associated Primary Containment Isolation valves to maintain RCS and Primary Containment integrity under abnormal conditions. A failure of these isolation valves to isolate directly allows Reactor Coolant to be released outside the Primary Containment (Containment Bypass), resulting in a Loss of RCS and Loss of Containment. An RCS Line is ANY line that communicates directly with the Reactor. An RCS Line Break with indication of continuing flow is classified under this EAL, due to the continuing discharge of Reactor Coolant outside the Primary Containment along with a potential for further "break propagation". This is the only condition that warrants classification under this EAL.

EAL - 3.2.3.b  
Rev. 01

Valid is defined as the isolation signal specifically being the result of an RCS Line Break, thus ensuring that the RCS discharge is of significant magnitude to pose a threat to the integrity of the RCS Barrier. This precludes unwarranted Event Classification as the result of condition that result in limited leakage with no potential for "break propagation", including valve packing leaks outside Primary Containment and RWCU Pump Seal Leaks. In addition, isolation signal generated from known failures in other systems, that do not result in Reactor Coolant discharging outside the Primary Containment do not warrant Event Classification under this EAL either. Examples of such failures include a high temperature isolation resulting from a loss of ventilation or cooling water, spurious actuation during I&C surveillance testing or a low Reactor Water Level Condition due to a Loss of High Pressure injection capability.

In addition, this EAL ALLOWS for valve closure from the Main Control Room to isolate any systems that did not completely isolate, prior to event classification. Valve closure is defined as the closure of ANY valve from the Main Control Room in the system(s) that did not completely isolate. For example, if the isolation logic fails to cause valve closure, but operator actions implemented in the Main Control Room successfully isolates the effected system, then classification under this EAL is not warranted. This includes Motor Operated Valves that are not control by the isolation logic, but are manually controlled from the Main Control Room. Effected system is defined as the system that is providing the flowpath outside the Primary Containment.

### Barrier Analysis

RCS Barrier has been lost

### ESCALATION CRITERIA

Emergency Classification will escalate based on the Potential Loss or Loss of additional Fission Product Barriers per EAL Section 3.0.

### DISCUSSION

NSSSS isolations, as well as HPCI and RCIC steam line isolations, are associated with systems that are part of the RCS boundary and penetrate the Primary Containment. Isolation requirements for these lines are covered in 10CFR50, Appendix A, General Design Criteria 55. These systems form a closed loop outside the Primary Containment, and are not open or potentially open to the environment. They are included in this EAL since they represent an extension of the RCS boundary beyond the Primary Containment, and a potential release path from the RCS to the environment. Without a completed isolation, continuing flow/leakage represents a situation where Reactor Coolant is discharging outside the Primary Containment, including areas in the Reactor Building addressed in the EOPs.

Indication of continuing flow/leakage includes: flow indication through isolated lines, increasing Reactor Building area temperatures, area radiation levels, sump levels, or room

EAL - 3.2.3.b  
Rev. 01

levels in spaces associated with affected lines, as well as increases in Plant Vent Effluent levels.

## DEVIATION

This EAL is being considered a loss of the reactor coolant boundary since actuation of listed isolation system indicate a leak of significant magnitude, and an isolation failure. The classification for exceeding this EAL remains consistent with NUMARC guide lines.

## REFERENCES

NUMARC NESP-007, RC1  
10 CFR50, App. A, GDC 55  
10 CFR 100  
HC.OP-SO.SM-0001(Q), Isolation Systems Operation  
HC.OP-AB.ZZ-0114(Q), Loss of Primary Containment Integrity  
HC.OP-AB.ZZ-0116(Q), Containment Isolations and Recovery from an Isolation  
HC.OP-AB.ZZ-0203(Q), Main Steam Line High Radiation  
HC.OP-AR.SP-0001(Q), Radiation Monitoring System Alarm Response  
HC.OP-AR.ZZ-0011(Q), Annunciator Response Procedures, Window C6  
HC.OP-AR.ZZ-0012(Q), Annunciator Response Procedures, Window C8  
HC.OP-EO.ZZ-0100 (Q)-FC, Reactor Scram  
HC.OP-EO.ZZ-0101 (Q)-FC, Reactor Pressure Vessel (RPV) Control  
HC.OP-EO.ZZ-0102 (Q)-FC, Primary Containment Control  
HC.OP-EO.ZZ-0103 (Q)-FC, Reactor Building Control  
HC.OP-EO.ZZ-0104 (Q)-FC, Radioactive Release Control  
HCGS Technical Specifications LCO 3/4.3, Instrumentation  
HCGS UFSAR, Section 6.2.4.3.1

### 3.0 Fission Product Barriers

#### 3.2 RCS Barrier

##### 3.2.4 EMERGENCY COORDINATOR JUDGMENT

###### 3.2.4.a/ 3.2.4.b

IC Potential Loss (= 3 POINTS) or Loss of RCS Barrier (= 4 POINTS)

EAL

ANY condition, in the opinion of the EC, that indicates EITHER  
a Potential Loss OR Loss of the RCS Barrier

OPERATIONAL CONDITION - 1, 2, 3

BASIS

This EAL allows the Emergency Coordinator (EC) to address any condition that affects the integrity of the RCS Barrier that is not already covered elsewhere in the Fission Product Barrier Table. A complete loss of the ability to monitor the RCS barrier should be considered as a "Potential Loss" of that barrier.

Barrier Analysis

RCS Barrier has been potentially lost or lost.

ESCALATION CRITERIA

Emergency Classification will be escalate based on the Potential Loss or Loss of additional barriers per EAL section 3.0.

DISCUSSION

None

DEVIATION

None

EAL - 3.2.4.a/3.2.4.b

Rev. 01

**REFERENCES**

NUMARC NESP-007, RC6

EAL - 3.2.4.a/3.2.4.b  
Rev. 01

### 3.0 Fission Product Barriers

#### 3.3 Containment Barrier

##### 3.3.1 REACTOR WATER LEVEL

IC Potential Loss of Containment Barrier = 1 POINT

EAL

PSE&G  
CONTROL  
COPY # HECG0065

Reactor Water Level CANNOT BE RESTORED AND MAINTAINED  
above -200" (Minimum Zero Injection RPV Water Level)

OPERATIONAL CONDITION - 1, 2, 3

#### BASIS

Inability to restore and maintain Reactor Water Level above -200" (Minimum Zero Injection RPV Water Level), results in a loss of adequate core cooling by all mechanisms, causing a Potential Loss of the Fuel Clad Barrier. Without adequate core cooling, the integrity of the Containment is being challenged and can no longer be assured. Appropriate classification under this EAL is based on the failure of injection systems to restore and maintain Reactor Water Level above -200", following a condition that causes level to decrease below the threshold.

For example, a large break LOCA is expected to cause Reactor Water Level to momentarily decrease below -200", due to the response time of Low Pressure ECCS. As these systems initiate and commence injection to the Reactor, water level will begin to increase and should be able to be maintained above -200". In this case, classification under this EAL is not appropriate as plant systems have performed their intended design function and will eventually restore adequate core cooling by core submergence. However, in the event that Low Pressure ECCS and alternate injection system, as defined in the EOPs are in a degraded condition (i.e., Station Blackout, ECCS Suction Strainer plugging, etc.) and Reactor Water Level can not be restored and maintained above -200", then classification under this EAL should occur due to the Potential Loss of Containment from the release of energy to the containment from imminent fuel failure.

#### Barrier Analysis

Primary Containment Barrier has been potentially lost.

EAL - 3.3.1  
Rev. 02

## ESCALATION CRITERIA

Emergency Classification will escalate based upon the Potential Loss or Loss of additional Fission Product Barriers per EAL Section 3.0.

## DISCUSSION

Core submergence is the preferred method for maintaining adequate core cooling. The failure to reestablish Reactor Water Level above -161", the Top of Active Fuel (TAF), for an extended period of time could lead to significant fuel damage. With Reactor Water Level below TAF, but above the Minimum Zero Injection RPV Water Level (-200"), adequate core cooling occurs due to the cooling effects of steam generated in the covered portion of the core flowing through the uncovered portion (Steam Cooling). The Minimum Zero Injection RPV Water Level is defined in the Emergency Operating Procedures.

This method of cooling precludes any fuel clad temperature in the uncovered portion of the core from exceeding 1800°F. As Reactor Water Level drops below -200" with no injection available, this method of cooling becomes inadequate. Prolonged lack of cooling may result in severe overheating of the fuel clad, additional release of energy from accelerated clad oxidation, and eventual fuel melting.

For events starting from full power operation, the failure to promptly reflood could result in some fuel melting. Even under these conditions vessel failure and containment failure with resultant release to the public would not be expected for some time. Reactor Water Level remaining below TAF for an extended amount of time represents an early indicator that significant core damage is in progress while providing sufficient time to initiate public protective actions.

Ample time should be provided for Low Pressure ECCS and alternate injection systems restore Reactor Water Level prior to entry into this classification. The time basis for deciding whether or not Reactor Water can be maintained > -200" should be based on the rate of reactor depressurization, the availability of low pressure injection sources, (ECCS and alternate injection systems), and the rate of Reactor coolant inventory loss. Indications such as Reactor Water Level trend, injection flow rates, containment parameter trends, and low pressure injection system operability should also be considered.

In the event Reactor Water Level can not be restored  $> -200''$ , Severe Accident Guidelines entry is required (containment flooding) by the EOPs. This will attempt to flood the containment as a means of flooding the RPV, and use a flooded containment as a heat sink for the nuclear fuel.

If all Reactor Level instrumentation is lost and EOP 206 or EOP 206A is entered, then a classification of a Site Area Emergency is warranted, based on EALs 3.1.1.a & 3.2.1.b (-161"). EOP 206(A) assures a level at Top of Active Fuel will be maintained when successful, "at least 4 SRVs are open and RPV press is at least 75 psig above supp chamber press, etc."; then this EAL (-200") is not appropriate. If EOP 206(A) is not successful, the process will not restore and maintain reactor level above -200" (SAG entry is required). A General Emergency is the appropriate classification based on EALs 3.1.1.b, 3.2.1.b & 3.3.1.

#### DEVIATION

None

#### REFERENCES

NUMARC NESP-007, PC4

HC.OP.EO.ZZ-0101 (Q)-FC, Reactor Pressure Vessel (RPV) Control

HC.OP.EO.ZZ-0101A (Q)-FC, ATWS - RPV control

HC.OP.EO.ZZ-206 (Q)-FC, RPV Flooding

HC.OP.EO.ZZ-0206A (Q)-FC, ATWS RPV Flooding

BWR Owners Group Emergency Procedure and Severe Accident Guidelines, Revision 1

### 3.0 Fission Product Barriers

#### 3.3 Containment Barrier

##### 3.3.2 DRYWELL PRESSURE/H<sub>2</sub>

###### 3.3.2.a/ 3.3.2.c

IC Potential Loss of Containment Barrier = 1 POINT

EAL

Suppression Chamber pressure CANNOT BE MAINTAINED below 65 psig

OR

Primary Containment H<sub>2</sub> concentration >4% and O<sub>2</sub> concentration >5%

#### OPERATIONAL CONDITION - 1, 2, 3

#### BASIS

Containment venting required by the EOPs indicates a degrading condition in containment and is implemented in an effort to preclude containment failure. Venting is required before Suppression Chamber pressure reaches 65 PSIG or Hydrogen concentration reaches the Lower Explosive Limit (LEL = 4%) and Oxygen concentration reaches 5%. Exceeding these parameters creates the potential for an unisolable breach of the primary containment, which could result in an uncontrolled, unmonitored, and untreated release of radioactivity to the environment. This EAL represents a Potential Loss of Containment, since containment venting is required due to Containment parameters potentially exceeding their design limits. The magnitude of any radiological release is dependent upon events leading to the requirement for emergency venting, including a loss of the RCS and a loss of the Fuel Clad Barriers.

A Downcomer failure, by itself, does not represent a Loss of the Primary Containment Barrier. This failure does, however, render the Primary Containment inoperable per the Technical Specification, as Primary Containment integrity has been compromised. A Downcomer failure combined with a large break LOCA will likely result in a Potential Loss of Primary Containment under this EAL if Containment pressure can not be maintained below 65 PSIG and Containment Venting is required.

EAL - 3.3.2.a/3.3.2.c

Rev. 02

## Barrier Analysis

Primary Containment Barrier has been potentially lost.

## ESCALATION CRITERIA

Emergency Classification will escalate based on the Potential Loss or Loss of additional Fission Product Barriers per EAL Section 3.0.

## DISCUSSION

Venting of the Primary Containment is initiated to preserve containment integrity under accident conditions. Primary Containment venting is required when Suppression Chamber cannot be maintained below 65 psig, which is well above the maximum pressure expected to be present in the Primary Containment during a design basis Loss of Coolant Accident (LOCA).

Primary Containment venting is also required based on hydrogen concentrations exceeding 4%. H<sub>2</sub> concentration in excess of 6.0 % requires Emergency Depressurization and subsequent containment venting. Venting is continued until either H<sub>2</sub> concentration has been reduced to <6.0% or O<sub>2</sub> levels have been reduced to <5.0%. Venting with elevated hydrogen concentration conditions ensures that containment failure resulting from a hydrogen detonation or deflagration does not occur.

The elevated hydrogen in the containment may result from excessive zircaloy-water reaction occurring following a LOCA. Additionally, hydrogen and oxygen gas may be introduced into the containment environment from long term disassociation of water in the Suppression Chamber.

EOP procedural guidance in these cases is provided to vent the Primary Containment regardless of off-site dose consequences. Although radiological releases resulting from venting containment may exceed EPA limits, a controlled, monitored, and isolable release is preferred to a potential uncontrolled, unmonitored radiological release that would result from a failure of containment.

## DEVIATION

None

**REFERENCES**

NUMARC NESP-007, PC1, PC2

HC.OP-AB.ZZ-0201 (Q), Drywell High Pressure/Loss of Drywell Cooling

HC.OP-EO.ZZ-0101 (Q)-FC, Reactor Pressure Vessel (RPV) Control

HC.OP-EO.ZZ-0102 (Q)-FC, Primary Containment Control

HC.OP-EO.ZZ-0318 (Q)-FC, Containment Venting

BWR Owners Group Emergency Procedure and Severe Accident Guidelines, Revision 1

### 3.0 Fission Product Barriers

#### 3.3 Containment Barrier

##### 3.3.2 DRYWELL PRESSURE/H<sub>2</sub>

##### 3.3.2.b/ 3.3.2.d/ 3.3.2.e

IC Loss of Containment Barrier = 2 POINTS

EAL

Containment Failure as indicated by a rapid drop in Drywell pressure following a rise in pressure above 1.68 psig

OR

Drywell pressure response not consistent with LOCA conditions

OR

Containment is Vented by the Emergency Operating Procedures (EOPs)

OPERATIONAL CONDITION - 1, 2, 3

BASIS

Containment failure indicated by a rapid decrease in Drywell pressure following a significant rise in Drywell pressure is indicative of a Loss of the Containment barrier. This EAL specifically represents a Loss of Containment, whereby an unisolable breach of the Containment structure has occurred. Conditions that result in a drop in Drywell pressure following a pressure rise that are not the direct result of a Containment failure do not warrant classification under this EAL. These events include the initiation of Drywell Sprays, the re-establishment of Drywell Cooling, Containment Venting as required by the EOPs, and anticipated Drywell pressure drop due to ambient losses.

Containment Venting is a controlled loss of containment. This venting is performed for the purpose of preventing an unisolable, unmonitored radiological release of containment gases.

A Downcomer failure, by itself, does not represent a Loss of the Primary Containment Barrier. This failure does, however, render the Primary Containment inoperable per the Technical Specification, as Primary Containment integrity has been compromised. A

EAL - 3.3.2.b/3.3.2.d/3.3.2.e

Rev. 02

Downcomer failure combined with a large break LOCA will likely result in a Potential Loss of Primary Containment under EAL 3.3.2.a if Containment pressure cannot be maintained below 65 PSIG and Containment Venting is required.

### **Barrier Analysis**

Primary Containment Barrier has been lost.

### **ESCALATION CRITERIA**

Emergency Classification will escalate based on the Potential Loss or Loss of additional Fission Product Barriers per EAL Section 3.0.

### **DISCUSSION**

Appropriate classification under this EAL occurs as the result of a Containment failure. Drywell pressure reaching 1.68 psig indicates that there is a significant release of reactor coolant to the Containment. Unless this source of leakage is isolated or the Reactor is depressurized, Drywell pressure would not be expected to drop in a rapid manner.

Other indications such as Reactor Building Area Radiation Monitors (ARMs) radiation levels, Reactor Building area temperatures, Reactor Building floor and sump levels, Plant Effluent radiation levels, and containment isolation status should be used to confirm the loss of containment integrity if possible. Reactor Building to Torus vacuum breaker status should be monitored to ensure that this pathway does not result in a loss of containment integrity.

### **DEVIATION**

None

### **REFERENCES**

NUMARC NESP-007, PC1

HC.OP-AB.ZZ-0114 (Q), Loss of Primary Containment Integrity

HC.OP-AB.ZZ-0116 (Q), Containment Isolations and Recovery from an Isolation

HC.OP-AB.ZZ-0201 (Q), Drywell High Pressure/Loss of Drywell Cooling

HC.OP-EO.ZZ-0100 (Q)-FC, Reactor Scram

HC.OP-EO.ZZ-0101 (Q)-FC, Reactor Pressure Vessel (RPV) Control

HC.OP-EO.ZZ-0102 (Q)-FC, Primary Containment Control

HC.OP-EO.ZZ-0103 (Q)-FC, Reactor Building Control

BWR Owners Group Emergency Procedure and Severe Accident Guidelines, Revision 1

### 3.0 Fission Product Barriers

#### 3.3 Containment Barrier

##### 3.3.3 DRYWELL ATMOSPHERE POST ACCIDENT (DAPA) RADIATION LEVEL

IC Potential Loss of Containment Barrier = 1 POINT

EAL

DAPA Radiation Monitor reading $\geq$ 28000 R/hr
--

OPERATIONAL CONDITION - 1, 2, 3

##### BASIS

Drywell Atmosphere Post Accident (DAPA) monitor reading  $\geq$  28000 R/hr indicates significant fuel damage, well in excess of the level corresponding to the loss of the RCS and Fuel Clad barriers. This threshold corresponds to approximately 20% fuel clad damage. Regardless of whether or not containment is challenged, this amount of activity in containment, if released, could have severe consequences and it is prudent to treat this condition as a Potential Loss of containment.

##### Barrier Analysis

Primary Containment Barrier is potentially lost.

##### ESCALATION CRITERIA

Emergency Classification will escalate based on the Potential Loss or Loss of additional Fission Product Barriers per EAL Section 3.0.

##### DISCUSSION

NUREG-1228, "Source Term Estimation During Incident Response to Severe Nuclear Power Plant Accidents", states that releases of severe magnitude are not possible if plant systems function as designed, and any accident with a release of 20% or greater of the gap region must be considered severe.

Using attachment 2 of EPIP 205H, 10% clad damage is represented by a DAPA reading of  $1.4E4$  R/hr at 0.1 hrs after shutdown (the most conservative). This is shown on the

EAL - 3.3.3  
Rev. 02

attachment as the 1% TID line. Extrapolating to 20% clad damage gives a reading of 2.8E4 R/hr.

Exceeding a DAPA reading of 28000 R/hr should meet the criteria for declaration of a General Emergency.

**DEVIATION**

None

**REFERENCES**

NUMARC NESP-007, PC3

NUREG-1228 - Source Term Estimation During Incident Response to Severe Nuclear Power Plant Accidents

EPIP 205H, TSC - Post Accident Core Damage Assessment

### 3.0 Fission Product Barriers

#### 3.3 Containment Barrier

##### 3.3.4 RCS LINE BREAK/CONTAINMENT BYPASS

###### 3.3.4.a

IC Potential Loss of Containment Barrier = 1 POINT

EAL

RCS Line Break OUTSIDE Primary Containment, resulting in a Valid Isolation Signal for ANY one of the following systems:

- NSSSS (excluding Main Steam Lines)
- HPCI
- RCIC

AND

NO indication of CONTINUING FLOW / LEAKAGE OUTSIDE the Primary Containment through the effected system AFTER valve closure from the Main Control Room has been attempted

OPERATIONAL CONDITION - 1, 2, 3

BASIS

An RCS Line Break outside Primary Containment that results in a Valid Isolation Signal for any of the systems listed in the EAL requires closure of the associated Primary Containment Isolation valves to maintain RCS and Primary Containment integrity under abnormal conditions. A failure of these isolation valves to isolate directly allows the transport of Reactor Coolant or containment atmosphere to outside the Primary Containment (Containment Breach or Bypass), resulting in a Loss of Containment.

A RCS Break with successful automatic isolation is excluded from this EAL, since it is covered under RAL 11.3.2 (ESF actuation). An RCS Line Break with manual isolation from the Control Room and indication of successful isolation is the only condition that warrants classification under this EAL. A Main Steam Line Break with successful isolation is excluded from this EAL, since it is covered under EAL 3.2.3.a.

EAL - 3.3.4.a  
Rev. 02

Valve closure is defined as the closure of ANY valve from the Main Control Room in the system(s) that did not completely isolate. For example, if the isolation logic fails to cause valve closure, but operator actions implemented in the Main Control Room successfully isolates (one valve per penetration) the effected system, then an Unusual Event declaration is warranted.

Effected system is defined as the system that is providing the flowpath outside the Primary Containment.

Valid is defined as the isolation signal specifically being the result of an RCS Line Break, thus ensuring that the RCS discharge is of significant magnitude to pose a threat to the integrity of the Primary Containment Barrier.

### Barrier Analysis

Primary Containment Barrier has been potentially lost

### ESCALATION CRITERIA

Emergency Classification will escalate based on the Potential Loss or Loss of additional Fission Product Barriers per EAL Section 3.0.

### DISCUSSION

NSSSS isolations, as well as HPCI and RCIC steam line isolations are associated with systems that are part of the RCS boundary and penetrate the Primary Containment. Isolation requirements for these lines are covered in 10CFR50, Appendix A, General Design Criteria 55. These systems form a closed loop outside the Primary Containment, and are not open or potentially open to the environment. They are included in this EAL since they represent an extension of the RCS boundary beyond the Primary Containment, and a potential release path from the RCS to the environment.

Indication of continuing flow/leakage includes: flow indication through isolated lines, increasing Reactor Building area temperatures, area radiation levels, sump levels, or room levels in spaces associated with affected lines, as well as increases in Plant Vent Effluent levels.

**DEVIATION**

None

**REFERENCES**

NUMARC NESP-007, PC5

10 CFR50, App. A, GDC 55

10 CFR 100

HC.OP-SO.SM-0001(Q), Isolation Systems Operation

HC.OP-AB.ZZ-0114(Q), Loss of Primary Containment Integrity

HC.OP-AB.ZZ-0116(Q), Containment Isolations and Recovery from an Isolation

HC.OP-AB.ZZ-0203(Q), Main Steam Line High Radiation

HC.OP-AR.SP-0001(Q), Radiation Monitoring System Alarm Response

HC.OP-AR.ZZ-0011(Q), Annunciator Response Procedures, Window C6

HC.OP-AR.ZZ-0012(Q), Annunciator Response Procedures, Window C8

HC.OP-EO.ZZ-0101 (Q)-FC, Reactor Pressure Vessel (RPV) Control

HC.OP-EO.ZZ-0102 (Q)-FC, Primary Containment Control

HC.OP-EO.ZZ-0103 (Q)-FC, Reactor Building and Radioactive Release Control

HCGS Technical Specifications, LCO 3/4.3

HCGS UFSAR, Section 6.2.4.3.1

### 3.0 Fission Product Barriers

#### 3.3 Containment Barrier

##### 3.3.4 RCS LINE BREAK/CONTAINMENT BYPASS

###### 3.3.4.b

IC Loss of Containment Barrier = 2 POINTS

EAL

Isolation Signal for ANY one of the following systems:

- NSSSS
- PCIS
- HPCI
- RCIC

AND

Indication of CONTINUING FLOW / LEAKAGE OUTSIDE the Primary Containment through the effected system AFTER valve closure from the Main Control Room has been attempted

OPERATIONAL CONDITION - 1, 2, 3

BASIS

An Isolation Signal for any of the systems listed in the EAL requires closure of the associated Primary Containment Isolation valves to maintain RCS and Primary Containment integrity under abnormal conditions. A failure of these isolation valves to isolate directly allows the transport of Reactor Coolant or containment atmosphere to outside the Primary Containment (Containment Breach or Bypass), resulting in a Loss of Containment.

This EAL addresses two conditions under which RCS is being transported OUTSIDE the Primary Containment. The first condition is associated with an Isolation signal being generated as the result of an RCS Line Break with a failure of the isolation valves to close. In this condition, an ABNORMAL FLOWPATH exists for RCS to be discharged directly outside the Primary Containment. The second condition is associated with the failure of both Inboard

EAL - 3.3.4.b

Rev. 02

and Outboard Isolation valves to **FULLY** close following an Isolation signal. In this condition, a flow path from containment atmosphere to areas outside of the Primary Containment exists.

In addition, this EAL **ALLOWS** for valve closure from the Main Control Room to isolate any systems that did not completely isolate, prior to event classification. Valve closure is defined as the closure of **ANY** valve from the Main Control Room in the system(s) that did not completely isolate. For example, if the isolation logic fails to cause valve closure, but operator actions implemented in the Main Control Room successfully isolates the effected system, then an Unusual Event declaration is warranted under EAL 3.3.4.a.(Potential Loss).

This includes Motor Operated Valves that are not control by the isolation logic, but are manually controlled from the Main Control Room. Effected system is defined as the system that is providing the flowpath outside the Primary Containment.

### Barrier Analysis

Primary Containment has been lost.

### ESCALATION CRITERIA

Emergency Classification will escalate based on the Potential Loss or Loss of additional Fission Product Barriers per EAL Section 3.0.

### DISCUSSION

PCIS Isolations are associated with systems having lines that are either: 1) connect directly to the Primary Containment atmosphere and penetrate the Primary Containment; or 2) penetrate the Primary Containment and are neither part of the RCS boundary and are not connected directly to the Primary Containment atmosphere (e.g. RACS, Chilled Water). Isolation requirements for these lines are covered in 10CFR50, App. A, General Design Criteria 56 and 57 respectively. This event, therefore, may potentially connect the RCS or the Primary Containment atmosphere to the environment. Without a completed isolation, continuing flow/leakage represents a release path from the RCS or Primary containment to the environment.

NSSSS isolations, as well as HPCI and RCIC steam line isolations, are associated with systems that are part of the RCS boundary and penetrate the Primary Containment. Isolation requirements for these lines are covered in 10CFR50, App. A, General Design Criteria 55. These systems form a closed loop outside the Primary Containment, and are not open or potentially open to the environment. They are included in this EAL since they represent an extension of the RCS boundary beyond the Primary Containment, and a potential release path from the RCS to the environment. Without a completed isolation, continuing leakage

represents a Primary System discharging outside the Primary Containment (Containment Bypass), including areas in the Reactor Building addressed in the EOPs.

Indication of continuing flow/leakage includes: flow indication through isolated lines, increasing Reactor Building area temperatures, area radiation levels, sump levels, or room levels in spaces associated with affected lines, as well as increases in Plant Vent Effluent levels.

The isolation valve status of all isolation groups is monitored for quick reference on SPDS, to be backed up by operator observation of valve status.

## DEVIATION

NUMARC Primary Containment Barrier Example Flowchart (PC2) suggests that for the "Containment Isolation Valve Status after Containment Isolation Signal" EAL, a failure of both valves in any one line to close AND downstream pathway to the environment exists be included as a threshold for classification of an Unusual Event. In order to include the condition where the Inboard Valve fails to close and an RCS Line Break exists between the Primary Containment wall and Outboard Valve, the condition that both valves fail to close is NOT being included in the EAL. Indication of continuing flow / leakage OUTSIDE the Primary Containment will provide an adequate threshold for Event Classification, since both isolation valves must be open for continuing leakage Outside the Primary Containment, except as noted above.

## REFERENCES

NUMARC NESP-007, PC2  
10CFR50, App. A, GDC 55, 56, 57  
10 CFR 100  
HC.OP-SO.SM-0001(Q), Isolation Systems Operation  
HC.OP-AB.ZZ-0116(Q), Containment Isolations and Recovery from an Isolation  
HC.OP-AB.ZZ-0203(Q), Main Steam Line High Radiation  
HC.OP-AR.SP-0001(Q), Radiation Monitoring System Alarm Response  
HC.OP-AR.ZZ-0011(Q), Annunciator Response Procedures, Window C6  
HC.OP-AR.ZZ-0012(Q), Annunciator Response Procedures, Window C8  
HC.OP-EO.ZZ-0100 (Q)-FC, Reactor Scram  
HC.OP-EO.ZZ-0101 (Q)-FC, Reactor Pressure Vessel (RPV) Control  
HC.OP-EO.ZZ-0102 (Q)-FC, Primary Containment Control  
HC.OP-EO.ZZ-0103 (Q)-FC, Reactor Building Control  
HCGS Technical Specifications LCO 3/4.3, Instrumentation  
HCGS UFSAR Sections 6.2.4.3.1, 6.2.4.3.2, 6.2.4.3.3

### 3.0 Fission Product Barriers

#### 3.3 Containment Barrier

##### 3.3.5 EMERGENCY COORDINATOR JUDGMENT

###### 3.3.5.a/ 3.3.5.b

IC Potential Loss or Loss of Containment Barrier = 2 POINTS

EAL

ANY condition, in the opinion of the EC, that indicates EITHER  
a Potential Loss OR Loss of the Containment Barrier

OPERATIONAL CONDITION - 1, 2, 3

BASIS

This EAL allows the Emergency Coordinator (EC) to address any condition that effects the integrity of the Containment Barrier that is not already covered elsewhere in the Fission Product Barrier Table. A complete loss of the ability to monitor the Containment Barrier should be considered as a "Potential Loss" of that barrier.

Barrier Analysis

Containment Barrier has been potentially lost or lost.

ESCALATION CRITERIA

Emergency Classification will escalate based on the Potential Loss or Loss of additional barriers per EAL section 3.0.

DISCUSSION

None

DEVIATION

None

3.3.5.a/3.3.5.b

Rev. 02

**REFERENCES**

**NUMARC NESP-007, PC6**

**3.3.5.a/3.3.5.b  
Rev. 02**

## 8.0 System Malfunctions

### 8.1 Loss of Heat Removal Capability

#### ALERT - 8.1.2

IC Inability to Maintain the Plant in Cold Shutdown

EAL

PSE&G  
CONTROL  
COPY #

HECG0065

Unplanned, Complete Loss of ALL Technical Specification required systems available to provide Decay Heat Removal functions

AND

EITHER one of the following occur:

- RCS Temperature has risen to  $> 200^{\circ}\text{F}$   
(Excluding a  $< 15$  minute rise  $> 200^{\circ}\text{F}$  with a heat removal function restored)
- An UNCONTROLLED temperature rise is RAPIDLY approaching  $200^{\circ}\text{F}$   
(with NO heat removal function restored)

#### OPERATIONAL CONDITION - 4, 5

#### BASIS

Loss of Decay Heat Removal capabilities necessary to maintain Cold Shutdown conditions could potentially lead to core damage if corrective actions are not implemented. Declaration of an Alert is warranted when ALL Technical Specification required systems are not available to provide Decay Heat Removal functions and cannot be restored to prevent boiling in the core.

The specification of an RCS temperature rise, rather than specific equipment failures, recognizes the potential for long heatup times providing adequate time for restoration of some form of alternate cooling.

The statement "Unplanned, Complete Loss of ALL Technical Specification required systems available to provide Decay Heat Removal functions" is intended to represent a complete loss of functions available, or an inadequate ability, to provide core cooling during the Cold Shutdown and Refueling Modes, including alternate decay heat removal methods. This EAL allows for actions taken IAW OP-AB.ZZ-0142, Loss of Shutdown Cooling (Abnormal Operating Procedure) to reestablish RHR in the Shutdown Cooling Mode or provide for an

EAL - 8.1.2

Rev. 01

alternate methods of decay heat removal, with the intent of maintaining RCS temperature below 200°F.

For loss of an in-service Decay Heat Removal system with other decay heat removal methods available, actions taken to provide for restoration of a decay heat removal function may require time to implement. If the event results in RCS temperature "momentarily" (for less than 15 minutes) rising above 200°F with heat removal capability restored, Emergency Coordinator judgment will be required to determine whether heat removal systems are adequate to prevent boiling in the core and restoration of RCS temperature control. Momentary (not to exceed 15 minutes) unplanned excursions above 200°F, when alternate decay heat removal capabilities exist, should not be classified under this EAL.

NRC analysis has shown that specific sequences can result in core uncover within 15 to 20 minutes and severe core damage within an hour after decay heat removal capability has been lost. Unplanned is defined as a condition that is not due to scheduled operations or maintenance activities, in which an RHR system is intentionally removed from service.

#### **Barrier Analysis**

N/A

#### **ESCALATION CRITERIA**

Emergency Classification will escalate to a Site Area Emergency based on inability to maintain RPV Water level above the Top of the Active Fuel, or rising Radiological Releases.

#### **DISCUSSION**

The Residual Heat Removal (RHR) system provides the normal method for decay heat removal operating in the Shutdown Cooling Mode. With RHR unavailable for shutdown cooling operation, (including the loss of SACS and/or service water which supply cooling water to the RHR heat exchangers), alternate decay heat removal system can be aligned to control decay heat. An unavailability of these systems, can result in a gradual rise in RCS temperature to the values specified in this EAL. The rate of rise in coolant temperature would be dependent on the amount of decay heat present. The threshold for this EAL is the RCS temperature transition value between Operational Conditions 4 and 3.

Procedural guidance is provided to establish an alternate method of decay heat removal. These alternate methods include: aligning Reactor Water Cleanup system (RWCU), with maximum RACS aligned to the Non-Regenerative Heat Exchanger; aligning Condensate Transfer via the ECCS injection lines; aligning RPV Head Spray with RPV Water Level established above + 80"; maximizing Fuel Pool Cooling if the RPV head is removed and the reactor cavity flooded; using the "C" RHR pump crosstied to the "A" RHR loop.

If these alternate means are unavailable, or ineffective, decay heat removal must be accomplished by feed-and-bleed using ECCS systems and discharging steam to the Suppression Pool via the SRVs.

**DEVIATION**

None

**REFERENCES**

**NUMARC NESP-007, SA3**

**NUMARC Questions and Answers, June 1993, "System Malfunction Question #6b"**

**HC.OP-AB.ZZ-0142 (Q), Loss of Shutdown Cooling**

**HC.OP-EO.ZZ-0101 (Q)-FC, Reactor Pressure Vessel (RPV) Control**

**HC.OP-EO.ZZ-0102 (Q)-FC, Primary Containment Control**

**Hope Creek Appendix A based on NEDO-2121, Supplement A to BWR Owners Group  
Emergency Procedure Guidelines, Revision 4**

**HCGS Technical Specifications Sections 3/4.3, 3/4.4.9, 3/4.7.1, 3/4.7.2**

## 8.0 System Malfunctions

### 8.1 Loss of Heat Removal Capability

#### SITE AREA EMERGENCY - 8.1.3.a

IC Loss of Reactor Water Level that has or will Uncover Fuel in the Reactor Vessel

EAL

Reactor Water Level REACHES -161" (Top of Active Fuel)

#### OPERATIONAL CONDITION - 4, 5

##### BASIS

Reactor Water Level reaching -161" (Top of Active Fuel) indicates a loss of core submergence. Without core submergence, the integrity of the fuel clad barrier can no longer be assured, even with the reduced decay heat levels in Cold Shutdown and Refuel. This event is classified based on reaching the Reactor Water level threshold (instead of being able to restore and maintain above the threshold) due to the potentially severe consequences of a loss of core submergence.

Since the design of the normal and emergency makeup systems should preclude this condition, an extreme challenge to their ability to provide core cooling by submergence has occurred. Additionally, ECCS availability and Containment Integrity requirements may be relaxed under these Operational Conditions, thus classification at the Site Area Emergency level is warranted.

##### Barrier Analysis

Fuel Clad Barrier has been potentially lost  
RCS Barrier has been lost.

##### ESCALATION CRITERIA

Emergency Classification will escalate to a General Emergency based on abnormal Radiological Releases.

EAL - 8.1.3.a  
Rev. 01

## DISCUSSION

Core Submergence ensures adequate core cooling. When RPV water level decreases to below Top of Active Fuel (TAF) the ability to effectively remove decay heat can no longer be guaranteed and the Fuel Cladding Barrier can no longer be considered intact. Sustained partial or total core uncover can result in clad damage and a significant release of fission products to the reactor coolant. Sustained core uncover can also result in a breach of the reactor vessel, or an unisolated intersystem LOCA with the RHR System.

## DEVIATION

None

## REFERENCES

NUMARC NESP-007, SS5

HC.OP-EO.ZZ-0101 (Q)-FC, Reactor Pressure Vessel (RPV) Control

HC.OP-EO.ZZ-0201 (Q)-FC, Alternate Level Control

## 8.0 System Malfunctions

### 8.1 Loss of Heat Removal Capability

#### SITE AREA EMERGENCY- 8.1.3.b

IC Complete Loss of Functions Needed to Achieve Cold Shutdown Conditions

EAL

Loss of Main Condenser capabilities, as evidenced by an inability to remove Decay Heat from the Reactor

AND

Loss of Torus capabilities as evidenced by EITHER one of the following:

- Entry into an Unsafe region of ANY of the following curves:
  - Heat Capacity Temperature Limit (HCTL) Curve
  - Heat Capacity Level Limit (HCLL) Curve
  - Pressure Suppression Pressure (PSP) Curve
  - SRV Tailpipe Level Limit Curve
- Insufficient SRV capacity to reduce RPV pressure

OPERATIONAL CONDITION - 1, 2, 3

BASIS

A Complete Loss of decay heat removal systems required to ACHIEVE Cold Shutdown conditions from a Hot Shutdown condition, represents a significant challenge to the plant due to the failure of multiple systems designed for the protection of the public. Hence, declaration of a Site Area Emergency is warranted.

This EAL specifically includes a degradation of those plant systems required to ACHIEVE a Cold Shutdown condition. It does NOT include an inability to MAINTAIN a Cold Shutdown condition. The inability to MAINTAIN Cold Shutdown Conditions is specifically addressed by EAL 8.1.2. Hence, a Loss of RHR Shutdown Cooling is not included in this EAL.

This EAL includes a loss of Service Water or SACS capabilities, based on the effect a loss of these systems has on the ability to maintain Torus capabilities with the Safe Region of the

EAL - 8.1.3.b  
Rev. 01

referenced EOP curves. Loss is defined as the systems being unavailable to perform their intended design function. Hence, in the case where the Main Condenser became isolated from the Reactor due to an MSIV Isolation, but the MSIV could be reopened by procedure, or Main Steam Line drains can control pressure, then a Loss of the Main Condenser capabilities has not occurred.

### Barrier Analysis

N/A

### ESCALATION CRITERIA

Emergency Classification will escalate to a General Emergency based on loss of Fission Product Barriers or Radiological Releases.

### DISCUSSION

In this event, a loss of both the normal heat sink for the Reactor and an impending severe degradation of alternate heat removal capability to the Torus has occurred. Loss of the heat sink for the reactor when in a Hot Shutdown condition will limit the ability to maintain that Operational Condition, or to cooldown the reactor if required.

The Main Condenser can be lost for a variety of reasons; loss of Circulating Water, loss of the Turbine Control and/or Bypass Valve functions, Main Steam Line isolation, etc. With the Main Condenser not available and without the RHR System lined up in Shutdown Cooling Mode, decay heat must be removed from the RCS by HPCI, RCIC or the SRVs and be absorbed in the Suppression Pool (SP). Loss of the pressure control ability of the SRVs as indicated by the inability to reduce RPV pressure represents a loss of control of a major RCS parameter which could result in RPV overpressure conditions, or the inability to cooldown if Cold Shutdown is required.

The HCTL curve is defined as the highest Torus temperature at which initiation of RPV depressurization will not result in exceeding either the SP design temperature or the Primary Containment pressure limit before the rate of energy transfer from the RPV to the Primary Containment is beyond the capacity of the Containment Vent.

The HCLL curve is defined as the higher of either the elevation of the Containment downcomer opening or the lowest Torus level at which initiation of RPV depressurization will not result in exceeding the HCTL.

Violation of either curve would require an immediate emergency depressurization, thus ensuring that the immediately present thermal energy in the RCS has been transferred to the Primary Containment while maintaining the Containment within design limits. This represents a serious potential threat to the Primary Containment Barrier.

EAL - 8.1.3.b  
Rev. 01

## DEVIATION

The NUMARC IC associated with EAL SS4 suggests that the IC should include a Complete Loss of Functions needed to achieve or maintain Hot Shutdown. The NUMARC basis includes both reactivity control and decay heat removal. At Hope Creek, as with all other BWRs, the operator action of placing the Reactor Mode Switch in the Shutdown position that results in Control Rod inserting into the core such that the Reactor will remain shutdown under all conditions without boron, places the Reactor in a Hot Shutdown condition. No additional actions are required to maintain the Reactor in this condition.

Systems are required and additional operator actions are required to achieve Cold Shutdown conditions. Based on this, Hope Creek has modified the NUMARC IC for SS4 to apply specifically to a total loss of decay heat removal, since reactivity control concerns are addressed under the ATWS Section. This IC and EAL are consistent with the requirements for declaration of a Site Area Emergency.

## REFERENCES

NUMARC NESP-007, SS4

HC.OP-EO.ZZ-0100 (Q)-FC, Reactor Scram

HC.OP-EO.ZZ-0101 (Q)-FC, Reactor Pressure Vessel (RPV) Control

HC.OP-EO.ZZ-0102 (Q)-FC, Primary Containment Control

Hope Creek Appendix A based on NEDO-2121, Supplement A to BWR Owners Group

Emergency Procedure Guidelines, Revision 4

HCGS Technical Specifications 3/4.1.3, 3/4.1.5