



JUN 12 2000


L-2000-119
10 CFR 50.36

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

Re: Turkey Point Units 3 and 4
Docket Nos. 50-250 and 50-251
Monthly Operating Report - May, 2000

In accordance with the requirements of Turkey Point Units 3 and 4 Technical Specification 6.9.1.5, and the guidance of Generic Letter 97-02, attached are the May, 2000, Operating Data Reports and Summaries of Operating Experience for Turkey Point Units 3 and 4.

Very truly yours,



R. J. Hovey
Vice President
Turkey Point Plant

CLM

Attachments

cc: Regional Administrator, Region II, USNRC
Senior Resident Inspector, USNRC, Turkey Point Plant

IE24

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-250
UNIT: Turkey Point #3
DATE: June 6, 2000
COMPLETED BY: C. L. Mowrey
TELEPHONE: (305) 246-6204

REPORT MONTH May, 2000

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
5/1/2000	718
5/2/2000	719
5/3/2000	718
5/4/2000	716
5/5/2000	716
5/6/2000	715
5/7/2000	714
5/8/2000	713
5/9/2000	712
5/10/2000	708
5/11/2000	703
5/12/2000	700
5/13/2000	699
5/14/2000	700
5/15/2000	699
5/16/2000	703
5/17/2000	702
5/18/2000	706
5/19/2000	711
5/20/2000	711
5/21/2000	709
5/22/2000	707
5/23/2000	701
5/24/2000	706
5/25/2000	702
5/26/2000	698
5/27/2000	583
5/28/2000	693
5/29/2000	697
5/30/2000	699
5/31/2000	703

OPERATING DATA REPORT

DOCKET NO. 50-250
UNIT NAME TURKEY POINT UNIT 3
DATE June 6, 2000
COMPLETED BY C. L. Mowrey
TELEPHONE (305) 246-6204

REPORTING PERIOD May, 2000
(Month/Year)

1. Design Electrical Rating (MWe-Net)_____ **720**
2. Maximum Dependable Capacity (MWe-Net)_____ **693**

	<u>MONTH</u>	<u>-YTD-</u>	<u>CUMULATIVE</u>
3. Number of Hours Reactor Was Critical_____	744.0	3005.4	172622.8
4. Number of Hours Generator Was On Line_____	744.0	2985.3	170387.4
5. Unit Reserve Shutdown Hours_____	0.0	0.0	121.8
6. Net Electrical Energy (MWH)_____	522676	2080254	110013462

UNIT SHUTDOWNS

DOCKET NO. 50-250
UNIT NAME: Turkey Point #3
DATE: June 6, 2000
COMPLETED BY: C. L. Mowrey
TELEPHONE: (305) 246-6204

REPORT MONTH May, 2000

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Cause & Corrective Action Comments
N/A	N/A	N/A	N/A	N/A	N/A	N/A

1

F - Forced
S - Scheduled

2

Reason
A - Equipment Failure
B - Maintenance or Test
C - Refueling
D - Regulatory restriction
E - Operator Training &
License Examination
F - Administrative
G - Operational Error (Explain)
H - Other (Explain)

3

Method
1 - Manual
2 - Manual Scram
3 - Automatic Scram
4 - Continuation
5 - Other (Explain)

SUMMARY OF OPERATING EXPERIENCE

DOCKET NO. 50-250
UNIT: Turkey Point #3
DATE: June 6, 2000
COMPLETED BY: C. L. Mowrey
TELEPHONE: (305) 246-6204

REPORT MONTH May, 2000

Unit 3 operated essentially at 100% until May 27, when power was reduced to 55% to fix a casing leak on the 3B Steam Generator Feed Pump. Power was returned to 100% later that day and remained at essentially 100% for the rest of the month.

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-251
UNIT: Turkey Point #4
DATE: June 6, 2000
COMPLETED BY: C. L. Mowrey
TELEPHONE: (305) 246-6204

REPORT MONTH May, 2000

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
5/1/2000	714
5/2/2000	716
5/3/2000	715
5/4/2000	714
5/5/2000	714
5/6/2000	712
5/7/2000	712
5/8/2000	678
5/9/2000	291
5/10/2000	643
5/11/2000	700
5/12/2000	698
5/13/2000	698
5/14/2000	700
5/15/2000	699
5/16/2000	702
5/17/2000	701
5/18/2000	702
5/19/2000	710
5/20/2000	710
5/21/2000	708
5/22/2000	705
5/23/2000	700
5/24/2000	704
5/25/2000	703
5/26/2000	698
5/27/2000	695
5/28/2000	694
5/29/2000	697
5/30/2000	699
5/31/2000	703

OPERATING DATA REPORT

DOCKET NO. 50-251
UNIT NAME TURKEY POINT UNIT 4
DATE June 6, 2000
COMPLETED BY C. L. Mowrey
TELEPHONE (305) 246-6204

REPORTING PERIOD May, 2000
(Month/Year)

1. Design Electrical Rating (MWe-Net)_____ **720**
2. Maximum Dependable Capacity (MWe-Net)_____ **693**

	<u>MONTH</u>	<u>-YTD-</u>	<u>CUMULATIVE</u>
3. Number of Hours Reactor Was Critical_____	744	3594.6	169868.8
4. Number of Hours Generator Was On Line_____	744	3576.3	165498.6
5. Unit Reserve Shutdown Hours_____	0.0	0.0	577.2
6. Net Electrical Energy (MWH)_____	511906	2532486	107940856

UNIT SHUTDOWNS

DOCKET NO. 50-251
 UNIT NAME: Turkey Point #4
 DATE: June 6, 2000
 COMPLETED BY: C. L. Mowrey
 TELEPHONE: (305) 246-6204

REPORT MONTH May, 2000

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Cause & Corrective Action Comments
N/A	N/A	N/A	N/A	N/A	N/A	N/A

1

F - Forced
S - Scheduled

2

Reason
 A - Equipment Failure
 B - Maintenance or Test
 C - Refueling
 D - Regulatory restriction
 E - Operator Training &
 License Examination
 F - Administrative
 G - Operational Error (Explain)
 H - Other (Explain)

3

Method
 1 - Manual
 2 - Manual Scram
 3 - Automatic Scram
 4 - Continued
 5 - Other (Explain)

SUMMARY OF OPERATING EXPERIENCE

DOCKET NO.	<u>50-251</u>
UNIT:	<u>Turkey Point #4</u>
DATE:	<u>June 6, 2000</u>
COMPLETE BY:	<u>C. L. Mowrey</u>
TELEPHONE:	<u>(305)246-6204</u>

REPORT MONTH May, 2000

Unit 4 operated at essentially 100% reactor power until May 8, when power was reduced to 40% to perform a turbine valve test. Power was returned to 100% on May 10, and remained at essentially 100% for the rest of the month.