

UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON D. C. 20555

November 24, 1992

Docket No. 50-251

MEMORANDUM FOR: Ellis W. Merschoff, Director
Division of Reactor Projects, RII

FROM: Gus C. Lainas, Assistant Director
for Region II Reactors
Division of Reactor Projects I/II
Office of Nuclear Reactor Regulation

SUBJECT: CLOSE OUT OF TASK INTERFACE AGREEMENT (TIA)
TIA 92-28, TURKEY POINT UNIT 4 RESTART
FOLLOWING HURRICANE 'i', KIDREW (TAC NO. M84370 & M84371)

We have completed responsibilities assigned to NRR in TIA 92-28, as identified below:

1. Review of the licensee's 10 CFR 50.59 evaluation for the interim fire protection system configuration and review of the Unit 2 stack structural integrity are complete. The results of our review are documented in meeting notes dated October 14, 1992. (Meeting was held on September 22, 1992.) The licensee plans to restore the fire protection system to its design basis by November 15, 1992. Therefore, no further NRR review of the fire protection system is required.
2. Conditional Core Damage Frequency (CCDF) following the storm has been estimated. The CCDF estimate is documented in a memorandum from A. Thadani to T. Murley dated October 27, 1992 (Accession Number 9211030123).
3. Regarding review of licensee's Individual Plant Examination (IPE) analyses to take into consideration the experience from the storm and the changes to the plant configuration and systems as a result of the storm, by meeting notes dated October 14, 1992, and our letter dated October 15, 1992 (which forwards the staff's Safety Evaluation of the licensee's IPE), we requested the licensee to inform us of its schedule for revisiting its IPE analyses. The licensee has not established a schedule for this effort. When the licensee's new IPE analysis is available, staff will perform its review under a new Technical Assignment Control (TAC) number.

Thus all the items assigned to NRR in the TIA are now complete and closed.

9212040323 921124

PDR ADOCK 05000251

P PDR