Duke Power
A Duke Energy Company

Duke Power
526 South Church Street
P.O. Box 1006
Charlotte, NC 28201-1006

June 14, 2000

U.S Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555

Subject: Duke Energy Corporation
Catawba Nuclear Station, Units 1, and 2
Docket Numbers 50-413 and 50-414
Monthly Performance and Operation Status-May, 2000

Please find attached information concerning the performance and operation status of the Catawba Nuclear Station for the month of May, 2000 and **Revision 1** for unit 2 on the Monthly Refueling Information Request page for the months of March and April, 2000.

Any questions or comments may be directed to Roger A. Williams at (704) 382-5346.

Sincerely,

Terry Dimmery, Manager
Nuclear Business Support

Attachment
XC:
L. A. Reyes, Regional Administrator
USNRC, Region II

Chandu Patel, Project Manager
USNRC, ONRR

INPO Records Center

Ms. Margaret Aucoin
Nuclear Assurance Corporation

Dottie Sherman, ANI Library
American Nuclear Insurers

Darrell Roberts, Senior Resident Inspector

IE24

NRR 0063

Document Control Desk
U.S. NRC - Catawba

bxc:

Gary Gilbert (CN01RC)
K. E. Nicholson (CN01RC)
RGC Site Licensing File
ELL (EC05O)

Operating Data Report

Docket No.	50-413
Date	June 14,2000
Completed By	Roger Williams
Telephone	704-382-5346

Operating Status

1. Unit Name: Catawba 1
2. Reporting Period: May 1, 2000 - May 31, 2000
3. Licensed Thermal Power (MWt): 3411
4. Nameplate Rating (Gross MWe): 1305 *
5. Design Electrical Rating (Net Mwe): 1145
6. Maximum Dependable Capacity (Gross MWe): 1192
7. Maximum Dependable Capacity(Net MWe): 1129
8. If Changes Occured in Capacity Ratings (Items Number 3-7) Since Last Report, Give Reasons:

Notes: *Nameplate Rating (GrossMWe) calculated as 1450.000 MVA * .90 power factor per Page iii, NUREG-0020.

9. Power Level To Which Restricted, If Any (Net MWe):
10. Reason for Restrictions, If any:

	This Month	YTD	Cumulative
11. Hours in Reporting Period	744.0	3647.0	130824.0
12. Number of Hours Reactor was Critical	744.0	3626.3	105842.9
13. Reactor Reserve Shutdown Hours	0.0	0.0	0.0
14. Hours Generator On-Line	744.0	3611.3	104388.5
15. Unit Reserve Shutdown Hours	0.0	0.0	0.0
16. Gross Thermal Energy Generated (MWH)	2532012	60581098	391615093
17. Gross Electrical Energy Generated (MWH)	901581	4384466	121694893
18. Net Electrical Energy Generated (MWH)	856013	4160001	114676109
19. Unit Service Factor	100.0	99.0	79.8
20. Unit Availability Factor	100.0	99.0	79.8
21. Unit Capacity Factor (Using MDC Net)	101.9	101.0	77.5
22. Unit Capacity Factor (Using DER Net)	100.5	99.6	76.6
23. Unit Forced Outage Rate	0.0	1.0	6.6

24. Shutdown Scheduled Over Next 6 Months (Type, Date and Duration of Each)

25. If ShutDown At End Of Report Period, Estimated Date of Startup

26. Units in Test Status (Prior to Commercial Operation)

	Forcast	Achieved
Initial Criticality		
Initial Electricity		
Commercial Operation		

UNIT SHUTDOWNS

DOCKET NO. 50-413
UNIT NAME: Catawba 1
DATE: June 14, 2000
COMPLETED BY: Roger Williams
TELEPHONE: 704-382-5346

REPORT MONTH: May, 2000

No.	Date:	Type F - Forced S - Scheduled	Duration Hours	(1) Reason	(2) Method of Shutdown R/X	Licensed Event Report No.	Cause and Corrective Action to Prevent Recurrence
			No	Outages	for the Month		

Summary:

(1) Reason

A - Equipment failure (Explain)
B - Maintenance or Test
C - Refueling
D - Regulatory restriction
E - Operator Training/License Examination
F - Administrative
G - Operator Error (Explain)
H - Other (Explain)

(2) Method

1 - Manual
2 - Manual Trip/Scram
3 - Automatic Trip/Scram
4 - Continuation
5 - Other (Explain)

MONTHLY REFUELING INFORMATION REQUEST

1. Facility name: Catawba Unit 1

2. Scheduled next refueling shutdown: October 2000

3. Scheduled restart following refueling: November 2000

THE PROJECT MANAGER HAS BEEN ADVISED BY SEPARATE COMMUNICATION OF ANY T.S. CHANGE OR LICENSE AMENDMENT. THEREFORE, QUESTIONS 4 THROUGH 6 WILL NO LONGER BE MAINTAINED IN THIS REPORT.

4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment?

   If yes, what will these be?

   If no, has reload design and core configuration been reviewed by Safety Review Committee regarding unreviewed safety questions?

5. Scheduled date(s) for submitting proposed licensing action and supporting information.

6. Important licensing considerations (new or different design or supplier, unreviewed design or performance analysis methods, significant changes in design or new operating procedures).

7. Number of Fuel assemblies (a) in the core: 193
   (b) in the spent fuel pool: 784

8. Present licensed fuel pool capacity: 1418
   Size of requested or planned increase: ---

9. Projected date of last refueling which can be accommodated by present license capacity: November 2009

DUKE POWER COMPANY DATE: June 14, 2000

Name of Contact: R. A. Williams Phone: (704) - 382-5346

Operating Data Report

Docket No.	50-414
Date	June 14,2000
Completed By	Roger Williams
Telephone	704-382-5346

Operating Status

1. Unit Name: Catawba 2
2. Reporting Period: May 1, 2000 - May 31, 2000
3. Licensed Thermal Power (MWt): 3411
4. Nameplate Rating (Gross MWe): 1305 *
5. Design Electrical Rating (Net Mwe): 1145
6. Maximum Dependable Capacity (Gross MWe): 1192
7. Maximum Dependable Capacity(Net MWe): 1129
8. If Changes Occured in Capacity Ratings (Items Number 3-7) Since Last Report, Give Reasons:

Notes: *Nameplate Rating (GrossMWe) calculated as 1450.000 MVA * .90 power factor per Page iii, NUREG-0020.

9. Power Level To Which Restricted, If Any (Net MWe):
10. Reason for Restrictions, If any:

	This Month	YTD	Cumulative
11. Hours in Reporting Period	744.0	3647.0	120840.0
12. Number of Hours Reactor was Critical	744.0	2884.5	98407.1
13. Reactor Reserve Shutdown Hours	0.0	0.0	0.0
14. Hours Generator On-Line	744.0	2859.0	97039.6
15. Unit Reserve Shutdown Hours	0.0	0.0	0.0
16. Gross Thermal Energy Generated (MWH)	2533773	69866594	377466470
17. Gross Electrical Energy Generated (MWH)	908725	3336210	112752133
18. Net Electrical Energy Generated (MWH)	863700	3154751	106411747
19. Unit Service Factor	100.0	78.4	80.3
20. Unit Availability Factor	100.0	78.4	80.3
21. Unit Capacity Factor (Using MDC Net)	102.8	76.6	77.9
22. Unit Capacity Factor (Using DER Net)	101.4	75.5	76.9
23. Unit Forced Outage Rate	0.0	3.3	7.8

24. Shutdown Scheduled Over Next 6 Months (Type, Date and Duration of Each)

25. If ShutDown At End Of Report Period, Estimated Date of Startup

26. Units in Test Status (Prior to Commercial Operation)

	Forcast	Achieved
Initial Criticality		
Initial Electricity		
Commercial Operation		

UNIT SHUTDOWNS

DOCKET NO. 50-414
UNIT NAME: Catawba 2
DATE: June 14, 2000
COMPLETED BY: Roger Williams
TELEPHONE: 704-382-5346

REPORT MONTH: May, 2000

No.	Date:	Type F - Forced S - Scheduled	Duration Hours	(1) Reason	(2) Method of Shutdown R/X	Licensed Event Report No.	Cause and Corrective Action to Prevent Recurrence
			No	Outages	for the Month		

Summary:

(1) Reason

A - Equipment failure (Explain)
B - Maintenance or Test
C - Refueling
D - Regulatory restriction
E - Operator Training/License Examination
F - Administrative
G - Operator Error (Explain)
H - Other (Explain)

(2) Method

1 - Manual
2 - Manual Trip/Scram
3 - Automatic Trip/Scram
4 - Continuation
5 - Other (Explain)

MONTHLY REFUELING INFORMATION REQUEST

1. Facility name: Catawba Unit 2

2. Scheduled next refueling shutdown: September 2001

3. Scheduled restart following refueling: October 2001

THE PROJECT MANAGER HAS BEEN ADVISED BY SEPARATE COMMUNICATION OF ANY T.S. CHANGE OR LICENSE AMENDMENT. THEREFORE, QUESTIONS 4 THROUGH 6 WILL NO LONGER BE MAINTAINED IN THIS REPORT.

4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment?

   If yes, what will these be?

   If no, has reload design and core configuration been reviewed by Safety Review Committee regarding unreviewed safety questions?

5. Scheduled date(s) for submitting proposed licensing action and supporting information.

6. Important licensing considerations (new or different design or supplier, unreviewed design or performance analysis methods, significant changes in design or new operating procedures).

7. Number of Fuel assemblies (a) in the core: 193
   (b) in the spent fuel pool: 756

8. Present licensed fuel pool capacity: 1418
   Size of requested or planned increase: ---

9. Projected date of last refueling which can be accommodated by present license capacity: May 2012

DUKE POWER COMPANY DATE: June 14, 2000

Name of Contact: R. A. Williams Phone: (704) - 382-5346

CATAWBA NUCLEAR STATION

MONTHLY OPERATING STATUS REPORT

APRIL 2000

1. Personnel Exposure -

The total station liquid release for APRIL has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.

The total station gaseous release for APRIL has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.

Revision 1

MONTHLY REFUELING INFORMATION REQUEST

1. Facility name: Catawba Unit 2

2. Scheduled next refueling shutdown: September 2001

3. Scheduled restart following refueling: October 2001

THE PROJECT MANAGER HAS BEEN ADVISED BY SEPARATE COMMUNICATION OF ANY T.S. CHANGE OR LICENSE AMENDMENT. THEREFORE, QUESTIONS 4 THROUGH 6 WILL NO LONGER BE MAINTAINED IN THIS REPORT.

4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment?

   If yes, what will these be?

   If no, has reload design and core configuration been reviewed by Safety Review Committee regarding unreviewed safety questions?

5. Scheduled date(s) for submitting proposed licensing action and supporting information.

6. Important licensing considerations (new or different design or supplier, unreviewed design or performance analysis methods, significant changes in design or new operating procedures).

7. Number of Fuel assemblies (a) in the core: 193
   (b) in the spent fuel pool: 756

8. Present licensed fuel pool capacity: 1418
   Size of requested or planned increase: --

9. Projected date of last refueling which can be accommodated by present license capacity: May 2012

DUKE POWER COMPANY DATE: May 11, 2000

Name of Contact: R. A. Williams Phone: (704) - 382-5346

Revision 1

MONTHLY REFUELING INFORMATION REQUEST

1. Facility name: Catawba Unit 2

2. Scheduled next refueling shutdown: Currently Refueling

3. Scheduled restart following refueling: April 2000

THE PROJECT MANAGER HAS BEEN ADVISED BY SEPARATE COMMUNICATION OF ANY T.S. CHANGE OR LICENSE AMENDMENT. THEREFORE, QUESTIONS 4 THROUGH 6 WILL NO LONGER BE MAINTAINED IN THIS REPORT.

4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment?

   If yes, what will these be?

   If no, has reload design and core configuration been reviewed by Safety Review Committee regarding unreviewed safety questions?

5. Scheduled date(s) for submitting proposed licensing action and supporting information.

6. Important licensing considerations (new or different design or supplier, unreviewed design or performance analysis methods, significant changes in design or new operating procedures).

7. Number of Fuel assemblies (a) in the core: 193
   (b) in the spent fuel pool: 756

8. Present licensed fuel pool capacity: 1418
   Size of requested or planned increase: ---

9. Projected date of last refueling which can be accommodated by present license capacity: May 2012

DUKE POWER COMPANY DATE: April 12, 2000

Name of Contact: R. A. Williams Phone: (704) - 382-5346