



Duke Energy Corporation
526 South Church Street
P.O. Box 1006
Charlotte, NC 28201-1006

June 14, 2000

U.S Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555

Subject: Duke Energy Corporation
McGuire Nuclear Station, Units 1 and 2
Docket Numbers 50-369 and 50-370
Monthly Performance and Operation Status-May, 2000

Please find attached information concerning the performance and operation status of the McGuire Nuclear Station for the month of May, 2000.

Any questions or comments may be directed to Roger A. Williams at (704) 382-5346.

Sincerely,


Terry Dimmery, Manager
Nuclear Business Support

Attachment
XC:

L. A. Reyes, Regional Administrator
USNRC, Region II

Frank Rinaldi, Project Manager
USNRC, ONRR

INPO Records Center

Ms. Margaret Aucoin
Nuclear Assurance Corporation

Dottie Sherman, ANI Library
American Nuclear Insurers

Scott Schaeffer, Senior Resident Inspector

NRR 063

IE24

Document Control Desk
U.S. NRC - McGuire

bxc:

M. T. Cash (MG01RC)
RGC Site Licensing File
ELL (EC050)

Operating Data Report

Docket No. 50-369
 Date June 14, 2000
 Completed By Roger Williams
 Telephone 704-382-5346

Operating Status

1. Unit Name: **McGuire 1**
2. Reporting Period: **May 1, 2000 - May 31, 2000**
3. Licensed Thermal Power (MWt): **3411**
4. Nameplate Rating (Gross MWe): **1305 ***
5. Design Electrical Rating (Net Mwe): **1180**
6. Maximum Dependable Capacity (Gross MWe): **1144**
7. Maximum Dependable Capacity (Net MWe): **1100**
8. If Changes Occured in Capacity Ratings (Items Number 3-7) Since Last Report, Give Reasons:

Notes: *Nameplate Rating (GrossMWe) calculated as 1450.000 MVA * .90 power factor per Page iii, NUREG-0020.

9. Power Level To Which Restricted, If Any (Net MWe): _____

10. Reason for Restrictions, If any: _____

	This Month	YTD	Cumulative
11. Hours in Reporting Period	744.0	3647.0	162167.0
12. Number of Hours Reactor was Critical	716.2	3619.2	122037.2
13. Reactor Reserve Shutdown Hours	0.0	0.0	0.0
14. Hours Generator On-Line	701.7	3604.7	120834.6
15. Unit Reserve Shutdown Hours	0.0	0.0	0.0
16. Gross Thermal Energy Generated (MWH)	2356504	36431858	410360842
17. Gross Electrical Energy Generated (MWH)	822625	4313918	132988175
18. Net Electrical Energy Generated (MWH)	791241	4165291	127300342
19. Unit Service Factor	94.3	98.8	74.5
20. Unit Availability Factor	94.3	98.8	74.5
21. Unit Capacity Factor (Using MDC Net)	96.7	103.8	68.9
22. Unit Capacity Factor (Using DER Net)	90.1	96.8	66.5
23. Unit Forced Outage Rate	5.7	1.2	10.7
24. Shutdown Scheduled Over Next 6 Months (Type, Date and Duration of Each)			

25. If ShutDown At End Of Report Period, Estimated Date of Startup

26. Units in Test Status (Prior to Commercial Operation)

	Forecast	Achieved
Initial Criticality	_____	_____
Initial Electricity	_____	_____
Commercial Operation	_____	_____

UNIT SHUTDOWNS

DOCKET NO. 50-369UNIT NAME: McGuire 1DATE: June 14, 2000COMPLETED BY: Roger WilliamsTELEPHONE: 704-382-5346REPORT MONTH: May, 2000

No.	Date:	Type F - Forced S - Scheduled	Duration Hours	(1) Reason	(2) Method of Shutdown R/X	Licensed Event Report No.	Cause and Corrective Action to Prevent Recurrence
1	05/25/00	F	42.32	A	3		'1C' STEAM GENERATOR LO LO LEVEL

Summary:

McGuire unit 1 began the month of May, 2000 operating at 100% full power. The unit operated at or near 100% full power until 05/25/00 at 2044, when a unit runback occurred due to feedwater pump '1A' trip. (The pump trip was due to the feedwater transient resulting from loss of the vital inverter.) A reactor trip occurred at 2046 due to '1C' steam generator lo lo level. The unit was placed on-line 05/27/00 at 1505. During power escalation, the unit held at 41% power from 05/28/00 at 0035 to 0059 due to high generator hydrogen temperatures. The unit held at 50% power from 0154 to 0220 to calibrate power range detectors. The unit held at 86% power from 0830 to 0915 to calibrate power range detectors and thermal power outputs. The unit returned to 100% full power on 05/28/00 at 1834 and operated at or near 100% full power the remainder of the month.

(1) Reason

A - Equipment failure (Explain)

B - Maintenance or Test

C - Refueling

D - Regulatory restriction

E - Operator Training/License Examination

F - Administrative

G - Operator Error (Explain)

H - Other (Explain)

(2) Method

1 - Manual

3 - Automatic Trip/Scram

5 - Other (Explain)

2 - Manual Trip/Scram

4 - Continuation

MONTHLY REFUELING INFORMATION REQUEST

1. Facility name: McGuire Unit 1
2. Scheduled next refueling shutdown: March 2001
3. Scheduled restart following refueling: April 2001

THE PROJECT MANAGER HAS BEEN ADVISED BY SEPARATE COMMUNICATION OF ANY T.S. CHANGE OR LICENSE AMENDMENT. THEREFORE, QUESTIONS 4 THROUGH 6 WILL NO LONGER BE MAINTAINED IN THIS REPORT.

4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment?

If yes, what will these be?

If no, has reload design and core configuration been reviewed by Safety Review Committee regarding unreviewed safety questions?

5. Scheduled date(s) for submitting proposed licensing action and supporting information.
6. Important licensing considerations (new or different design or supplier, unreviewed design or performance analysis methods, significant changes in design or new operating procedures).
7. Number of Fuel assemblies (a) in the core: 193
(b) in the spent fuel pool: 951
8. Present licensed fuel pool capacity: 1463
Size of requested or planned increase: ---
9. Projected date of last refueling which can be accommodated by present license capacity:
November 2005

DUKE POWER COMPANY

DATE: June 14, 2000

Name of Contact: R. A. Williams

Phone: (704) - 382-5346

Operating Data Report

Docket No. 50-370
 Date June 14, 2000
 Completed By Roger Williams
 Telephone 704-382-5346

Operating Status

1. Unit Name: McGuire 2
2. Reporting Period: May 1, 2000 - May 31, 2000
3. Licensed Thermal Power (MWt): 3411
4. Nameplate Rating (Gross MWe): 1305 *
5. Design Electrical Rating (Net Mwe): 1180
6. Maximum Dependable Capacity (Gross MWe): 1144
7. Maximum Dependable Capacity (Net MWe): 1100
8. If Changes Occured in Capacity Ratings (Items Number 3-7) Since Last Report, Give Reasons:

Notes: *Nameplate Rating (GrossMWe) calculated as 1450.000 MVA * .90 power factor per Page iii, NUREG-0020.

9. Power Level To Which Restricted, If Any (Net MWe): _____

10. Reason for Restrictions, If any: _____

	This Month	YTD	Cumulative
11. Hours in Reporting Period	744.0	3647.0	142463.0
12. Number of Hours Reactor was Critical	744.0	3647.0	114978.2
13. Reactor Reserve Shutdown Hours	0.0	0.0	0.0
14. Hours Generator On-Line	744.0	3647.0	113781.3
15. Unit Reserve Shutdown Hours	0.0	0.0	0.0
16. Gross Thermal Energy Generated (MWH)	2534850	48337109	410906836
17. Gross Electrical Energy Generated (MWH)	884048	4177477	130433927
18. Net Electrical Energy Generated (MWH)	852423	4027196	125166061
19. Unit Service Factor	100.0	100.0	79.9
20. Unit Availability Factor	100.0	100.0	79.9
21. Unit Capacity Factor (Using MDC Net)	104.2	100.4	77.5
22. Unit Capacity Factor (Using DER Net)	97.1	93.6	74.5
23. Unit Forced Outage Rate	0.0	0.0	6.2
24. Shutdown Scheduled Over Next 6 Months (Type, Date and Duration of Each)			

25. If ShutDown At End Of Report Period, Estimated Date of Startup

26. Units in Test Status (Prior to Commercial Operation)

	Forecast	Achieved
Initial Criticality	_____	_____
Initial Electricity	_____	_____
Commercial Operation	_____	_____

UNIT SHUTDOWNS

DOCKET NO. 50-370

UNIT NAME: McGuire 2

DATE: June 14, 2000

COMPLETED BY: Roger Williams

TELEPHONE: 704-382-5346

REPORT MONTH: May, 2000

No.	Date:	Type F - Forced S - Scheduled	Duration Hours	(1) Reason	(2) Method of Shutdown R/X	Licensed Event Report No.	Cause and Corrective Action to Prevent Recurrence
			No	Outages	for the Month		

Summary:

(1) Reason

- A - Equipment failure (Explain)
- B - Maintenance or Test
- C - Refueling
- D - Regulatory restriction

- E - Operator Training/License Examination
- F - Administrative
- G - Operator Error (Explain)
- H - Other (Explain)

(2) Method

- 1 - Manual
- 2 - Manual Trip/Scram
- 3 - Automatic Trip/Scram
- 4 - Continuation
- 5 - Other (Explain)

MONTHLY REFUELING INFORMATION REQUEST

1. Facility name: McGuire Unit 2
2. Scheduled next refueling shutdown: September 2000
3. Scheduled restart following refueling: October 2000

THE PROJECT MANAGER HAS BEEN ADVISED BY SEPARATE COMMUNICATION OF ANY T.S. CHANGE OR LICENSE AMENDMENT. THEREFORE, QUESTIONS 4 THROUGH 6 WILL NO LONGER BE MAINTAINED IN THIS REPORT.

4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment?

If yes, what will these be?

If no, has reload design and core configuration been reviewed by Safety Review Committee regarding unreviewed safety questions?

5. Scheduled date(s) for submitting proposed licensing action and supporting information.
6. Important licensing considerations (new or different design or supplier, unreviewed design or performance analysis methods, significant changes in design or new operating procedures).
7. Number of Fuel assemblies (a) in the core: 193
(b) in the spent fuel pool: 1117
8. Present licensed fuel pool capacity: 1463
Size of requested or planned increase: ---
9. Projected date of last refueling which can be accommodated by present license capacity:
June 2003

DUKE POWER COMPANY

DATE: June 14, 2000

Name of Contact: R. A. Williams

Phone: (704) - 382-5346

McGUIRE NUCLEAR STATION

MONTHLY OPERATING STATUS REPORT

APRIL 2000

1. Personnel Exposure -

The total station liquid release for APRIL has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.

The total station gaseous release for APRIL has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.