

James S. Baumstark
Vice President
Nuclear Engineering

Consolidated Edison Company of New York, Inc.
Indian Point 2 Station
Broadway & Bleakley Avenue
Buchanan, New York 10511

Internet: baumstarkj@coned.com
Telephone: (914) 734-5354
Cellular: (914) 391-9005
Pager: (917) 457-9698
Fax: (914) 734-5718

June 19, 2000

Re: Indian Point Unit No. 2
Docket No. 50-247

Document Control Desk
US Nuclear Regulatory Commission
Mail Station P1-137
Washington, DC 20555


SUBJECT: Indian Point Unit 2 Cycle 15 Core Operating Limit Report (COLR)

Dear Sirs:

In accordance with Indian Point Unit 2 Technical Specification 6.9.1.11, enclosed is the IP2 COLR for Cycle 15.

Should you or your staff have any questions concerning this item, please contact Mr. John McCann, Manager, Nuclear Safety & Licensing (914) 734-5129.

Sincerely,



A801

cc: Mr. Hubert J. Miller
Regional Administrator - Region I
US Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Mr. Patrick D. Milano, Project Manager
Project Directorate I-1
Division of Reactor Projects I/II
US Nuclear Regulatory Commission
Mail Stop 14B-2
Washington, DC 20555

Senior Resident Inspector
US Nuclear Regulatory Commission
PO Box 38
Buchanan, NY 10511

Prepared by:

AS PERTELGA
W. OSMIN Ap. Home 1/4/6

Reviewer:

A. J. Horn

Reviewer:

Reviewer:

Reviewer:

Reviewer:

SNSC Review:

NA PREVIOUS SERIAL 2742 6/11/60
SC-OC-370-MM

Reviewer:

Meeting No. / Date

Approval:

Meeting No. / Date _____
Signature Deborah J. Gorme

Signature

1 6/16/00

Date _____

6/19/00

Effective Date

BIENNIAL REVIEW

Reviewer / Date

Reviewer / Date

For use as field copy. Valid for 24 hours:

Control Room Supervisor

Date / Time

Reference USE

CREW 0479

INDIAN POINT STATION UNIT NO 2, CYCLE 15
CORE OPERATING LIMITS REPORT

RPC-6
Rev. 4

NOTE

The Technical Specification references shown next to each Factor OR Limit in this COLR, are there to identify the corresponding sections in Technical Specifications, that refer to the COLR.

The data presented in this report applies to Cycle 15 Only and may NOT be used for other cycles of operation. Any technical change to this graph requires a Safety Evaluation to be performed.

NUCLEAR ENTHALPY RISE HOT CHANNEL FACTOR

NOTE

P is the fraction of full power at which the core is operating.

$$F_{\Delta}^N \leq 1.70 [1 + 0.3 (1-P)]$$

Tech. Spec. 3.10.2.1

HEIGHT DEPENDENT HEAT FLUX HOT CHANNEL FACTOR FOR
≤ 25% TUBE PLUGGING

NOTE

K(Z) is the fraction given in Figure 1 AND
Z is the core height location of F_0 .

$$\text{IF } P > .5, F_0(Z) \leq (2.50/P) \times K(Z)$$

Tech. Spec. 3.10.2.1

$$\text{IF } P \leq .5, F_0(Z) \leq (5.00) \times K(Z)$$

Tech. Spec. 3.10.2.1

NA-PREVIOUS SNSC #7742 6/4/6

SE-00-376-MM

SNSC

[Signature]

Approved

6/19/60

Effective Date

INDIAN POINT STATION UNIT NO 2, CYCLE 15
CORE OPERATING LIMITS REPORT

RPC-6 |
Rev. 4

AXIAL FLUX DIFFERENCE ENVELOPE LIMITS

The Indicated Axial Flux Difference limit is the Target Band; i.e., the Target \pm 5%.

Tech. Spec. 3.10.2.6.1

The Axial Flux Difference Envelope Limits at 90 percent power are -11%, +11% AND increase by -1% and +1%, for each 2% of rated power below 90% power, as indicated by Graph RPC-5, Target Flux And Operating Envelope Diagram.

Tech. Spec. 3.10.2.6.1

INSERTION LIMITS

The Shutdown Banks shall be fully withdrawn when the reactor is critical OR approaching criticality.

Tech. Spec. 3.10.4.1

The Control Bank Insertion Limits for Criticality, are as indicated by Figure 2.

Tech. Spec. 3.10.4.2

NA Previous SNSC #2742 6/11

SE-370-MM

SNSC

A. J. [Signature]


Approved

6/19/00

Effective Date

FIGURE 2

FIGURE 3.10-3.
ROD BANK INSERTION LIMITS
(Four Loop Operation)
100 Step Overlap




NA PREV SNSC #2742 9/16
SE-00-372-MH
SNSC
A. J. Herman
Approved
6/19/00
Effective Date

INDIAN POINT STATION UNIT NO 2, CYCLE 15
CORE OPERATING LIMITS REPORT

RPC-6 1
 Rev. 4

FIGURE 1 HOT CHANNEL FACTOR NORMALIZED OPERATING ENVELOPE
 (For S.G. Tube Plugging up to 25%)



NAPREVIAS SN# #2742 6/16/00
SE-00-370-MN
 SN#C
A. J. Gorm
 Approved
6/19/00
 Effective Date