



PECO PowerLabsSM
Testing and Solutions, Guaranteed.

50-784
PECO Energy Company
175 North Cain Road
Coatesville, PA 19320

June 20, 2000

Kenneth Peters
New York Power Authority
Indian Point # 3 Nuclear Power Plant
P.O. Box 315
Buchanan, NY 10511

Subject: Valve Operation Test & Evaluation System (VOTES)
Re-calibrations

Reference: Letter - G.C. Bell (PECO PowerLabs) to Kenneth Peters (IP3) dated 5/26/2000

Dear Mr. Peters:

The Votes clamps listed below, as originally identified in the referenced letter, were re-calibrated and determined to be in tolerance.

IP3 M-1943-0005	Liberty Technology Model No. MCC-100
IP3 M-1943-0004	Liberty Technology Model No. MCC-100
IP3 M-1943-0002	Liberty Technology Model No. ECC-225
IP3 M-1965-0002	Liberty Technology Model No. ECC-225

We regret any inconvenience the event, as described in the referenced letter, may have had on your operation. We believe that the actions we have taken in response to the event will serve to prevent its recurrence.

Sincerely,

George C. Bell
Director

Copy to:
H. J. Miller
USNRC
475 Allendale Road
King of Prussia, PA 19406

USNRC
Document Control Desk
Washington, DC 20555-0001

Acc 1