



U.S. NUCLEAR REGULATORY COMMISSION
OFFICE OF NUCLEAR REGULATORY RESEARCH

December 1981
Division 1
Task CE 913-5

DRAFT REGULATORY GUIDE AND VALUE/IMPACT STATEMENT

Contact: C. Schulten (301)443-5910

PROPOSED REVISION 2* TO REGULATORY GUIDE 1.13

SPENT FUEL STORAGE FACILITY DESIGN BASIS

A. INTRODUCTION

General Design Criterion 61, "Fuel Storage and Handling and Radioactivity Control," of Appendix A, "General Design Criteria for Nuclear Power Plants," to 10 CFR Part 50, "Domestic Licensing of Production and Utilization Facilities," requires that fuel storage and handling systems be designed to ensure adequate safety under normal and postulated accident conditions. It also requires that these systems be designed (1) with a capability to permit appropriate periodic inspection and testing of components important to safety, (2) with suitable shielding for radiation protection, (3) with appropriate containment, confinement, and filtering systems, (4) with a residual heat removal capability having reliability and testability that reflects the importance to safety of decay heat and other residual heat removal, and (5) to prevent significant reduction in fuel storage coolant inventory under accident conditions. This guide describes a method acceptable to the NRC staff for implementing Criterion 61.

B. DISCUSSION

Working Group ANS-57.2 of the American Nuclear Society Subcommittee ANS-50 has developed a standard that details minimum design requirements for

*The substantial number of changes in this proposed revision has made it impractical to indicate the changes with lines in the margin.

This regulatory guide and the associated value/impact statement are being issued in draft form to involve the public in the early stages of the development of a regulatory position in this area. They have not received complete staff review and do not represent an official NRC staff position.

Public comments are being solicited on both drafts, the guide (including any implementation schedule) and the value/impact statement. Comments on the value/impact statement should be accompanied by supporting data. Comments on both drafts should be sent to the Secretary of the Commission, U.S. Nuclear Regulatory Commission, Washington, D.C. 20555, Attention: Docketing and Service Branch, by **MAR 5 1982**

Requests for single copies of draft guides (which may be reproduced) or for placement on an automatic distribution list for single copies of future draft guides in specific divisions should be made in writing to the U.S. Nuclear Regulatory Commission, Washington, D.C. 20555, Attention: Director, Division of Technical Information and Document Control.

spent fuel storage facilities at nuclear power stations. This standard was approved by the American National Standards Committee N18, Nuclear Design Criteria. It was subsequently approved and designated ANSI N210-1976/ANS-57.2, "Design Objectives for Light Water Reactor Spent Fuel Storage Facilities at Nuclear Power Stations," by the American National Standards Institute on April 12, 1976.

Primary facility design objectives are:

- a. To prevent loss of water from the fuel pool that would uncover fuel,
- b. To protect the spent fuel from mechanical damage, and
- c. To provide the capability for limiting the potential offsite exposures in the event of significant release of radioactivity from the fuel.

If spent fuel storage facilities are not provided with adequate protective features, radioactive materials could be released to the environment as a result of either loss of water from the storage pool or mechanical damage to fuel within the pool.

1. LOSS OF WATER FROM STORAGE POOL

Unless protective measures are taken to prevent the loss of water from a fuel storage pool, the spent fuel could overheat and cause damage to fuel cladding integrity, which could result in the release of radioactive materials to the environment. Equipment failures in systems connected to the pool could also result in the loss of pool water. A permanent coolant makeup system designed with suitable redundancy or backup would prevent the fuel from being uncovered should pool leaks occur. Further, early detection of pool leakage and fuel damage can be made using pool-water-level monitors and pool radiation monitors that alarm locally and also at a continuously manned location to ensure timely operation of building filtration systems. Natural events such as earthquakes or high winds can damage the fuel pool either directly or by the generation of missiles. Earthquakes or high winds could also cause structures or cranes to fall into the pool. Designing the facility to withstand these occurrences without significant loss of watertight integrity will alleviate these concerns.

2. MECHANICAL DAMAGE TO FUEL

The release of radioactive material from fuel may occur as a result of fuel-cladding failures or mechanical damage caused by the dropping of fuel elements or objects onto fuel elements during the refueling process and at other times.

Plant arrangements consider low-probability accidents such as the dropping of heavy loads (e.g., a 100-ton fuel cask) where such loads are positioned or moved in or over the spent fuel pool. It is desirable that cranes capable of carrying heavy loads be prevented from moving into the vicinity of the stored fuel.

Missiles generated by high winds also are a potential cause of mechanical damage to fuel. This concern can be eliminated by designing the fuel storage facility to preclude the possibility of the fuel being struck by missiles generated by high winds.

3. LIMITING POTENTIAL OFFSITE EXPOSURES

Mechanical damage to the fuel might cause significant offsite doses unless dose reduction features are provided. Dose reduction designs such as negative pressure in the fuel handling building during movement of spent fuel would prevent exfiltration and ensure that any activity released to the fuel handling building will be treated by an engineered safety feature (ESF) grade filtration system before release to the environment. Even if measures not described are used to maintain the desired negative pressure, small leaks from the building may still occur as a result of structural failure or other unforeseen events.

The staff considers Seismic Category I design assumptions acceptable for the spent fuel pool cooling, makeup, and cleanup systems. Tornado protection requirements are acceptable for the water makeup source and its delivery system, the pool structure, the building housing the pool, and the filtration-ventilation system. Regulatory Guide 1.52, "Design, Testing, and Maintenance Criteria for Post Accident Engineered-Safety-Feature Atmosphere Cleanup System Air Filtration and Adsorption Units of Light-Water-Cooled Nuclear Power Plants," and Regulatory Guide 1.140, "Design, Testing, and Maintenance Criteria for Normal Ventilation Exhaust System Air Filtration and Adsorption Units of Light-Water-Cooled Nuclear

Power Plants," provide guidelines to limit potential offsite exposures through the filtration-ventilation system of the pool building.

Occupational radiation exposure is kept as low as is reasonably achievable (ALARA) in all activities involving personnel, and efforts toward maintaining exposures ALARA are considered in the design, construction, and operational phases. Guidance on maintaining exposures ALARA is provided in Regulatory Guide 8.8, "Information Relevant to Ensuring That Occupational Radiation Exposures at Nuclear Power Stations Will Be As Low As Is Reasonably Achievable."

C. REGULATORY POSITION

The requirements in ANSI N210-1976/ANS-57.2, "Design Objectives for Light Water Reactor Spent Fuel Storage Facilities at Nuclear Power Stations,"* are generally acceptable to the NRC staff as a means for complying with the requirements of General Design Criterion 61, "Fuel Storage and Handling and Radioactivity Control," of Appendix A, "General Design Criteria for Nuclear Power Plants," to 10 CFR Part 50 as related to light-water reactors (LWRs), subject to the following clarifications and modifications:

1. In lieu of the example inventory in Section 4.2.4.3(1), the example inventory should be that inventory of radioactive materials that are predicted to leak under the postulated maximum damage conditions resulting from the dropping of a single spent fuel assembly onto a fully loaded spent fuel pool storage rack. Other assumptions in the analysis should be consistent with those given in Regulatory Guide 1.25 (Safety Guide 25), "Assumptions Used for Evaluating the Potential Radiological Consequences of a Fuel Handling Accident in the Fuel Handling and Storage Facility for Boiling and Pressurized Water Reactors."

2. In addition to meeting the requirements of Section 5.1.3, boiling of the pool water may be permitted only when the resulting thermal loads are properly accounted for in the design of the pool structure, the storage racks, and other safety-related structures, equipment, and systems.

*Copies may be obtained from the American Nuclear Society, 555 North Kensington Avenue, La Grange Park, Illinois 60525

3. In addition to meeting the requirements of Section 5.1.3, the fuel storage pool should be designed (a) to prevent tornado winds and missiles generated by these winds from causing significant loss of watertight integrity of the fuel storage pool and (b) to prevent missiles generated by tornado winds from striking the fuel. These requirements are discussed in Regulatory Guide 1.117, "Tornado Design Classification." The fuel storage building, including walls and roof, should be designed to prevent penetration by tornado-generated missiles or from seismic damage to ensure that nothing bypasses the ESF-grade filtration system in the containment building.

4. In addition to meeting the requirements of Section 5.1.5.1, provisions should be made to ensure that nonfuel components in fuel pools are handled below the minimum water shielding depth. A system should be provided that, either through the design of the system or through administrative procedures, would prohibit unknowing retrieval of these components.

5. In addition to meeting the requirements of Section 5.1.12.10, the maximum potential kinetic energy capable of being developed by any object handled above stored spent fuel, if dropped, should not exceed the kinetic energy of one fuel assembly and its associated handling tool when dropped from the height at which it is normally handled above the spent fuel pool storage racks.

6. In addition to meeting the requirements of Section 5.2.3.1, an interface should be provided between the cask venting system and the building ventilation system to minimize personnel exposure to the "vent-gas" generated from filling a dry loaded cask with water.

7. In addition to meeting the requirements of Section 5.3.3, radioactivity released during a Condition IV fuel handling accident should be either contained or removed by filtration so that the dose to an individual is less than the guidelines of 10 CFR Part 100. The calculated offsite dose to an individual from such an event should be well within the exposure guidelines of 10 CFR Part 100 using appropriately conservative analytical methods and assumptions. In order to ensure that released activity does not bypass the

filtration system, the ESF fuel storage building ventilation should provide and maintain a negative pressure of at least 3.2 mm (0.125 in.) water gauge within the fuel storage building.

8. In addition to the requirements of Section 6.3.1, overhead handling systems used to handle the spent fuel cask should be designed so that travel directly over the spent fuel storage pool or safety-related equipment is not possible. This should be verified by analysis to show that the physical structure under all cask handling pathways will be adequately designed so that unacceptable damage to the spent fuel storage facility or safety-related equipment will not occur in the event of a load drop.

9. In addition to the references listed in Section 6.4.4, Safety Class 3, Seismic Category I, and safety-related structures and equipment should be subjected to quality assurance programs that meet the applicable provisions of Appendix B, "Quality Assurance Criteria for Nuclear Power Plants and Fuel Reprocessing Plants," to 10 CFR Part 50. Further, these programs should obtain guidance from Regulatory Guide 1.28, "Quality Assurance Program Requirements (Design and Construction)," endorsing ANSI N45.2, and from the applicable provisions of the ANSI N45.2-series standards endorsed by the following regulatory guides:

- 1.30 (Safety Guide 30) "Quality Assurance Requirements for the Installation, Inspection, and Testing of Instrumentation and Electric Equipment" (N45.2.4).
- 1.38 "Quality Assurance Requirements for Packaging, Shipping, Receiving, Storage, and Handling of Items for Water-Cooled Nuclear Power Plants" (N45.2.2).
- 1.58 "Qualification of Nuclear Power Plant Inspection, Examination, and Testing Personnel" (N45.2.6).
- 1.64 "Quality Assurance Requirements for the Design of Nuclear Power Plants" (N45.2.11).

- 1.74 "Quality Assurance Terms and Definitions" (N45.2.10).
- 1.88 "Collection, Storage, and Maintenance of Nuclear Power Plant Quality Assurance Records" (N45.2.9).
- 1.94 "Quality Assurance Requirements for Installation, Inspection, and Testing of Structural Concrete and Structural Steel During the Construction Phase of Nuclear Power Plants" (N45.2.5).
- 1.116 "Quality Assurance Requirements for Installation, Inspection, and Testing of Mechanical Equipment and Systems" (N45.2.8).
- 1.123 "Quality Assurance Requirements for Control of Procurement of Items and Services for Nuclear Power Plants" (N45.2.13).

10. The spent fuel pool water temperatures stated in Section 6.6.1(2) exceed the limits recommended by the NRC staff. For the maximum heat load during Condition I occurrences with normal cooling systems in operation and assuming a single active failure, the pool water temperature should be kept at or below 60°C (140°F). Under abnormal maximum heat load conditions (full core unload) and also for Condition IV occurrences, the pool water temperature should be kept below boiling.

11. A nuclear criticality safety analysis should be performed in accordance with Appendix A to this guide for each system that involves the handling, transfer, or storage of spent fuel assemblies at LWR spent fuel storage facilities.

12. The spent fuel storage facility should be equipped with both electrical interlocks and mechanical stops to keep casks from being transported over the spent fuel pool.

13. Sections 6.4 and 9 of ANS-57.2 list those codes and standards referenced in ANS-57.2. Although this regulatory guide endorses with clarifications and modifications ANS-57.2, a blanket endorsement of those referenced codes and

standards is not intended. (Other regulatory guides may contain some such endorsements.)

D. IMPLEMENTATION

The purpose of this section is to provide information to applicants regarding the NRC staff's plans for using this regulatory guide.

This proposed revision has been released to encourage public participation in its development. Except in those cases in which an applicant proposes an acceptable alternative method for complying with specified portions of the Commission's regulations, the method to be described in the active guide reflecting public comments will be used in the evaluation of applications for construction permits and operating licenses docketed after the implementation date to be specified in the active guide. Implementation by the staff will in no case be earlier than June 30, 1982.

APPENDIX A

NUCLEAR CRITICALITY SAFETY

1. SCOPE OF NUCLEAR CRITICALITY SAFETY ANALYSIS

- ✓ 1.1 A nuclear criticality safety analysis should be performed for each system that involves the handling, transfer, or storage of spent fuel assemblies at light-water reactor (LWR) spent fuel storage facilities.
- ✓ 1.2 The nuclear criticality safety analysis should demonstrate that each LWR spent fuel storage facility system is subcritical (k_{eff} not to exceed 0.95).
- ✓ 1.3 The nuclear criticality safety analysis should include consideration of all credible normal and abnormal operating occurrences, including:
 - a. Accidental tipping or falling of a spent fuel assembly,
 - b. Accidental tipping or falling of a storage rack during transfer,
 - c. Misplacement of a spent fuel assembly,
 - d. Accumulation of solids containing fissile materials on the pool floor or at locations in the cooling water system,
 - e. Fuel drop accidents,
 - f. Stuck fuel assembly/crane uplifting forces,
 - g. Horizontal motion of fuel before complete removal from rack,
 - h. Placing a fuel assembly along the outside of rack, and
 - i. Objects that may fall onto the stored spent fuel assemblies.
- ✓ 1.4 At all locations in the LWR spent fuel storage facility where spent fuel is handled or stored, the nuclear criticality safety analysis should demonstrate that criticality could not occur without at least two unlikely, independent, and concurrent failures or operating limit violations.
- ✓ 1.5 The nuclear criticality safety analysis should explicitly identify spent fuel assembly characteristics upon which subcriticality in the LWR spent fuel storage facility depends.

✓ 1.6 The nuclear criticality safety analysis should explicitly identify design limits upon which subcriticality depends that require physical verification at the completion of fabrication or construction.

✓ 1.7 The nuclear criticality safety analysis should explicitly identify operating limits upon which subcriticality depends that require implementation in operating procedures.

2. CALCULATION METHODS AND CODES

Methods used to calculate subcriticality should be validated in accordance with Regulatory Guide 3.41, "Validation of Computational Methods for Nuclear Criticality Safety," which endorses ANSI N16.9-1975.

3. METHOD TO ESTABLISH SUBCRITICALITY

✓ 3.1 The evaluated multiplication factor of fuel in the spent fuel storage racks, k_s , under normal and credible abnormal conditions should be equal to or less than an established maximum allowable multiplication factor, k_a ; i.e.,

$$✓ k_s \leq k_a$$

The factor, k_s , should be evaluated from the expression:

$$✓ k_s = k_{sn} + \Delta k_{sb} + \Delta k_u + \Delta k_{sc}$$

where

k_{sn} = the computed effective multiplication factor; k_{sn} is calculated by the same methods used for benchmark experiments for design storage parameters when the racks are loaded with the most reactive fuel to be stored,

Δk_{sb} = the bias in the calculation procedure as obtained from the comparisons with experiments and including any extrapolation to storage pool conditions,

Δk_u = the uncertainty in the benchmark experiments, and

Δk_{sc} = the combined uncertainties in the parameters listed in paragraph 3.2 below.

✓ 3.2 The combined uncertainties, Δk_{sc} , include:

- a. Statistical uncertainty in the calculated result if a Monte Carlo calculation is used,
- b. Uncertainty resulting from comparison with calculational and experimental results,
- c. Uncertainty in the extrapolation from experiment to storage rack conditions, and
- d. Uncertainties introduced by the considerations enumerated in paragraphs 4.3 and 4.4 below.

✓ 3.3 The various uncertainties may be combined statistically if they are independent. Correlated uncertainties should be combined additively.

✓ 3.4 All uncertainty values should be at the 95 percent probability level with a 95 percent confidence value.

✓ 3.5 For spent fuel storage pool, the value of k_a should be no greater than 0.95.

4. STORAGE RACK ANALYSIS ASSUMPTIONS

✓ 4.1 The spent fuel storage rack module design should be based on one of the following assumptions for the fuel:

- ✓ a. The most reactive fuel assembly to be stored at the most reactive point in the assembly life, or
- ✓ b. The most reactive fuel assembly to be stored based on a minimum confirmed burnup (see Section 6 of this appendix).

Both types of rack modules may be present in the same storage pool.

✓ 4.2 Determination of the most reactive spent fuel assembly includes consideration of the following parameters:

- a. Maximum fissile fuel loading,
- b. Fuel rod diameter,
- c. Fuel rod cladding material and thickness,
- d. Fuel pellet density,
- e. Fuel rod pitch and total number of fuel rods within assembly,
- f. Absence of fuel rods in certain locations, and
- g. Burnable poison content.

✓ 4.3 The fuel assembly arrangement assumed in storage rack design should be the arrangement that results in the highest value of k_s considering:

- a. Spacing between assemblies,
- b. Moderation between assemblies, and
- c. Fixed neutron absorbers between assemblies.

✓ 4.4 Determination of the spent fuel assembly arrangement with the highest value of k_s shall include consideration of the following:

- a. Eccentricity of fuel bundle location within the racks and variations in spacing among adjacent bundles,
- b. Dimensional tolerances,
- c. Construction materials,
- d. Fuel and moderator density (allowance for void formations and temperature of water between and within assemblies),

- e. Presence of the remaining amount of fixed neutron absorbers in fuel assembly, and
- f. Presence of structural material and fixed neutron absorber in cell walls between assemblies.

✓ 4.5 Fuel burnup determination should be made for fuel stored in racks where credit is taken for burnup. The following methods are acceptable:

- a. A minimum allowable fuel assembly reactivity should be established, and a reactivity measurement should be performed to ensure that each assembly meets this criterion; or
- b. A minimum fuel assembly burnup value should be established as determined by initial fuel assembly enrichment or other correlative parameters, and a measurement should be performed to ensure that each fuel assembly meets the established criterion; or
- c. A minimum fuel assembly burnup value should be established as determined by initial fuel assembly enrichment or other correlative parameters, and an analysis of each fuel assembly's exposure history should be performed to determine its burnup. The analyses should be performed under strict administrative control using approved written procedures. These procedures should provide for independent checks of each step of the analysis by a second qualified person using nuclear criticality safety assessment criteria described in paragraph 1.4 above.

✓ The uncertainties in determining fuel assembly storage acceptance criteria should be considered in establishing storage rack reactivity, and auditable records should be kept of the method used to determine the fuel assembly storage acceptance criterion for as long as the fuel assemblies are stored in the racks.

✓ Consideration should be given to the axial distribution of burnup in the fuel assembly, and a limit should be set on the length of the fuel assembly that is permitted to have a lower average burnup than the fuel assembly average.

5. USE OF NEUTRON ABSORBERS IN STORAGE RACK DESIGN

5.1 Fixed neutron absorbers may be used for criticality control under the following conditions:

- a. The effect of neutron-absorbing materials of construction or added fixed neutron-absorbers may be included in the evaluation if they are designed and fabricated so as to preclude inadvertent removal by mechanical or chemical action.
- b. Fixed neutron absorbers should be an integral, nonremovable part of the storage rack.
- c. When a fixed neutron absorber is used as the primary nuclear criticality safety control, there should be provision to:
 - (1) Initially confirm absorber presence in the storage rack, and
 - (2) Periodically verify continued presence of absorber.

✓ 5.2 The presence of a soluble neutron absorber in the pool water should not normally be used in the evaluation of k_s . However, when calculating the effects of Condition IV faults, realistic initial conditions (e.g., the presence of soluble boron) may be assumed for the fuel pool and fuel assemblies.

6. CREDIT FOR BURNUP IN STORAGE RACK DESIGN

6.1 Consideration should be given to the fact that the reactivity of any given spent fuel assembly will depend on initial enrichment, ^{235}U depletion, amount of burnable poison, plutonium buildup and fission product burnable poison depletion, and the fact that the rates of depletion and plutonium and fission product buildup are not necessarily the same.

6.2 Consideration should be given to the practical implementation of the spent fuel screening process. Factors to be considered in choosing the screening method should include:

- a. Accuracy of the method used to determine storage rack reactivity;
- b. Reproducibility of the result, i.e., what is the uncertainty in the result?
- c. Simplicity of the procedure; i.e., how much disturbance to other operations is involved?
- d. Accountability, i.e., ease and completeness of recordkeeping; and
- e. Auditability.

DRAFT VALUE/IMPACT STATEMENT

1. PROPOSED ACTION

1.1 Description

Each nuclear power plant has a spent fuel storage facility. General Design Criterion 61, "Fuel Storage and Handling and Radioactivity Control," of Appendix A, "General Design Criteria for Nuclear Power Plants," to 10 CFR Part 50, "Domestic Licensing of Production and Utilization Facilities," requires that fuel storage and handling systems be designed to ensure adequate safety under normal and postulated accident conditions. The proposed action would provide an acceptable method for implementing this criterion. This action would be an update of Regulatory Guide 1.13, "Spent Fuel Storage Facility Design Basis."

1.2 Need for Proposed Action

Since Regulatory Guide 1.13 was last published in December of 1975, additional guidance has been provided in the form of ANSI standards and NUREG reports. The Office of Nuclear Reactor Regulation has requested that this guide be updated.

1.3 Value/Impact of Proposed Action

1.3.1 NRC

The applicants' basis for the design of the spent fuel storage facility will be the same as that used by the staff in its review of a construction permit or operating license application. Therefore, there should be a minimum number of cases where the applicant and the staff radically disagree on the design criteria.

1.3.2 Government Agencies

Applicable only if the agency, such as TVA, is an applicant.

1.3.3 Industry

The value/impact on the applicant will be the same as for the NRC staff.

1.3.4 Public

No major impact on the public can be foreseen.

1.4 Decision on Proposed Action

The guidance furnished on the design basis for the spent fuel storage facility should be updated.

2. TECHNICAL APPROACH

The American Nuclear Society published ANS-57.2 (ANSI N210), "Design Objectives for Light Water Reactor Spent Fuel Storage Facilities at Nuclear Power Stations." Part of the update of Regulatory Guide 1.13 would be an evaluation of this standard and possible endorsement by the NRC. Also, recommendations made by Task A-36, which were published in NUREG-0612, "Control of Heavy Loads at Nuclear Power Plants," would be included.

3. PROCEDURAL APPROACH

Since Regulatory Guide 1.13 already deals with the proposed action, logic dictates that this guide be updated.

4. STATUTORY CONSIDERATIONS

4.1 NRC AUTHORITY

Authority for this regulatory guide is derived from the safety requirements of the Atomic Energy Act of 1954, as amended, through the Commission's regulations, in particular, General Design Criterion 61 of Appendix A to 10 CFR Part 50.

4.2 Need for NEPA Assessment

The proposed action is not a major action as defined by paragraph 51.5(a)(10) of 10 CFR Part 51 and does not require an environmental impact statement.

5. CONCLUSION

Regulatory Guide 1.13 should be updated.