

ORIGINAL ACRST-3120

OFFICIAL TRANSCRIPT OF PROCEEDINGS  
NUCLEAR REGULATORY COMMISSION  
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

Title: MEETING: PLANT OPERATIONS  
AND FIRE PROTECTION

TRO4 (ACRS)  
RETURN ORIGINAL  
TO BJWHITE  
M/S T-2E26  
415-7130  
THANKS!

Work Order No.: NRC-1351

LOCATION: Lisle, IL

DATE: Wednesday, June 14, 2000

PAGES: 1 - 254

ANN RILEY & ASSOCIATES, LTD.

1025 Connecticut Ave., NW, Suite 1014

Washington, D.C. 20036

202-342-0034

ACRS Office Copy - Retain  
for the Life of the Committee

DISCLAIMER

UNITED STATES NUCLEAR REGULATORY COMMISSION'S  
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

JUNE 14, 2000

The contents of this transcript of the proceeding of the United States Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards, taken on June 14, 2000, as reported herein, is a record of the discussions recorded at the meeting held on the above date.

This transcript had not been reviewed, corrected and edited and it may contain inaccuracies.

1 UNITED STATES OF AMERICA  
2 NUCLEAR REGULATORY COMMISSION  
3 ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

4 \*\*\*

5 MEETING: PLANT OPERATIONS AND FIRE PROTECTION

6  
7 U.S.N.R.C., Region III

8 801 Warrenville Road

9 Lisle, IL

10 Wednesday, June 14, 2000

11 The committee met, pursuant to notice, at 8:30  
12 a.m.

13 MEMBERS PRESENT:

14 DANA A. POWERS, Chairman

15 GEORGE APOSTOLAKIS, Vice-Chairman

16 JOHN J. BARTON

17 MARIO V. BONACA

18 ROBERT L. SEALE

19 JOHN D. SIEBER

20 GRAHAM B. WALLIS

21  
22  
23  
24  
25  
ANN RILEY & ASSOCIATES, LTD.  
Court Reporters  
1025 Connecticut Avenue, NW, Suite 1014  
Washington, D.C. 20036  
(202) 842-0034

## P R O C E E D I N G S

[8:30 a.m.]

CHAIRMAN BARTON: Good morning. The meeting will now come to order. This is a meeting of the ACRS Subcommittees on Plant Operations and Fire Protection.

I am John Barton, Chairman of the Subcommittee on Plant Operations, and Jack Sieber is Chairman of the Fire Protection Subcommittee.

ACRS members in attendance are George Apostolakis, Dana Powers, Mario Bonaca, Robert Seale, Robert Uhrig, Jack Sieber, and Graham Wallis.

The purpose of this meeting is to discuss selective technical components of the plant operations and fire protection issues. The subcommittee will gather information, analyze relevant issues and facts, and formally proposed positions and actions, as appropriate, for deliberation by the full committee.

Jit Singh is the Cognizant ACRS Staff Engineer for this meeting.

The rules for participation in today's meeting have been announced as part of the notice of this meeting previously published in the Federal Register on May 24, 2000.

A transcript of the meeting is being kept and will be made available as stated in the Federal Register Notice.

ANN RILEY & ASSOCIATES, LTD.  
Court Reporters  
1025 Connecticut Avenue, NW, Suite 1014  
Washington, D.C. 20036  
(202) 842-0034

1           It is requested that speakers first identify  
2 themselves and speak with sufficient clarity and volume so  
3 they can be readily heard.

4           We have received no written comments from members  
5 of the public.

6           We will now proceed with the meeting, and I call  
7 upon Mr. Jim Dyer to begin.

8           MR. DYER: Thank you, Mr. Barton. Good morning.  
9 Welcome to Region III. I'm Jim Dyer, I'm the Regional  
10 Administrator for the Regional Office. With me here today  
11 are Mr. Marc Dapas, who is the Deputy Director of the  
12 Division of Reactor Projects; Mr. Jack Grobe, who is the  
13 Division Director, Division of Reactor Safety; and, Mr. Jim  
14 Caldwell, who is Deputy Regional Administrator.

15           Also, throughout the day, we've scheduled an  
16 agenda, which copies are available for the public over by  
17 the coffee pot and as you come into the conference room, and  
18 the various members of the staff will be addressing the  
19 subcommittees today, based on the information we understand  
20 that you request, and if you want additional information,  
21 we're very flexible. We'll try to get anybody who is here  
22 on the staff to answer your questions or present anything in  
23 particular you wish to address.

24           I think, going to my first slide, a little  
25 background about Region III. This was the recent addition

1 to the package, so we'll have copies made. But just Region  
2 III encompasses an eight-state area involving, on the  
3 reactor side, involves 16 operating sites, 24 operating  
4 reactors, and those are the people sitting at the table  
5 right now, particularly Mr. Grobe and Mr. Dapas, have the  
6 principal responsibilities for safety oversight in those  
7 areas.

8 We also have a Division of Nuclear Materials  
9 Safety and Division of Resource Management and Assessment.

10 Our reactors are relatively close to each other in  
11 the eight-state region and particularly in the State of  
12 Illinois, and it makes convenient travel from the Region III  
13 offices here in Lisle.

14 CHAIRMAN BARTON: Something that can't be said  
15 about travel to here.

16 MR. DYER: Yes. Just a little overview about the  
17 regional organization, and I can make some introductions of  
18 the folks, the staff.

19 What I really want to just focus on is the upper  
20 half of the chart we provided you here. For our  
21 presentation here, what we plan to do is I was going to go  
22 through the overall regional organization and then allow the  
23 division directors, particularly the Division of Reactor  
24 Safety and Division of Reactor Projects, to go into their  
25 more detailed reviews of their staffing and how we're

1 organized to manage our safety responsibilities here in the  
2 region.

3 I guess, first of all, we are organized with four  
4 divisions, three technical divisions; that is Division of  
5 Resource Management, the Division of Nuclear Materials  
6 Safety, Cindy Pederson is out today, and we didn't plan on  
7 her participating. They do have some responsibility for the  
8 decommissioning reactors. So if you have any questions that  
9 go into that arena, we'll bring somebody down to discuss  
10 that with you.

11 Additionally, Mr. Grobe, Division of Reactor  
12 Safety, and in my oversight and role, the way I look at the  
13 way the region operates is somewhat of a matrix organization  
14 between DRS and DRP. I view the Division of Reactor Safety  
15 as the functional experts in the various areas. So their  
16 responsibilities are in the operations, engineering, plant  
17 support areas, radiological protection, fire protection, and  
18 that.

19 In those areas, they're responsible for looking at  
20 specific areas across all of our 16 operating reactor sites.  
21 So for the case of operator licensing, they're responsible  
22 for overseeing of the operator licensing and operations  
23 inspections, team inspections, and calibrating safety  
24 assessment at all 16 sites across that one functional area.

25 Then separately from that is the Division of

1 Reactor Projects, which is organized by reactor assignments  
2 to the various sites, under Mr. Dapas and Mr. Grant, and  
3 these are organized more in lines with projects.

4 They're our generalist inspectors and basically  
5 they are responsible for everything that goes on at that  
6 site. So within the region, if a particular event occurs or  
7 a particular issue comes up at a site, there should be two  
8 points of contact that have cognizance over that area.

9 One, the DRP point of contact from a generalist  
10 view, because it affects that site and you can integrate the  
11 impact of the assessment across all the functions at that  
12 site and put it in that proper context.

13 The second would be from the functional area  
14 review and taking a look at, from Mr. Grove's DRS point, how  
15 does this -- what are the lessons learned, how are we  
16 consistent across all of our 16 sites in the way we're  
17 treating that area.

18 So that's the general oversight of how the region  
19 is orchestrated and integrated. In particular, the key  
20 aspect of regional activities that establishes and  
21 identifies the issues we're going to follow up is at 8:15  
22 every morning, we conduct a review of plant events and plant  
23 status. Normally, it's in this room. This morning it was  
24 taking place in our other conference room down the hall on  
25 the third floor.

1           But in that meeting, we will go through any  
2 reported events for the night and any emerging issues that  
3 come from the sites, from the resident inspectors, we bring  
4 them up and put them on the table and discuss what is our  
5 response going to be to those activities.

6           CHAIRMAN BARTON: So is this organizational  
7 structure you described pretty similar in all four regions?

8           MR. DYER: It's identical in all four regions.  
9 It's just my concept of operations, if you would, as to how  
10 they -- other regions may decide to do things differently.  
11 We all have morning meetings, but we all have some  
12 differences as to how we would approach a morning event or  
13 an emerging issues.

14           CHAIRMAN BARTON: Thank you.

15           MR. DYER: I think a little bit about the Regional  
16 Administrator staff; in particular, this is also similar to  
17 all the regions. Of most interest to you is probably our  
18 area of enforcement and allegations. If there are any  
19 questions that would come up regarding -- by the  
20 subcommittees today. Mr. Brent Clayton is here this morning  
21 and he is available, if you have any questions, or he is  
22 going to spend some time this morning and we'll bring him  
23 back or we'll get a member of his staff, if there are any  
24 questions about the allegations or the enforcement  
25 activities that we have going on here in the region.

1           Additionally, we also have an Office of  
2 Investigations, which is similar in all regions, a Public  
3 Affairs staff, and then a Regional State Liaison Officer.  
4 Mr. Roland Lickus had to take his son to a doctor's  
5 appointment this morning. He is going to come in a little  
6 bit later.

7           I think what is unique to Region III is our  
8 relationship with the Illinois Department of Nuclear Safety.  
9 I'm convinced there is no state that has the extent of  
10 nuclear oversight that the Illinois Department of Nuclear  
11 Safety has with their resident inspectors at all the six  
12 sites that are operating in Illinois and their extensive  
13 emergency planning and incident response capabilities.

14           If you care to discuss our relationship or how we  
15 interact with Illinois Department of Nuclear Safety, Roland  
16 is probably the best person to talk to with that.

17           Additionally, we have a regional counsel, who is  
18 in our -- spends a lot of his time involved with reactor  
19 enforcement cases, and particularly, now that recently we  
20 have had a lot of discrimination issues that have taken a  
21 lot of our time and have been a challenge.

22           So that's the basic overview of our organization  
23 here, from a regional administrator's level. I guess I  
24 would ask if there are any questions.

25           DR. POWERS: I guess one thing that has just

1 emerged for the committee is we're anticipating getting a  
2 power upgrade application from Guianardo, rather substantial  
3 one. So any thoughts you have on that power upgrade that  
4 you think we ought to know about would be useful, if there  
5 is a chance during the day.

6 MR. DYER: Okay. You're going to have the senior  
7 reactor analysts later on the day and I know they may be  
8 more informed. I know Mike Parker was out there with  
9 Research and did some walk-downs.

10 DR. POWERS: I think we would be interested in thoughts  
11 about are there synergistic effects associated with going to  
12 power upgrades and high burn-up fuels in an aging plant.  
13 Things like that. It's the first of what we see of many  
14 rather substantial power upgrades. I hesitate to quote the  
15 exact amount, but it's about 15 percent power up rate, which  
16 would mean they're about 20 percent of what they had in the  
17 past.

18 MR. DYER: We can certainly comment on the impact  
19 that has on the inspection program. But the technical  
20 viability, NRR reviewers get involved.

21 DR. POWERS: Sure. And insights that you have  
22 that are peculiar to you that we would be most interested  
23 in.

24 MR. DYER: And Commonwealth Edison is also looking  
25 at what I consider to be rather substantial power up rates

1 for both the Quad Cities and the Dresden stations.

2 DR. POWERS: I think there's going to be a covey  
3 of them coming in.

4 DR. SIEBER: Speaking of coveys. You've had the  
5 privilege or honor or whatever of not being involved in the  
6 first sub-group of license renewal activities and perhaps it  
7 would be more appropriate to address this question for  
8 Regions I or II, but I don't see any of them here.

9 How do you anticipate a license renewal  
10 application would impact the regional activities?

11 MR. DYER: Quite frankly, I don't think it is  
12 going to impact. We'd love to have one. Right now, we  
13 don't have any takers. I think Commonwealth Edison is --  
14 both Commonwealth Edison and the management company, which  
15 formed Duane Arnold, Monticello and that, are both talking  
16 about it, but --

17 DR. SIEBER: No one has committed yet.

18 MR. DYER: Nobody has committed and I think  
19 they're at least six months away from doing that. I know  
20 that we really haven't taken a look at that for license  
21 renewal.

22 MR. GROBE: We can talk in a little bit more  
23 detail when we get into the details of how my division  
24 operates.

25 MR. DAPAS: I think, in summary, though, it's

1 probably relatively transparent to the new inspection  
2 program.

3 DR. SIEBER: I had one other question. Are any of  
4 the people out here representing the public as opposed to  
5 members of your staff?

6 MR. DYER: They are all our staff.

7 DR. SIEBER: Okay.

8 MR. DYER: All of which I believe may be giving  
9 you presentations later today.

10 DR. SIEBER: Okay. I was just curious.

11 MR. DYER: Okay. Next slide, please. Following  
12 up, I think that a few of the activities that we've recently  
13 completed or are in the process of completing that may  
14 provide some areas for later discussions, of course, is some  
15 of our more recent regional accomplishments.

16 We did implement the pilot program at both Quad  
17 Cities and Prairie Island. I think in particular, it was a  
18 unique relationship, particular with the Quad Cities sites,  
19 in that it involved integrating the Illinois Department of  
20 Nuclear Safety into this program.

21 We conducted the training here in this room, in  
22 fact, and brought all the Illinois Department of Nuclear  
23 Safety folks in to cross-train them. Secondly, Quad Cities  
24 had some unique performance indicator verification issues  
25 and it really opened up, I think for the industry and the

1 NRC, an understanding as to just how many different ways you  
2 can calculate performance indicators.

3 And as a result of that, Commonwealth Edison  
4 really took the lead, I believe, for the industry to  
5 solidify and come up with a common way of doing it.

6 I think Oliver Kingly, at our last review, made  
7 the comment that he says he never realized that they had  
8 seven different ways of calculating EFTY within the  
9 Commonwealth organization, and depending on which  
10 organization you asked, as to how much reactor burn they've  
11 done, they have a different way of calculating it.

12 So it was those kinds of things, and the same  
13 thing with how they recorded availability. It was  
14 interesting.

15 DR. POWERS: The NRC seems to have about seven  
16 different ways of calculating availability, depending on  
17 what rule you go to.

18 MR. DYER: We have transitioned to the new  
19 oversight program at all our sites, with the exception of  
20 D.C. Cook. I would like to add that while you were in  
21 transit yesterday, I signed the D.C. Cook 0350 closure  
22 letter. So D.C. Cook is -- the closeout has been done and  
23 now they're in the process of heating up and testing their  
24 systems in mode three and trying to wrestle with a problem  
25 with the turbine-driven aux feedwater pump this morning.

1           But they will be the final plant to transition  
2 after the restart of Unit 1, and that will be later this  
3 year.

4           CHAIRMAN BARTON: When do you see them fully under  
5 the new oversight process?

6           MR. DYER: Jack probably has the best -- I was  
7 asked that at the Commission meeting, and I would say about  
8 six months after startup.

9           MR. GROBE: One of the things that we have to  
10 consider is how effective the performance indicators are  
11 before we transition them back to the regular oversight  
12 program. That's been shut down for almost three years. So  
13 there is no valid performance indicator data, with the  
14 exception of maybe in the health physics and emergency  
15 planning areas.

16           So we'll be looking at the performance indicator  
17 data and turn the plant back to the routine inspection  
18 program as soon as we feel comfortable that the way the  
19 program is structured, we can effectively monitor the plant  
20 performance.

21           CHAIRMAN BARTON: Thank you.

22           MR. DYER: We completed our PPR reviews for the  
23 end of cycle on the pilot plants and also did some mid-cycle  
24 reviews for the other plants, just to get them going in. Of  
25 note, as a result of the review, we, believe, are the only

1 region, and we have two yellow performance indicators within  
2 the region, Kewaunee, alert notification system and siren  
3 system is in a yellow status, and we completed the 95-002  
4 inspection, which is the supplemental inspection at  
5 Kewaunee.

6           Additionally, Quad Cities, the HPCI system went  
7 into a yellow status because of availability on an auxiliary  
8 oil pump, and we can discuss those. We have not done any  
9 supplemental inspections or held the public meetings yet  
10 with respect to the Quad Cities plants. That was just a  
11 recent issue.

12           Again, implementing the revised enforcement  
13 process, and if there are any questions, Brent Clayton is  
14 available in that arena.

15           Some of the areas -- one of the areas that's been  
16 a major shift here in the region and a major focus is -- I  
17 don't know if you know of the RIT system, which is our cost  
18 accounting system, which is used as the basis to budget our  
19 resources. We have found that we have not been accurately  
20 recording our costs and things that we thought were going in  
21 one of the cost bins, such as follow-up inspections or plant  
22 assessment, were, in fact, going in a completely different  
23 bin, some of our SRA training time.

24           So we've wrestled with our cost accounting system  
25 and it's clear that under the new budget constraints and

1 that, that we are going to have to become better managers of  
2 our resources and understand what our budget resources are  
3 and what the plans are that we're doing.

4 DR. SIEBER: Does that affect the licensee  
5 billing?

6 MR. DYER: It turns out that licensee billing was  
7 about the only thing we did right, as far as the inspection.  
8 We were very good with inspection reports, but there's a lot  
9 of non-direct costs. That would be plant assessments,  
10 follow-up on technical issues, things like that that we were  
11 getting coded to other administrative duties and things like  
12 that.

13 So it sort of skewed our model and didn't capture  
14 accurately what the costs of how the region did business,  
15 and we've subsequently gone back and cleaned it up. So  
16 hopefully for the rest of this fiscal year, we should.

17 But fee billing was it -- the inspection efforts,  
18 the direct inspection, as well as prep and doc for the  
19 inspection reports was pretty much -- that was done well.

20 DR. SIEBER: Is it fair to say that the net effect  
21 of all of this was to tend to put more time or more pressure  
22 on the administrative rather than the programmatic side?

23 MR. DYER: Yes. The real impact was on -- we  
24 receive resources for plant assessment. By and large, those  
25 were under-billed, those resources, and administrative was

1 over-billed.

2 DR. SIEBER: That can be embarrassing in the long  
3 run.

4 MR. DYER: As you'll find out later on, we've had  
5 -- when I first got here a year and a half ago, we had, I  
6 believe, six plants that were receiving enhanced oversight  
7 under 0350. Every one of the managers at this table was  
8 overseeing either Commonwealth Edison or at least one or two  
9 of the facilities that were preparing to restart.

10 And when the budgets -- and the staff was  
11 similarly supporting all those activities. And when the  
12 cost data came back and we were budgeted six and a half FTE  
13 for plant assessment, and we spent two and a half, which  
14 just didn't make sense.

15 So we knew something was up. Everybody was  
16 spending all their time in 0350 panels and oversight and  
17 when the cost data -- that's when we started looking as to  
18 why we did it and what it was was we had some old cost codes  
19 that we had been using for years and they were translating  
20 to some sort of different -- so it's caused a -- it's been a  
21 rather substantial effort.

22 Again, we made also a focus on improving our  
23 communications, enhancing them, particularly to get the  
24 implementation of the new oversight program. There's more  
25 rumors flying around about the program, as any time you go

1 through a significant change.

2 We've held monthly meetings, enhanced meetings,  
3 with the divisions and have done some very good training. I  
4 think it's paying off now. I think the folks at the working  
5 level that are actually leading the change and the  
6 transition and they are the ones that have the best concept  
7 of what's going on at the plants.

8 CHAIRMAN BARTON: I want to ask you a question.

9 MR. DYER: Sure.

10 CHAIRMAN BARTON: Regarding that. If I were a  
11 "good plant" in this region, as defined by you folk, now  
12 under the new oversight program, with the baseline  
13 inspection program, would I be receiving more or less  
14 inspection hours?

15 MR. DYER: Absolutely more. I have a slide. I  
16 can diverge from that, if you want to.

17 CHAIRMAN BARTON: We just heard that yesterday  
18 loud and clear as a complaint. So we wondered whether it  
19 was true or whether we were just hearing a story.

20 MR. GROBE: We are going to talk about that  
21 specific aspect in some more detail.

22 CHAIRMAN BARTON: Okay. Good.

23 DR. POWERS: The question has some things to it in  
24 that it may be true now, but it is going to be true once  
25 you're in a more steady-state on the inspection program.

1 MR. DYER: Right. We are probably the extreme  
2 region for that concept, but --

3 MR. GROBE: The reason for that is that under the  
4 old program, we had some flexibilities, and we'll get into  
5 that in detail. We had a number of problem plants and I  
6 don't remember the total numbers, but it was upward, over a  
7 period of years, 20,000 inspection hours at D.C. Cook,  
8 similar at Clinton and other sites.

9 So a plant like Davis-Besse, which was one of our  
10 better performers, under the flexibility of the old program,  
11 got significantly fewer hours.

12 The baseline, the risk-informed baseline is  
13 intended to establish not a ceiling, but a floor, and that  
14 floor is higher than what Davis-Besse got in the past.

15 MR. DAPAS: And we'll explain why there was that  
16 flexibility under the old program and relative to the new  
17 program.

18 DR. POWERS: I mean, I guess the question that  
19 comes to mind is why shouldn't there be that flexibility. I  
20 mean, if you're going to have problem plants, and you are on  
21 occasion going to have those, why shouldn't you put your  
22 resources where the squeaky wheel is and let the guys that  
23 are doing a pretty good job --

24 MR. DYER: Well, I think it's a little more  
25 complex than that. We're going to get into it. We have

1 about an hour set aside for this.

2 And let me just close out. Part of the issue is  
3 that -- I'm quite pleased and, Jack, you couldn't wipe the  
4 smile off his face, but the fact that yesterday was the  
5 final closeout of our 0350 process and our formal restart  
6 0350 process for D.C. Cook is -- that has been a -- that is  
7 a significant impact on the region and that's the final one.

8 As I said when I got here, we were doing it with  
9 LaSalle, Quad Cities had just started up, we had Clinton, we  
10 had Cook, Peach Bottom, Point Beach wasn't that far away  
11 from restart. So there was a number of -- we have literally  
12 been focusing from plant to plant.

13 And last year at this time, the great fear was  
14 that if Clinton kept delaying and LaSalle kept moving their  
15 schedule up, it looked like both of them were going to  
16 restart within a week of each other. They subsequently  
17 restarted about a month apart. So that was a great relief,  
18 because a region literally cannot handle two restarts  
19 simultaneously of problem plants coming up.

20 So now we're poised to do the D.C. Cook restart  
21 and we are getting resources from all the other regions in  
22 order to support the final closeout of the inspections, as  
23 well as the actual startup.

24 CHAIRMAN BARTON: But with Cook coming back, that  
25 will only help the stability question in this area.

1 MR. DYER: I believe it actually helps more the  
2 northeast, because it's the tie lines. When Commonwealth  
3 Edison came back, Chicago was flush and the last time I  
4 talked to Oliver Kingsley, it looks like they could actually  
5 have excess power. What they want to do is it get to the  
6 northeast, where there's a need for power, and the tie has  
7 been right there at D.C. Cook. They have been able to route  
8 power through that intertie out of the main grid.

9 So they've actually been wheeling power south and  
10 then back up.

11 DR. SIEBER: Or it would go through Canada.

12 MR. DYER: Right.

13 DR. SIEBER: To what extent does headquarters hold  
14 the region accountable when a plant -- I'll speak louder.  
15 To what extent does headquarters hold the region responsible  
16 or accountable if a plant emerges as a problem plant?

17 MR. DYER: Well, you have to take a look at how  
18 did it occur and it's more you do a root cause analysis, if  
19 it's caused by an event; you know, should we have found it  
20 earlier, and done that.

21 I don't think it's any kind of fingerpointing or  
22 blaming as a result of that, but it always causes you to  
23 reflect. And I can say it's not only just the region that  
24 has the problem plant.

25 When the Commonwealth Edison problems came up and

1 the Cook problems came up, and Millstone, even when I was in  
2 Region IV as Deputy Regional Administrator, we were all  
3 looking could that happen here. It's a general --

4 DR. SIEBER: Do you think the oversight process  
5 will help you identify precursors to problem plant issues  
6 more so than the old inspection program?

7 MR. DYER: I don't that the oversight process will  
8 help the NRC identify it. I think the deregulation is going  
9 to force the commercial nuclear industry to take a greater  
10 role in fixing, and the cost, the main cost in production,  
11 those areas, the pressures that they now feel are far more  
12 than what the NRC used to put on them.

13 They have to be a much more demanding manager now of their  
14 plants in order to accomplish the shorter outages, in order  
15 to bless the less than one reactor trip per year, on an  
16 average now, in the industry.

17 That's not NRC-driven. That's economics-driven,  
18 in my mind. And no matter how much I, as a regulator,  
19 challenge the licensee to improve performance, it's going to  
20 cost them a couple hundred thousand dollars a day now when a  
21 plant goes off-line, that's making the difference.

22 So I think our critical focus is shifting to make  
23 sure that they follow the prescribed processes and that  
24 they're playing by the rules, if you would; that when a  
25 system is inoperable, they declare inoperable and do the

1 right thing, as opposed to how are they fixing it. That's  
2 the emphasis.

3 MR. GROBE: The new inspection program is more  
4 indicative than it is predictive and that's one of the  
5 concerns that we have in how we implement this, to retain  
6 the ability to identify the early precursors of more  
7 significant problems.

8 We're going to get into that in a lot of detail  
9 with lessons learned on the new inspection program to date.

10 DR. POWERS: And if you find routes to prediction  
11 under the new inspection program, we're going to be real  
12 interested, because it really is an indicative program.

13 DR. SIEBER: One more short question. With all  
14 the emphasis on cost-cutting and economical production, do  
15 you see things like the plant material condition going up or  
16 down, or programs being eliminated or consolidated to the  
17 detriment of the whole program, or other issues that are not  
18 being attended to that otherwise, in a more generous  
19 economic situation, might be attended to?

20 MR. DYER: I guess from my perspective, I've seen  
21 an investment in the plant. The thought of looking at  
22 extending the life cycle, the prospects of doing that and  
23 whatever they run, they've got to run well. Those are the  
24 key things that we've seen.

25 Particularly, what we saw was a total focus, I

1 believe, from some of our plants is when they were shut down  
2 under the 0350 process and trying to get restart, they took  
3 a focus away from operations and they were focused on  
4 getting the plant fixed, whether it was reconstituting the  
5 design basis, modifying the plant to fix a long-term  
6 problem, or doing whatever is necessary to get their  
7 procedures and infrastructure effective.

8           There had been a lack of focus on maintaining the  
9 operating crews and maintaining the plant in an operating  
10 status net. So now that we've seen the plants once they  
11 start up, there has been a shift toward that operational  
12 safety focus, an increase in number of licensed operators.

13           In Region III, and I think Jack probably has a  
14 better handle on the budget numbers than I do, but I think  
15 we were looking at typically we were running between 30 and  
16 50 exams a year and once Cook, Clinton and ComEd got up and  
17 running, in the past year and a half, two years, there now  
18 -- our number of licenses are upwards of 160, demand for us  
19 to give 160 licenses.

20           So it's literally tripled our workload in a short  
21 period of time. That's put a pressure on the region to get  
22 a lot of qualified license examiners and borrow them from  
23 headquarters and management, which is what Jack has done,  
24 but that kind of a ramp rate, if you would, has put a severe  
25 strain on the regional resources for that program.

1           But that's what we're seeing now, is an enhanced  
2 focus on operations and an investment in the plant. So I  
3 think almost all the plants are --

4           DR. POWERS: I was just going to comment in  
5 response to your question about material condition. I think  
6 under the new program, when you look at unavailability,  
7 performance indicators, if the licensees are maintaining a  
8 material condition, you would expect to see that manifested  
9 in transients caused by equipment problems and challenges to  
10 the operator.

11           So I think the new program has carved out a role  
12 of ensuring that material condition is being maintained or  
13 at least flagging to us that there are problems in that  
14 area, and then we would go in and look at the licensees'  
15 root cause evaluation and corrective actions as part of our  
16 supplemental inspection of a particular performance  
17 indicator threshold, for like system unavailability.

18           MR. GROBE: Jim and Marc are focusing primarily on  
19 reactor operations and those issues that directly make  
20 money. In some of the peripheries, we've seen some  
21 problems; for example, in the security and safeguards area.  
22 Commonwealth Edison substantially changed their approach to  
23 event response and protecting the plant from a physical  
24 threat and we just recently completed what is referred to  
25 our OSRE, operational safety response evaluation, at Quad

1 Cities and they performed poorly.

2 They changed the strategy also at LaSalle and  
3 Braidwood, significantly reducing the number of armed  
4 responders, for example. And we have exercises there later  
5 this month.

6 DR. SIEBER: So that was an issue involving the  
7 security organization as opposed to operation involvement in  
8 security.

9 MR. GROBE: And I think Jim's point on the  
10 financial demands is really key. Those things that can  
11 produce power and ensure equipment reliability are getting a  
12 lot of attention.

13 DR. POWERS: I think we can say the same thing in  
14 fire protection, because it doesn't generate kilowatts, it  
15 may be getting less attention than some of the other things,  
16 as well.

17 DR. SEALE: Not very well.

18 DR. SIEBER: Well, this is apparent or has been  
19 apparent for some years. I've worked with LaSalle for a  
20 couple of years and they had a lot of fire protection work  
21 orders that had aged substantially and I see the same thing  
22 on division valves at other sites and people say, well, as  
23 long as the valve is open, we're okay, but if you rupture  
24 the main, you may put the your whole system out, because you  
25 can't isolate.

1           So I think that that often needs attention,  
2 because it somehow jumps outside the risk-significant  
3 portions of the plant, which are the CAT-1, structures,  
4 systems and components.

5           MR. DYER: One other, on the same spin, I was just  
6 thinking, you know, in the case of Clinton, was one of the  
7 plants that was really run on a shoestring. It was a single  
8 unit utility. I think we have seen a significant commitment  
9 of resources and improvement and a change over there,  
10 particularly since Amergen took over and purchased the site,  
11 and it was shortly thereafter that they came out with a  
12 business plan that included looking at license renewal as  
13 opposed to the mentality when it was Illinois Power, which  
14 was get the plant restarted itself.

15           So it was do what was necessary to restart the  
16 plant, which it did not include training new operators.

17           DR. WALLIS: Do you find that consolidation of  
18 plants under single owners is helpful then, in general?

19           MR. DYER: We've had limited experience with that.  
20 The Amergen is the first one under, and now the management  
21 company is just trying to formulate and they really haven't  
22 had an impact yet.

23           Commonwealth Edison, we've had a seesaw  
24 relationship with over the years. Right now, it's riding a  
25 wave up and it's doing better. So I'm waiting to see.

1 MR. CALDWELL: I think the real answer to your  
2 question, though, is it's going to be case specific. I  
3 don't think you can make a generic statement about how  
4 deregulation is going to affect all the plants. The  
5 single-unit sites, if they don't have a lot of resources, it  
6 may have a major impact. These sites that are now being  
7 taken over by large companies, they can't afford to have the  
8 kind of shutdowns that we've seen in the past, the  
9 multi-year shutdowns.

10 So they're going to have to focus on making sure  
11 the plants are properly maintained. So it's going to be up  
12 to us to look at the different facilities and the different  
13 situations they're in and to try and understand it. But I  
14 don't think you can make a statement across the board that  
15 it's going to have the same impact.

16 MR. DAPAS: That's one of the things the agency is  
17 looking at is industry consolidation and there is a working  
18 group that I'm involved in to understand what changes may be  
19 necessary in certain program areas as a result of industry  
20 consolidation.

21 DR. SIEBER: I don't want to ask too many  
22 questions and get you off schedule.

23 MR. DYER: I think I've blown my schedule.

24 DR. SIEBER: I'm sorry.

25 DR. POWERS: We have a tradition of doing that.

1 MR. DYER: Yes. But what I was going to do is now  
2 turn the meeting over to Jack Grobe and Mark Dapas and let  
3 them get into more of the details of how the DRS and DRP  
4 organization goes, consistent with our program.

5 MR. GROBE: We had some donuts delivered and, Dr.  
6 Barton, do you want to just take three minutes?

7 CHAIRMAN BARTON: No, we're behind schedule. If  
8 you want a donut, get up and help yourself.

9 MR. GROBE: Excellent. We've laid out an agenda  
10 that I think that I think, we had coordinated with Jit, that  
11 hopefully meets your needs. We've got about 65 slides to go  
12 through, which our ability to do that is probably limited,  
13 but our goal is to make sure that we answer all your  
14 questions.

15 So I'm going to try to be a little bit of a  
16 gatekeeper on the clock and move us along as we go.

17 But the first thing we're going to do is talk a  
18 little bit about how we're structured, how we're  
19 implementing the new program and some lessons learned on the  
20 new program, and then invite Sonia Burgess up to talk about  
21 our senior reactor analyst program. She's one of my SRAs.

22 MR. DAPAS: I thought I'd start out with kind of a  
23 broad overview of our geographic responsibilities. You can  
24 use the slides of you can go through the handouts we  
25 provided, whichever is easiest for you.

1           But we are responsible for 24 operating reactors  
2 at 16 sites, and that consists of 13 pressurized water  
3 reactors and 11 boiling water reactors. As Jim said, our  
4 responsibility encompasses an eight-state area. We've got  
5 six sites in Illinois, two sites in Wisconsin, three sites  
6 in Michigan, two sites in Minnesota, two sites in Ohio, and  
7 one site in Iowa.

8           And as Mr. Dyer mentioned, it's relatively easy to  
9 travel to any site. We can get to Prairie Island and  
10 Monticello, which is near Minneapolis-St. Paul, Twin Cities  
11 area, in a day; same thing with Duane Arnold, near Cedar  
12 Rapids, Iowa. So that doesn't present the challenge that it  
13 does to some of the other regions in terms of being able to  
14 get to the sites.

15           The Division of Reactor Projects, or DRP, has  
16 roughly 75 professional and administrative staff. Most of  
17 the inspection staff in DRP has an engineering background or  
18 a technical science degree. So we have a fairly  
19 professional staff.

20           And we've organized the branches to provide  
21 additional oversight to D.C. Cook; D.C. Cook, of course,  
22 being an agency-focused plant. We've got one branch  
23 dedicated to Cook, which results in the other five branches  
24 have three sites apiece, and we thought that was appropriate  
25 considering all the inspection activities and coordination

1 of our technical issue resolution that's associated with  
2 restart preparations by the licensee. And I'll go through  
3 more specifically how we're organized in a minute.

4           Next slide, please. I thought I would talk a  
5 little about the functional responsibilities for the  
6 Division of Reactor Projects. One of the most important  
7 functions we have is inspection program management. DRP is  
8 the clearinghouse for the inspection program. We're sort of  
9 a gatekeeper for regulatory activities associated with the  
10 specific sites. We manage the site-specific inspection  
11 plan.

12           I expect the branches to be cognizant of all NRC  
13 activities. That means specialist inspections that are  
14 ongoing by the Division of Reactor Safety Inspectors, DRS,  
15 allegations, status of enforcement actions. The branches  
16 are knowledgeable of all the inspection findings,  
17 performance indicator information, and any outstanding  
18 inspection follow-up items.

19           So all regulatory activities and issues that  
20 impact on inspection responsibility are pretty much  
21 processed through DRP.

22           We maintain a continuous on-site inspection.  
23 Specific inspection activities are carved out for the  
24 residents on a periodic basis, and that's, of course, within  
25 the context of the new baseline inspection program.

1 But there is a premium placed on that on-site  
2 inspection and the ability to observe activities firsthand.

3 DR. WALLIS: Excuse me. Continuous to me means it  
4 goes on all the time. That can't quite possible.

5 MR. DAPAS: We don't have 24-hour coverage.  
6 Continuous meaning that we have a day-to-day presence.

7 DR. WALLIS: That everyday there is a presence.

8 MR. DAPAS: Yes, correct. Daily on-site  
9 inspection would probably be more appropriate.

10 MR. CALDWELL: They also, they live in the general  
11 area and are available to go in for event response, or if  
12 there is a particular issue.

13 DR. SIEBER: Do you have any problems filling  
14 those jobs, are you shorthanded?

15 MR. DAPAS: I was going to talk a little about  
16 some of the staffing challenges we have in maintaining the  
17 resident positions fully staffed and give you an idea of  
18 where we're at.

19 DR. SIEBER: When you do that, you can also talk  
20 about rotation, there is a certain rotation that's supposed  
21 to occur that sometimes doesn't because of lack of  
22 personnel.

23 MR. DAPAS: I was going to comment on that  
24 specific item.

25 DR. SEALE: I would also like to hear about

1 growing those positions in the sense that the revised  
2 inspection process, the interest in risk-informed regulation  
3 and so forth seem to be adding to the challenges that the  
4 inspectors face, having to operate in a slightly different  
5 environment, knowing when to inquire of the risk analysts  
6 about appropriate information concerning the operations at  
7 the moment and so on.

8 I would be interested in how you are growing those  
9 people in that sense.

10 MR. DAPAS: I think we will touch upon that. If  
11 we don't, point that out, please. The residents are the  
12 focal point for agency interface with the licensee. Of  
13 course, there's the routine exit meetings and where the  
14 resident staffs discuss their specific inspection results.

15 They maintain cognizance of the results of any DRS  
16 inspections. When the licensee identifies any type of  
17 degraded equipment, which would result in like a technical  
18 specification limiting condition or LCO entry, that's  
19 communicated to the resident inspector and reportable events  
20 are communicated to the residents, any notice of enforcement  
21 discretion requests that are developing.

22 Basically, the resident is the information conduit  
23 and that includes licensing issues. Certainly, there's  
24 discussions between the NRR project manager and the specific  
25 licensee representatives involved in licensing activities,

1 but the residents are cut in on that and they inform the  
2 region of outstanding licensing issues.

3 So they're clearly the focal point for that  
4 communication between the NRC and the licensee, which  
5 underscores our goal of assigning mature, professional  
6 individuals to the sites, because they are the eyes and ears  
7 of the agency, in many regards.

8 Also, the resident staff serves as first  
9 responders for incident response, as Jim Dyer mentioned and  
10 Jim Caldwell. The resident inspector would respond to the  
11 control room and the senior resident inspector would respond  
12 to the technical support center for any type of emergency  
13 event declaration, like an unusual event or an alert.  
14 Anytime the licensee mans their emergency plan.

15 And they provide NRC management with information  
16 to determine the appropriate agency response, monitoring,  
17 standby, or initial activation, and they ensure the licensee  
18 is following their emergency operating procedures and  
19 actions for each emergency event classification.

20 One of the central things that the residents  
21 communicate early on to regional management and headquarters  
22 management is, is the plant in a safe condition, what are  
23 the licensee concerns, what are the principal areas that  
24 they're focusing on. So that first communication is very  
25 important in terms of the agency responding appropriately.

1           Next slide, please. I thought it would be  
2 informative just to discuss briefly some of the specific  
3 inspection activities that a typical resident encounters.  
4 There is clearly a focus on operations. We target  
5 activities where the plant is configured with the greatest  
6 risk impact. As an example, if the licensee is going to  
7 perform an integrated test of the emergency core cooling  
8 systems, that involves a lot of coordination between the  
9 operators, both in the control room and in the plant, valve  
10 and switch manipulations.

11           That may be a risk-significant evolution that we  
12 would want the residents to observe.

13           Event follow-up, as I mentioned before, that could  
14 be a reactor trip, a partial loss of off-site power, plant  
15 transient, any particular event that challenges the operator  
16 response and the residents are there to follow-up on that.

17           DR. POWERS: Let me legitimately make a point  
18 about this response to any event that occurs, that the  
19 resident has to do. He becomes literally the eyes and ears  
20 in those cases, at least for the first hour or two, he is  
21 the eyes and ears of the agency.

22           But one would hope that that's an activity that he  
23 doesn't get to practice very often. How does he practice?  
24 How does he develop skill in that area?

25           MR. DAPAS: We will talk about the detailed

1 qualification program that a resident goes through, but  
2 there's a lot of mentoring. The senior resident inspectors  
3 have experience in event response. There's, of course,  
4 simulator courses that the resident staff takes in  
5 Chattanooga, where the plant is put through -- the simulator  
6 is run through different emergency transients, and the  
7 residents clearly understand what EOP should be implemented,  
8 emergency operating procedures.

9 And there is a specific procedure for event  
10 follow-up, which gives the inspectors guidance of particular  
11 things that they should be looking for. And one of the  
12 things that I think is effective when we have our oral  
13 qualification board, which we'll talk more about, it's not  
14 uncommon to ask a question, you'll be walking into the  
15 control room and there's this, this and this going on, what  
16 areas are you focused on, what information are you trying to  
17 ascertain.

18 So we try, to the extent we can, to prepare the  
19 residents to be able to provide that event response and  
20 communicate the information.

21 MR. GROBE: The other thing is the resident  
22 inspectors in Region III, the folks we've tried to place out  
23 there, are experienced and, as Marc, said, mature people,  
24 extensive experience as system test engineers, integrated  
25 test engineers, folks that had come through the Division of

1 Reactor Safety. For the operator licensing program,  
2 operator licensing folks have extensive knowledge and  
3 appreciation of what's going on in the plant.

4 And within a very short period of time,  
5 approximately a half an hour, they're going to have a ton of  
6 support from the regional office.

7 DR. POWERS: Yes. But it's really that they're  
8 working on their own and having to use their own judgment.  
9 Of course, nothing schools judgment better than experience.  
10 And the number of events we have, I mean, we just don't have  
11 very many.

12 So experience -- it did remind me of the  
13 simulators in Chattanooga. That of course, would be a good  
14 thing, having a proceduralized thing, that's a very good  
15 thing.

16 MR. GROBE: And that's the primary focus of our  
17 requal training. They get extensive systems training  
18 initially, but the requal is primarily focused on the  
19 simulator.

20 DR. SIEBER: And it's been my experience, also,  
21 that resident inspectors participate in licensing drills.  
22 They are either observers or actual players, and that's  
23 really good experience for them, because they not only learn  
24 what the licensee is supposed to do, but they see how the  
25 licensees act and how to communicate with them.

1 MR. GROBE: When we get into the new inspection  
2 program, you're going to see that we have less flexibility  
3 to do that.

4 DR. SEALE: You can't essentially tag along when a  
5 plant operator is going through -- or a plant operations  
6 team is going through a simulator exercise with a  
7 plant-specific simulators.

8 Do your inspectors get to, if you will, watch this  
9 and ask themselves what their role would be as they go  
10 through that?

11 MR. GROBE: Once every two years, we have a  
12 requalification inspection, where we observe the licensees'  
13 simulator examinations, and a few years ago, we made a  
14 decision, for that exact purpose, to include one of the  
15 residents on the requal team, and we try to do that whenever  
16 we can.

17 But we wouldn't be in a mode of interfacing with  
18 the people that are in the midst of an examination.

19 DR. SEALE: I understand that's a very careful  
20 line there.

21 MR. GROBE: It gets the operators into the  
22 simulator.

23 DR. SEALE: Exactly.

24 MR. GROBE: And it gets the resident inspectors  
25 into the simulator on some periodic basis. The one area

1 that I'm concerned about, and we're looking at trying to do  
2 something about, is that we have very limited training on  
3 CMG, the severe accident management guidelines. All the  
4 licensees that had training on the CMG materials and our  
5 emergency responders have limited training in that area, and  
6 we're looking at trying to do something to familiarize the  
7 staff and management on the severe accident management.

8 MR. DAPAS: When I was talking about event, I  
9 talked about it in the context of a significant event. Of  
10 course, event can cover a broad spectrum, certainly.

11 One of things that we engulf with our event  
12 response procedure is an assessment of the risk associated  
13 with that particular event to determine should we initiate a  
14 special inspection, and that's pretty clearly defined.

15 DR. APOSTOLAKIS: How do you do this? How do you  
16 assess the risk?

17 MR. DAPAS: We look at conditional core damage  
18 probability. We look at what was the particular equipment  
19 configuration, mitigative systems, et cetera, and what is  
20 the risk associated with that challenge.

21 Obviously, when you have an event, if it's a loss  
22 of off-site power, reactor scram, you had the initiating  
23 event, now what's the consequence of that, what systems were  
24 available.

25 DR. APOSTOLAKIS: So for each unit, you have a

1 PRA?

2 MR. GROBE: No. We have very limited tools  
3 available to the residents, broad guidelines on what are the  
4 most risk-significant systems and things of that nature.

5 MR. DAPAS: But it's different than what we did  
6 have in the past, which was more deterministic. I think as  
7 a result of the Indian Point 2 event, we incorporated more  
8 risk perspectives into our event response procedure.

9 DR. POWERS: I'm not sure we can get into it right  
10 in this presentation, but one thing that you might comment  
11 on, we have discussed this issue of tools, risk tools  
12 available to the residents and the wisdom of whether they  
13 really want tools, to have more tools or not, because  
14 they've got a full-time job as it is, that's maybe adequate  
15 if they have risk information resources available to them,  
16 the role that normally is played by your senior reactor  
17 analysts.

18 But asking a guy a question and being able to look  
19 it up yourself are two different things. So this balance  
20 between information directly available to them and resources  
21 available to them is interesting. I don't know how you make  
22 the decisions. If you have thoughts on that, it would be  
23 interesting to hear.

24 MR. GROBE: Truly, I don't believe we want the  
25 residents doing risk analysis in an event response. They

1 need to be aware of what's going on at the plant, what are  
2 the precursors to further severity of the event, making sure  
3 that the licensee is focusing in the right areas and  
4 providing information to us.

5 But both of your risk analysts are on-call. We  
6 got into this just recently with an event. It's difficult  
7 to provide risk analysis on any sort of short timeframe.  
8 We're trying to develop a concept where within a few hours,  
9 they can provide the agency some risk insight, but not any  
10 sort of analytical or very technically defensible risk  
11 analysis on a period of a couple of hours, to determine  
12 whether or not that could provide further insight on the  
13 extent of the team that we should send out or the type of  
14 response the agency should take.

15 Within a matter of 24 hours, we should be able to  
16 provide some fairly defensible risk analysis of what's  
17 happened.

18 From a responder point of view, 24 hours is not  
19 terribly useful. So there is an interesting conundrum  
20 there.

21 DR. POWER: That's really incredibly useful  
22 information there, because I'm wrestling with how fast we  
23 should be able to do risk information and I think you've  
24 given me a key. Clearly 24 hours is too long. Now, what is  
25 the appropriate time? It sounds to me like an hour or two

1 is the kind of rate you'd really like to be able to do  
2 things in.

3 MR. CALDWELL: Let me clarify something here.  
4 What Jack is talking about is the type of follow-up event  
5 response we would conduct. The inspector, the resident is  
6 still going to go to the site on an event response and  
7 they're in the mode of observation. They'll go to the  
8 control room, they'll observe operator actions, they'll  
9 observe plant conditions, and that information will be fed  
10 back to us.

11 But they will not be constrained by some sort of  
12 probabilistic review. But our follow-up event response  
13 would -- our special inspection or AIT or whatever we decide  
14 we might need will depend on the risk of the event itself.

15 MR. DYER: I think the residents need to have a  
16 general understanding of the risk models, what are the  
17 vulnerabilities at the plant. As they go in and they  
18 initially respond, they're not in an inspection mode.  
19 They're in a protect public health and safety mode in the  
20 incident response, as we all are in that role.

21 And so from that perspective, when they go in,  
22 they need to know what are the critical assumptions, what  
23 are the vulnerabilities, what are they going to check on,  
24 what are they doing, are they following their EOPs, are they  
25 staying in their modeled assumptions and that.

1 DR. BONACA: I have a question. RES has been  
2 developing plant-specific models, PRA models, they are  
3 simplified, or apparently they're getting into a more  
4 complex presentation of the plants.

5 Are they available at the region level, those  
6 models?

7 MR. GROBE: Sonia.

8 MS. BURGESS: Yes. The models that we are talking  
9 about are available in the region. Mike Parker and myself  
10 are the ones that have the models here in the region. The  
11 residents at the sites do not have the models.

12 MR. DYER: They're going to make a presentation  
13 and talk to you later on. So I think the answer is yes.

14 MR. GROBE: The residents understand the  
15 risk-significant systems and they understand that their  
16 principal focus is do you have the ability to move water, do  
17 you have the ability to provide electrical power where you  
18 need it, do you have containment through piping systems. So  
19 that's what they're focused on, what the licensee is  
20 prioritizing as far as their response to the event, and  
21 that's where they need to be focusing.

22 MR. DAPAS: I think that's best illustrated -- we  
23 had a recent example here with Palisades, where they had a  
24 problem with the diesel generator output breaker, where the  
25 breaker failed and they could not open it. They had lost

1 control power. The residents responded to the control room  
2 to understand what was the impact on emergency A/C power  
3 availability and communicated out to the branch chief, and  
4 then we had Sonia Burgess involved looking at what's the  
5 ongoing risk impact of not being able to open the output  
6 breaker and what damage may have been -- when you motorized  
7 the generator, was there a problem.

8 So that would provide us a perspective, what's the  
9 risk significance of the plant continuing to operate in this  
10 condition and should we provide any augmented support to the  
11 resident staff.

12 DR. WALLIS: As the technology advances, one could  
13 imagine that inspectors in the future could have some  
14 handheld computation device which would give them a SPAR.

15 MR. GROBE: We get very anxious when we start  
16 talking in that area, because a lot of this is instinctual  
17 on how you respond to an event. Let's just say we get  
18 anxious.

19 DR. POWERS: Well, I think my own view was that  
20 inspectors have more to do with providing the input to risk  
21 modeling on a pump than they do running the pump.

22 DR. SEALE: They need to be able to communicate.

23 DR. POWERS: And you'd be -- I mean, all of these  
24 things. One of the biggest concerns that I have about the  
25 oversight program is it's taking away from hours in the

1 plant to hours at the desk, and that's a tradeoff which  
2 ought to be consciously made.

3 And having risk tools to play with, it quickly  
4 becomes risk tools that you have to play with and that is  
5 just another detraction from eyeballs on the plant.

6 But I'm looking at, at the same time, this guy  
7 should have all of the support he thinks he needs in  
8 answering questions, in his mind, about risk. So it's  
9 really tools for Sonia and her team that I think we're  
10 talking about here.

11 DR. BONACA: On the other hand, my question was  
12 more in the direction of just part of the maintenance rule  
13 now, the operators can take out-of-service multiple  
14 components and, of course, there is a requirement for the to  
15 evaluate the risk significance and to what extent a resident  
16 does a spot-check for a given configuration that he may  
17 consider risky enough for him to ask a question, without  
18 having to depend entirely on the plant staff.

19 I think that is an important objective long-term,  
20 it seems to me.

21 MR. DAPAS: Nora Collins was smiling. She is  
22 going to be talking later about on-line risk and I think can  
23 provide some insights in that area.

24 MR. CALDWELL: There are a couple of issues  
25 associated with the SRAs availability of having the analyst.

1 So we're looking at succession planning for the SRAs, but  
2 integral in that is there's a task group they're putting  
3 together with NRR and the regions to look at that question.

4 But integral to that is a discussion on training  
5 and what types of training that the various levels need and  
6 one of the -- the regions, I guess, got together and decided  
7 one of the aspects of training that all the inspectors need,  
8 including the resident inspectors, was risk inspection  
9 planning, which would go to what you're talking about; what  
10 things should you look at and when should you look at them.

11 So there is a task group that's going to look at  
12 the types of training that should go to the residents, the  
13 type of residents that should go to senior inspectors here  
14 in the region, and succession planning for the SRAs.

15 DR. POWERS: I think that speaks to the issue of  
16 how detailed and how high quality we have to have the risk  
17 resources, not necessarily the turnaround time, but the  
18 quality and detail, which is an issue in itself, whether the  
19 SPAR models are adequate or we need something more detailed,  
20 because inspectors tend to look at things at at least one  
21 level down on the level of modeling PRAs.

22 I mean, it's the same problem the engineer at the  
23 plant has. He tends to work on things that are a level  
24 down.

25 MR. DAPAS: For the sake of timeliness here, I'm

1 just going to kind of go through examples of each activity  
2 here, but I'll just point out a couple of things.  
3 Operability evaluations, clearly, the residents get involved  
4 in evaluating the impact of degraded equipment.

5           If a pump is supposed to deliver X amount of flow  
6 for the surveillance procedure, it doesn't pass the  
7 surveillance test, and then the licensee does an evaluation  
8 and says, well, the pump can still perform its intended  
9 function, that can lead into a 50.59 evaluation, because the  
10 pump operation may be different than described in the final  
11 safety analysis report, et cetera. So they get involved in  
12 that.

13           Severe weather preparations --

14           DR. POWERS: We're going through a substantial  
15 change of 50.59.

16           MR. DAPAS: Correct.

17           DR. POWERS: And there's a high judgmental  
18 capacity content to this on what is a minimal change in the  
19 impact assumptions, things like that.

20           MR. DAPAS: I think our safety system design  
21 inspections get more intrusive into the quality of the  
22 50.59. The role of the resident is the licensee conducts a  
23 50.59 and they kind of look at does this make sense. If  
24 they need more additional help, they can engage DRS  
25 inspectors.

1           But looking at it from the programmatic aspect, I  
2 think select samples as part of your design inspection.

3           MR. GROBE: I think, if I understand your question  
4 correctly, it was what's the staff's reaction to the  
5 judgment and the subjectivity that might go into the new  
6 decisions in the rule.

7           I think the staff truly was uncomfortable with  
8 some of the Draconian outputs of using the rule as it was  
9 written before. Some unreviewed safety questions that were  
10 really insignificant would result in enforcement action.

11           So on that specific issue, while it involves more  
12 judgment, I think the staff is more comfortable. There are  
13 a number of areas with the new inspection program that the  
14 staff is not as comfortable as what we used to have and we  
15 can get into some of those.

16           But that's an area I'm not sure we have a lot of  
17 concern with. The implementation we haven't actually seen  
18 yet, so we're going to have to walk through that.

19           DR. SIEBER: I think we would like to hear your  
20 concerns later on that, so we know what they are.

21           MR. DAPAS: Now I more fully understood your  
22 question. Severe weather preparation, with the plants we  
23 have located here in northern climates, we get involved a  
24 lot in that. In fact, we had an issue at Point Beach  
25 regarding freeze protection for a safety injection recirc

1 line, tangible example of where inadequate freeze protection  
2 resulted in problems.

3 And problem identification and resolution. An  
4 integral part of each inspection procedure is ten to 15  
5 percent of that is dedicated to follow-up for problem  
6 identification and resolution, and that, of course, is the  
7 foundation of new program, corrective actions.

8 And there's two aspects to that. Of course,  
9 annual review and then follow-up on issues specific to the  
10 area being covered by the individual module, like  
11 surveillance testing.

12 DR. SIEBER: In that regard, under the new  
13 oversight process and significance determination, they  
14 aren't writing as many violations. On the other hand, we're  
15 probably writing more non-cited violations, and all those  
16 are supposed to go into the CAT.

17 Do you folks follow-up inspecting CAT to make  
18 sure?

19 MR. GROBE: Not all of them. There's two. One is  
20 that we do a regular inspection of the effectiveness of the  
21 corrective action program and that's run out of Merck's  
22 division, and we have people on that inspection.

23 In addition to that, we sample a portion of  
24 non-cited violations as part of that inspection, but we  
25 don't look at all of them, and that's part of the new

1 inspection program that actually makes sense, because the  
2 violations we identify are a very small portion of the total  
3 number of issues that need to be corrected on a yearly  
4 basis.

5 So we'll select a portion of the violations we  
6 identify and that were non-cited, as well as a large number  
7 of other issues that we focus, from a risk perspective, on  
8 trying to get the more important ones.

9 DR. SIEBER: I guess my personal feeling is that  
10 NRC gave up something when it moved from deterministic  
11 systems into risk-based systems and significance  
12 determination. What you gave up was the ability to write a  
13 violation and get a written response and a commitment from  
14 the licensee that you could follow-up up on and for a given  
15 unit that could have been anywhere from five to 20 items a  
16 year.

17 On the other hand, once you give that up, you have  
18 to put a little more emphasis and follow up with a  
19 corrective action program to make sure that it didn't  
20 disappear.

21 MR. DAPAS: You're right. That's a balancing act,  
22 obviously. The crux of the new program was what's the  
23 appropriate amount of regulatory burden. You're writing  
24 violations, the licensee has to respond, what is the  
25 threshold for that.

1           That's why we -- we put great stock in our problem  
2 identification and resolution inspection. We think that's a  
3 critical aspect of the new program.

4           DR. SIEBER: Even the Commissioners see that as a  
5 key. They're very adamant about that.

6           DR. POWERS: Well, I think the Commissioners see  
7 it more than the headquarters staff.

8           MR. DYER: Well, I don't know that. I think it's  
9 we -- a lot of the violations, I think, as Jack said  
10 earlier, a lot of the violations that we wrote, we were  
11 spending a lot of time on correspondence that didn't improve  
12 the safety of the plant.

13          DR. SIEBER: Yes. We were on the other end.

14          MR. DYER: So I think the new program does allow  
15 -- what we have to do is take significant actions when we  
16 find a licensee is not -- when they break that trust.

17           And one of the things we get through here, when we  
18 start looking at the new program, that is the importance of  
19 the cross-cutting issues, in my mind, as a regulator, and,  
20 in particular, the corrective action program.

21           As you said, we are turning a lot over. This will  
22 make for a more efficient and effective way of regulating  
23 and allow the licensee to prioritize, but they have to have  
24 a good program.

25          MR. CALDWELL: There's a major challenge to the

1 licensee that comes out of this. In the past, when we wrote  
2 a violation, it came out in our report, they had to respond.  
3 Typically, they had to get senior management to agree with  
4 the response, so that the managers were heavily involved in  
5 those activities, at least the inspection activities that we  
6 conducted.

7 Now, it's included in their corrective action  
8 program. So the licensee's management has the challenge of  
9 staying involved in those issues that occur. They are going  
10 to have to be asking more questions and getting more  
11 involved in their corrective action program. So it is a  
12 challenge.

13 MR. GROBE: Our ability to cause licensee  
14 management to engage in issues is diminished under the new  
15 inspection program. One of the things that we got good at  
16 and our staff gets very good at is appreciating a broader  
17 perspective and focusing on root cause.

18 Now, as Jim indicated, the licensee has to take  
19 that burden completely on themselves, which is appropriate,  
20 but our ability to direct that, unless it results in a  
21 risk-significant issue under the SDP, is limited.

22 DR. SIEBER: One final question, which you can  
23 answer yes or no. You have exit meetings when you conclude  
24 an inspection, either a resident or a specialist inspection.  
25 Since the new oversight process and the burden has changed,

1 do you have any idea whether the level of management that  
2 attends those exit meetings has changed to a lower level  
3 since there is less management involvement?

4 MR. DAPAS: I can actually comment on that  
5 specifically. I think there's actually been a higher  
6 engagement of management, because we communicate at that  
7 exit meeting some issues that may not be documented in the  
8 report, and that's a program office policy decision that  
9 some issues that don't rise to the threshold of an  
10 inspection finding or a green issue, the licensee is  
11 interested in hearing about those and those are communicated  
12 at the exit meeting.

13 Many times, a site vice president or plant  
14 management wants to hear those firsthand.

15 DR. SIEBER: That's good input for me, because I  
16 would have expected, just human nature being what it was,  
17 that it would have gone the other way. So that's good.  
18 Thank you very much.

19 MR. DYER: I think the other dynamic in that is,  
20 again, the economic pressures. Licensees realize that the  
21 NRC inspection findings that are below the threshold for  
22 being documented in the report can, in fact, affect their  
23 operation, you know, may provide them an insight or  
24 something maybe to address before it -- it's a precursor.

25 In today's environment, that's necessary.

1 DR. SIEBER: Thank you.

2 CHAIRMAN BARTON: Gentlemen, we're going to have  
3 to move this along a little bit. Maybe we can have some  
4 more questions during the lunch break. We're one-third  
5 through item three, which was supposed to be completed at  
6 this point. So I think we need to kind of hold questions  
7 and have maybe some discussion during lunch. Otherwise,  
8 we'll never get through today.

9 MR. DAPAS: The last point I was going to make is  
10 performance indicator verification, obviously an important  
11 activity the residents are engaged in.

12 We had a number of lessons learned from the pilot  
13 program that have been communicated to licensees, and that  
14 underscores the importance of consistent application of the  
15 performance indicators, and I think we're going to talk more  
16 specifically about those a little later on.

17 Next slide, please. This is just a slide showing  
18 how the division is organized, as Mr. Dyer said, relatively  
19 consistent across the regions. We are currently only one  
20 site is staffed at N+1, that's D.C. Cook; of course, our  
21 agency focus plant, and we're actively recruiting to fill  
22 the reactor engineer vacancies that exist.

23 I'm going to talk a little bit more later on about  
24 the challenges that have been presented to DRP in trying to  
25 fully staff in the context of the new inspection program

1 requirements.

2 DR. WALLIS: You have four vacancies here at the  
3 reactor engineer level?

4 MR. DYER: That's correct.

5 MR. GROBE: What we've done is added overage  
6 positions. Several of those positions are overage, and  
7 we've done that in operator licensing and both engineering  
8 branches and in the reactor engineering DRP. And the goal  
9 is to minimize the amount of downtime we have, when we lose  
10 a number of the staff.

11 So we're trying to fill those up. Once we fill  
12 them, we're going to have a substantial buffer, we hope.

13 MR. CALDWELL: These reactor engineers are not  
14 intended to be overage positions. We do have overage  
15 positions elsewhere, but we're trying to stay ahead of our  
16 -- unfortunately, we never meet our ceiling. And so we're  
17 trying to get ahead of the ceiling so that we at least have  
18 utilization of all the FTE who are left.

19 MR. DAPAS: We bring the reactor engineer on board  
20 and a vacancy occurs at the plant and that's got to be our  
21 primary focus, is making sure the sites are fully staffed.  
22 So it's an ongoing challenge to try and fully staff the  
23 reactor engineer position while keeping the resident program  
24 fully staffed.

25 DR. WALLIS: Because if you lose one more, you'll

1 have none, it looks like. Four out of five.

2 MR. DAPAS: We're heading the other direction.

3 DR. APOSTOLAKIS: I have a question. I'm looking  
4 at the report from the web site regarding the maintenance  
5 rule. It says that you interviewed two licensed reactor  
6 operators and three senior reactor operators to determine if  
7 they understood the general requirements of the maintenance  
8 rule.

9 Is this something that you do routinely? I mean,  
10 what if they don't understand it, what would you do?

11 MR. DAPAS: Which -- I'm not familiar --

12 CHAIRMAN BARTON: This is the follow-up to the  
13 maintenance inspection report that was done in the regions.  
14 Part of that was going in and asking various people on the  
15 stations what was their knowledge of the maintenance rule.  
16 Remember that part of it?

17 DR. APOSTOLAKIS: Is it still the situation that  
18 we will interview people to see if they understand something  
19 under the new revised oversight process? Is that part of  
20 the baseline inspection?

21 MR. DYER: Not that I know of. That might have  
22 been a special inspection. Was that done under a TI?

23 MR. DAPAS: I thought that was associated with  
24 implementation of the new maintenance rule.

25 CHAIRMAN BARTON: That's what it was.

1 MR. GROBE: It was a special inspection.

2 MR. SINGH: It was a follow-up inspection to the  
3 original inspection.

4 MR. GROBE: Right, where there were open issues,  
5 and you go back out, and part of that, I think, was ensuring  
6 that the licensee understood performance goals and on-line  
7 risk assessment.

8 CHAIRMAN BARTON: A lot of that was going into the  
9 control room to ask the SROs, the supervisors, how was their  
10 knowledge of the maintenance rule.

11 MR. GROBE: We have one our maintenance rule  
12 experts here, Any Dunlop.

13 MR. DUNLOP: The maintenance rule baseline  
14 inspections and most likely what this was, there were some  
15 open issues that came up during the baseline inspections and  
16 what we did at each of the sites, when we had open issues,  
17 we would go back and follow-up on them, and that's most  
18 likely what this inspection report is discussing, a  
19 follow-up inspection to address any open issues that had  
20 come up.

21 I'm not sure, I wasn't part of the follow-up. I  
22 was part of the original inspection.

23 DR. APOSTOLAKIS: It's not really this specific  
24 thing that I'm asking about. I'm just asking, in the  
25 future, with the new oversight process, is there room there

1 for us as an agency to see how much the licensee knows about  
2 something? Aren't we supposed to be moving towards a more  
3 performance-based system? Is there a cross-cutting issues  
4 that says try to see how much this operator at the plant  
5 knows?

6 MR. DUNLOP: I think the maintenance rule is  
7 supposed to be one of our first performance-based rules that  
8 we put into effect and I think the purpose of the baseline  
9 inspections was to, unfortunately, have a programmatic  
10 review of what the licensees know and how the program was  
11 actually put together. I know as part of the new A-4 new  
12 maintenance rule, there will be some PI developed and we'll  
13 be doing some inspections at some of the sites.

14 How much we'll be looking into the programmatic  
15 aspects versus the performance-based, I don't that's been  
16 determined yet.

17 MR. DUNLOP: I believe that inspection was sort of  
18 a -- the baseline and the follow-up was sort of to set the  
19 groundwork to then go forward. In the future, I don't  
20 believe we're going to be quizzing people on their knowledge  
21 level.

22 I think part of the baseline inspection, if I  
23 remember correctly, part of it was to see did the training  
24 take. When you go in and you took it, when they had  
25 implemented a change in the program, part of our inspection

1 is, okay, did the training take, do people understand their  
2 responsibilities.

3 And as a basis for that, that was the nature of  
4 the questioning and I think that was specifically called out  
5 in a temporary inspection, which would be not part of -- it  
6 would be a one-time inspection, not part of a routine  
7 inspection that we would continue.

8 So it would take the headquarters, if they  
9 decided, for some other reason, that we needed to go back  
10 out and periodically reverify the training, then we could  
11 look at it again, but it wouldn't be part of our normal  
12 routine program.

13 MR. GROBE: I was going to say, by contrast,  
14 whenever we observe an activity, I expect the inspectors to  
15 be assessing the knowledge level of the people that are  
16 performing that activity of the procedures and the specific  
17 work they're doing.

18 So we would continue to evaluate, if we observe a  
19 maintenance activity or a test activity or an operations  
20 activity or talk to an engineer about a calculation, we'd be  
21 assessing their understanding of what they're trying to  
22 accomplish and their understanding of the procedures  
23 involved in that.

24 So we will still be getting into assessing the  
25 capability of the people to accomplish the work they're

1 trying to accomplish for those activities where we're  
2 observing performance.

3 But as Andy pointed out, that was strictly a  
4 programmatic inspection. It didn't involve actual  
5 implementation of the program as much as on a day-to-day  
6 basis, as much as the programs, procedures and training.

7 DR. APOSTOLAKIS: There are similar findings in  
8 other places, and I'm not questioning you why you did this.  
9 I'm trying to see what the future will be under the new  
10 oversight process. We have the cross-cutting issues, of  
11 course.

12 MR. DAPAS: We have an individual that actually  
13 has probably conducted the resident inspector portion of  
14 that and certainly can speak to what the new program entails  
15 as far as the maintenance rule.

16 DR. APOSTOLAKIS: While you're getting the  
17 microphone. I've made several findings here that really I  
18 didn't expect to see. For example, The company nuclear  
19 review board members were thoroughly prepared for the  
20 September '98 meeting.

21 MR. DAPAS: Does that embody observations and --

22 DR. APOSTOLAKIS: Yes, but is it going to be in  
23 the future, are they going to be observe whether people are  
24 well prepared. There was a finding later that the expert  
25 panel deliberations were not recommended, and so on.

1           And I thought that in the new oversight process,  
2 what really matters is the decisions of the expert panel and  
3 not whether they document what they're doing.

4           So the question is how much of this is going to  
5 change in the future, if any?

6           MR. DYER: I think you'd have to look at either  
7 the Quad Cities or the Prairie Island plant issues matrix to  
8 get a better understanding as to what the new program is  
9 going to look like. Davis-Besse was under the old program.

10          DR. APOSTOLAKIS: I understand. This is old.

11          MR. DYER: And there's a specific module. So the  
12 resident inspectors, once every 18 months, had to go observe  
13 an off-site review committee, and they do the best they can.

14          MR. COLLINS: I can talk to that. My name is  
15 Laura Collins, and I was a resident inspector at the pilot  
16 plant, Quad Cities, and did the maintenance rule inspection  
17 portions for the residents there a lot.

18          The kind of observations that you're talking  
19 about, unless they were to really result in a problem,  
20 because we're more results-oriented, are not the kinds of  
21 things, I don't think, we would be documenting anymore.

22          But we would still be, if we observed those  
23 things, communicating them to the licensee, so that they can  
24 learn from them.

25          So if we make those observations, we're going to

1 share everything that we observe with the licensee, but we  
2 have higher thresholds for findings. There's got to be some  
3 kind of a result of that improper implementation of the  
4 maintenance rule.

5 DR. APOSTOLAKIS: So that in the future, then, you  
6 would not particularly care about how the expert panel  
7 conducts its business. You would just look at the results.

8 MS. COLLINS: That's right.

9 DR. APOSTOLAKIS: Is that the correct perception?

10 MS. COLLINS: We start with the results.

11 DR. APOSTOLAKIS: But you may get back into the  
12 thing, I mean, if you want to understand --

13 MR. DYER: I think one of the things that the  
14 utilities, the vice presidents, are particularly interested  
15 in is if we said we observed the meeting, we have no  
16 findings, a lot of times they'll ask you, what did you think  
17 of the conduct of the meeting, and that's one of those  
18 issues that may be provided below the line, but it's not  
19 going to be documented in the inspection report, there's no  
20 response required.

21 MR. CALDWELL: And it's not that we don't -- you  
22 said we may not care about it anymore. We still care, but  
23 we wouldn't document it necessarily. We would communicate  
24 it to the licensee, if we felt that would give them some  
25 insight.

1 DR. SIEBER: Unless you came away with the feeling  
2 that the result was inadequate, and then you may go further  
3 to find out why that is.

4 MR. DYER: Now, if we come out with an inadequate  
5 safety review, we may take it back to there was an  
6 inadequate safety review, it was not adequately reviewed and  
7 people weren't prepared, something like that. But it would  
8 be tied to the results.

9 MR. DAPAS: Or then the expert panel concluded  
10 this system should be -- there should be performance goals  
11 established for this system to review its importance and  
12 risks, and the licensee didn't address that, that would be a  
13 result.

14 DR. APOSTOLAKIS: I agree, but that is clearly  
15 within the new rules of the game.

16 DR. BONACA: How do you know if there is no  
17 implementation. What I'm trying to say, there are examples  
18 there, some examples where the PRA defined some component  
19 that's safety-significant, but determined it wasn't really  
20 safety-significant and, therefore, they did not report this  
21 activity.

22 Now, there is an importance also in the  
23 documentation. You've got to make a determination that the  
24 decision ultimately was the correct one. Performance-based  
25 doesn't mean you're waiting until you have an event. It

1 means that you're performing the right things. So you still  
2 have a burden on the processes that you have to inspect and  
3 the show of the work.

4 DR. APOSTOLAKIS: See, what confuses me -- and,  
5 again, I'm not referring to a specific thing, but is that in  
6 Washington, we're being told time and time again that  
7 managing the plant and the organizational aspects are really  
8 the licensee's responsibility and we should not get  
9 involved.

10 In fact, several of the research projects of the  
11 Office of Research have been killed on that principle. And  
12 then I come here and I see that an appropriate feedback  
13 process was in place, operators responded conservatively to  
14 plant transients, operators were prepared for the possible  
15 closure of feedwater regulating valve surveillance testing.

16 All this is organizational management, isn't it?

17 MR. GROBE: No.

18 DR. SEALE: It's

19 CHAIRMAN BARTON: It's observation of plant  
20 operations, George.

21 DR. APOSTOLAKIS: But there is a feedback process?  
22 That's their business.

23 MR. GROBE: Well, it's also required pursuant to  
24 Appendix B.

25 DR. APOSTOLAKIS: So what we are told there is not

1 entirely accurate. I'm trying to reconcile the views. It's  
2 very fuzzy, isn't it?

3 CHAIRMAN BARTON: Especially when you're assessing  
4 management's competence and safety culture versus  
5 observation of plant operation.

6 DR. APOSTOLAKIS: That's an extreme, I agree. I  
7 agree. But having an appropriate feedback process, it seems  
8 to me, is an organizational issue.

9 MR. GROBE: I'm not sure what the context of that  
10 was. But it's important, though. For example --

11 DR. APOSTOLAKIS: Plant issue matrix of  
12 Davis-Besse, dated September 28, '99.

13 MR. GROBE: For example, within the training  
14 context, the feedback process is absolutely critical,  
15 because on a system-based training process, you have to have  
16 that loop. In the training inspection, that's part of what  
17 we look at.

18 Within the context of an oversight committee, the  
19 engagement of the committee in questioning the quality of  
20 the product and understanding it is critical to the outcome.  
21 So if we only look at the outcome of the meeting, there may  
22 be significant things that they missed because they weren't  
23 well prepared for the meeting.

24 And it gets to root cause, really. If we're going  
25 to have inspectors in the field observing the activities,

1 those are the kinds of things we expect them to look at. As  
2 Laura pointed out, those issues wouldn't find their way into  
3 a report today unless they resulted in a risk-significant  
4 finding.

5 MR. DAPAS: And that's the key. Regulatory  
6 engagement is a product of the consequence of that, but we  
7 would still feed that observation back to the licensee.

8 MR. GROBE: Exactly. Both positive and negative.  
9 If we found that the people performing a maintenance or a  
10 test activity were very qualified and competent and  
11 displayed that in their discipline, in the way they  
12 approached their job, provide that feedback.

13 DR. APOSTOLAKIS: So the action matrix of the new  
14 oversight process, that would not be triggered. That would  
15 not be affected by these observations. You just provide the  
16 feedback.

17 MR. GROBE: That's right.

18 DR. APOSTOLAKIS: Because there is nothing white.

19 MR. GROBE: That's right.

20 MR. CALDWELL: You also understand we're in the  
21 initial implementation phase of this new process, this is  
22 what we think, we may learn something as we go along and  
23 change our approach, but right now, that would be the  
24 outcome.

25 MR. DYER: What we found at the two pilot plants

1 that we've implemented the program in, when we first went to  
2 -- we actually applied the SDP to it and we went through our  
3 formal exit and said here's our formal observations and the  
4 utility management look at us and say is that all, you've  
5 been here for a month, you need to give us more feedback.

6 It evolved out of that --

7 MR. GROBE: Tell us what you really think.

8 MR. DYER: Yes. And evolved out of that is we  
9 have a formal exit now where we say here is what is formally  
10 going in the inspection report, here's our observations that  
11 aren't going to make the report.

12 MR. GROBE: Dr. Barton, in the interest of time,  
13 let me quickly go through the next six or eight slides, and,  
14 Bruce, keep up with me.

15 In the Division of Reactor Safety, we really have  
16 five major functions; engineering inspections, health  
17 physics and emergency preparedness inspections, safeguards  
18 inspections. We also have operator licensing and that  
19 includes initial examinations, upgrade examinations, as well  
20 as requal inspections, and incident response is one of the  
21 major functions of the Division of Reactor Safety.

22 Let me just highlight a few things in the  
23 engineering inspection area that are new and exciting. We  
24 have a much stronger emphasis today on design inspections.  
25 We have an inspection called the safety system design

1 inspection, or the SSDI. We also have an inspection that  
2 focuses more heavily on the Appendix R design of the plant  
3 and the ability of the plant to sustain a debilitating fire.

4 Those are two inspections that are new, much  
5 stronger emphasis in the design area.

6 DR. POWERS: I attended the fire protection forum  
7 and it was an interesting complaint. They said, gee, you  
8 guys are focusing all your attention on this Appendix R and  
9 the safe shutdown and neglecting all this other fire  
10 inspection stuff, and it's just not right. The fact is we  
11 haven't done the Appendix R safe shutdown inspections in the  
12 past to the extent that they probably should have been done.

13 And now we're just bringing things back to some  
14 sort of proper balance.

15 MR. GROBE: And we're not disregarding classical  
16 fire protection either. That's part of the resident  
17 program. But there's a summary on the slide of the types of  
18 engineering inspections we get engaged in and we'll go into  
19 some more detail later on some of those.

20 In the safeguards area, we look at contingency  
21 response, access control and fitness-for-duty primarily,  
22 and, as Marc indicated earlier, each component of our  
23 inspection program, we look at problem identification and  
24 resolution or the effectiveness of the corrective action  
25 program.

1 DR. SIEBER: When you do an OSRE, though, that  
2 also involves the operations people, right? With strategies  
3 and so forth.

4 MR. GROBE: Exactly.

5 DR. SIEBER: But that's not part of your baseline  
6 inspection. You're just looking at cameras in the field and

7 --

8 MR. GROBE: Contingency response is actually --

9 DR. SIEBER: Is that in there?

10 MR. GROBE: Yes. It's kind of in there in hiatus  
11 right now. OSRE is suspended and we're trying to work with  
12 the industry to come up with a better way to do  
13 force-on-force drills.

14 DR. POWERS: One of the questions that I've had  
15 about that is the extent to which we can use some of the  
16 computational tools that have been developed by the national  
17 laboratories, among other people, I think, for simulating  
18 these force-on-force exercises.

19 They won't do everything that the OSRE does for  
20 you, but they would certainly augment or maybe reduce the  
21 need to do actual OSRE type activities. Have you looked  
22 into this at all?

23 MR. GROBE: I don't know.

24 CHAIRMAN BARTON: It's a civilian industry  
25 initiative at this point.

1 MR. GROBE: These are simulation type tools that

2 --

3 DR. POWERS: They were originally developed -- the  
4 ones I know about, the ones that were originally developed  
5 were Air Force bases in Europe. They became concerned when  
6 the Red Army was running around, could they, in fact, defend  
7 their weapons systems from an intrusion force, and that  
8 would be different than an ordinary military fighting force.

9 And they had done a lot of exercises with these  
10 guys with laser rifles and things that had sensors all over  
11 them and they computerize it and out of that they come up  
12 with what's the optimal strike force against it, what are  
13 the vulnerable sites, locations on the facility and things  
14 like that.

15 MR. GROBE: I'll look into it.

16 DR. POWERS: They eventually got very  
17 sophisticated, but I don't know whether they've gone into  
18 the commercial sector or not.

19 MR. GROBE: I have not heard about it.

20 DR. POWERS: They resulted in massive changes to  
21 the way they the military protected their facilities. I  
22 mean, they were shocked at how easy it was to break in.

23 MR. GROBE: Appreciate that insight.

24 In the rad protection area, three primary focuses;  
25 plant protection of the people on-site, radioactive waste

1 and transportation, and protection of the public, effluents  
2 and environmental protection.

3 DR. SIEBER: This is probably where Illinois  
4 Department of Radiation Safety comes in quite a bit.

5 MR. GROBE: Well, they're much more intrusive.  
6 They have reactor safety specialists that are resident at  
7 the sites. They are very sophisticated, very impressive  
8 organization. Not quite as good as us, though.

9 DR. SIEBER: Well, I knew that.

10 MR. GROBE: In emergency preparedness, we observe  
11 exercises, as well as do programmatic reviews on a regular  
12 basis. Operator licensing, I mentioned earlier, we do  
13 initial exams. Sometimes those are SRO, instant SROs exams,  
14 sometimes reactor operator exams.

15 We also do upgrade exams and requalification  
16 inspections. In each area, again, problem identification  
17 and resolution.

18 Incident response, we maintain and coordinate for  
19 the region maintenance of our incident response capability,  
20 and that includes exercises, training, equipment and  
21 facilities, as well as interface with Federal, state and  
22 local, and unique in Region III is some tribal interface up  
23 at the Prairie Island plant.

24 The division is broken up into four branches. Two  
25 engineering branches, one focusing primarily on electrical,

1 which includes environmental qualification, I&C, fire  
2 protection, electrical engineering and analyses; mechanical,  
3 which gets into mechanical, civil structural, as much as we  
4 do these days, maintenance rule, in-service inspection,  
5 steam generator replacement, steam generator tube  
6 inspections, things of that nature.

7 An operator licensing branch, which is very busy  
8 these days. Unlike some other regions, for example, Region  
9 I puts emergency preparedness and operator licensing  
10 together in one branch. This branch is strictly focused on  
11 operator licensing.

12 DR. WALLIS: Does mechanical engineering include  
13 thermal hydraulics?

14 MR. GROBE: Are you talking, for example, of -- we  
15 do heat sink inspections.

16 DR. WALLIS: Heat and fluid, yes. Water and  
17 steam, where they are and what they're doing, how well they  
18 are performing their function.

19 MR. GROBE: Within the reactor, we don't do a lot  
20 of inspection from a thermal hydraulic point of view.  
21 However, from a heat sink point of view, heat exchanger  
22 performance, we do some inspection in that area.

23 Plant support is health physics, emergency  
24 preparedness and incident response in that branch.

25 MR. DAPAS: You can get into those aspects,

1     though, like with an operability evaluation, where the  
2     licensee is using thermal hydraulic analysis to support a  
3     particular conclusion. We might look at that.

4             MR. GROBE: We just completed safety system design  
5     inspection at Point Beach and the focus was the service  
6     water system, a lot of thermal hydraulic analysis involved  
7     in that.

8             That was fired through the scrub oaks on Division  
9     of Reactor Safety.

10            CHAIRMAN BARTON: Very good, you did good. At  
11     this point, I'd like to break until 10:30.

12            [Recess.]

13            CHAIRMAN BARTON: We're back in session. Marc,  
14     are you still on?

15            MR. DAPAS: Yes. The next presentation that we  
16     wanted to address was the comparison of the new program to  
17     the old program. I think some of you have raised some  
18     questions. In the context of the new program, I think this  
19     is an opportunity to more thoroughly address some of those.

20            As an example, I know Mr. Seale raised a question  
21     about the resource expenditure tracking and we can talk  
22     about what challenges that presents.

23            Rather than continue to use overheads here, if we  
24     can just go through the slides, if that's okay with you.

25            CHAIRMAN BARTON: That's fine.

1 MR. DAPAS: Great. Starting on page 20, when we  
2 looked at the old program, that was pretty much broken up  
3 into thirds between the core program, what was previously  
4 termed the regional initiative, and special inspections.  
5 Special inspections was our mechanism for following up to  
6 specific events.

7 And as we talked about a little earlier, we use  
8 risk as a gauge in determining what's the appropriate  
9 engagement in terms of numbers of folks we send to the site.

10 The regional initiative, of course, involves some  
11 subjective judgment about the declining licensee performance  
12 in a particular area or aspect of plant operations, and we  
13 would send some folks out to do a more intrusive review of  
14 that.

15 Under the new program, it's pretty much baseline  
16 loaded, and the baseline represents that minimum amount of  
17 inspection required to verify that licensee performance is  
18 within the licensee response band, whereas under the old  
19 program, the core represented that minimal amount of  
20 inspection to verify the plant was being operated safely.

21 As you know, whether you're in the licensee  
22 response band or regulatory response band, there's still a  
23 sufficient safety margin. So it's a little different  
24 approach.

25 There is clearly greater flexibility in applying

1 inspection resources under the old program. An inspection  
2 procedure could be closed using judgment on whether the  
3 intent was met.

4 For example, inspection procedure 71.707, which  
5 dealt with operational safety verification, that would  
6 include observation of control room activities, an  
7 engineered safety system feature walk-down.

8 The inspector could decide, based on reading the  
9 inspection procedure, I met the intent of this procedure  
10 with X number of hours. Under the new program --

11 MR. GROBE: Before you go on, that's exactly what  
12 got Davis-Besse down in the 1,800 hour range. I'm sorry.

13 MR. DAPAS: When you look at the sampling size  
14 under the new program, X number of surveillance tests need  
15 to be observed, X number of operability evaluations.  
16 There's a certain periodicity; for example, looking at maybe  
17 a couple samples a month.

18 And under the one-size-fits-all approach within  
19 the licensee response band, the baseline inspection program  
20 is fairly rigorous in the scope and estimated number of  
21 hours to complete the inspection procedure. And as Jack  
22 pointed out, that can translate to what is perceived to be  
23 an increased regulatory burden for a licensee like  
24 Davis-Besse, where there was more flexibility in determining  
25 was the intent of the procedure met.

1           In the new program, you have to implement the full  
2 scope to satisfy the inspection procedure objectives.

3           MR. GROBE: Philosophically, what we've done is on  
4 the side of the angels. We looked at risk, we picked out  
5 what are the most significant risk-related activities.  
6 Based on the impact on the risk of that activity, we  
7 identified those attributes that were important to inspect  
8 and we assigned, developed inspection procedures and figured  
9 out how much resources it would take to do it, and it came  
10 out to, whatever it is, 2,100, 2,200 hours.

11           The challenge, point number one, is that that  
12 consumes almost 95 percent of our resources. So the  
13 combination of things; the new thresholds to get to a white,  
14 yellow or red finding are fairly high. So we don't expect  
15 to have much supplemental inspection. But we also have much  
16 less capability to respond to a problem of that nature, and  
17 we're going to have to depend on other regions and  
18 headquarters to supply us resources, whereas in the past,  
19 that 33 percent regional initiative, we could target those  
20 resources based on management judgment.

21           That made us less predictable, and that was one of  
22 the concerns the licensees had.

23           DR. SIEBER: The real opportunity, and I realize  
24 it may be a second or third generation in the application,  
25 to achieve this is the extent to which you can make the

1 inspections plant-specific, with justification.

2 MR. GROBE: We make all the inspections  
3 plant-specific.

4 DR. SIEBER: In terms of coverage, not in terms of --

5 MR. GROBE: In terms of amount of hours, is that  
6 what you're saying?

7 DR. SIEBER: Yes.

8 MR. GROBE: We talked about modifying the baseline  
9 based on performance. But that gets back to where we were  
10 and there is a lot of reticence to do that very quickly.  
11 If, after a few years, we find out that they're --

12 DR. SIEBER: Maturing.

13 MR. CALDWELL: But it also is the way the system  
14 is set up, we're not capable of doing that right now,  
15 because there is not a gradation in green band. That's  
16 licensee response band, that's where we stay at. So those  
17 folks that are in that band get the baseline inspection  
18 program, whether they're at the top of the band or at the  
19 bottom of the band. That's the way the new oversight  
20 process works.

21 So to try to come up with a way of reducing  
22 inspection of one licensee over another is not -- within  
23 this current program, that's not possible.

24 MR. GROBE: The pendulum swung to predictability.  
25 We are extremely predictable now. The question is whether

1 or not we've taken too much of the judgment out, such that  
2 we can no longer predict problems.

3 DR. POWERS: What I worry about, especially this  
4 point about the inspectors losing judgment capability, it  
5 seems to me that the good inspector can quickly say in this  
6 area, I've met the intent here, and there are enough  
7 problems for me to worry about here, this other area is more  
8 complicated for me to understand, me personally to  
9 understand than the average inspector, and there may be  
10 bigger issues here, and so I need to spend more of my hours  
11 here.

12 That judgment seems to be something that I want  
13 him to exercise very much.

14 MR. GROBE: It's been reduced in the new program.

15 DR. POWERS: And it seems like he's -- that that's  
16 the flexibility that is a real loss.

17 MR. DAPAS: Let me comment on that. As I  
18 understand the new inspection program, the sampling size is  
19 intended to be risk-informed. Operability evaluations is  
20 clearly going to be a risk-significant activity. If the  
21 licensee doesn't adequately evaluate the impact of degraded  
22 equipment, will the equipment perform its intended function.

23 That's clearly related to risk. So what is an  
24 appropriate sample size to gauge how the licensee is  
25 performing in that particular area.

1           In the past, under the old program, you may decide  
2 to watch one surveillance test and you felt that you've met  
3 the objectives of the procedure. Under the new program,  
4 there may be two surveillance tests that you look at on a  
5 monthly basis, and that's the risk-informed sample size.

6           So it's more prescriptive in that regard and  
7 that's why the hours are more rigorous.

8           Now, I think after the first year of  
9 implementation across all the sites, we may end up  
10 revisiting the scope of a given inspection procedure and  
11 we're also providing feedback on a continuous basis.

12           If the inspector is performing a certain  
13 inspection procedure and feels that the scope of the  
14 procedure needs to be refined, they provide feedback and  
15 that's communicated to the program office.

16           CHAIRMAN BARTON: Well, the intent of the whole  
17 initial implementation for one year is to make adjustments  
18 after that one year.

19           MR. DAPAS: Correct.

20           CHAIRMAN BARTON: Right, sure.

21           MR. DAPAS: That's my understanding.

22           DR. WALLIS: It seems to very ironic that the  
23 reason for all this is to get away from prescriptive  
24 regulation. They seem to have moved to more prescriptive  
25 inspection.

1 MR. CALDWELL: It's prescriptive in the sense that  
2 the inspection size or inspection scope and type were  
3 supposed to be, as best we could, risk-informed. In other  
4 words, you're focusing your resources in the area where  
5 there is the biggest bang for the buck.

6 The desire to make it such that each region and  
7 each inspector does it essentially the same way for  
8 consistency, but to answer Dr. Powers' question, if an  
9 inspector feels they have to spend more time to accomplish a  
10 given sample size or given objective, they would take the  
11 time necessary to accomplish the objective.

12 So if the inspector felt comfortable in this area  
13 and was able to get it done pretty fast, that's what they  
14 would do to accomplish the objective of the inspection. If  
15 they felt that they needed more time in another area, they  
16 would do it, they would spend the time.

17 So the judgment in that respect is still there.

18 MR. GROBE: But they right now don't have the  
19 latitude to say I'm going to do 18 operability evaluations  
20 versus 24.

21 MR. CALDWELL: Right.

22 MR. GROBE: But in addition to that, there's  
23 barriers. We have put -- depending on the types of  
24 inspections, the error bands can be up to 25 percent as far  
25 as number of hours. To go outside that band requires fairly

1 high approval.

2 So we need to get engaged in what it is that's  
3 causing the inspector to have to spend a lot more time, as  
4 managers.

5 MR. DAPAS: And that's because we've communicated  
6 that the baseline inspection program is that minimal amount  
7 of inspections necessary to verify licensee performance is  
8 still within that licensee response band.

9 MR. GROBE: We spoke earlier about observing more  
10 behaviors and you talked in the context of management.  
11 Those are the types of things that would give you confidence  
12 that you can make your sample size smaller.

13 If you looked at the procedures and the guidance  
14 and you looked at the training and you looked at how the  
15 people were engaged in their job, in the past, we -- and all  
16 of those things were very positive, so you had a high level  
17 of confidence in the competence of the people and how their  
18 work activity is controlled, we would feel comfortable  
19 scaling back on sample size. Now we don't have that  
20 flexibility.

21 DR. APOSTOLAKIS: Do you think that the new  
22 oversight process can be modified to accommodate some of  
23 these concerns, without affecting its intent regarding  
24 predictability, for example, too much?

25 MR. GROBE: It's difficult. One of the things we

1 haven't thrown on the table is that it's my sense that one  
2 of the motivators of this predictability was the financial  
3 community having confidence in a regulatory oversight not  
4 influencing negatively the financial viability of the  
5 company, from a stock point of view.

6 So I'm not sure how that would work and we'd have  
7 to do that jointly with the industry.

8 DR. SIEBER: What do you do with a plant like  
9 Zion?

10 MR. GROBE: Zion?

11 DR. SIEBER: Yes. They still do the -- they  
12 haven't applied for decommissioning yet.

13 MR. GROBE: In the decommissioning area, our level  
14 of inspection is directly related to the level of activity  
15 that the licensee has on-site.

16 DR. SIEBER: So you would cut back on the number  
17 of residents you have there.

18 MR. GROBE: There are no residents.

19 MR. CALDWELL: We have inspectors here in the  
20 region that go up there, and Zion is not that far away, but,  
21 yes, our inspection program is based on the decommissioning.  
22 There is actual inspection plan for decommissioning  
23 reactors.

24 MR. DAPAS: Which is outside the baseline program.  
25 Moving right along. Certainly, under the old

1 program, we used deterministic processes in our enforcement  
2 policy to guide our assessment of significance associated  
3 with inspection findings.

4 Under the new program, we process findings in the  
5 significance determination process, which is based on the  
6 probabilistic risk type analysis. I'd just simplify that  
7 down into two concepts. You've got frequency of initiating  
8 event and then the defense-in-depth regarding mitigative  
9 capability and if you have a particular piece of degraded  
10 equipment or unavailable equipment, you look at what impact  
11 does that have on the mitigative capability.

12 You look at the availability of redundant  
13 equipment. You can credit operators for recovery actions.  
14 And then there is a plant-specific phase two worksheet that  
15 is supposed to bring to the table the specific  
16 configurations unique to that plant in terms of equipment  
17 redundancy.

18 CHAIRMAN BARTON: Are they all out and back now,  
19 are the plants commenting on them?

20 MR. DAPAS: Yes. Sonia, you might be able to  
21 speak to that. I'm not sure of the exact status.

22 MS. BURGESS: As far as the agency-wide, no. Our  
23 region, yes, with the exception of D.C. Cook. We have put  
24 our comments back to Research, who has, in turn, given them  
25 to BNL.

1           MR. GROBE: We took a different approach in Region  
2     III than some of the other regions took. We had either Mike  
3     or Sonia out on each site visit to make sure that we had a  
4     clear understanding of the SDP and the licensee effectively  
5     integrated plant-specific issues into the SDP.

6           Some of the other regions had Research do that or  
7     headquarters staff. As Sonia indicated, she and Mike have  
8     finished all the sites, with the exception of Cook, and we  
9     need to get on Cook pretty soon here.

10          MR. PARKER: But to be more specific, we don't  
11     have the comments back from BNL and back from Research yet.  
12     So they're not integrated into the current process.

13          MR. GROBE: We have hand markups of the SDP.

14          DR. APOSTOLAKIS: Are you comfortable with the  
15     SDP?

16          MR. PARKER: Am I comfortable with the SDP? I'm  
17     very comfortable with the site visits we accomplished and  
18     the corrections and the adjustments we made to them, but  
19     right now the difficulty we have is working with the  
20     residents, because it's not integrated into the formal SDP  
21     worksheets.

22          MR. GROBE: It would be interesting to march about  
23     a dozen inspectors up and ask them that same question,  
24     because there's a lot of -- we use the terms risk-informed  
25     and risk-based. The SDP is primarily risk-based.

1           And an excellent example, and if Laura is still  
2 here, she can provide some of the details, if I screw up on  
3 the details, there was a finding at Quad Cities involving  
4 motor-operated valves, where the licensee did not  
5 effectively correct problems on a timely basis, the  
6 motor-operated valve setup.

7           The end result was that they had a number of  
8 deficiencies that, if you take together, made it clear that  
9 their motor-operated valve program was not functioning.

10           When I say motor-operated valve program, the setup  
11 of the valves to make sure that they could handle  
12 differential pressures and all those things.

13           From an SDP point of view, though, at any given  
14 time, there was not sufficient valves that were determined  
15 at that time to be non-functional, such that you got out of  
16 the green band.

17           So it was a green finding, yet, it was clear to us  
18 that there were systemic problems in the way the engineering  
19 work was done to set up the valves, and that was a green  
20 finding. So those are the kinds of issues.

21           We're comfortable with the SDP. It clearly tells  
22 us what it's supposed to tell us, and that is whether or not  
23 that one specific finding is of risk-significance, given the  
24 other situations that occurred at exactly the same time.

25           DR. APOSTOLAKIS: So what you're saying is that

1 the actual finding may be limited to one or two components,  
2 when, in fact, there is suspicion that there is a common  
3 cause failure that might affect many more.

4 MR. DAPAS: If you have information that there's a  
5 common cause --

6 DR. APOSTOLAKIS: This is one possibility.

7 MR. DAPAS: -- that has to be explored as part of  
8 the SDP. You have to have clear information that --

9 DR. APOSTOLAKIS: But why couldn't you do that for  
10 the MOVs?

11 MR. DAPAS: This was more of a programmatic  
12 concern.

13 DR. APOSTOLAKIS: A programmatic common cause  
14 failure.

15 MR. GROBE: We have a task group right now working  
16 on what we call cross-cutting issues and right now what the  
17 agency considers cross-cutting issues are the effectiveness  
18 of the corrective action program, the effectiveness of human  
19 performance, and the safety conscious work environment,  
20 which is really kind of hard to separate from the  
21 effectiveness of corrective action program.

22 We've got some concerns in other areas. Being  
23 from the Division of Reactor Safety, engineering is a big  
24 part of my life, and effectiveness of engineering, we think,  
25 is a cross-cutting issue.

1           We are trying to work through those things and we  
2 will be, over the next year, trying to more clearly define  
3 how you handle cross-cutting issues and this valve issue is  
4 a cross-cutting issue.

5           DR. APOSTOLAKIS: But let's come back to the  
6 common cause failure. Usually there is a suspicion that  
7 there is potential for common cause failure. Very rarely  
8 you find all valves down. You look at one or two failure  
9 and say, well, gee, this mechanism could have affected the  
10 others.

11           MR. DAPAS: That's right. If the torque switch  
12 settings weren't set appropriately on valve X, the licensee  
13 should try and determine extent of condition, is that the  
14 case with other valves, and that could be a potential common  
15 mode failure.

16           DR. APOSTOLAKIS: Then you would go to the SDP?

17           MR. DAPAS: Correct, if there is sufficient  
18 information to indicate that that is the case. But the  
19 example that Jack was talking about, where the licensee is  
20 trending valve failures and it has programmatic  
21 implications, under the new program, the licensee should be  
22 putting that issue into their corrective action program and  
23 addressing it.

24           In our annual PI&R inspection, problem  
25 identification and resolution, that might be an issue that's

1 part of our smart sample, where we would go in and evaluate  
2 did the licensee look at this from a broader context, did  
3 they take appropriate corrective action.

4 MR. GROBE: On that specific issue, Mike and Laura  
5 -- Mike, you were involved in that, weren't you?

6 MS. BURGESS: I was.

7 MR. GROBE: Pardon me? You were?

8 MS. BURGESS: I was. I sat on the SDP panel and  
9 the SDP panel did not believe that that was a common cause  
10 failure, that that was a cross-cutting issue thing, but that  
11 was not a hardware, there was no evidence that other valves  
12 were exhibiting those kind of failures.

13 So each individual -- or this valve had to stand  
14 alone and go through the SDP process, which turned out to be  
15 a green.

16 MR. GROBE: The threshold for a common cause from  
17 engineering issues is very high.

18 DR. APOSTOLAKIS: So when you say the SDP panel,  
19 is it you or the licensees?

20 MS. BURGESS: The SDP panel is the NRC. It's one  
21 SRA from every region and a branch chief from every region,  
22 also, plus the program office.

23 DR. BONACA: Also, if you had a significance  
24 determination for a certain event and found it was not  
25 significant enough, but you have evidence that it would

1 repeat again, the determination would not -- but then you  
2 would refer back to your corrective action program.

3 MR. DAPAS: That gets to how robust is your  
4 corrective action program. Each time there is an event, you  
5 have to look at the significance, or each time there is an  
6 issue or equipment problem, you look at the significance of  
7 that associated with unavailability via the significance  
8 determination process.

9 And if that reflects a repeat occurrence, that  
10 calls into question the licensee's corrective action  
11 program. But, again, degree of regulatory engagement is  
12 based on the overall significance.

13 For example, you could have repeat issues that are  
14 such low significance, it would be inappropriate for us to  
15 engage. Now, we expect the licensee to address those,  
16 because, of course, the whole premise is the licensee needs  
17 to address those low level issues before they manifest  
18 themselves in more significant concerns or events.

19 MR. GROBE: I don't want to leave anybody with the  
20 impression that we're not committed to make the program,  
21 because we are. I want to make sure that we help expose the  
22 challenges.

23 DR. POWERS: Understanding that the team that set  
24 these programs up were under an enormous time pressure, did  
25 a heroic job and did a job under the understanding that

1 there were going to be rough edges.

2 I think these are the kinds of rough edges that  
3 are anticipated in this program and getting them all out in  
4 the air early is the only way they're going to get  
5 corrected.

6 What we're seeing is some resistance to any  
7 changes in programs on the licensee side, which is amazing,  
8 but I think there are things that have to be done better and  
9 managerial and inspector flexibility strike me as you're  
10 really losing something if you take that out of the ballgame  
11 where that judgment component comes in.

12 I mean, what are we paying these guys to be  
13 educated for if they don't use their judgments?

14 DR. BONACA: The reason why I was pursuing that  
15 issue before, also, is the fact that on the licensee side,  
16 it's been a common defense for a long time that this issue  
17 happened, but it wasn't of such significance.

18 And so although it is an important element of the  
19 determination, it's also, at times, a defense and an attempt  
20 to pick more -- there are other links to other events that,  
21 in fact, make it significant because it's a repeat.

22 So I'm only saying that the significance  
23 determination process right now doesn't lead you necessarily  
24 to assess significance based on the fact that you have  
25 repeats, and those are very important because then we have

1 programmatic issues.

2 MR. DAPAS: Well, if you recall, our enforcement  
3 policy previously had an allowance to address inadequate  
4 corrective action, which there are supposed to be actions to  
5 prevent recurrence.

6 But in looking at this and taking a step backward,  
7 one of the issues clearly that the industry challenged the  
8 NRC on, and ultimately Congress, was that our regulatory  
9 activities resulted in unnecessary regulatory burden. And I  
10 think, as an agency, we determined the best approach in  
11 trying to establish a uniform baseline to determine  
12 significance is using risk, and we came up with the  
13 significance determination process, and I think that needs  
14 -- there's additional modifications that need to be made to  
15 that.

16 But I think we concluded that going forward for  
17 initial implementation, that exercising that process and  
18 engaging, as a regulator, when thresholds were crossed, if  
19 that had been sufficiently established to ensure that plants  
20 are being operated safely while we continue to refine and  
21 further exercise that.

22 MR. GROBE: Any other questions on number three?  
23 Because that seemed to be a big focus of --

24 DR. APOSTOLAKIS: Well, I remember when we had a  
25 presentation on the significance determination process. It

1 seemed to me there was a lot of room for judgment there and  
2 that's why I asked the question whether you are comfortable  
3 with it.

4           Given a certain finding, is it a routine matter to  
5 determine its risk significance or people are still learning  
6 how to do that is understandable.

7           MR. GROBE: The level one and level two reviews  
8 should be -- the staff should be capable of doing those.  
9 Our risk analysts had primarily gotten involved at the level  
10 two as we're learning and their workload has just been huge  
11 to try to help the staff learn how to use these tools.

12           When you get to level three, and our risk analysts  
13 are engaging with the licensees' risk analysts, you get, I  
14 think, a very highly defensible risk position. It takes a  
15 lot of effort to get there, several months worth of work has  
16 been our experience.

17           But the tools are still in the stage of  
18 development and as Mike and Sonia indicated, the level two  
19 worksheets, we just have pencil markups on them right now.  
20 But the tools should be effective and there is going to be a  
21 growing period where the staff learns how to use them.

22           But those tools -- do you want to comment on the  
23 adequacy?

24           MR. PARKER: Yes. I guess I'd say I agree with  
25 you, George. There is a lot of latitude there and we need

1 to make sure that we apply the appropriate assumptions and  
2 that we can validate them and support them.

3 But in a lot of cases, it's very positive for the inspector  
4 because an inspector can sit back and say, hey, I've got an  
5 issue, I'm going to assume this equipment is out of service,  
6 and still results in an insignificant issue from risk, and  
7 he can move on without putting more resources into it based  
8 on that bounding assumptions.

9 So it could help the inspector out to move on,  
10 where, in the past, we might have pursued an issue to the  
11 end.

12 Now he can step back and say, hey, this is not  
13 risk significant, the licensee is addressing it, and he can  
14 move on to other issues.

15 But Sonia and I would work with inspectors, if they have an  
16 issue they believe, with some of their conservative  
17 assumptions, is going to come out to be potentially risk  
18 significant, then we'll try to make sure that we can  
19 validate those assumptions.

20 DR. APOSTOLAKIS: It appears, then, from your  
21 answer, that item number two would be affected, as well, in  
22 that you haven't really lost all the flexibility that you  
23 thought you had lost.

24 MR. DAPAS: Let me comment on that. This gets  
25 back to Dr. Powers' point about inspector flexibility. One

1 of the things that, in Region III, we have attempted to  
2 communicate to the resident staff, as well as the regional  
3 inspectors and DRS, is that we've put people out in the  
4 field that we think have mature judgment, have experience,  
5 and if an issue that the licensee identifies or that we  
6 identify doesn't comport with your internal risk meter, you  
7 think there are issues there, we should ask those questions.

8           And as you screen that through the SDP and you  
9 look at the different assumptions, to understand why or why  
10 that is not a risk significant issue, and that's feedback  
11 that we would provide to the program office, if we think  
12 that the SDP should have an allowance to ensure that this  
13 issue screens out.

14           And that's got to be well supported, but that's  
15 where, in my view, the inspector judgment is brought to the  
16 table and says I think this is reflective of the licensee  
17 performance and I think we ought to have a way in our  
18 process to capture that.

19           Now, that might be in the context of a  
20 cross-cutting issue, that might manifest itself in a change  
21 to the SDP, but it gets back to we continue to refine this  
22 and we look at lessons learned, is there a particular issue  
23 that may be screened out as green that subsequently does  
24 manifest itself as a problem before you see a performance  
25 indicator threshold change.

1           We need to go in and look at that and say does  
2 that mean that the SDP needs to be modified. So I look at  
3 it as a continuing work in progress.

4           DR. APOSTOLAKIS: Now, this is done here, right?  
5 The SDP.

6           MR. PARKER: The phase one and phase two would be  
7 done at the sites or with the regional inspectors or with  
8 the resident inspectors and if it screens out to be  
9 potentially risk significant as far as the colors go, then  
10 Sonia and I would be involved with those activities at that  
11 time.

12           But we might be working with inspectors up front  
13 because they have some questions or difficulty.

14           DR. SIEBER: We had heard testimony a couple  
15 months ago about an incident at a plant, not in Region III,  
16 where the significance determination process was used by the  
17 staff and it screened green. On the other hand, there were  
18 two orders of magnitude difference between the staff's  
19 opinion of risk and the licensee's opinion of risk.

20           Are you prepared somehow or other to deal with a  
21 contest like that?

22           MS. BURGESS: The agency is part of the process of  
23 validating the SDPs. We've done the first phase, where  
24 we've actually sat down with the licensee and looked do we  
25 have the right mitigating systems down, have we implemented

1 everything in your updated PRA.

2           The second portion of the validation is we would  
3 be going to the site with scenarios of a green-white  
4 threshold, something that would be -- an issue that would  
5 put it in a white issue, a potential risk significant issue,  
6 and we will have the licensee run it through their risk  
7 program, computer program, to see if they get the same  
8 answer.

9           We will also be looking for things that trip the  
10 green-white threshold from the licensee's computer program  
11 and then use our SDP to say are we getting a green-white  
12 threshold or are we still in the green and if we are in the  
13 green, yes, we do have a problem, we have non-conservative,  
14 and that's what we're trying to avoid.

15           DR. SIEBER: I think part of the problem there was  
16 not so much is the model correct or the process correct, but  
17 how the model was applied to this particular instance.

18           MR. PARKER: That's possible and that's what I  
19 think the new process makes -- makes it a little bit more  
20 comfortable, that we're supposed to be entertaining and  
21 having dialogue with the utility more sooner than we would  
22 in the past, where we would -- on a potential phase two, the  
23 residents, the senior reactor analysts will be talking with  
24 the PRA organization to try to understand how they've  
25 modeled it, they have more sophisticated models, and what

1 did we miss or what perspective didn't we consider or that  
2 we might have inappropriately considered.

3 So we're trying to have that before we get to any  
4 escalated activities in those areas.

5 DR. SIEBER: Have you and the industry agreed on a  
6 set of rules as to how these things will be modeled or is  
7 this a case by case basis?

8 MR. DAPAS: Again, the SDP, I think, to answer  
9 your question, is a tool that the agency is using to  
10 determine the significance of findings, and we want that to  
11 be sufficiently conservative that we don't screen out  
12 something that has risk significance.

13 My experience with the pilot program and listening  
14 to discussions with sites and other regions involved in the  
15 pilot program is we concluded that an issue, say, was of  
16 white significance based on our application of the  
17 significance determination process. The licensee brought  
18 more detailed risk information to the table, with maybe a  
19 more sophisticated model, with different assumptions, where  
20 they had concluded it's not that significant.

21 So I've seen more examples of that versus --

22 DR. SIEBER: This is the one I cited as an example  
23 of that and I see that coming to a contest someplace down  
24 along the line if you get into civil penalty areas.

25 MR. DAPAS: But before we go there, before the

1 agency is going to make a final risk determination, we  
2 afford the licensee an opportunity to engage us and explain  
3 here's the results of our analysis, and that's where the  
4 senior reactor analyst gets involved in phase three.

5 It essentially affords the licensee an opportunity  
6 to bring their risk expertise and assessment to the table  
7 and we would consider that. But ultimately we would have  
8 responsibility for rendering a decision on the significance  
9 and then take appropriate action, per the action matrix,  
10 which, again, be it a white issue or yellow issue, doesn't  
11 get into civil penalties. It gets into is it a cited or  
12 non-cited violation, if it's a regulatory requirement.

13 MR. PARKER: I think the burden is on us right  
14 now, though, and we need to be very careful in using SDP.  
15 As Sonia pointed out, we haven't validated it yet with the  
16 licensees. So it's a licensee -- if we have differing  
17 results, we need to step back and look at the reasonableness  
18 of theirs and why we have that discrepancy and make sure  
19 we're working with the program office and experts and the  
20 practitioners back in headquarters.

21 DR. SIEBER: There is some uncertainty, which  
22 could be quite large, going into all these things. The  
23 question is, is it really different or is the uncertainty so  
24 large that they actually overlap. That's the problem you'll  
25 have to deal with.

1           MR. DAPAS: And I think that's one of the most  
2 important aspects when the licensee brings their risk  
3 assessment to the table, is understanding the bounds of  
4 uncertainty and that gets back to the assumptions; that any  
5 risk conclusion is a function of the assumptions and that's  
6 something I think we wrestle with is the uncertainty.

7           DR. SIEBER: I see that as a challenge.

8           MR. DAPAS: Right.

9           MR. GROBE: I went to get back to the flexibility  
10 question, because I think that's critical to the ability of  
11 our programs to be predictive, and they're no longer  
12 predictive, and I'll use a case study, one that I'm familiar  
13 with, D.C. Cook.

14           D.C. Cook would have been green and for years they  
15 would have been green. Yet, we were never comfortable with  
16 their performance and particularly in the engineering area,  
17 and we applied a number of -- and this also gets to, I  
18 think, your question on lessons learned.

19           We applied a number of special inspections over a  
20 period of three to four years, including an operations  
21 safety team inspection, what we called a system operations  
22 performance inspection, which had an engineering emphasis,  
23 and then we re-allocated one of our architect engineering  
24 inspections to Cook, because we still weren't comfortable.

25           And it wasn't until we did that that we found the

1 issues. Those wouldn't have been found and they wouldn't  
2 have been revealed, I don't believe, through our PIs, at  
3 least looking back in history.

4 There was a number of risk significant issues that  
5 were found after the plant shut down. This is some of the  
6 soul-searching we did and it was emphasized by Chairman  
7 Jackson at the time that we do this.

8 And we did two things, the lessons learned  
9 specifically on our inspection programs in the area of  
10 surveillance, because we didn't find the problems with the  
11 ice condensers at Cook, and it had to do with the way in  
12 which we were doing some surveillance testing activities.

13 But more importantly, from a programmatic point of  
14 view, we looked at how we were looking at engineering and  
15 that really resulted in a safety system design inspection.

16 We did not have as strong a design engineering  
17 emphasis in our program as we do today under the new  
18 program.

19 So hopefully that new design engineering emphasis  
20 will help us reveal problems like Cook that we didn't find,  
21 and didn't find until we did the architect engineering  
22 inspection.

23 MR. DAPAS: Just to clarify, we did do a  
24 feasibility study that looked at the inspection issues at  
25 Cook and what would that result in terms of the action

1 matrix, but as Jack said, taking that back one step, would  
2 the baseline program have resulted in the identification of  
3 those issues in order to assess the significance, and I  
4 think that's, as he pointed out, the genesis of a more  
5 comprehensive look at design via the safety system design  
6 inspection, because there is the recognition that  
7 performance indicators don't provide you the information you  
8 need to really get a good assessment of engineering  
9 performance.

10 DR. SIEBER: Now, one of the industry initiatives  
11 is to change 303, I guess, so that you can change modes with  
12 something inoperable. And if you had an incident at a plant  
13 or a condition that's screens green and the licensee shut  
14 down, you now would have lost another tool to keep them down  
15 until they fixed everything, before they start up again.

16 What would you do in that instance?

17 MR. DAPAS: I'm not sure I fully follow the  
18 question.

19 MR. GROBE: Right now, if the licensee finds  
20 themselves in a situation where their technical  
21 specifications cause them to do something that is  
22 unnecessary, we have a process for dealing with that, the  
23 enforcement discretion process, and risk is a big  
24 contributor to that decision-making.

25 I'm not aware of this initiative to do away with

1 303.

2 CHAIRMAN BARTON: It's 304.

3 MR. CALDWELL: But that would require a change to  
4 the tech specs. I mean, if the agency decided to allow them  
5 to change modes without certain pieces of equipment, then  
6 you're right, we would not have a dog in that fight. We  
7 wouldn't be able to restrict them from starting up because  
8 of that particular component.

9 But as far as I know, that hasn't occurred yet.

10 DR. SIEBER: I'm thinking about where we should be  
11 coming from as this issue matures.

12 MR. DAPAS: The tech specs, as I understand, are  
13 to prescribe which equipment is -- whose operation is  
14 important to assure you can respond to any kind of transient  
15 or impact on the plant.

16 So if equipment is included in tech specs, the  
17 operability of that is --

18 DR. SIEBER: Where it is now is where it would be.

19 MR. DAPAS: Right.

20 MR. GROBE: Philosophically, it should be  
21 risk-informed, right?

22 MR. DAPAS: Right.

23 MR. GROBE: In which case, mode changes with risk  
24 significant equipment out of service shouldn't be committed.

25 MR. CALDWELL: I guess the big concern here would

1 be if we did it generically. I think each plant would have  
2 to say they're -- not get rid of 304, but to actually pick  
3 out the components they think are no longer required for  
4 specific modes and then you would have to do a risk analysis  
5 for each of those components.

6 And if the agency were to agree, if the industry  
7 came in with a proposal that we shouldn't have mode  
8 restrictions based on equipment, then that would be a big  
9 concern, because you wouldn't have analyzed each component  
10 to see if it had a risk significance.

11 DR. SIEBER: The problem there is that most of  
12 those occur between the mode four and the mode three.

13 MR. CALDWELL: Right.

14 DR. SIEBER: Which there's not very many PRAs out  
15 there for that. So what do you use for the tool?

16 MR. GROBE: It's an interesting question, because  
17 most of the safety systems are required at mode four and yet  
18 they're not necessary to mitigate an accident at that mode.

19 MR. CALDWELL: But they -- you're right. It would  
20 be a philosophical discussion, because it is now a tool and  
21 a lever to make sure the plant is completely back in  
22 operation prior to changing modes.

23 If you allowed folks to wait until the exact time  
24 when he component was needed, then you're running up against  
25 clocks and some people would put it off to the last minute

1 and others wouldn't.

2 Right now it works pretty good because licensees  
3 know, in their outage, that in order to come out of the  
4 outage, they have to have everything back and working.

5 DR. SIEBER: Right. There's no way out.

6 MR. CALDWELL: It's been, I believe, successful in  
7 terms of plants are operating better coming out of outages  
8 now than they had in the past.

9 DR. SIEBER: I agree.

10 MR. DAPAS: Moving on to, I guess, insight number  
11 four that we offer regarding the new program compared to the  
12 old program. The old program involved more direct  
13 observation of plant activities. Under the new program,  
14 there is an increased emphasis on inspection preparation and  
15 office review, with, of course, the exception of testing,  
16 where we do continue to have a number of direct  
17 observations.

18 I'll give you an example, like maintenance. Under  
19 the old program, we might observe the maintenance activity,  
20 like a pump rebuild, was the work procedure sufficiently  
21 comprehensive, are the steps being followed, et cetera.

22 Under the new program, we focus on has the  
23 licensee conducted a risk assessment for that particular,  
24 say, on-line maintenance activity. We would evaluate the  
25 effectiveness of that risk assessment and licensee control

1 of the maintenance activity.

2 And I thought Laura Collins, who actually has been  
3 an inspector under both the old program and then involved in  
4 the pilot program, could maybe give another example in terms  
5 of the maintenance rule, because I know there were some  
6 questions that.

7 MS. COLLINS: We actually have two procedures that  
8 we look at maintenance. We have one that is called  
9 maintenance rule implementation and we have one I will talk  
10 about later, which is sort of our evaluation of their  
11 on-line risk assessments.

12 Under the maintenance rule one, which is the  
13 resident inspectors' largest number of samples and largest  
14 number of hours, that is largely a review of equipment  
15 problems that they have had and how they've dealt with them  
16 under the maintenance rule, and that's quite a bit different  
17 from our previous maintenance observation kind of inspection  
18 that Mark talked about.

19 So to me, that's a big distinct difference right  
20 there in the area of maintenance.

21 The other one is the area of operations, which we  
22 largely reviewed routine operations. Now we focus more on  
23 non-routine evolutions and don't look so much at the routine  
24 operations.

25 So those are just two examples of how we're not

1 directly reviewing routine activities in the field.

2 DR. SIEBER: And that means much less observation  
3 of activities and more going through papers.

4 MR. DAPAS: The focus has shifted a little. It's  
5 understanding the licensee's evaluation of risk associated  
6 with that activity, their control of that particular  
7 activity.

8 Inspection preparation, the inspectors need to  
9 understand the risk importance of a particular structure,  
10 system or component, or evolution that's being selected for  
11 the sample, and that's where there may be more preparation  
12 involved in saying, okay, here is a specific testing  
13 evolution I'm going to observe because it's important from a  
14 risk standpoint, and then the preparation involved with  
15 going out and reviewing that activity.

16 But where that presents a challenge, that I'll  
17 talk about a little later, is the licensee may be planning  
18 to do a surveillance test tomorrow evening. The resident  
19 inspector spends time getting ready to observe that and then  
20 it's deferred and the inspector was planning to do another  
21 activity on Thursday of that week.

22 And we selected that specific surveillance test  
23 because it's more risk significant, where, under the old  
24 program, you could just pick another surveillance test and  
25 observe that.

1           The risk importance was less of an issue, and  
2 that's where it impacts inspection planning and resource  
3 utilization.

4           MR. GROBE: We're getting way behind schedule. I  
5 wanted to make one more observation regarding observation of  
6 activities. In addition to some of the resident issues, in  
7 the plant support area, EPHP and safeguards, it's had a very  
8 significant impact.

9           You can do the new safeguards inspection program  
10 from the guard shack. You don't even have to go into the  
11 plant. In the area of health physics, much fewer activities  
12 being observed in the plants as far as how they're  
13 controlling the activities from a radiological protection  
14 point of view.

15           In the EP area, during the programmatic inspection  
16 it doesn't require you to go into any of the emergency  
17 planning facilities. So you don't actually observe whether  
18 the facilities are in a state of readiness.

19           A lot of these are compensated for through the  
20 PIs, the performance indicators, but in some cases, not very  
21 well.

22           So there has been a shift from reviewing  
23 activities that have already occurred through looking at the  
24 paperwork to -- and away from direct observation in the  
25 plant.

1 DR. SIEBER: How do you feel about that?

2 MR. GROBE: Our inspectors are not as comfortable  
3 with that as they were in the past.

4 DR. WALLIS: I'm wondering of the public would be  
5 as comfortable with that.

6 MR. GROBE: It's a new program and it's dependent  
7 on multiple prongs. One of those prongs is performance  
8 indicators and another one is effectiveness of the  
9 licensee's corrective action system. So we're putting our  
10 eggs in different baskets and we need to see how it works.

11 MR. DAPAS: But, also, when you look at the  
12 particular inspection procedure, there's associated  
13 objectives which are supposed to result in our acquiring the  
14 information we need, and that can be arrived at via direct  
15 observation or review of, for example, the licensee's  
16 control of the maintenance evolution.

17 The key is do you obtain the information you need  
18 to make an informed judgment, from my perspective.

19 MR. CALDWELL: There is an ongoing feedback  
20 process. These particular issues that Jack talked about are  
21 issues that we've fed back to the program office and will  
22 continue to feed back.

23 So I expect to see some changes to the program  
24 after the first year of implementation. So maybe a year  
25 from now, we can talk about it again and see where we come

1 out on this. These are just early observations.

2 DR. SIEBER: Have you made your thoughts known to  
3 the headquarters?

4 MR. CALDWELL: Certainly.

5 MR. GROBE: We do that and we've been rather  
6 proactive I that regard. I think we've pretty much covered  
7 item number five. Why don't we go on to item six.

8 MR. DAPAS: Regarding inspection resources, as  
9 we've touched upon, there was more flexibility under the old  
10 program, in a couple aspects.

11 In addition to the inspection scope, where we  
12 talked about how prescriptive that can be under the new  
13 program, we had more opportunity with use of regional  
14 initiative, we had N+1 inspector, where you could use that  
15 particular inspector to conduct some regional initiative in  
16 the area of operations. There was more flexibility with  
17 tapping DRS engineering resources to go out and do some  
18 regional initiative inspection.

19 Now, under the new program, that DRS resource and  
20 that former N+1 resource, which now may be assigned to the  
21 region, is fully encumbered by the new program. So there's  
22 less flexibility in that regard, which, of course, again,  
23 was by design with the new program and the inspection scope.

24 But when you have extended absences or vacancies,  
25 that requires back-filling the complete program, and so that

1 results in a greater degree of sophistication in inspection  
2 program management. The branch chiefs out in the audience  
3 can tell you that they have to plan hours in detail for,  
4 say, a six-week inspection period so they can readily  
5 identify where there are holes and you can't -- you can only  
6 defer some inspection to a limited degree, because that  
7 creates the bow-way that you're going to have address during  
8 the next inspection period.

9           And when you have sample size ramifications, the  
10 number of activities that you need to look at per month,  
11 that's where that becomes an issue.

12           So we have to have contingency plans in place if  
13 we're going to support a rotational assignment to another  
14 program office or we've got a vacancy at a particular site  
15 because the individual left for a promotional opportunity or  
16 reassignment to the region.

17           In order to implement the new program, we've got  
18 to have two fully engaged people at the site. There is some  
19 flexibility there, but not a lot. Frequently, you will hear  
20 a branch comment that I need some help during this time  
21 period because inspector X is going to be involved in this  
22 activity, and it causes us to continually focus on what are  
23 our priorities and what we can support, because we don't  
24 have the latitude right now of saying that we have completed  
25 the baseline program with this amount of inspection, like

1 you could under the old program with the core inspection  
2 hours.

3 MR. GROBE: I think as far as public awareness, we  
4 are greatly aware that the public is taking opportunity,  
5 taking advantage of the web site information that's  
6 available to them. The PIs are on the web. Our inspection  
7 reports are in the web, and that is a significant  
8 improvement over the --

9 DR. WALLIS: It's on the web. Do you have a way  
10 of counting how many people -- how many times it's actually  
11 looked at?

12 MR. GROBE: Actually, Augie Specter counts it and  
13 reports on it regularly, in thousands of hits. I can't  
14 remember what the numbers are.

15 DR. WALLIS: They actually stay with it. They  
16 don't just hit and leave.

17 MR. GROBE: The question I got is how many of  
18 those were Augie logging on. But he's counting those. And  
19 I headed a public meeting out at Cook, a lady who called  
20 herself Auntie Nuke, who had downloaded a lot of stuff off  
21 the web. So the public is taking advantage of it.

22 DR. POWERS: One of the things I find -- items  
23 that show up that say, in effect, management is very well  
24 prepared for the safety review, to be as helpful for me to  
25 understand the plant as those that say the operators didn't

1 handle the jumper control very well.

2 The upside and the downside are very valuable to  
3 me. Now it sounds like the upside is going to be  
4 disappearing.

5 MR. GROBE: No, it's gone.

6 DR. POWERS: It's gone. And somehow I worry about  
7 the communication aspect, to me and everybody else.

8 MR. GROBE: We all shared your concerns, but it  
9 was the view of the industry that that's what they wanted  
10 from the standpoint of communication in our inspection  
11 report, and, by definition, that's what goes into the PIM  
12 and goes onto the web.

13 MR. CALDWELL: Well, our observations and findings  
14 that go into the PIM are supposed to be risk-informed and  
15 it's very difficult to risk-inform the positive. So you  
16 wouldn't be able to do what you might like to do, and that's  
17 come up with a balance. But a positive comment would weigh  
18 as heavily as a yellow or a white finding, in which case a  
19 positive comment may have little or no safety significance.  
20 There is no way to evaluate that.

21 So the decision was made to just --

22 DR. POWERS: Philosophically, George, I think he's  
23 hit upon a flaw in this PRA technology.

24 DR. APOSTOLAKIS: No, it has not been used.

25 DR. POWERS: It only gives us good ways to

1 quantify the negative and no good ways to quantify the  
2 positive.

3 DR. APOSTOLAKIS: That's what we have done so far,  
4 but one can actually say that because they're doing such and  
5 such, the human error probabilities that were assumed in the  
6 past are actually lower, so there's a positive impact on  
7 plant safety, or that the failure rates are expected to be  
8 on the lower side.

9 DR. POWERS: Your problem is one of communication,  
10 George.

11 DR. APOSTOLAKIS: Why?

12 DR. POWERS: That I can understand, well, a number  
13 going from three to four, as in  
14 times-ten-to-the-minus-fifth.

15 DR. APOSTOLAKIS: But not from three to two?

16 DR. POWERS: But the other way, the positive -- I  
17 mean, how do I understand going from 99 to 99.9?

18 DR. APOSTOLAKIS: It's just that we've never used  
19 it that way.

20 DR. POWERS: That's right.

21 MS. BURGESS: But I think you can understand that  
22 if a licensee puts -- adds another diesel, then I think  
23 everyone can understand they have decreased their risk. So  
24 those kinds of things can be put into our report.

25 DR. POWERS: He tells me all the time that I can't

1 assume they've decreased their risk.

2 DR. APOSTOLAKIS: I think that's a good point, but  
3 we can say something. The thing is we've never attempted to  
4 say how improving things, if we're finding the good things.  
5 I wanted to say something, but Dr. Powers destroyed my  
6 thinking.

7 DR. POWERS: I've been successful again today.

8 CHAIRMAN BARTON: Yes. Before this deteriorates  
9 further, do you want to continue?

10 DR. APOSTOLAKIS: He probably can't even remember.  
11 If everything is green, that is a message, right?

12 DR. POWERS: I insist that that's a degraded  
13 message.

14 DR. APOSTOLAKIS: And that's why people are trying  
15 to --

16 DR. POWERS: When everything is green, then you  
17 start looking at what are the shades of green and you see  
18 these things where guys plot where they lie on the green  
19 band and people start paying attention to that and not  
20 paying attention to the fact that it's green.

21 MR. GROBE: What's interesting is green is not  
22 good. A green finding is a finding. If you have 100 green  
23 findings, that's not better than having one green finding,  
24 that's worse, because that might be indicative of a systemic  
25 problem.

1           And the colorization, I have a lot of problems  
2 with these colors.

3           DR. SEALE: Amen.

4           DR. APOSTOLAKIS: So the ideal is no findings.

5           MR. GROBE: Well, no. If we have no findings, my  
6 concern would be that the inspection program is not  
7 functioning effectively.

8           MR. CALDWELL: The idea should be that we're an  
9 active regulatory body, we're inspecting, we're having  
10 findings. The findings are not such that it's outside of  
11 the industry response band, which means it's staying within  
12 a band that we're allowing them to correct their problems.

13           That is a plus or minus, however you want to look  
14 at it. If they drop out of that band, then people can ask  
15 questions about their safety.

16           DR. APOSTOLAKIS: But this raises, again, an issue  
17 that is a favorite of mine. I've raised it several times,  
18 but I don't know that I got a response.

19           CHAIRMAN BARTON: So you're going to try again  
20 anyhow.

21           DR. APOSTOLAKIS: Yes. What is the purpose of  
22 these inspections? I mean, there are two alternatives, in  
23 my mind. One is to make sure that the risk profile of the  
24 plant, as we're understanding through the IPE and PRA,  
25 remains the same, especially hasn't shifted upwards. So

1 that's a plant-specific finding or determination.

2 The other is to look at it as one unit in the  
3 population of 103 units and see whether you are -- I mean,  
4 that particular unit is within the industry norm or it's a  
5 percentile. These are two very different things.

6 And the third one, I guess, is to make sure that  
7 the licensing basis is still met, which is not -- it is  
8 related to the risk profile, but it's not the same thing.

9 And I'm not sure that the designers of this  
10 process really articulated very well what their objective  
11 was. In some instances, I get answers that, yeah, it's  
12 industry-wide, we're very interested in what's happening, is  
13 this an outlier or not. In other cases, no, we really want  
14 this plant to remain the way it was risk-wise.

15 So what, in your opinion, is the objective of all  
16 of this? I mean, we have a risk profile, we have in the  
17 PRA, you do all these determinations such as PIs and the  
18 action matrix and so on, because that's related to the green  
19 now, because if everything is green and I can conclude that  
20 the risk profile has not changed, then things should be all  
21 right.

22 Because then I get into the business of how many  
23 greens do I have, how many findings, one versus 100.

24 MR. GROBE: Possibly. I wouldn't suggest you  
25 count findings, but what's important is to understand the

1 root cause of the findings and what that root cause can do  
2 to the risk profile.

3 DR. APOSTOLAKIS: So the potential for getting out  
4 of the green.

5 MR. GROBE: Exactly.

6 DR. APOSTOLAKIS: That's what you worry about.

7 MR. GROBE: Exactly.

8 DR. APOSTOLAKIS: But have you any idea as to what  
9 the intent of the oversight process is?

10 MR. DAPAS: Both aspects are addressed. When you  
11 have a particular inspection finding, that's got to be  
12 placed in the appropriate context of a given plant  
13 configuration. You have to bring plant-specific PRA  
14 knowledge to bear.

15 I think the performance indicators address that  
16 across the industry, where if we set a threshold for number  
17 of scrams that would result in regulatory engagement, that  
18 threshold is a function of overall industry performance.

19 DR. APOSTOLAKIS: And it shouldn't be, in my view.

20 MR. DAPAS: That may be a few, but that's at least  
21 my understanding of the intent of the program.

22 DR. APOSTOLAKIS: The inspection findings are  
23 plant-specific, but the PRAs are --

24 MR. DAPAS: Well, the PI is plant-specific, if you  
25 will, in terms of you had scram X, you had transient X, but

1 the threshold --

2 DR. APOSTOLAKIS: It's an industry --

3 MR. GROBE: And the same thing with inspection  
4 findings in the SDP. The base risk profile of a plant might  
5 be five-ten-to-the-minus-five, it might be  
6 one-ten-to-the-minus-seven, but the threshold for a green  
7 finding is ten-to-the-minus-six, no matter what the base PRA  
8 of that plant is.

9 DR. APOSTOLAKIS: But, you see, the fact that the  
10 thresholds are so high has made the utilities themselves to  
11 have more stringent plant-specific thresholds for internal  
12 use.

13 MR. DAPAS: Right. And the reason for that is  
14 because we told the industry they shouldn't be using our PIs  
15 to manage their plant. I would expect them to have more  
16 restrictive, if you will, indicators so that they can  
17 address problems before it does cross the threshold.

18 MR. CALDWELL: That goes back to what Marc had  
19 mentioned earlier. The basis of this program is an  
20 effective problem identification and corrective action  
21 program on the part of the licensee. So they have to have  
22 in place their performance indicators or whatever they think  
23 is necessary to identify their problems early and resolve  
24 them before they become bigger issues.

25 That is what we are relying on. We have to see

1 now if that works or not by implementing this program and  
2 see how well the licensees' corrective action programs --  
3 how effective they are.

4 DR. BONACA: But you said before that D.C. Cook  
5 would have been all green.

6 MR. GROBE: It was all green.

7 DR. BONACA: So there would have been no signal  
8 coming from the indicators for action. So does it mean that  
9 the action at D.C. Cook was successive or does it mean that  
10 the indicators really have been a big help?

11 MR. CALDWELL: I missed that conversation. I  
12 think Jack is saying the performance indicators may have  
13 been all green. I'm not sure our inspection findings would  
14 have been all green. Our inspection findings likely would  
15 have been something other than green.

16 DR. BONACA: So you didn't check for that.

17 MR. GROBE: No, we did. We ran all the LERs and  
18 findings prior to the outage through the -- at that time, it  
19 was a very preliminary draft SDP, and didn't come up with  
20 any significant findings.

21 I don't know if we came up with any whites, but it  
22 wasn't until after the outage that you started seeing  
23 yellows and reds.

24 The point I was trying to make was that the level  
25 of resource expenditure that we put into Cook, we would not

1 be able to do today. And somebody earlier mentioned that  
2 the program is more indicative than predictive, and that's  
3 true. We have less capability of being predictive, unless  
4 the thresholds are crossed with a specific finding.

5 MR. DAPAS: And that gets back to, if you recall,  
6 our discussion with the Commission. One of the fundamental  
7 premises that the industry proposes is that performance  
8 indicators would be crossed, threshold changes before there  
9 is a significant programmatic concern that manifests itself.

10 Right now, I think there are some differing  
11 schools of thought and that's why the role of cross-cutting  
12 issues, I think, has played such -- the importance of that  
13 has been elevated.

14 There is a task force that's looking at human  
15 performance and corrective action programs and safety  
16 conscious work environment, cross-cutting issues, because  
17 not everyone full ascribes to this tenet that you will see  
18 performance decline clearly manifested in the PIs before you  
19 see risk significant inspection findings.

20 DR. POWERS: The committee has advised the  
21 Commission that we consider that an assumption that needs to  
22 be validated. You're only reinforcing that opinion.

23 MR. GROBE: The lunchroom across the way gets busy  
24 at around noon.

25 MR. CALDWELL: What we're doing is we're having --

1 they're bringing over sandwiches and some salads.

2 CHAIRMAN BARTON: We'll just keep going then.

3 MR. CALDWELL: So I can let you know, it's \$10 a  
4 person, and we should be bringing -- we'll bring a table in  
5 right behind here and you can go over and pick up and eat as  
6 you wish.

7 CHAIRMAN BARTON: Excellent. I'd like to get  
8 through the SRA process before lunch, then we can take a  
9 break, if we can get to it.

10 MR. DAPAS: I've just got one point left to make  
11 on the public awareness. I think clearly there has been a  
12 public outreach effort associated with the new program,  
13 industry workshops, et cetera, which I think is a positive  
14 initiative.

15 We have touched upon the DRP --

16 DR. WALLIS: Well, public outreach, how broad is  
17 the public that gets involved? Public outreach, how broad  
18 is the public involved?

19 MR. DAPAS: We've invited, like, for example, when  
20 we've conducted meetings on the new program and we're going  
21 forward with meetings at each of the sites within six months  
22 of initial implementation. Certain officials, et cetera,  
23 we're inviting, but it varies, the degree of public  
24 attendance.

25 We're trying to advertise that via web and other

1 communication forums, but it does vary.

2 MR. GROBE: We don't see a lot of public awareness  
3 -- public involvement.

4 MR. DAPAS: It depends on the site.

5 DR. WALLIS: Public should not consist only of  
6 people with some personal interest, like an economic  
7 viability of their plant.

8 MR. DAPAS: Right. Right.

9 MR. CALDWELL: It's strictly -- I think it's  
10 strictly related to how interested the surrounding area is  
11 in that plant and most of our plants do not have active  
12 public involvement. So when we have these meetings, they  
13 are not widely attended.

14 But we do put out a lot of announcements to that  
15 effect and people could attend, if they wanted. And I  
16 suspect if there was an interest, like one of our  
17 facilities, Prairie Island, there's an interest in dry cask  
18 storage. And so we always get a pretty good attendance at  
19 those. But it's really related to how well the public - I  
20 look at it this way. If you don't get a lot of public  
21 attendance, that means that they feel comfortable with that  
22 plant as it is.

23 Otherwise, they would be coming to the meeting to  
24 try to understand or express their views.

25 MR. DAPAS: My comment was more in the context of

1 the old program, where really the only public outreach, I  
2 would offer, was a meeting to discuss SALP results, versus a  
3 more concerted effort.

4 I've touched upon some of the DRP challenges here.  
5 One of the challenges we face, of course, is feedback and  
6 dissemination of lessons learned on the new program as we  
7 attempt to further revise that, and there's a number of  
8 forums for doing that.

9 We've got feedback forms, weekly conference calls  
10 with the program office, inspector seminars, and then, of  
11 course, DRP/DRS counterpart meetings, where Jack and Mike  
12 and Geoff Grant attend to discuss some issues with the new  
13 program.

14 DR. WALLIS: One measure of success might be that  
15 there were lessons learned which were useful when you  
16 actually look back at it.

17 MR. DAPAS: Right. Which gets into the  
18 self-assessment area. We have been given an opportunity to  
19 weigh in and comment on the self-assessment plan  
20 development, which includes appropriate metrics, and this is  
21 in support of the IOU we have to the Commission to evaluate  
22 the new program and report to the Commission in June.

23 And headquarters is currently involved in our  
24 inspection report review to help ensure consistency and we  
25 do plan public workshops to obtain feedback, which was

1 fairly well received in the pilot program.

2 Unless there are any questions, that pretty much  
3 summarizes DRP's involvement in the new and old programs.

4 MR. GROBE: Let me just highlight one challenge  
5 that we're going to be talking about a little more later, I  
6 hope, in the Division of Reactor Safety. There's a number  
7 listed here, but the one that's most significant for us is a  
8 change in required expertise.

9 We depended heavily on contract resources when we  
10 needed design expertise in the past. We no longer have the  
11 financial resources to procure contract resources in that  
12 area.

13 So that's a challenge for us. It's a staffing  
14 challenge. It's a recruiting challenge, and we're trying to  
15 meet that and we'll get into some more detail later.

16 The other issue is risk analysis capability and  
17 why don't we just go right into the risk presentation that  
18 Sonia has prepared.

19 MS. BURGESS: Here's a little background. In  
20 October of 1995, the SRA position was developed to assist  
21 the agency in transitioning to a new risk-informed arena in  
22 the way we do business.

23 I don't believe that in 1995 the Commission  
24 realized what a large leap we were going to make ultimately  
25 into getting our whole process into the risk-informed arena.

1           Fortunately, when the transition, the pilots, the  
2 new reactor oversight pilot program started, the SRA program  
3 was fully staffed in all of the regions and we were fully  
4 trained and qualified and certified.

5           I think that has been a big asset in the success  
6 we have had in implementing the new reactor oversight  
7 process.

8           Some of the bullets highlighted here are just some  
9 of the key things that we do here in the region. Our  
10 biggest role right now is to support the new oversight  
11 program.

12           We were very much involved in the development and  
13 the implementation of a pilot process here in the region and  
14 we sat on a lot of committees, helped in reviewing many  
15 procedures, things of that nature.

16           Our main support now is in the SDP arena. As has  
17 been brought up, Mike and I have visited every site in our  
18 region, because we think it's imperative that these SDP  
19 tools that we have been giving to the inspectors are  
20 accurate, that the licensee agrees that they're accurate,  
21 and that they are -- although simplified, they are the best  
22 tool that we have produced to date.

23           DR. POWERS: The question that often comes up, to  
24 my mind, is the scenarios they have are very simplified.  
25 Are they simplified by intent or out of necessity?

1 MS. BURGESS: The scenarios on the SDP worksheets,  
2 like the loss of off-site power?

3 DR. POWERS: Right.

4 MS. BURGESS: I think, yes, they're definitely  
5 simplified out of necessity. We certainly do not have the  
6 resources of the capability to model 50 initiating events  
7 and that's typical of a licensee's own PRA analysis. So we  
8 have narrowed it down to probably ten to 12 initiating  
9 events. Has there ever been a demonstration that -- with  
10 some rigor -- that narrowing it down to these ten or 11  
11 events constituted an adequate description of the risk  
12 profile of the plant?

13 DR. POWERS: Yes. And in our site visits, along  
14 with the other regions, these scenarios, these initiating  
15 event scenarios have captured the majority of the risk  
16 contribution from their PRAs.

17 MR. PARKER: I would also add that we started out  
18 with, I think, four to six initiators and we did some pilot  
19 activities with the program office. One of them was one of  
20 our plants in the region.

21 We went there and tried to do some V&V by taking  
22 some scenarios, some major systems and correlating it with  
23 the licensee's PRA and we found some non-conservative in  
24 ours, where the licensee identified it as a fairly high risk  
25 activity.

1           And that's where we had to step back, as an  
2 agency, and I think it set us back several months, trying to  
3 identify additional initiators that were necessary to truly  
4 capture the majority of the risks, as Sonia says, that we  
5 are right now, that we were able to pick that up.

6           DR. POWERS: I might be willing to concede they  
7 captured the CDF. The question is, did they capture the  
8 risk.

9           MR. PARKER: That's some of the -- I mean, right  
10 now, what we're looking at is internal events and some of  
11 the difficulty we have in using the tool is we don't have an  
12 effective tool in place for containment, for shutdown, for  
13 external events. So there's a lot of -- the majority of the  
14 risk is still being captured through screening tools that  
15 we're trying to put in place right now and when we have  
16 those type of issues, that Sonia and I have to get involved  
17 with it, we have to get involved with the licensee's IPEEE,  
18 and we have to work with headquarters in a lot of cases if  
19 it involves external events, it's just a screening basis in  
20 IPEEE.

21           So we might not be able to capture all that  
22 ourselves.

23           MR. DAPAS: A good example of that is a recent  
24 issue we had at Quad Cities with -- what is it, Marc -- safe  
25 shutdown makeup pump and that being unavailable and how you

1 bring the external event fire risk into play. There's not a  
2 tool used. We used risk achievement worth, I think, and CDF  
3 to come up with an overall risk assessment.

4 We discussed it as part of the significance  
5 determination panel. We communicated that to the licensee  
6 as the most appropriate tool we have right now and then the  
7 licensee is going to come to the table with their assessment  
8 of the risk impact in terms of fire risk.

9 DR. POWERS: So you don't even have things like  
10 five available to you.

11 MR. PARKER: No.

12 MS. BURGESS: No.

13 DR. POWERS: One of the -- an anecdote, to which  
14 I've never had a resolution, is I believe it's Brown's Ferry  
15 that uses ORAM for outage management and they were showing  
16 me how it worked. I know a little bit about ORAM.

17 And they said, well, look for this particular  
18 outage, we set up a configuration that had this red region  
19 and by manipulating things around, we were able to change  
20 the way we did our outage, so that instead of having a red  
21 region and everything else green, we had two orange regions  
22 and everything else green.

23 And I have puzzled and puzzled to understand how  
24 one concludes that two oranges is better than one red.

25 MR. PARKER: That, I think, is some of the

1 difficulty in ORAM, is it's mainly a deterministic tool and  
2 you're looking at defense-in-depth and most utilities don't  
3 have a probabilistic shutdown model.

4 I think some of the plants are going there and we might be  
5 able to look at it a little closer, but you pointed out some  
6 of the difficulties we have with our tools. The licensees  
7 are trying to suppress and reduce their overall risk and  
8 from their perspective, they didn't enter a red, which was  
9 prohibited, and it's very subjective and that's  
10 decision-making.

11 DR. WALLIS: When you compare with the licensee's  
12 PRA, you just compare with the results or you compare with  
13 the details?

14 MR. PARKER: You're talking about SDP?

15 DR. WALLIS: Yes.

16 MR. PARKER: When we're looking at findings?

17 DR. WALLIS: Looking at your model versus the  
18 licensee's. You have a simplified model. How much of his  
19 PRA do you have access to?

20 MR. PARKER: We have very little access to most of  
21 the PRAs, but when we did some of our benchmarking, we  
22 wanted to get the cut-sets and the importance from there so  
23 we can extract that and figure out what were the dominant  
24 cut-sets that were affecting our SDP model.

25 DR. WALLIS: It's a peculiar kind of detective

1 work, or maybe there are some assumptions made that you  
2 don't know anything about.

3 MR. PARKER: That's right.

4 DR. WALLIS: Which is reducing the licensee's  
5 result. Don't you have a way of finding out what they are?

6 MS. BURGESS: Only if there is an issue or a  
7 finding in that. I mean, we don't have a PRA inspection.

8 MR. PARKER: I think you're stepping back to what  
9 I would call the infrastructure. We still haven't even  
10 established a PRA certification. But on the other hand, we  
11 are basing our SDP as closely as we can to the licensee's  
12 IPE or their updated PRA model, and we haven't validated  
13 that model yet.

14 So I understand and appreciate your comment and I  
15 think the agency is pursuing that, but, again, we're  
16 progressing slowly. Maybe there's different things we need  
17 to prioritize in this arena, too.

18 MR. DAPAS: There is a conceptual issue here,  
19 though. I think we -- if a piece of equipment is failed or  
20 unavailable, we run that through the SDP, we communicate  
21 the results of that, then the licensee can bring to the  
22 table more risk-specific information from their PRA.

23 Now, obviously, when we've got an issue and we're  
24 running it through the SDP, the licensee is doing the same  
25 thing, because they understand the SDP, we've communicated

1 to them, 0609 defines specifically what that SDP tool is.

2 If it looks like this is going to screen out as a  
3 white finding, they're rather proactive in communicating to  
4 us their assumptions and what their PRA model says. So  
5 there is that dialogue.

6 DR. WALLIS: Assumption is the key word, because  
7 assumption really is not worth anything unless it can be  
8 challenged and defended. And if there is some mysterious  
9 assumption you don't know about, that's like magic. It's  
10 just like getting whatever you want.

11 MR. DAPAS: We should challenge that.

12 MR. GROBE: Your point is very good, and that is  
13 that we don't know what the assumptions are in the model.  
14 The IPE that the staff reviewed a number of years ago was  
15 many generations earlier than what is currently being used  
16 at the sites.

17 So to a large extent, we have to depend upon the  
18 -- that there has been an intelligent evolution of the model  
19 that the licensees use.

20 DR. BONACA: On the other hand, the event,  
21 whatever you're evaluating, it's a fact. So you know what  
22 you're going to check inside the model. It's not  
23 hypothetical issues.

24 In general, you may question their assumptions in  
25 the model to represent the --

1 DR. APOSTOLAKIS: Do we --

2 DR. BONACA: But now the fact that you have a  
3 specific event happening, it allows you to go back and  
4 verify the assumptions.

5 MR. GROBE: But they don't have it here. Is that  
6 part of the SDP, the phase three?

7 MS. BURGESS: Phase three. Phase three will  
8 challenge the licensee's assumptions, where we're different,  
9 and take a look at what their program does, what their  
10 assumptions are, and the validity of those assumptions.

11 DR. APOSTOLAKIS: What, in your opinion, would be  
12 the ideal tool that should be available to implement a  
13 risk-informed regulatory system, especially the oversight  
14 process? What would you like to have?

15 MS. BURGESS: Personally, I think that some kind  
16 of standard for a PRA is just essential.

17 DR. APOSTOLAKIS: But you would also like to have  
18 a plant-specific PRA on the computer.

19 MR. PARKER: Right now we have safety monitoring  
20 and I guess my perspective is to be able to have access to  
21 the licensee's plant models and be able to manipulate them  
22 and understand them. But we need to start where Sonia says,  
23 that we certify your PRA or have some level of certification  
24 to say this PRA meets certain thresholds and standards.

25 DR. APOSTOLAKIS: Let's take a specific plant,

1 like Davis-Besse. What PRA information do you have?

2 MS. BURGESS: In fact, I was there two weeks ago  
3 to do their SDP worksheets. They have gone through an  
4 extensive PRA update. Prior to my visit, the only thing we  
5 had was what was documented in late 1980s.

6 DR. APOSTOLAKIS: But do you have --

7 MS. BURGESS: We have the docketed IPE here, which  
8 is --

9 DR. APOSTOLAKIS: The PRA as they changed it.

10 MS. BURGESS: I was able to bring back, from my  
11 visit of two weeks ago, the executive summaries, some of the  
12 system notebooks that are used in the service water systems,  
13 component cooling water. I was able to get risk achievement  
14 worth, a lot of importance measures of systems, things like  
15 that. They give us a better idea of how they have changed  
16 their --

17 DR. APOSTOLAKIS: I don't understand why they  
18 don't give you the whole PRA.

19 MR. PARKER: Because we haven't mandated it. It's  
20 not required through the regulations and no utility --

21 DR. APOSTOLAKIS: The risk achievement worth is  
22 not required either.

23 MR. PARKER: I understand, but I guess what -- you  
24 said this is our chance. I would like to see us have some  
25 type of requirement or standard where the utilities are

1 providing us their routine updates, no different than they  
2 would on an FSAR. That's a difficulty we're having right  
3 now with our SDP tool.

4 The SDP tool was put together by BNL, Brookhaven  
5 National Lab, using the IPE and the SRAs are having to go  
6 out and reevaluate that based on the licensees' current  
7 models. So significant changes are taking place.

8 DR. APOSTOLAKIS: We have been told by some  
9 licensees that they have -- especially the ones who have  
10 risk monitors -- they have PC versions of their PRA, they  
11 can see the impact of the change within a minute.

12 MR. GROBE: On-line risk monitor.

13 DR. APOSTOLAKIS: Sure. Would you like to have  
14 something like that?

15 MS. BURGESS: Yes. Now, we do have -- like Mike  
16 said, we do have safety monitor. Unfortunately --

17 MR. PARKER: We have the program.

18 MS. BURGESS: We have the program and we have the  
19 eight models, which are like the Westinghouse tool for a  
20 Westinghouse four-loop or things like that. We do not have  
21 plant-specific models.

22 Now, some plants in our region -- as a case in  
23 point, Kewaunee has given Research their program, their  
24 model, and Research has given it to INEL and INEL is in the  
25 process of converting it to SAPHIRE. So we have their

1 actual model.

2 DR. APOSTOLAKIS: Now, wouldn't the SPAR models  
3 eventually meet the needs you have when INEL completes --

4 MR. PARKER: I think there is a potential that it  
5 could meet most of our needs. The difficulty is going to be  
6 they're working on low power shutdown models. They're  
7 working on some containment and those have -- a lot of that  
8 activity has been deferred because of the SDP activities in  
9 progress that we can't -- we weren't able -- there are  
10 competing resources.

11 So I don't see us getting there for several years.

12 MR. GROBE: We're significantly resource  
13 constrained.

14 DR. APOSTOLAKIS: But you mentioned that the  
15 licensee is under no obligation to give you the PRA. But  
16 isn't it in their best interest to do that?

17 MS. BURGESS: We believe it is.

18 DR. APOSTOLAKIS: I mean, if they want  
19 risk-informed regulation, we can't do it without risk  
20 information.

21 MR. GROBE: We've been able to encourage several  
22 licensees, just from an efficiency point of view, of  
23 interacting with the staff, encouraged them to give us some  
24 of their risk analyses.

25 The problem is, as Sonia and Mike have pointed

1 out, one, is that there is no standard. So you have widely  
2 differing approaches, and second is there is no requirement  
3 to provide it.

4 So it's only a phone call from Steve or myself  
5 that says, listen, our interface would be much more  
6 efficient if we had such and such and then we'll get some  
7 documents.

8 DR. WALLIS: I'm not sure you need the standard.  
9 If I look at thermal hydraulic codes, it used to be that the  
10 staff would simply look at some codes provided by licensees.  
11 But now in reviewing thermal hydraulic code, the staff is  
12 moving to the position we want the code, we want the source  
13 code, we want to be able to run it, we want to be able to  
14 try things with it and see what it does.

15 MS. BURGESS: Many licensees are very reluctant to  
16 put their updated PRA on the docket.

17 DR. WALLIS: But ideally that's what it should be.  
18 It should be completely open.

19 MS. BURGESS: They just do not wish to have it on  
20 the docket.

21 DR. POWERS: If you can think about the headaches  
22 it would involve when it's updated, it's a significant  
23 process.

24 Let me ask you. You've mentioned this need for  
25 certification a lot and there is an activity going on with

1 the standards committee to set the standard for the PRA, and  
2 I think NRC has a limited voice in that committee setting  
3 that up.

4 Do you have a voice with those representatives on  
5 that committee?

6 MS. BURGESS: The regions?

7 DR. POWERS: Yes.

8 MS. BURGESS: No, we don't have a particular  
9 voice. Research is the member of that committee and I would  
10 characterize their participation as much more than just a  
11 minor committee member.

12 DR. POWERS: Mary Drouin and her troops.

13 DR. SEALE: That confirms what we found out from  
14 them last week.

15 MR. DAPAS: We're not precluded from providing  
16 input there. If Mary Drouin is the representative, I've  
17 worked with Mary, I know Sonia. We'd have no problem  
18 calling her up and saying, hey, we think this needs to be  
19 considered.

20 So we are not precluded from that opportunity, but  
21 there is not an outreach effort, if you will.

22 DR. SEALE: You're not getting timely information  
23 on what the status of that -- the evolution of that  
24 so-called certification process.

25 MR. DAPAS: Nobody else is either. Other than

1 what I read in the PRA implementation plan updated  
2 Commission paper.

3 DR. POWERS: It seems to me that -- I think  
4 there's a wealth of information at that end of the table on  
5 what the minimums ought to look like, just because of the  
6 pain, it's knowledge that's been gained by pain.

7 I'm wondering if we can't find a mechanism to do a  
8 download so that there is some hope that maybe that gets  
9 represented in the standard, because the last thing you want  
10 to do is get a standard back that's no good to you, that  
11 doesn't standardize the things that you want standardized.

12 DR. SIEBER: It's harder to undo that kind of a  
13 thing than it is to write it in the first place.

14 DR. APOSTOLAKIS: Will you have an opportunity to  
15 comment on the ASME standard? I mean, the public is  
16 welcome, so you are welcome, too.

17 MS. BURGESS: I believe the region will have a --

18 MR. PARKER: More than likely, Research has been  
19 very accommodating in requesting our resources to comment  
20 and provide feedback to all the new inspection processes and  
21 generally the NUREGs that are coming out, too. So I would  
22 see no difference in this regard.

23 DR. APOSTOLAKIS: There is a workshop, as you  
24 probably know, on the 27th of this month. Do you plan to  
25 attend?

1 MS. BURGESS: No.

2 DR. POWERS: They've got more than they can keep  
3 up with as it is.

4 MS. BURGESS: Yes. We've been very busy.

5 MR. DAPAS: But, George, not to convey we don't  
6 think that's an important activity. Like verification and  
7 phase two workshops we think is a high priority, as well, so  
8 that we can ensure we're capturing the licensee  
9 plant-specific information.

10 So there's competing priorities we're trying to  
11 wrestle with.

12 DR. APOSTOLAKIS: Is it fair to say that we risk-inform the  
13 regulations with very limited risk information on our part?

14 MS. BURGESS: Yes.

15 DR. POWERS: When you look at this risk-informed  
16 regulation, only a third of it is risk-informed. The rest  
17 of it is something.

18 MR. GROBE: It's all risk-informed, it's to a  
19 degree.

20 DR. APOSTOLAKIS: It's not quantitative.

21 DR. POWERS: This is the argument I sometimes make  
22 with the gentleman to my left and say we've always done  
23 risk-informed regulation, we didn't write these regulations  
24 because we didn't think there was any risk there.

25 DR. APOSTOLAKIS: That's right, and I have been

1 persuaded, as always when I hear a reasonable argument.

2 CHAIRMAN BARTON: All right. Where are we here?

3 DR. APOSTOLAKIS: I think Sonia is telling us --  
4 the last four bullets, we understand that you're doing that.  
5 Do you want to move on to --

6 MS. BURGESS: One initiative that we actually -- I  
7 did want to make a point, the initiative that we are doing  
8 that we are going to -- we're doing outage risk assessments.  
9 The plant is in an outage, Mike and I will go out to a site,  
10 sit down with the scheduling people of the outage from the  
11 licensee, understand where their risk significant evolutions  
12 are and helping to focus the resident staff on what to look  
13 at out, what to be observant of, what the most risk  
14 significant issues and evolution is.

15 DR. POWERS: Do you have an understanding of what  
16 the risk significant evolutions are during an outage, can  
17 you tell me?

18 MS. BURGESS: Quite honestly, I think that our new  
19 inspection procedure for outage work is pretty good on  
20 hitting PWR/BWR risk significant evolutions, from a broad  
21 perspective, to give, I think, excellent guidance to the  
22 resident staff.

23 DR. POWERS: I'll look at it.

24 MR. GROBE: What we found is that the licensee's  
25 risk analysts aren't getting involved early enough in

1 looking at the outage plan. We have been prepared to go out  
2 and look at the outage plan and the risk analysts, in some  
3 cases, haven't even started looking at it.

4 Are you asking the question because we haven't  
5 really developed a shutdown risk model yet?

6 DR. POWERS: The committee has had the chance to  
7 review a proposed rule in the area of shutdown regulation,  
8 and rejected it, fairly sternly, on the basis that we didn't  
9 feel like we had risk information about shutdown sufficient  
10 to know what to regulate, and asked that Research undertake  
11 a study to develop a risk profile during shutdown  
12 operations, not only planned outages, but unplanned outages,  
13 as well, and that has not progressed.

14 So as a result, I don't have the kind of  
15 information base of what constitutes risk-significant  
16 evolutions during outages that I have for normal operations  
17 gained from things like the beginning of WASH-1400 and up to  
18 NUREG 1150, and even the IPE insights document I find a  
19 wonderful source of information about what is risky in a  
20 plant during operations.

21 But I don't have that for outages. I've got a  
22 huge inventory of, which I seem to now have a hobby of  
23 collecting, of incidents that occur during various types of  
24 outages and I know the kinds of things that get you in  
25 trouble and I'm sure I could write a regulation to make sure

1 those things never happen again and I find, in general, they  
2 don't ever happen again, people correct things.

3 But I don't have a feeling for how you get into  
4 these problems and what kinds of things to look for.

5 MR. PARKER: And you bring up a good point.  
6 That's what we're trying to do is look at those issues,  
7 those risk insights that we have some knowledge on, but  
8 we're using the tools defense-in-depth and some of the NEI  
9 guidance to say, hey, mid-loop operation and different  
10 operations like that are highly risk significant conditions  
11 and that's the one tool we have.

12 But to go back to your point, the one opportunity  
13 that we have is Perry is developing the shutdown model and  
14 they intend to put that on their safety monitor, where they  
15 will be able to have a probabilistic on-line risk monitor,  
16 and it will be very interesting to be able to tie that into  
17 their outage coming up next February.

18 But they hope to have it in place so they can use  
19 it for their outage planning activities and that will be a  
20 unique opportunity for us in the region to be able to see if  
21 there's any insights that come out of that and share it with  
22 other plants.

23 DR. POWERS: I think these things are all good. I  
24 wish that you would have the kind of data that's in the PRA  
25 community about the details of these models, because I know

1 that we have substantial questions about how you go about  
2 modeling human error in these kinds of situations, which are  
3 very different from operational situations.

4 And I don't see the kind of debate between  
5 gentlemen, such as on my left, and his peers on how you go  
6 about doing that modeling that I have seen in connection  
7 with operational events and see the way that you set up the  
8 structure, the fault trees and event trees for shutdown  
9 events and the detailed discussions and the philosophy that  
10 I see for operational events.

11 And so these things get created, I'm glad, and  
12 they're going to help a lot, just like you said, but I would  
13 -- I'm not sure they raise my comfort level an awful lot.

14 MR. PARKER: Well, that's what stirred up my  
15 interest as far as certification. When we went out and did  
16 the SDP activities, to look at some of the human performance  
17 that we're crediting in our SDP that we have generic values,  
18 ten-to-the-minus-one for a high stress and  
19 ten-to-the-minus-two, and then we see the utility call it a  
20 ten-to-the-minus-four for the same thing, we haven't  
21 validated that and we're very uncomfortable and headquarters  
22 is stepping back and looking, is it appropriate to use the  
23 licensee's numbers versus ours.

24 And when we have an issue that results in a human  
25 performance, how do we deal with that and where do we go; do

1 we step back and look at the licensee's assumptions and  
2 their basis and validation behind that.

3 So there's a lot of questions in that area where  
4 human performance becomes a real issue.

5 MR. DAPAS: That underscores the need for some  
6 type of standard, in my view. From my perspective, your  
7 comments are clearly valid about we have limited  
8 risk-informed our processes. You're attempting to use the  
9 tools you have. If the licensee is proactive, like they are  
10 at Perry, you want to learn from that.

11 I think in the interim, though, we've tried to  
12 come up with the SDP, recognizing its limitations, and we  
13 have some tool to use to assess significance until we maybe  
14 develop some standard where the licensee says here is my PRA  
15 and we have confidence that it's sufficiently rigorous and  
16 we can use that in our determination of risk.

17 Right now, we have this --

18 DR. APOSTOLAKIS: But will the licensee say here  
19 is my PRA?

20 MR. DAPAS: They don't have to right now.

21 DR. APOSTOLAKIS: So does the Commission know that  
22 you are a little bit constrained in your efforts?

23 MS. BURGESS: Yes.

24 MR. DAPAS: I hope so.

25 DR. POWERS: They should understand the

1 limitations of the SDP.

2 DR. APOSTOLAKIS: But, I mean, in order to  
3 understand -- if we are the only ones, it doesn't work.

4 DR. POWERS: They have asked for us to talk to  
5 them on the SDP, on whether the PIs are truthfully risk  
6 significant. I don't think they're ready for the answer  
7 we're going to give them. And since I get to be the  
8 messenger, I may be dead next week.

9 MS. BURGESS: Slide 28 just highlights three  
10 bullets, that the SRAs in the region are extremely involved  
11 in the new process, very active and very busy just resolving  
12 findings and issues that inspectors from DRS and DRP are  
13 bringing to the table, running through the SDP process.

14 Since these worksheets are not yet completed, done  
15 with the revisions, the SRAs are involved in almost every  
16 issue.

17 DR. POWERS: I understand people are looking into  
18 expanding the workforce of SRAs.

19 MR. GROBE: We can talk about that a little bit.

20 MR. DAPAS: That's one of the staffing challenges  
21 Jack mentioned.

22 MR. GROBE: Yes. Could we hold off on that?

23 DR. POWERS: Sure.

24 MR. GROBE: Because we have another staffing  
25 issue. There is one thing we haven't touched on with Mike

1 and Sonia that we talked about briefly earlier was how the  
2 SRAs and risk analysts are going to get involved in event  
3 response. We've only had one substantive event since the  
4 new program went into force, and that was at Palisades.

5 And what we found was that there was a disconnect  
6 between management's expectation of what could be provided  
7 and what we actually had the capability to do.

8 So why don't you guys talk a little bit about how  
9 Palisades went and what we expect to be able to perform in  
10 the future, how we expect to be able to perform?

11 MS. BURGESS: With any event, preliminary  
12 information is just that, preliminary, and it seems to  
13 change minute by minute. So with the best information that  
14 we get, based on a senior resident at the site giving us, we  
15 were able to probably within an hour or an hour and a half  
16 give a rough big picture estimate of the situation of the  
17 event, conditional core damage probability.

18 DR. POWERS: I just have to interject an anecdote.  
19 In the hours following the Chernobyl accident, they called  
20 Moscow to explain they had an accident and the guy on site  
21 says, well, they've had accident here, but things don't look  
22 too bad.

23 That shows you how good preliminary information  
24 can be.

25 MR. DAPAS: Pretty gross estimate.

1 DR. SIEBER: It's all relative.

2 MR. GROBE: But our residents have a little bit  
3 more flexibility to speak what's on their mind.

4 MS. BURGESS: So we're able to give -- we have  
5 limited tools with the SAPHIRE model and the GEM model and  
6 obviously our model is not as extensive as the licensee is  
7 being able to model certain components and that, but I think  
8 we are able to provide a rough estimate, for event response  
9 purposes, of whether we need to send a special inspection or  
10 an EIT or an IIT.

11 I think in a lot of cases, definitely IIT is going  
12 to be self-revealing anyway.

13 DR. POWERS: You're saying that you've got enough  
14 information that you can provide information to management  
15 to make these kinds of decisions.

16 MR. DAPAS: Right. Do we need a special  
17 inspection? Are we comfortable that we have the big deal  
18 threshold or do we have time to acquire additional  
19 information and then maybe we need to send another inspector  
20 from another site versus --

21 DR. POWERS: When you decide, you make a decision  
22 and say I'm going to send a special inspection team to get  
23 to the bottom of this. You give that team a charter.

24 MR. DAPAS: Correct.

25 DR. POWERS: And you have enough information to

1 give a charter.

2 MR. GROBE: The charter is developed within the  
3 first couple hours.

4 DR. POWERS: But when they do their best, they've  
5 had their week or maybe a weekend, they never occur at good  
6 times, right? You've had -- and they've brought forth what  
7 they need. Can you write what you would say is a good  
8 risk-informed charter from one of these AITs or IITs?

9 MS. BURGESS: I believe we can. Just in the past,  
10 before the probabilistic risk insight was used, we also used  
11 deterministic risk insights. And our charters were very  
12 right on the money when we sent out a team and I don't see  
13 any difference now that the probabilistic risk insight is  
14 added.

15 I think we can do a very capable job of giving a  
16 real good charter to the team.

17 MR. DAPAS: But I think we would focus on things  
18 like is the licensee evaluating the risk significance, is  
19 the licensee trying to determine extended condition, is the  
20 licensee conducting a root cause, and, if not, we would  
21 challenge the licensee. And, again, that assumes that there  
22 is clearly risk significance associated with this that  
23 prompted us to send the special inspection.

24 MR. SINGH: I want to ask a question. SRA is a  
25 part of the AIT team most of the time?

1 MS. BURGESS: Not necessarily. It's dependent.

2 MR. GROBE: The last time we went an SRA out was  
3 the tornado that hit Davis-Besse. That was a year and a  
4 half ago or so.

5 MR. PARKER: The flexibility is in the program  
6 that if they think that there is a potential that there is  
7 some uncertainty or some concerns that we have, that they  
8 can --

9 MR. SINGH: How about, say, if you have an  
10 inspection team inspection, do you have an SRA as part of  
11 the team?

12 MR. GROBE: We certainly have that flexibility.  
13 But generally, usually, a special team is our lowest level  
14 of response. Generally, that's very targeted on equipment  
15 problems, root cause, things like that.

16 MR. CALDWELL: But I guess the answer, we haven't  
17 had a special inspection in this new process yet. So we're  
18 telling you what we think.

19 MR. SINGH: Because the reason I ask, I asked the  
20 question to Region IV when they had a fire at Diablo Canyon  
21 last month, and they had a special inspection and they sent  
22 the SRA up there.

23 MR. GROBE: That was a significant, complicated  
24 event.

25 DR. POWERS: One of the things the committee has

1 to do is advise the Commission on where it should be  
2 spending its research resources and we're wondering if they  
3 are under-investing in developing these tools to be used by  
4 the SRAs.

5 MR. GROBE: We're clearly resource constrained  
6 right now. Almost all of our agency resources are going  
7 towards the SDPs and as they pointed out, the shutdown  
8 model, low power model, containment model --

9 MR. DAPAS: Risk-informed PIs is another  
10 initiative that Research has embarked on.

11 MR. GROBE: The interesting, I get anecdotal  
12 feedback, but I understand that the industry is not  
13 interested in risk-informed PIs. That the amount of money  
14 that it would take to implement it doesn't give them  
15 sufficient payback.

16 DR. POWERS: What had been proposed up till now, I  
17 agree with industry on that.

18 DR. APOSTOLAKIS: But if we couple this with the  
19 maintenance rule, will it be much easier to define those  
20 PIs? They already did a lot of it for the maintenance rule.  
21 So there seems to be a distance or gap between the  
22 maintenance rule and risk-informed regulations and using the  
23 PIs. I don't understand why. I mean, what I don't  
24 understand is why didn't the staff at headquarters say, when  
25 they were establishing the oversight process, that the PIs

1 were plant-specific and the licensees should propose the  
2 thresholds.

3 They did it with the maintenance rule.

4 MR. DAPAS: I think the licensee, in many regards,  
5 has weighed in on the thresholds here.

6 DR. APOSTOLAKIS: But they have their own.

7 MR. GROBE: Not plant-specific.

8 DR. APOSTOLAKIS: They have their own.

9 MR. DAPAS: There was a strong emphasis with the  
10 PIs to minimize the dollar cost of implementation. So they  
11 depended very heavily on indicators.

12 DR. APOSTOLAKIS: Now they'll pay the price for  
13 the severe criticism that everything that is expected to be  
14 green and they don't mean anything and this and that, and it  
15 seems to me that there was an easier way of approaching it.

16 DR. WALLIS: Dana was asking about tools and I  
17 think you gave an answer about resources. Tools, to me,  
18 enable you to do more with fewer resources.

19 MR. GROBE: That's what I was talking about; that  
20 is, the resources are currently focused on other tool  
21 development and our ability to develop all these tools is  
22 resource constrained.

23 MR. DAPAS: From a regional perspective, I would  
24 offer we are certainly interested in any tools research can  
25 provide us.

1 DR. WALLIS: It may be we could get some  
2 resources, or someone, to RES to develop things for you,  
3 that's a different kind of resource.

4 MR. DAPAS: As long as they don't come from the  
5 region.

6 DR. WALLIS: Yes.

7 DR. POWERS: That's another question.

8 Unfortunately, the ACRS has no role to play in that. That's  
9 an NRC management function. But it's one we certainly worry  
10 about, because it doesn't do any good to pay Peter by taking  
11 from Paul.

12 DR. SIEBER: Well, I think there is one other  
13 point, and that is that recently in the development of a lot  
14 of the criteria involved with license renewal, there was a  
15 notable contribution made by some people from one of the  
16 regions in helping to put together part of that approach. A  
17 lot of us, at least I personally am convinced that the  
18 Commission would do itself a great favor if it would make  
19 greater use of the talent that exists within the regions  
20 and, in particular, those people who are the senior  
21 inspectors, who have real knowledge of how the plants work,  
22 when they put together some of these proposals and ideas.

23 And so to that extent, we may be doing you the  
24 disfavor of suggesting that you be a greater participant,  
25 but I hopefully would believe that that's, in the long run,

1 a productive thing rather than counter-productive. I mean,  
2 we have to be frank with you on that.

3 MR. GROBE: We're one agency, though, and what's  
4 best for the overall safety of the industry is where our  
5 focus is.

6 DR. SIEBER: Yes.

7 DR. POWERS: My boss used to say that he was  
8 giving you an opportunity to exercise your management  
9 talent.

10 MR. CALDWELL: I think you're exactly right that  
11 there are resources in the regions that would help out a lot  
12 of the development of new programs, et cetera, but there  
13 needs to be a shift in resources, because typically the  
14 development is in headquarters.

15 So in order for that to work effectively, then we  
16 need to shift some resources to the regions so that the  
17 regions have that flexibility to interact or get involved in  
18 the development activities. Because right now, it's the  
19 program office that does all the development and they  
20 resources for that. But we wouldn't disagree that we think  
21 the talent we have in the regions could help that process.  
22 It's just that we are base-loaded right now.

23 DR. SIEBER: Every time we've had a blood drive in  
24 this organization, the people who have contributed have been  
25 research and the regions. You don't understand.

1 MR. CALDWELL: I understand. I have to say,  
2 though, that the program offices have taken some pretty  
3 significant cuts and tried to prevent those cuts from the  
4 region. So we have fared reasonably well in the past; in  
5 fact, most recently.

6 My point is that if we're going to use regional  
7 resources for developmental programs, then you have to  
8 recognize that in the budget.

9 DR. SIEBER: I agree.

10 MR. CALDWELL: And take some of the developmental  
11 resources from the program office and put them in the  
12 regions. We are perfectly happy to do that and be involved.  
13 It's just that we have to be careful that we have enough  
14 folks.

15 DR. WALLIS: You can be very involved in defining  
16 what are the problems, what could be the solutions, what  
17 would help you. You're the customer for something. I don't  
18 see you being quite so involved as a resource in developing  
19 something, but very involved in being articulate and somehow  
20 expressing what it is you need, what the characteristics  
21 have to be of something which comes out of some research  
22 activity.

23 MR. CALDWELL: A lot of the details of this new  
24 program, though, were developed by regional resources.

25 MR. GROBE: That's right. That happened under the

1 old program, so we had some flexibility and we sent a lot of  
2 folks into headquarters.

3 MR. DAPAS: Task groups, et cetera.

4 CHAIRMAN BARTON: Since lunch seems to be out the  
5 door, we'll break for lunch from now until 1:15.

6 [Whereupon, the meeting was recessed, to reconvene  
7 this same day at 1:15 p.m.]

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

## AFTERNOON SESSION

[1:15 p.m.]

1  
2  
3 CHAIRMAN BARTON: We've got till 3:00. We don't  
4 want to miss anything that you want to tell us you feel is  
5 important, but try to get wrapped up by 3:00.

6 MR. GROBE: Well, why don't I fly through the  
7 training analysis, then.

8 CHAIRMAN BARTON: Okay.

9 MR. GROBE: I mentioned earlier that in the area  
10 of engineering inspections, that we've had to evolve our  
11 expertise and that's because we're doing more design  
12 inspections and we can no longer rely on contract resources.

13 CHAIRMAN BARTON: Right.

14 MR. GROBE: In addition, we've got a fairly high  
15 turnover rate. A number of our individuals have left the  
16 jobs with utilities, as well as we had a number of  
17 retirements.

18 So we've been in a fairly strong recruiting mode  
19 and we've been trying to emphasis recruiting of individuals  
20 with a stronger design expertise.

21 That's different than the expertise we've had in  
22 the past in the region. We've had some design expertise,  
23 but not a lot.

24 CHAIRMAN BARTON: Are those people hard to find  
25 now?

1 MR. GROBE: Absolutely. Absolutely. And we had  
2 some folks go out to the east coast out of Region I to try  
3 to find out if there was anybody interested in joining up.

4 But basically it's the engineering firms,  
5 utilities and military that are our recruiting pool.

6 The safety system design inspection is five  
7 engineers for three weeks and, again, if we're going to be  
8 successful in those inspections, they have to be qualified  
9 with design experience, mechanical, electrical and I&C  
10 system engineers.

11 The Appendix R inspection, the fire protection  
12 inspection is three multi-disciplined engineers, and, again,  
13 they have to have very unique experience. They have to be  
14 experienced in Appendix R inspection capability, and we're  
15 going to talk a little bit about the kind of training that  
16 they --

17 CHAIRMAN BARTON: Are they ongoing or is that a  
18 one-shot deal?

19 MR. GROBE: We had inspections early, following  
20 publishing the rule, through the '80s, that were, at that  
21 time, intended to be one-shot inspections. Since then, the  
22 inspections were suspended. Now, under the new program,  
23 we've re-initiated some inspections.

24 For a while, we were doing inspections out of --  
25 that had the acronym FPMI, fire protection functional

1 inspections, those were done out of headquarters and they  
2 were not programmatic in nature in the sense that they were  
3 mandated to be done at every plant.

4 But this is not an FPMI. It's not at that level  
5 of detail. But it does touch on the same elements that a  
6 fire protection functional inspection touched on.

7 You need somebody with fire protection engineering  
8 capability. We don't have a fire protection engineer, but  
9 we've trained one of our engineers to assess those kinds of  
10 attributes of the licensees' design.

11 We also need an I&C or an electrical engineer, but  
12 it's unique expertise in evaluating Appendix R types of I&C  
13 issues. And then you need a system operations engineer to  
14 look at how the licensee would implement procedures  
15 post-fire and whether their plans are feasible.

16 DR. POWERS: Do you have plans to do induced  
17 station blackouts?

18 MR. GARDNER: Yes. I'm not saying Region III has,  
19 but there are some in the country, that because of the fear  
20 of not being able to contain spurious operations, they go  
21 into a station blackout condition, and that's a concern,  
22 obviously.

23 MR. CALDWELL: We don't have them.

24 MR. GARDNER: Not that I'm aware of in Region III,  
25 that's what I said. I'm not sure there are any in Region

1 III. We'll find out.

2 MR. GROBE: We should introduce Ron. This is Ron  
3 Gardner. Ron is my electrical engineering branch chief. We  
4 do our fire protection inspections out of the electrical  
5 engineering branch.

6 DR. POWERS: The induced station blackout is a  
7 problem, it's a recovery.

8 MR. GARDNER: Well, it puts you into a condition  
9 that you don't want to get into.

10 MR. GROBE: Just to touch briefly on what we've  
11 been able to accomplish to date, we hired a Ph.D. I&C  
12 engineer who had 12 years of experience designing control  
13 systems for fighter jets, digital control systems for  
14 fighter jets. We're trying to turn him into a nuclear power  
15 plant I&C inspector.

16 We hired, he's on yet on board, but he's accepted  
17 our offer, an I&C engineer who was one of the co-chair of  
18 the Appendix R BWR owner's group. So extensive Appendix R  
19 experience.

20 We hired an electrical engineer that had extensive  
21 experience in the industry, as well as prior inspection  
22 experience, and we just brought in a mechanical engineer,  
23 he's a former senior resident inspector, into the mechanical  
24 engineering branch.

25 The area that we're having trouble is mechanical

1 design, piping stress analysis, that sort of thing. We're  
2 still looking for that resource and we're still looking for  
3 another electrical engineer. But we've had some success in  
4 this area. They are hard to come by.

5 I want to talk a little bit about training. Ron?

6 MR. GARDNER: In the 1980s, when we did the  
7 64-100, I don't know if you remember that number, baseline  
8 inspections, that were actually to make sure licensees were  
9 meeting their required date for implementing 50.48 and  
10 Appendix R, we had degreed fire protection engineers in just  
11 about every region and we augmented our people with NRR  
12 resources and contractors.

13 We had a very good team. Unfortunately, since the  
14 1980s, we've lost those fire protection engineers. We lost  
15 one to NRR, one went to actually OI. And then the FPFIs  
16 came back, and I can talk about how we got to where -- some  
17 of that's with Generic Letter 92-18, you might be aware. So  
18 you know how we've gotten there.

19 In any case, unfortunately, today, with the  
20 baseline program introducing the FPI, we don't have degreed  
21 fire protection engineers. We have inspectors that were  
22 doing the base fire protection inspection and that is a far  
23 degree of difference between that and design of fire  
24 protection systems.

25 As Jack indicated, we have started training a fire

1 protection engineer. We had a training session that NRR put  
2 on, two sessions each a week in Brookhaven, you may have  
3 heard of that. We're having a follow-up training session in  
4 the region here in September, one day, unfortunately.

5 For the first couple of inspections, we're having  
6 a contractor assist. We're doing an inspection right today,  
7 the last day of the inspection is Friday, at Braidwood, fire  
8 protection inspection.

9 We have two Brookhaven contractors. That's OJT  
10 that we're getting from them. We have NRR technical expert  
11 also on that team that's also giving them some training.

12 So through a combination of OJT and classroom  
13 training, we are attempting to reach a level that we feel  
14 comfortable with as far as the technical capability of our  
15 people in this area.

16 As you know, it's very complex, though.

17 MR. GROBE: For a period of six months, we've  
18 gotten limited contractor resources in the fire protection  
19 area, and for about 18 months in the design area, to put one  
20 contractor on each inspection team. And the goal of that is  
21 to develop some on-the-job training.

22 In addition, we're doing some internal course work  
23 on heat sink, thermal hydraulics, somebody mentioned heat  
24 transfer earlier, because we have a new inspection we hadn't  
25 done before, it's called heat sink. What it primarily

1 focuses on is the viability of heat exchangers.  
2 And we're exploring the TTC in other regions,  
3 discipline-specific course work in heat transfer, set-point  
4 methodology, instrument loop uncertainties. We hadn't  
5 focused a lot in the past in these areas, so we're looking  
6 at developing some internal course work in those areas.

7 CHAIRMAN BARTON: TTC?

8 MR. GROBE: TTC is the technical training center,  
9 currently in Chattanooga. I would expect most of this is  
10 stuff we're going to do.

11 MR. SINGH: I have a question. Before you  
12 suspended the inspections back in the '80s, did you ever do  
13 the triennial inspections in fire protection?

14 MR. GROBE: No. We didn't do one in this region.

15 MR. SINGH: You did not.

16 MR. GROBE: No. There were, I think, only three  
17 done in the entire country.

18 MR. SINGH: No. There were lots of them. I did  
19 all of them in Region IV.

20 MR. GROBE: Oh, did you?

21 MR. SINGH: Yes.

22 CHAIRMAN BARTON: How many did you do in Region  
23 IV?

24 MR. SINGH: Eight. So nothing was done. Thank  
25 you.

1 MR. GROBE: Any other questions in engineering?

2 MR. DAPAS: I just wanted to touch upon, starting  
3 with slide 42, some of the staffing challenges in the  
4 resident inspector program. We've experienced a relatively  
5 high turnover rate and consequent with that is the challenge  
6 to fill vacancies.

7 You have to post the vacancy, go through the  
8 selection process, and then train the individual, and with  
9 the qualification process, it can be several months before  
10 we have a fully engaged resident inspector replacement once  
11 we've identified the vacancy.

12 CHAIRMAN BARTON: The primary reason for the high  
13 turnover rate or does it vary?

14 MR. DAPAS: It varies. It can be promotional  
15 opportunity for the resident inspector that may go on to be  
16 a senior resident inspector or come into the regional  
17 office. It can be -- and that goes for both resident and  
18 inspector and senior resident inspector.

19 It's a bit more limited for the senior resident  
20 inspector in terms of promotional opportunities, but there  
21 have been a number of residents that have received  
22 promotions, or requests for lateral transfers. We had a  
23 resident inspector that wanted to go back to NRR to be a  
24 project manager and we supported that. He, of course, had  
25 family in that area and that seemed to be a win-win.

1           And in addition to that, there's attractive salary  
2 offers out there in the industry. Some of these plants that  
3 were in extended shutdowns, like Cook and others, plants  
4 that are merging, there's opportunities for experienced  
5 resident inspectors and you're dealing with signing bonuses,  
6 et cetera, and lucrative salary offers, that's been an  
7 attractive draw.

8           MR. CALDWELL: Was your question -- were you  
9 trying to get to whether there's dissatisfaction? I don't  
10 think we have -- I mean, there's always going to be some  
11 folks.

12           CHAIRMAN BARTON: But 12 percent is pretty high  
13 turnover.

14           MR. CALDWELL: I think most of the folks that left  
15 went for either geographic, promotion, or something that  
16 benefited them, either money or whatever. I don't think we  
17 lost anybody that just --

18           MR. DAPAS: Or early-out, I don't think so.

19           MR. CALDWELL: -- didn't like the program anymore.

20           MR. DAPAS: And that's one of the things we try  
21 and probe, was there some concern with or dissatisfaction  
22 with your working environment or et cetera.

23           DR. POWERS: But if the inspection program is  
24 going to turn them into automatons and eliminate  
25 discretionary and judgmental aspects of it, are you going to

1 lose people?

2 MR. DAPAS: I'd challenge that characterization of  
3 the new program, but --

4 DR. POWERS: I put the worst spin on it I can  
5 here.

6 MR. DAPAS: I think we are asking the inspectors  
7 to bring judgment to bear and as I said, in the context of  
8 what revisions do we need to make to the program, I know  
9 that Jim and I have had a lot of discussions, we place a  
10 high value and premium on experienced individuals with  
11 mature judgment and we value that and we're going to  
12 consider that input.

13 And we -- divisional meetings or one-on-one  
14 discussions with the residents, we go out to the site, we're  
15 continuing to encourage them to flush issues up to branch  
16 chief management, so those can be considered and evaluated,  
17 and not get locked into this, well, the new program doesn't  
18 allow me to do X or Y.

19 CHAIRMAN BARTON: One of the concerns I have is  
20 they do an SDP and they get frustrated because in the past  
21 it was the findings of violation and now you do it and it's  
22 --

23 MR. GROBE: It's an issue that we're having to  
24 focus some management attention on, because we've completely  
25 perturbed all of the structures that the staff had to

1 demonstrate their own --

2 CHAIRMAN BARTON: Exactly.

3 MR. GROBE: -- in terms of value. So we're  
4 building what is currently called a significant reactor  
5 finding. We're going to rename it, but we're doing more  
6 internal recognition of inspection issues that add value,  
7 but don't get to a white, yellow or red threshold, add value  
8 because they provide insight to the licensee or provide  
9 insight to us as far as inspection techniques or other  
10 issues that other plants can look at.

11 So we're trying to find ways to give the staff  
12 anchors for their value, but it is a challenge.

13 MS. NESTON: Does this 12 percent also include the  
14 rotation out of a particular plant because they've been  
15 there for so long?

16 MR. DAPAS: I'm not sure on that.

17 MR. CALDWELL: In the range, it could include  
18 someone who has rotated back to the region, because either  
19 their time was up or we've had individuals who didn't stay  
20 the full seven because they were grandfathered with the  
21 five. They came up to their five and decided they wanted to  
22 do something different and rotated either back to  
23 headquarters or here.

24 MS. NESTON: And they would be included in that 12  
25 percent.

1 MR. CALDWELL: They would be included in that.

2 MR. GROBE: In honesty, we haven't had a lot of  
3 folks that have been -- that have moved because they've  
4 gotten to their time limit. That's the exception, not the  
5 rule.

6 MR. DAPAS: That's with the extension to the seven  
7 years. But I think, and I view this as a positive, I think  
8 we've had a number of instances where feedback we've  
9 provided to the program office, discussion that we've  
10 generated in the different forums to discuss the new program  
11 has resulted in some change, and we try and build upon that  
12 as positive examples for the inspection staff, where  
13 expressing their views has resulted in revisiting of a given  
14 approach.

15 So we are encouraging that across the board as we  
16 go into initial implementation. The pilot program, we had  
17 input from really two branches, and now we've got input from  
18 all the branches, and there is a learning curve that they go  
19 through. Some of the feedback we're able to address as a  
20 result of lessons learned from the pilot program and then  
21 there's also additional insights that are communicated that  
22 we discuss and forward to the program office.

23 So I view that as kind of healthy. There's a long  
24 training period, as I mentioned, for qualification. You  
25 have to attend the BWR, the PWR series, plant-specific

1 system knowledge, on-the-job training, that's certainly a  
2 large aspect of the resident qualification program, and then  
3 the emergency preparedness responsibilities, understanding  
4 the licensee's emergency response plan, the NRC  
5 responsibilities.

6 And I caveat this, appropriately. Some PRA  
7 training that the residents receive so that they can  
8 understand the use of the SDP process and how risk impacts  
9 inspection activities, and then they go through a course, an  
10 oral qualification board, where we have various branch  
11 chiefs that sit and ask questions to test knowledge in the  
12 regulatory perspective.

13 CHAIRMAN BARTON: What happens if they fail the  
14 oral board? Do they get another shot?

15 MR. DAPAS: We have had a couple individuals, in  
16 my experience in the region, that we felt needed another  
17 qualification board. So there were particular areas where  
18 they had to concentrate and devote some additional study and  
19 then they were successful in their second board. But the  
20 branch chiefs, I think, are fairly successful in not  
21 offering or sponsoring a resident for a qualification board  
22 until they're pretty confident that they've acquired the  
23 requisite knowledge to be successful.

24 So we've had limited experience where that has  
25 occurred.

1 MR. SINGH: Do you also have an oral board for the  
2 regional inspectors?

3 MR. GROBE: Absolutely. Every inspector goes  
4 through an oral board.

5 MR. DAPAS: And then when we looked at the pool of  
6 experienced resources, that's a bit limited. Obviously, we  
7 draw from the Navy or shipyard or licensee operational  
8 experience.

9 DR. POWERS: If the Navy keeps working its folks  
10 as hard as they are right now, you'll have a big pool of  
11 people.

12 MR. DAPAS: We get some applicants that have a lot  
13 of experience in the nuclear power program that the Naval  
14 Reactors runs and that's because they are downsizing. So  
15 they're looking for other opportunities.

16 But this does require an aggressive recruiting  
17 program, because as I said, the competitive salaries and the  
18 signing bonuses in the industry, the lengthy process we have  
19 to go through for selection, rating panels and interviews,  
20 et cetera. So that can sometimes -- where employee X can  
21 say here, we're offering you a job here.

22 Sometimes we've been in the process of going  
23 through the selection and we're ready to forward an offer  
24 and individual X has said, well, I just took an offer a  
25 couple weeks ago with company Y. So sometimes we're

1 confronted with that and we look for ways to streamline  
2 that.

3 One of the things that we're also looking at is  
4 the entry level program, and that certainly is a resource  
5 investment, but we want people with experience. But, again,  
6 that can be limited, so we look and explore the entry level  
7 program.

8 MR. CALDWELL: Mark is going to try to hustle up  
9 here so we can get into the fire protection stuff, but I  
10 want to make sure, before he gets out of this, if you have  
11 any questions on this, because it is probably one of the  
12 most important programs we have; not necessarily because the  
13 other aspects, what we do is not important, it's because  
14 these are the folks that are on the site that are there all  
15 the time.

16 What they do is -- what I saw as the biggest  
17 change in the way the agency worked was that licensees now  
18 expect to have somebody there, so that they don't operate  
19 differently than they would if an NRC presence wasn't there.

20 I talked to some staff people and they told me  
21 that in the old days, when they knew the inspection team was  
22 coming out, they changed their mode of operation for that  
23 week and then changed back after they left.

24 So the resident program has provided a routine  
25 presence which keeps folks from operating differently when

1 we're there.

2 CHAIRMAN BARTON: It keeps them honest.

3 MR. CALDWELL: Well, I didn't want to say it that  
4 way, but that's essentially it. I didn't mean to interrupt  
5 you, Marc.

6 DR. POWERS: Well, there's another thing that you  
7 have to bear in mind, that all of us have to bear in mind,  
8 that there is a very, very crucial role that they play and  
9 this SDP process is their process for screening their  
10 findings and whatnot. So their level of responsibility, to  
11 my mind, has actually gone up in this new procedure and some  
12 of these things I worry about are responsibility and  
13 judgment, notwithstanding I think there are still concerns.

14 MR. GROBE: The SDP is not limited. The residents  
15 obviously have a role in evaluating their findings, but the  
16 region-based inspectors also use that, that the value to the  
17 inspection program that the residents add is -- I can't  
18 remember the number -- but several hundred hours of their  
19 time is allocated to what we call plant status and that --  
20 it's 650, and that's supposed to be a risk-informed  
21 assessment of what's going on, so that they can engage  
22 themselves in the right activities and also engage the  
23 region-based folks that come out in the right activities  
24 from the risk perspective.

25 MR. CALDWELL: I cut Marc off and I apologize.

1 MR. DAPAS: One of the things we talked earlier  
2 about is the impact of the training courses at the technical  
3 training center, when they're offered, but branch chief X  
4 has a vacancy and is successful in filling that, but the  
5 annual PWR course just completed, that individual has to  
6 wait till the next year to pick that up.

7 CHAIRMAN BARTON: So it's only given once a year.

8 MR. DAPAS: Right, and I guess that is a function  
9 of the demand that they have when you look across all the  
10 regions and all the offices, that they were only able to  
11 justify one course a year, but sometimes that does have an  
12 impact depending on when your individual reports on board.

13 And we already talked about absence from the site  
14 for an extended period. If you're attending a seven week  
15 course in Chattanooga, you're going through the  
16 qualification process, that impacts baseline program  
17 execution and site coverage and that requires pretty  
18 involved branch management of the inspection --

19 CHAIRMAN BARTON: You bring another inspector on  
20 board for that period of time, right?

21 MR. DAPAS: Right. We were looking at like a  
22 contingency plan. A good example is in an outage. The  
23 licensees are short during outages. There's I forget how  
24 many hours associated with the resident inspection portion  
25 of the outage. Do you recall, Laura?

1 MS. COLLINS: Eighty.

2 MR. DAPAS: Eighty hours. Doing that at what  
3 might be a 22-23 day period can be a real challenge if  
4 there's only one inspector on-site and branch chief X might  
5 ask the other branch chiefs can you help me out with sending  
6 someone during this outage period.

7 And as I mentioned, on-the-job training is a large  
8 part of the program. And the experienced SRIs look at  
9 resident inspector development as a high priority and their  
10 responsibility. It's kind of like I'm training my  
11 replacement coach. So they place a premium on that and I  
12 think we get a lot of value-added.

13 And the other thing, as I mentioned, we look at  
14 reduced training length when hiring high quality individuals  
15 who can hit the ground running. We have had some interim  
16 certifications in selected areas of the inspection program  
17 because an individual comes on board that has an extensive  
18 operations background.

19 And then the extensive cross-training. I was just  
20 looking yesterday at the number of residents and senior  
21 residents that have both PWR and BWR training, and so  
22 they're fungible to go to other sites without having to take  
23 the specific series course.

24 And the other aspect of this cross-pollinization is between  
25 DRS and DRP. We've had a resident inspector go to operator

1 licensing and a senior resident that reported to operator  
2 licensing, as well as an individual from the engineering  
3 branch going out and being a senior resident.

4 So there is some cross-pollinization between  
5 divisions which we think is real beneficial.

6 If there are any questions.

7 CHAIRMAN BARTON: Do resident inspectors get  
8 overtime?

9 MR. GROBE: Yes.

10 CHAIRMAN BARTON: Are they paid overtime?

11 MR. GROBE: Absolutely. Let's move on to risk  
12 training. What I'd like to do -- do you folks have any  
13 questions about the SRA training program? Are you familiar  
14 with that?

15 CHAIRMAN BARTON: No, I'm not familiar with it.  
16 What slide are you on, Sonia?

17 MS. BURGESS: I'm on 46. There's Region III is no  
18 different from the other regions. There's two SRAs in each  
19 of the regions and there is consideration of an additional  
20 risk trained person and that can take the form of a couple  
21 of different options.

22 One is using existing inspectors with additional  
23 risk training, so they can do it part-time, and another  
24 person that's dedicated to assist the SRAs in the analysis  
25 of risk.

1 CHAIRMAN BARTON: Have you been in a position of  
2 trying to assess what your needs are?

3 MS. BURGESS: Yes.

4 CHAIRMAN BARTON: You need another warm body or do  
5 you need an assistant?

6 MS. BURGESS: We have. The SRAs have put their  
7 input in and what we would desire, what we think we would  
8 need. We definitely think we'd need at least one additional  
9 risk person.

10 CHAIRMAN BARTON: A lot of times people will have  
11 one slot and they say, well, what I'll hire is a new senior  
12 reactor analyst. Point in fact, they've got enough senior  
13 reactor analysts. They need an assistant for them to help  
14 them carry out their jobs, and I'm just wondering if you had  
15 thoughts on that.

16 MR. CALDWELL: There's no plans to have an  
17 additional SRA slot. As I mentioned earlier, there's a task  
18 force that, in fact, the meeting starts -- the first meeting  
19 is on the 26th, of the four regions and headquarters, to  
20 talk about SRA succession planning, and that really is to  
21 talk about the type of training that you would give one,  
22 two, three, four, five individuals, I'm not going to  
23 prejudge how it comes out, but a number of individuals who  
24 would not be fully SRAs, but would have additional training  
25 that they could support the SRAs and the region in risk

1 assessments.

2 Not a short-term thing. I mean, the two SRAs are  
3 going to be just up their necks in work, but it's a  
4 recognition that there needs to be some more expertise in  
5 that area and a recognition that that you need to have  
6 somebody in the pipeline unless an SRA gets promoted or  
7 decides to leave.

8 DR. POWERS: They better not.

9 MS. BURGESS: That's a great segue into the next  
10 slides.

11 MR. GROBE: I was going to say there's a lot of  
12 personnel barriers associated with this, because the SRA  
13 position is a higher graded position than any other staff  
14 position we have in the region.

15 So there's a lot of issues that come up in the HR  
16 area.

17 MS. BURGESS: On slide 47 is the SRA training  
18 certification program or process is an 18 to 24-month  
19 program. It's divided into classroom and rotation and I've  
20 listed some of the technical training, the statistics, PRA  
21 training, and then the NRC PRA computer modeling training.  
22 That, in itself, can be up to 27 weeks of training.

23 CHAIRMAN BARTON: Where do they get the PRA  
24 training?

25 MS. BURGESS: In headquarters. And most of the

1 time, much of the training is contracted out. Brookhaven,  
2 INEL. So just the classroom portion of the training is a  
3 significant amount of time.

4 Rotations, there's nine months of rotation. Mike  
5 and I did five months in NRR in the PRA branch, we did three  
6 months in the Research PRA branch, and then we did one month  
7 at another region to get on-the-job training, with the  
8 assistance of an existing SRA, to see what their job duties  
9 were and how they conducted business in the region, and took  
10 that back to our region.

11 MR. CALDWELL: And that's one of the areas that  
12 we're going to look at. Now that we have experienced SRAs  
13 in the region, we may not need these extensive rotational  
14 assignments. They'll just spend their time with the SRAs in  
15 the region to get their on-the-job training. But the  
16 classroom training that she was talking about is extensive.

17 It's not a short-term fix if somebody leaves or  
18 you need additional help. It's something that we're trying,  
19 for the long-term, and come up with a plan that will keep  
20 people in the pipeline and bring up the whole level of the  
21 region's expertise of risk.

22 DR. POWERS: It also offers the opportunity for  
23 substantial job satisfaction improvements there, the guy  
24 feels like he's going into modern technology.

25 MR. GROBE: I think we've covered slide 48. Why

1 don't we go on to 49?

2 MS. BURGESS: Slide 49 just highlights some of the  
3 training that the regional inspector and the resident  
4 inspector would receive. This first bullet is a two-week  
5 class. It's a combination of the PRA basics plus we have  
6 how integrated the SDP process and now the PRA and the IPE  
7 all integrate into the SDP process. That's a two-week  
8 course.

9 An then also we've given extensive training on the  
10 SDP process itself. We've had a lot of workshops and with a  
11 lot of examples of issues from other regions and that's  
12 helped the inspectors put some practical use to the SDP.

13 MR. GROBE: Any questions in the risk training  
14 area? Before we get into the fire protection area, there  
15 were two questions that you asked earlier that we didn't  
16 really get a chance to answer, and I'll just give my  
17 perspective and open it up to Jim and Marc.

18 One had to do with power up rates. We don't have a  
19 lot of insight on power up rate, other than the fact that I  
20 could share with you a concern that I have. Jim Dyer  
21 mentioned Quad and Dresden are going to be coming in for  
22 some fairly significant power up rates and you indicated  
23 Duane Arnold is, and that has to do with secondary side  
24 capability and the ability of the operators to operate the  
25 plant in a higher, significantly higher power level, and

1 whether that's going to impact on initiating event  
2 frequency.

3 I don't have any more insight to share with you,  
4 other than that's a concern that we have, and I'd throw that  
5 open to Marc and Jim.

6 MR. DAPAS: The power up rate, I guess from the  
7 resident inspector perspective, I think you would get  
8 involved, the resident inspectors get involved in looking at  
9 if there's any tech spec ramifications. Many times, the  
10 tech spec package that comes out, headquarters is  
11 considering, the residents will be asked to review, to offer  
12 any perspective procedural implications.

13 So it's just really changes to the tech specs and  
14 procedures that result from the power up rate. I can't  
15 really envision any other area where the residents might be  
16 engaged.

17 CHAIRMAN BARTON: With a number like that, you're going to  
18 have to make some hardware system changes when you go in  
19 that level.

20 MR. CALDWELL: Right. Set point changes that have  
21 to be made and they have to be made as they go up.

22 MR. DAPAS: Which are captured in the tech specs.

23 CHAIRMAN BARTON: Yes, but they actually have to  
24 make changes in the plants. You have to -- because the trip  
25 set point stays the same, but the 100 percent power, as it's

1 calculated, changed, and so the trip set points have to be  
2 changed in the instrument and control.

3 But what Jack mentioned is something that I don't  
4 know that we have any insights into, but some licensees find  
5 that they get the up rate and they just don't have the  
6 capacity we have any insights into they tripped their auto  
7 valves or their turbines aren't set up, at least the way  
8 things are set up, to handle that type of --

9 CHAIRMAN BARTON: Fermi is a good example of that.

10 MR. CALDWELL: Right. So those are things that  
11 they have to kind of inch up to and that's what we will be  
12 watching, how they do that, how they control it, and most  
13 licensees, at least today, had done it very slowly and very  
14 deliberate.

15 DR. SIEBER: These major up rates, though, they're  
16 really talking about a new front end on the turbine and the  
17 things like that.

18 MR. CALDWELL: Yes.

19 DR. SIEBER: Which really changes the physical  
20 plant.

21 MR. DAPAS: But I'm not aware of any prescribed  
22 inspection activity where we would go out and verify that  
23 what the licensee communicated in their licensing submittal  
24 is, in fact, the case in terms of equipment modifications.

25 MR. GROBE: It would be an opportunity through the

1 affirmative plant mods inspection and the safety system  
2 design inspection to target some of those areas.

3 DR. SIEBER: But you know that the stress level on  
4 the plant is going to be higher.

5 The other you raised earlier was license renewals and we  
6 haven't had any in Region III, but we've seen that train  
7 coming down the tracks, and we assigned a project manager to  
8 stay aware of what's going on in the other regions and  
9 headquarters.

10 The inspection program for that activity is fairly  
11 significant and while it doesn't have any direct impact on  
12 the baseline program, it doesn't change anything we do in  
13 the context of baseline.

14 It's resource intensive and as we shared with you  
15 earlier, we don't have a lot of resources.

16 It's also a fairly unique expertise that's  
17 necessary. There is discussion underway right now, and  
18 maybe, Ron, you can expand on this, too, to capture that  
19 inspection activity out of headquarters or currently it's  
20 out of the regions.

21 Why don't you talk about what we've done as far as  
22 trying to gain insights in this area?

23 MR. GARDNER: As Jack indicated, we have a  
24 principal inspector that we've assigned to get with the  
25 other regions who have started down that path, to find out

1 what they've done, how they did it, what worked, what  
2 didn't, to try to get to the point where when we get our  
3 opportunity, we're not starting at ground zero, that we've  
4 already built on what other people have done and tried to  
5 make improvements.

6 AS Jack indicated there is some discussion about  
7 who will do what. There's a big portion, as you might  
8 imagine, of environmental qualification questions that come  
9 into life extensions of license renewal.

10 And I have been part of one of the research  
11 working groups, for years I was on that, on aging of  
12 materials and such. So I have an acute background in that  
13 also.

14 So I think we have the wherewithal to do the  
15 inspections, the challenge will be finding the resources to  
16 do it.

17 MR. GROBE: What's the total number of inspection  
18 hours we've seen?

19 MR. GARDNER: I can't remember.

20 MR. GROBE: My recollection is on the order of 700  
21 and something.

22 MR. GARDNER: I thought it was 800, roughly 800.

23 MR. GROBE: It's a very significant impact,  
24 because it has to be done a very short period of time.

25 DR. POWERS: We have a statutory responsibility

1 for all those and we're looking at a major tidal wave coming  
2 in at us and it could literally consume everything we do.

3 MR. GROBE: I think that captured all the  
4 questions that I had written down earlier. I think what I'd  
5 like to do now is go into the fire protection issues and  
6 turn it over to Ron Gardner. I know that you're going to  
7 have some questions. I suspect you're going to have some  
8 questions.

9 MR. GARDNER: As Jack indicated, my name is Ron  
10 Gardner. I'm the Chief of the Electrical Engineering branch  
11 in DRS and fire protection falls in my branch.

12 What I've tried to do is make a presentation that  
13 would address where the new program is going with fire  
14 protection, not only triennial, but also the more day-to-day  
15 review of fire protection and the normal fire protection  
16 things that the regions have been doing over the years.

17 We didn't stop that. We're just doing it in a  
18 different manner.

19 The first thing, I guess, on slide 55 that I want  
20 to emphasis is the risk contribution of a fire. It is  
21 significant and if you stop and think, with the fire, you  
22 can have a plant transient, you could have a reactor trip,  
23 you could have a loss of off-site power, you can -- we  
24 talked about self-induced station blackout.

25 All those require fairly significant reactor

1 operator actions. You can go beyond that, though, with the  
2 high-low pressure interface problem or a stuck-open PORV, a  
3 spurious operation of an SRV, and you enter a LOCA  
4 condition.

5 Compound that with a loss of off-site power and  
6 you've got very numerous operator actions. Then with a  
7 fire, you may have smoke, which could inhibit or prevent  
8 operator actions. You have flooding, you have the heat of  
9 the fire.

10 The fire itself is a very significant area of NRC  
11 historical perspective and it looks like it's going to  
12 continue, that we're going to maintain our focus on this.

13 There were a number of years where we backed off.  
14 Information Notice 92-18 and the subsequent problems we had  
15 with the implementation of that, that was regarding  
16 motor-operated valves and the potential for spurious  
17 operation and control room fires, to have the valves not  
18 only go to the wrong position, but to be destroyed  
19 mechanically because of the bypassing of the torque  
20 switches.

21 Also, we had some FPFIs that failed, with  
22 significant findings.

23 So going on to page 56, I wish there was a silver  
24 bullet where we could say here is the fix, that we could say  
25 the risk of fires has gone away by just doing this one

1 thing.

2 No one has been able to find that silver bullet.  
3 So that instead, what we find is the best approach and  
4 licensees have found the best approach is the definition  
5 methodology or mentality. It starts off by preventing  
6 fires, and I'll talk more about that when we talk about what  
7 the resident does and how we try to gauge how licensees are  
8 doing in preventing fires.

9 Then we have the part of rapidly detecting,  
10 controlling and putting a fire out. Great success, if you  
11 remember the Fermi turbine explosion, it released thousands  
12 and thousands of gallons of oil, EHC fluid, et cetera, and  
13 distributed it all over the plants, with all the water  
14 systems that were ruptured, and the fire was extinguished  
15 and rapidly extinguished, and that could have been a very,  
16 very significant fire and it didn't happen.

17 So that says that in that case, the rapid  
18 detection, control and extinguishment of the fire worked,  
19 and that involved obviously even the hydrogen system for the  
20 generator.

21 DR. SIEBER: One of the problems is, though, that  
22 when you have a big fire in the plant that involves  
23 operations, it's the operators who are the fire brigade.

24 MR. GARDNER: Often, and I'll about it. They have  
25 a lot of manual actions, too, sometimes to mitigate the

1 fire. One of the things that the licensees are required to  
2 do is for any fire area, is to dedicate or to preserve  
3 enough equipment to safely bring the plant to cold shutdown,  
4 and the performance goals they're trying to make is  
5 reactivity control.

6 They want to make sure the plant is no longer  
7 critical. They want to have makeup. They want to have  
8 decay heat removal. They want to have enough indication for  
9 the operators to know which manual actions to take or which  
10 actions and EOPs to follow. And a support system.

11 So that's quite a lot that you have to maintain  
12 regardless of whatever fire you can postulate. To do that,  
13 you have barriers, suppression, safe shutdown procedures,  
14 and you have a number of equipment and systems that are  
15 dedicated just for those operations that have to survive in  
16 the event of a fire in any given postulated fire area.

17 Unfortunately, there are no performance indicators  
18 existing today, and this is slide 57, to provide insights or  
19 to help us to say that we don't need to do an actual  
20 inspection.

21 And we haven't given credit for self-assessments.  
22 One of the reasons, and I'm not saying a significant reason,  
23 but one of the reasons was when we were doing the FPFIs,  
24 Prairie Island did a self-assessment. When we did the FPFIs,  
25 we gave them credit for it. So our FPFIs was focused on

1 determining the adequacy of their self-assessment.

2           When we went out there and looked around the  
3 plant, we found a number of issues that their  
4 self-assessment had missed, and they weren't small issues.  
5 I don't have -- if you look at the inspection report, you  
6 could see them.

7           They were fairly substantive issues, and we were  
8 surprised. I'm not sure if that had a major contribution to  
9 the fact that the NRC wants to at least start down the road  
10 of doing our own inspections, but it probably didn't help  
11 the licensee's cause any, because I know NEI was looking to  
12 see if they could have more credit for self-assessments.

13           MR. DAPAS: Didn't we also, though, Ron, have some  
14 have some real significant inspection findings in that area  
15 and that has furthered the point that we should  
16 independently verify.

17           MR. GARDNER: Right. Now, a number of licensees  
18 are doing self-assessments and they are finding significant  
19 issues, and that's to their credit. It's just whether or  
20 not we are comfortable with saying they are to the point now  
21 where they can find the amount of problems that we think are  
22 there still, and that's an unfortunate statement, but that's  
23 true, unfortunately.

24           Now, as I was indicating, it's not just a  
25 triennial or design inspection. We have a constant focus on

1 fire protection that's brought about by the residents.

2 On a quarterly basis, residents tour six to 12  
3 areas of the plant, and they're looking at the classical  
4 fire protection features. They're making sure that the  
5 licensee doesn't have extensive combustibles or ignition  
6 sources for those combustibles in the plant.

7 The licensee has requirements for storage of  
8 combustibles, et cetera, they're looking at that. They're  
9 making sure that the material condition of the fire  
10 protection systems is up to par, that they're not degrading.  
11 Operational lineup, say, for a CO2 or a halon system,  
12 they're making sure it's properly lined up, so if there is  
13 an automatic initiation, it would function.

14 They look at operational effectiveness of the  
15 equipment and of the licensee's fire brigade and fire  
16 barriers.

17 CHAIRMAN BARTON: Are those quarterly inspections  
18 what you require to be done during an outage?

19 MR. GARDNER: Required to be done during an  
20 outage.

21 CHAIRMAN BARTON: Yes.

22 MR. GARDNER: I'm not sure that the procedures  
23 differentiates between an outage and a non-outage condition.

24 CHAIRMAN BARTON: The only reason I bring it up,  
25 because in outage, you've got an opportunity to bring in a

1 lot more fire loading combustibles.

2 MR. GARDNER: That's why the residents are out  
3 doing this, because they're there during the outages and  
4 not. Usually, the region stays away from an engineering  
5 type inspection during an outage, the residents are there  
6 anyway.

7 MR. SINGH: This question came up last week when  
8 we were got in the NEI conference on fire protection. They  
9 don't want it during the outage, because there's too many  
10 combustibles, too many --

11 MR. GROBE: They don't want us to do an  
12 inspection?

13 CHAIRMAN BARTON: Yes, that's why.

14 MR. SINGH: They emphasized the point that they do  
15 not want the NRC doing inspections in the outage.

16 DR. APOSTOLAKIS: Do you have any IPEEEs yet?

17 MR. GARDNER: Any I what?

18 DR. APOSTOLAKIS: IPEEEs.

19 MR. GARDNER: We have the Generic Letter 88-20,  
20 Supplement 4, IPEEEs that the licensees have been providing.

21 DR. APOSTOLAKIS: So you have their IPEEEs.

22 MR. GARDNER: Yes, we do. If you recall, in fact,  
23 several years ago, Quad Cities released their  
24 5E-to-the-minus three that really stirred up the region to  
25 take action on that.

1 DR. APOSTOLAKIS: I wonder whether you can  
2 prioritize these fire areas that you're inspecting according  
3 to their --

4 MR. GARDNER: And I'll get into that in a minute,  
5 if I could, because that's one of the things we do as part  
6 of our triennial and it's also done by the resident  
7 inspectors when they are looking in their areas.

8 MR. GROBE: Step back for just a second. That's  
9 one of the reasons that we have to spend more time preparing  
10 for these inspections, because everything we do has to be  
11 risk-focused. So something as simple as selecting which  
12 plant fire areas to look at would involve some consideration  
13 of the risk significance of fire areas.

14 DR. APOSTOLAKIS: That's a one-time job, though.  
15 After you've done it, you have it for that time, correct?  
16 Unless something dramatic changes.

17 MR. GROBE: That's correct.

18 DR. APOSTOLAKIS: So it's an initial investment in  
19 a new process.

20 MR. GARDNER: No. What we find, and I'll go into  
21 that. It's changing. It's not a static. It's a dynamic  
22 number --

23 DR. APOSTOLAKIS: But the critical locations,  
24 unless you really change the plant, it's where the cages  
25 come together.

1 MR. GARDNER: Evidently there's other things. We  
2 have found that it's changing, and I'm going to that in a  
3 minute.

4 DR. APOSTOLAKIS: Okay.

5 DR. POWERS: There's a little problem in using the  
6 IPEEEs as the basis for prioritization.

7 MR. GARDNER: Right.

8 DR. POWERS: Because there are some crucial  
9 assumptions that some licensees have made in screening  
10 things out, I mean, things that just don't appear in the IPE  
11 have gotten screened out because though there's a high  
12 combustible loading, you can say, well, there's no ignition  
13 source. I can screen this area out.

14 Well, that's all well and good. What happens when  
15 an ignition source gets introduced?

16 MR. GARDNER: And I hope to get to that point,  
17 too. That's one of the subtle aspects of the new program  
18 versus the old, in that when we postulate a fire that can  
19 affect safe shutdown equipment, we have to be able to  
20 demonstrate how the combustibles, whether they be cables,  
21 scaffolding, whatever, how it can ignite, what is the  
22 ignition source, and then how you can get the fire to  
23 migrate from one part of the fire area to another.

24 In the past, we used to assume it just happened.  
25 We just say you have to assume it happens. Now we have to

1 develop a scenario to show reasonably that it will, in fact,  
2 because of the heat plume and of the effects of that plume,  
3 it will transverse the fire area.

4 So if I don't get into that further, if you need  
5 more when I go through it, let me know.

6 DR. POWERS: There are other subtleties in there,  
7 as well, because a lot of the IPEs have been done saying,  
8 well, the fire barrier penetration seals are 100 percent  
9 guaranteed absolutely effective. And I don't know of  
10 anything that's that guaranteed.

11 It's just one of these problems. You just can't  
12 look at an IPEEE and say, well, this is truth, it's truth if  
13 one person saw it.

14 MR. DAPAS: Ron, do the inspectors look at the IPE  
15 to understand the assumptions before they go out?

16 MR. GARDNER: Yes, and that's what I'm going to  
17 get into in just a couple slides.

18 On page 59, if we can go to that one, we shift  
19 from what the residents are doing on a monthly and a  
20 quarterly basis to an annual inspection.

21 It's always important to understand how the  
22 licensees fire brigade can perform. It may come down that  
23 they are the last of the defense-in-depth for a given fire  
24 area. So we hold them to a high standard.

25 DR. POWERS: We usually just assume that

1 defense-in-depth. In the good old deterministic days of  
2 Appendix R, we just assumed that fires aren't out until the  
3 fire brigade goes in to put it out.

4 MR. GARDNER: That may be true. I don't recall  
5 that.

6 DR. POWERS: Automatic suppression systems were  
7 assumed only to control fire and to actually put it out, you  
8 had to have somebody walk in there and put it out.

9 MR. GARDNER: At 3G, it gives credit for  
10 separation and if you don't have separation, for suppression  
11 and detection.

12 DR. POWERS: It's just suppression. It's not  
13 putting it out. The fire's not over until somebody actually  
14 goes in there and declares it out.

15 MR. GARDNER: From a design approach, it gives  
16 credit for suppression.

17 DR. POWERS: Under the new program, we weigh  
18 suppression. We have a fire mitigation frequency, I don't  
19 know if you're familiar with the new SDF, significance  
20 determination process for fire protection, and there is a  
21 formula for SMF which includes fire barriers, ignition  
22 frequency, and automatic suppression, manual suppression,  
23 and CC, which is common cause.

24 So that is figured in to the equation. Again, on  
25 the resident inspection portion, on an annual basis, they

1 check certain aspects of the fire brigade. What they would  
2 probably do is not ask for the fire brigade, but find one  
3 that is routinely scheduled and observe it.

4 The triennial inspections do not demand that a  
5 licensee do a fire brigade just for the triennial. We would  
6 get information from the residents about whether their  
7 perception of the fire brigade's adequacy was, as well  
8 reading what licensees are finding and documenting their own  
9 critiques of their fire brigade drills.

10 Now, on page 60, I shift to the triennial team  
11 inspection. This is not a classical fire protection,  
12 looking for combustibles. It is more focused on design.

13 And in the preparation aspect, we talk or  
14 communicate, get with the SRAs, the regional SRAs; if they  
15 are tied up, we get with headquarters SRAs, and we get the  
16 risk rankings for different fire areas, and we have found  
17 that the IPEEE can give you some numbers.

18 We go out to the site and we find that those  
19 numbers may have changed. That just happened at Braidwood.  
20 The numbers changed. I don't have all the reasons as to why  
21 it happened, I just know that it did happen.

22 We also look at the transient sequences. All of  
23 this is done in conjunction with the SRAs to assist us in  
24 saying which of these fire areas would probably be the best  
25 for our inspection to focus on.

1           One of the things we may stay away from, by the  
2 way, is the control room. The control room is so analyzed  
3 and has so many people in it that some of the other rooms,  
4 sometimes we think would be more bang for the buck, so to  
5 speak, to look at than the control room, which a licensee  
6 automatically assumes they're going to evacuate anyway.

7           But that is a case by case basis, we'd have to  
8 look again and look at the rankings.

9           We have a very important two to three day full  
10 team information gathering visit. That's where the full  
11 team goes to the plant. They walk down the fire protection  
12 systems, safe shutdown systems. They look at the P&IDs.  
13 They determine what might go wrong. They say that the  
14 licensee is relying on HPSI for makeup and they may look and  
15 say, okay, let's see if we can find a valve that, if it were  
16 to close, would isolate HPSI from the water supply it needs.

17           And then they would check that cable or that valve  
18 to see if it's been protected or not. They would look at  
19 spurious operations, et cetera.

20           So that first two or three days is a very  
21 important aspect of our inspection. Obviously, we look at  
22 risk rankings, we look at things like that.

23           Then we come back into the region for a week, the  
24 whole team does, take that information that they gleaned  
25 from that two to three day bag trip, we call it, and

1 determine their inspection plan.

2 They've finalized the areas they're going to  
3 inspect. They determine some cables, some areas of question  
4 they're going to focus on, and they get just about ready to  
5 go out there and start the inspection as if they had a very  
6 limited time, which they do, by the way.

7 CHAIRMAN BARTON: Wouldn't an inspector go look in  
8 the corrective action system to see how many outstanding  
9 items there are against fire protection system, deficiencies  
10 that haven't been corrected or are backlogged?

11 MR. GARDNER: We don't go into the licensee's  
12 corrective action program in detail. We have a small  
13 percentage of our inspection that looks at that.

14 What we try not to do is mind the licensee's  
15 corrective action program. We try to do an independent  
16 assessment of the licensee's fire protection program.

17 DR. APOSTOLAKIS: On 60, it says that you select  
18 three to five plant areas important risk for inspection.

19 MR. GARDNER: Right.

20 DR. APOSTOLAKIS: Then on 58, you said that you  
21 are inspecting six to 12 fire areas on a quarterly basis.

22 MR. GARDNER: On page 58, I was talking about the  
23 resident inspections. That's covered on a monthly or  
24 quarterly basis.

25 MR. GROBE: And that's just looking at classical

1 fire protection, combustibles, controlled ignition sources.

2 DR. APOSTOLAKIS: But the question is why can't  
3 these six to 12 plant fire areas be ranked according to risk  
4 so you focus on the risk significant areas?

5 MR. GARDNER: We do under the triennial design  
6 inspection. We pick the most risk significant --

7 MR. GROBE: Laura, did you guys, when you did this  
8 module, did you use IPEEE insights to focus risk?

9 MS. COLLINS: We did.

10 CHAIRMAN BARTON: So even the six to 12 areas are  
11 among the --

12 MR. GARDNER: Yes, sir. They are also risk-based  
13 or risk-informed. Excuse me.

14 DR. APOSTOLAKIS: The areas are risk-based. They  
15 come from the PRA.

16 MR. DAPAS: The inspections risk-inform, though,  
17 when they're selected in the areas.

18 DR. APOSTOLAKIS: That's right.

19 MR. GARDNER: The triennial inspection shifts from  
20 the classical fire protection to a design focused  
21 inspection.

22 DR. APOSTOLAKIS: Are these areas, though, you  
23 take them from the licensee's risk assessment.

24 MR. GARDNER: We look at the IPEEE, we talk to the  
25 SRAs and we get the licensee's assessment of the relative

1 risk.

2 DR. APOSTOLAKIS: So you may decide there are additional  
3 that require a tool, even though the licensee may have not  
4 found them to be a not very significant safety.

5 MR. GARDNER: That could happen. I'm not saying  
6 it's going to happen, but it could happen, certainly, if we  
7 found a basis for it. The resident inspector may have a  
8 reason for us to go to a particular fire area based on what  
9 they've been seeing.

10 DR. APOSTOLAKIS: See, that's where the standards  
11 w discussed earlier this morning become very important,  
12 because many licensees have used screening methodologies and  
13 unless you really look carefully at the assumptions that  
14 they have made, you may have missed important five areas.

15 The IFPI-805 is going to solve that, right?  
16 That's why ASME and ANS are not looking at fires. It's an  
17 IFPI that will do it. That means there's something fishy.  
18 You have to understand means this. Go ahead.

19 DR. POWERS: IFPI's expertise in fire risk  
20 assessment, just the personnel on the committee, it's just  
21 very, very limited. It's like one guy that really knows a  
22 lot about fire risk assessment. He may be the only guy in  
23 the country who a lot about fire risk assessment.

24 So to say that we will have a standard that means  
25 that you can look at a five analysis and have some

1 confidence that you don't have to go plowing into the  
2 assumptions. I think that's overly optimistic.

3 DR. APOSTOLAKIS: So they should have given to the  
4 ANS then.

5 DR. POWERS: We haven't see any product from ANS  
6 at all.

7 DR. APOSTOLAKIS: Yes. They are more experienced  
8 fire analysts there.

9 When are we going to review this?

10 MR. SINGH: August 28.

11 DR. POWERS: That's when the committee meeting is.

12 DR. APOSTOLAKIS: Do I have it? You gave it to  
13 me.

14 MR. SINGH: Yes, so you do have it. I have a  
15 question. Did you have a chance to provide a comment on the  
16 NFP-805?

17 MR. GARDNER: I did. I believe I did. It was  
18 some time ago, I believe, and I think I remember --

19 MR. SINGH: Let me ask you another question. When  
20 I was at the conference last week, they discussed this  
21 NFP-805.

22 Did you realize that they have taken out the high  
23 pressure enthalpies from the core and also the -- it's  
24 really watered down.

25 DR. APOSTOLAKIS: The agency is going to endorse

1 it for sure.

2 MR. GARDNER: Isn't it true that 805 will not be  
3 required to be endorsed? Is NFPA-805 going to be required  
4 to be endorsed or is it going to be --

5 MR. SINGH: It's not required, but they are  
6 forcing the NRC to look at it.

7 MR. GARDNER: But licensees will have an option as  
8 to whether they choose to enforcement.

9 DR. POWERS: And I suspect the number of licensees  
10 that will pick it up is going to be zip.

11 MR. GARDNER: That's my point.

12 DR. APOSTOLAKIS: I don't know about that. If  
13 it's nice and doesn't get into too much detail and it's a  
14 national standard, I think the licensees are going to push  
15 for it.

16 DR. POWERS: It makes Appendix R look like a  
17 cavalier off-the-cuff document. It's like doing Appendix R  
18 with a risk assessment.

19 DR. APOSTOLAKIS: That's tragic.

20 MR. GARDNER: Okay. Slide 61, the triennial team  
21 inspection has about 200 hours direct inspection and Region  
22 III is doing it in two weeks, other regions are doing it in  
23 a one week time period. And Region III is an outlier.

24 We think that two weeks gives us more time to  
25 develop our inspection questions and to have the licensee

1 give us the answers in a more deliberate fashion, so that we  
2 feel like we've accomplished what we need to accomplish.

3 DR. POWERS: One of the issues that came up at the  
4 fire protection forum, and if you're not attending those, I  
5 would really encourage you to attend. They are great  
6 meetings that are put on by NEI, but they have lots and lots  
7 of information coming in about lots of things.

8 One of the questions they had, when you take this  
9 bag visit, people have been through this, said, gee, it  
10 works a lot better if the whole team comes for the bag  
11 visit, not just a few guys.

12 Is that what you're planning to do?

13 MR. GARDNER: Yes, sir. In fact, we had the first  
14 plat, which was Braidwood, they questioned us as to why we  
15 had more than a team leader coming. They thought that just  
16 the team leaders only should show up and for the reasons I  
17 spoke to earlier, it's of great benefit for the whole team  
18 to be there, and that's what we plan to do.

19 DR. POWERS: And I think that's the experience in  
20 industry. It makes life a lot easier for them, and actually  
21 NRC got some pretty high praise for the people running these  
22 things, saying that they had -- they get a letter that says  
23 assemble the entire universe of documentation on fire  
24 protection, that the team leaders have been very effective  
25 in whittling that down to what actually was needed and

1 used. So NRC got some real strokes from the licensees on  
2 that, triennial inspections.

3 MR. GARDNER: Going on. We look at the fire area  
4 boundary design. Some plants have been forced, because of  
5 the vintage of the plant, to use huge areas. Quad Cities,  
6 originally, based on their design, used practically a whole  
7 turbine building as one fire area.

8 They and most licensees, through further review,  
9 are trying to narrow the scope of the fire areas to make it  
10 more user friendly, so to speak, for themselves and for the  
11 inspectors.

12 MR. DAPAS: That's because Quad Cities had to use  
13 bounding assumptions, because they didn't know the cable  
14 routing configuration.

15 MR. GARDNER: Yes, and also because unfortunately,  
16 when the first plants were built in the '60s, they didn't  
17 understand that it may be better to have more concrete walls  
18 than fewer, that those concrete walls could, in fact, be  
19 natural fire barriers. Brown's Ferry hadn't occurred yet,  
20 in other words.

21 Safe shutdown system selection adequacy. We see  
22 if the system they chose to have for makeup or for heat  
23 dissipation is functional during the fire or after the fire,  
24 et cetera.

25 System separation evaluation, we look at the 3G2

1 aspects. Any questions about those, I can enumerate on  
2 them. There's three basic ones.

3 When you're doing the inspection, you do a fire  
4 suppression -- slide 62 -- fire suppression.

5 DR. APOSTOLAKIS: What happened to 61? I have a  
6 question.

7 MR. GARDNER: Yes, sir.

8 DR. APOSTOLAKIS: The separation, as I recall from Appendix  
9 R, it says that trace carrying cables or redundant trains  
10 should be separated by at least 20 feet.

11 MR. GARDNER: There are three criteria, 20 feet is  
12 one, . No intervening combustibles, and automatic suppression  
13 and detection, if you use that method.

14 MR. GROBE: That's one exam criteria. Plus  
15 suppression and detection, plus no intervening combustibles.  
16 The 3G2A says --

17 DR. WALLIS: So this is 20 feet in the horizontal  
18 direction.

19 MS. BURGESS: Right.

20 MR. DAPAS: Right.

21 DR. APOSTOLAKIS: But in a PRA context, though, if  
22 they are 20 feet apart, that will, of course, inhibit spread  
23 of fire from one tray to the other, but there is a fire in  
24 the room and they're near the ceiling. Does it matter if  
25 it's 20 feet or 30?

1 MR. GROBE: That's why it requires -- the 20 feet  
2 is permitted, but only with suppression and detection. So  
3 you've got a sprinkler system to knock down the heat, you've  
4 detection to bring the operators in promptly or the fire  
5 brigade.

6 DR. APOSTOLAKIS: But these are all the  
7 defense-in-depth measures. But the separation criteria  
8 means nothing to identification, because you have a layer  
9 that tries --

10 MR. GROBE: It's somewhat of a compromise. There  
11 is a three-hour barrier or 20 feet horizontal with  
12 suppression and detection and no intervening combustibles.

13 The staff concluded that those were approximately  
14 equivalent in protective capability.

15 DR. APOSTOLAKIS: But if I have the suppression  
16 capability, then why do I need the 20 feet? Why is that  
17 important if I have --

18 MR. GROBE: Defense-in-depth. Probability of  
19 failure.

20 DR. SIEBER: If they're right up next to each  
21 other, suppression isn't going to help you.

22 DR. APOSTOLAKIS: I think they had in mind only  
23 propagation from one tray to the other. The fact that you  
24 will have a layer of gases that are hot.

25 MR. GARDNER: Well, if you have the 20 feet of

1 separation, you don't have intervening combustibles, and you  
2 have detection and suppression, we don't affect that the  
3 fire will affect both redundant trains and we will give you  
4 credit and say you are successful, you have protected  
5 adequately.

6 DR. APOSTOLAKIS: If there is a fire somewhere  
7 else in the room generating hot gases, then both the trays  
8 will be --

9 MR. SINGH: No, George.

10 DR. APOSTOLAKIS: No?

11 MR. SINGH: If the fire is in the corner, you  
12 still meet the 20 feet criteria.

13 DR. APOSTOLAKIS: If I have the trays 20 feet  
14 apart, near the ceiling.

15 MR. SINGH: Right.

16 DR. APOSTOLAKIS: And there is a fire in the  
17 corner. Very quickly, if you have enough combustibles,  
18 you're going to have a hot gas layer there.

19 MR. DAPAS: You have a sprinkler system.

20 MR. SINGH: You have a sprinkler system and you  
21 have a detection system.

22 DR. APOSTOLAKIS: So then why isn't the sprinkler  
23 system relevant if the separation is only ten feet? See, we  
24 selectively use it when it's --

25 MR. DAPAS: We can only conjecture what was in the

1 thought process. Some of us were around when that happened.

2 DR. APOSTOLAKIS: I think that you do not  
3 anticipate the hot gas layer from a third fire, that what  
4 they had in mind was spreading from one to the other, in  
5 which case all these measures make sense.

6 MR. DAPAS: We could only conjecture what was in  
7 their thought process.

8 DR. APOSTOLAKIS: There is one fire in the corner.  
9 You don't need a second fire. It is too hot. The reason  
10 I'm saying this is because the first time it was pointed out  
11 was after the first fire PRA was done and people said, yes,  
12 that is correct.

13 MR. GARDNER: Again, though, if you're going to  
14 use 20-foot, you can't have intervening combustibles. If  
15 you get into a diesel generator room, you're probably going  
16 to have to use a three-hour or a one-hour fire barrier.

17 So, you can't just blindly pick 20-foot. It  
18 depends on whether or not there's a chance that a fire that  
19 could occur as you were postulating in the middle. Then  
20 both drains go, but if that can happen, don't try to use the  
21 20-foot. Use another one. Okay? That's where we'd be  
22 looking.

23 One of the things -- on the first slide -- the  
24 first point on slide 62 is the fire suppression damage  
25 assessment.

1           This is the part where, when we come into a fire  
2 area that we've picked and we do the what-if scenario, what  
3 could go wrong, in other words, how likely is it, and then  
4 what are the consequences of it, that's the basis of our  
5 inspection.

6           Licensees would have protected, let's say, through  
7 20-foot separation, three-hour fire barrier, whatever. We  
8 don't find a problem with the barrier and we don't find a  
9 problem with the 20-foot, our rule indicates it's 21-foot,  
10 whatever.

11           We still don't stop, because what we find is that  
12 -- let's say, again, the licensee for a fire in that area is  
13 relying on a charging pump.

14           They have reliance on the BCT to be the initial  
15 source of water.

16           DR. WALLIS: How do you use this ruler when the  
17 conduits aren't parallel?

18           MR. GARDNER: We can take a average plane, a  
19 vertical plane, and walk that off. We can do it. We look  
20 at the valves from the DC-2 -- in fact, we've got this  
21 question at Braidwood.

22           The licensee had a cable for one of the valves on  
23 the BCT that ran through the fire zone and was unprotected,  
24 and it had been overlooked.

25           So, that's the kind of things we look at.

1           Sometimes the licensee has manual actions in a  
2 fire area, and they have -- in their procedure, the operator  
3 will come in and operate the valve manually.

4           At Braidwood, we found they were going into a room  
5 that was going to be 178 degrees. Our question was is this  
6 going to be a good idea?

7           They said water packs, and we said, well, it looks  
8 like he has to be there for cold shutdown. That's 72 hours.  
9 You know, most water packs will start boiling, if you're not  
10 too careful, after so many hours at 170-some degrees. It  
11 won't be boiling, but they'll be darn hot.

12           So, we have issues like that. That's the kind of  
13 thing we do through every fire area we pick, even when the  
14 barriers look pristine.

15           DR. POWERS: The step at which you have to assess  
16 the level of degradation of these is a step I've never  
17 understood very well.

18           MR. GARDNER: What level of degradation?

19           DR. POWERS: Okay. When you come in and you look  
20 at either manual fire capability or the fire suppression and  
21 detection capability, you have to make some sort of an  
22 assessment on the level of degradation -- high, medium, or  
23 low.

24           MR. GARDNER: Right.

25           DR. POWERS: And that's the step I've never

1 understood.

2 What constitutes high and what constitutes low?

3 MR. GARDNER: It is somewhat subjective. I'm not  
4 sure it is completely objective.

5 Let's say you found the BCT valve and now you say  
6 I have a potential fire area degradation; I want to run it  
7 through a SDP screening.

8 Phase one, which would be just a cursory, is there  
9 a potential for any significance, you whip right through and  
10 say yes.

11 You go into a phase two and you have to calculate  
12 the fire mitigation frequency, which uses, then -- which  
13 requires you to have first an ignition frequency for  
14 whatever combustibles are in that room, it looks at the  
15 barriers, and if there is degradation of the barriers,  
16 starting with the fire barriers, you do a moderate or --  
17 what's the term? -- highly degraded, I think, and those have  
18 numbers that adjust the risk.

19 That's somewhat subjective.

20 DR. POWERS: Yeah. I mean the numbers that are in  
21 there, that you actually plug into the formula -- I even  
22 actually found out where they came from, and they come out  
23 fine, but you have to make the subjective judgement on these  
24 things, what's the level of degradation here, and that was  
25 the step I never understood, and I have a set of notes from

1 the BNL course to see if I could understand better just that  
2 exact issue.

3 MR. GARDNER: I went to the BNL course, and I  
4 don't think the notes will help you.

5 What will happen is this -- whatever method -- and  
6 we usually are fairly conservative -- you go to, you will  
7 come out with, let's say, a white issue. That doesn't end  
8 the process. That's when you start refining the level two  
9 evaluation. You'll get the SRAs. The licensee will get  
10 their own SRAs in there.

11 You will elaborate to the licensee what  
12 assumptions you used to come to a white conclusion. One of  
13 them would be that you're assuming significant or high-level  
14 degradation to the fire barrier or the manual suppression,  
15 whatever it may be that you're doing in that part of the  
16 calculation, and the licensee would obviously come back and  
17 say they think it's moderate, and the difference between  
18 moderate and significant can make you from a green to a  
19 white, as you know.

20 DR. APOSTOLAKIS: But shouldn't the ultimate  
21 criteria, though, be, really, the relative speed with which  
22 a fire is expected to spread, how quickly you can stop that.  
23 That really should be the ultimate criteria.

24 MR. GARDNER: That's a part of it. It's much more  
25 complicated than that.

1 DR. APOSTOLAKIS: Like what else?

2 MR. GARDNER: Well, ignition frequency -- okay.  
3 First of all, you have to postulate --

4 DR. APOSTOLAKIS: Oh, you mean when you deal with  
5 --

6 MR. GARDNER: -- the plume and that there is a  
7 potential for --

8 DR. APOSTOLAKIS: But suppression deals with a  
9 fire that's already there.

10 MR. GARDNER: Yes.

11 DR. APOSTOLAKIS: So, Dr. Powers asks how do you  
12 decide that degradation is significant. What I'm saying is  
13 the criterion really should be can you arrest the growth of  
14 the fire before it does damage.

15 DR. POWERS: That's not the way the thing is set  
16 up, George.

17 DR. APOSTOLAKIS: I know it's not, because it was  
18 not done using risk assessment.

19 DR. POWERS: Yeah, it was. It was done using your  
20 wonderful fire technique.

21 DR. APOSTOLAKIS: No. No. We very clearly have  
22 an equality there. The time to damage has to be less --  
23 greater.

24 MR. GARDNER: I think if you're familiar with the  
25 fire protection SDP process, you can see that they have

1       tried to make --

2               DR. APOSTOLAKIS:  It's very hard to do.

3               MR. GARDNER:  -- a mathematical estimate of the  
4       significance, and I think the fire protection is less  
5       subjective than the internal events.  It makes it more  
6       difficult and it makes the people that use it have to be  
7       more sophisticated in their capability to understand risk  
8       and how to use it, but it's not perfect, and we're going to  
9       use it, and just like with the other one, we'll probably be  
10      revising it before long.

11              Continuing on with operator recovery action, when  
12      the fire has been somewhat put out, there's still smoke  
13      removal, de-watering.

14              At FERMI, we had six or seven hundred thousands of  
15      gallons of water to -- because of surface contamination --  
16      to decontaminate, and you'd be surprised at the public  
17      outcry when you tell them you're going to put it through  
18      filters and send it out to the lake.

19              DR. POWERS:  I'm not going to be surprised.

20              MR. GARDNER:  That's quite tricky.

21              Control re-unitization -- you try to re-establish  
22      your power systems that you've lost, get all your systems  
23      back now, instead of the ones that got you to safe shutdown,  
24      and return to service.

25              We also do a manual fire-fighting capability

1 assessment just to assist us with the SDP if it becomes an  
2 issue.

3 As parts of the design aspect we're looking at --  
4 and that's slide 63 and 64 -- we're looking at electronic  
5 circuit analyses common enclosure, high-impedance faults,  
6 spurious circuits.

7 If you want to discuss a high-impedance fault,  
8 it's an arcing fault.

9 Any of those things I could talk to you about in  
10 specifics, but in general, just for the purpose of what we  
11 do, is we're looking -- as electrical engineers, we're  
12 looking at common enclosure, associated circuit faults.

13 We're looking at common power supply. This goes  
14 into breaker coordination, fuse coordination.

15 A high-impedance fault is not your classical  
16 volted fault. It's not the one where you're estimating the  
17 contributions of your inductive motors. As they start  
18 stopping, they will actually feed faults, and when you're  
19 doing a normal fault analysis, you have to get all your  
20 contributions.

21 In this case, you're just doing a -- assuming that  
22 the fault is what they call a arcing fault, and that  
23 actually can be of more problem than a volted fault.

24 DR. APOSTOLAKIS: How can you have a spurious  
25 signal from an open circuit? Can you give me an example?

1 MR. GARDNER: If you have a circuit that's  
2 supposed to be open and you have a dual ground -- first  
3 ground on one side of the contact that's open and then you  
4 ground the other side, you now create a bypass around that  
5 closed -- an open circuit.

6 DR. POWERS: The Europeans, in testing their new  
7 modern cable insulation, found out that open circuits became  
8 closed circuits, because there was some copper oxide in the  
9 material that got reduced by the boric acid or borate that  
10 they put into it, and open circuits all became closed. I  
11 mean it was a conduction pathway.

12 MR. GARDNER: Sure.

13 DR. POWERS: And so, needless to say, they've kind  
14 of redesigned that new super insulation.

15 MR. SIEBER: Why are high-impedance faults more  
16 significant sometimes than volted vaults?

17 MR. GARDNER: If you can visualize the fact that  
18 you have a distribution panel -- let's say it's feeding  
19 125-volt DC and you're feeding, let's say, three loads that  
20 are part of your safe shutdown, and then you have four or  
21 five loads that aren't, but unfortunately, those four or  
22 five loads run through the fire area, and we will postulate  
23 that you will have multiple high-impedance faults on each  
24 one of those loads that runs through that fire area.

25 Each one of them could be an arcing fault, which

1 means the current of that fault will be slightly less than  
2 its breaker.

3 So, the combination of all of those currents can  
4 equal the tripping of the supply breaker to the whole  
5 distribution panel, which cuts off the power to the one you  
6 needed to suppress the fire or to deal with the fire.

7 MR. GROBE: We have about 30 minutes left. We're  
8 still in fire protection, and then we had a discussion of  
9 on-line maintenance.

10 Is your preference to stay with fire protection?

11 DR. POWERS: I would like to.

12 MR. GROBE: Okay. And if we have a few minutes --  
13 Laura, I'm kind of cutting you off, but -- Laura and Mike.  
14 If we have a few minutes, we'll talk about on-line  
15 maintenance; if not, then we'll just conclude with fire  
16 protection. And we'll skip the break.

17 MR. GARDNER: Any other questions about hot  
18 shorts, open circuits, high-impedance faults, common  
19 enclosure?

20 DR. POWERS: Well, you'll never get a resolution  
21 on that between the NRC and the licensees.

22 MR. GROBE: Well, you're not going to get it from  
23 us.

24 DR. POWERS: I understand. I'm asking for  
25 prognostication, not resolution here.

1 MR. GARDNER: I think you're talking about the  
2 classical question that's confronting us about whether a  
3 licensee has to assume multiple hot shorts versus a single.

4 That issue we wrote a TIA on, which is a task  
5 interface agreement, and we have not seen the definitive  
6 answer yet.

7 There have been meetings between the staff and NEI  
8 and the owners groups.

9 I believe, in talking to the staff, they're pretty  
10 sure that our position is going to be the position, but I'm  
11 sure if I talk to NEI, they'll probably tell me the  
12 opposite.

13 DR. POWERS: Are your licensees in this particular  
14 regional happy with that, or are they resisting?

15 MR. GARDNER: No, but Braidwood -- Commonwealth  
16 Edison is one of the licensees, and they were the basis for  
17 our task interface agreement. They emphatically said one.

18 MR. GROBE: Put some time-frames on it, Ron. The  
19 TIA was based on Dresden, wasn't it, and that was about four  
20 years ago?

21 MR. GARDNER: Yeah, four years ago, I'd say, we  
22 wrote that, right.

23 MR. CALDWELL: I think we were the first region to  
24 really address the issue.

25 MR. GARDNER: It might have been, yeah.

1 MR. SINGH: Hey, Ron? Does Perry have that same  
2 similar problem?

3 MR. GARDNER: Who's that?

4 MR. SINGH: Perry?

5 MR. GARDNER: As far as their position?

6 MR. SINGH: No, I mean do they comply with their  
7 hot short issue?

8 MR. GARDNER: When you're talking about hot  
9 shorts, you mean do they assume multiple hot shorts?

10 MR. SINGH: Yes.

11 MR. GARDNER: I'm not sure. We're getting ready  
12 to go to Perry, and one of the next two inspections will be  
13 Perry, and we'll find that out.

14 I didn't keep a catalog of who does what. We're  
15 going to pick them up on the FPI, and hopefully that will  
16 give NRR an opportunity to come to one position or the other  
17 when we find it during these inspections.

18 MR. CALDWELL: I think we scheduled our fire  
19 protection inspections to target those plants where we  
20 thought we would probably have the most question in terms of  
21 their approach, if I recall correctly.

22 MR. GARDNER: We did Braidwood partially for that  
23 reason. That was the first one. Perry is number three, and  
24 we're going to be looking at that.

25 Actually, we also picked Quad-Cities in December,

1 because Quad-Cities will complete, we hope, all of the  
2 modifications necessary to establish full compliance with  
3 Appendix R by November, which would make our December  
4 inspection like just in time, and if you have any questions  
5 on Quad --

6 DR. APOSTOLAKIS: Was there a high number?

7 MR. GARDNER: Yes.

8 DR. APOSTOLAKIS: The result of wrong analysis,  
9 very conservative analysis, or are they actually doing  
10 anything about it?

11 MR. PARKER: It depends on who you ask.

12 DR. APOSTOLAKIS: See, that's why I'm asking.

13 MR. PARKER: The licensee pointed out that there  
14 were some over-conservatisms in their analysis. So, they  
15 had to make some bounding assumptions.

16 So, that was part of it, and then they did  
17 implement some compensatory actions and were making  
18 modifications, because they did agree that their plant had a  
19 high fire risk vulnerability, but they claimed the 5 times  
20 to 10 to the minus 3 was really over-stating the full  
21 as-found condition, if you will.

22 MR. GROBE: You have to appreciate that the  
23 refined analysis with significant improvement is still 5 10  
24 to the minus 5. It's not low-risk, but it's equivalent to  
25 their --

1 DR. APOSTOLAKIS: Just from fire.

2 MR. GROBE: Yeah, just from fires.

3 We have two more topics. One's the SDP, which I  
4 sense a lot of familiarity with. The other is -- we've put  
5 together some slides on Quad, if you guys are particularly  
6 interested in Quad.

7 DR. POWERS: I think we can get Quad from another  
8 route.

9 MR. GROBE: Okay.

10 MR. GARDNER: Okay.

11 I can finish the last two slides, then.

12 Sixty-five is where I was headed.

13 The next, baseline use of risk information at the  
14 baseline fire protection inspection -- and as I tried to  
15 state earlier that both the triennial and the resident  
16 inspections are using risk information to guide where they  
17 look and how significantly and deeply they look when they  
18 pick those areas; also, that the fire protection  
19 significance determination process is in its own  
20 compartmentalized document, and it's IMC-0609, Appendix F,  
21 and that's a good document to have available if you're going  
22 to be following fire protection issues.

23 DR. POWERS: At least in the version they gave us,  
24 there's an egregious typographical error in Appendix F.  
25 When you go through the calculations, you come up with --

1 depending on how you read the typographical error, either  
2 with astronomical numbers for any plant or minuscule numbers  
3 for any plant.

4 MR. GARDNER: We had tried it a few weeks ago at  
5 Brookhaven, and we didn't find any errors like that, so  
6 maybe the version we had was a later version.

7 Slide 66.

8 We would expect that the resident inspector, with  
9 their understanding of the fire protection issues and the  
10 complexity of the SDP, would only be involved in phase one  
11 screening.

12 If it looks like it had to go further, they would  
13 engage the region and the SRAs.

14 The inspection team, however, will do a phase one  
15 and a phase two, and if, in fact, we find that the phase two  
16 is heading us towards other than green, we would continue to  
17 do that, and that would be a more protracted evolution, with  
18 inputs from the licensee and more refinement with the SRA in  
19 helping us to look at our assumptions and seeing if we were  
20 overly conservative.

21 That was all I had prepared.

22 Jack indicated I have some material on Quad, but  
23 you indicated you didn't need that.

24 So, any questions you have on this material, I'd  
25 be glad to discuss.

1 MR. SIEBER: I think your presentation was very  
2 good.

3 MR. GARDNER: Thank you.

4 MR. GROBE: You can tell, this is about as excited  
5 as Ron gets, but this and the SSDI inspection we feel are  
6 very meaningful inspection efforts. You can really find  
7 stuff with this kind of inspection, and we're excited about  
8 both of those inspection efforts, very detailed,  
9 design-oriented, intrusive-type inspection.

10 If there's a problem, we could find it with this  
11 type of inspection.

12 MR. PARKER: I hope all our inspections are  
13 meaningful, though.

14 MR. GROBE: Yeah, but these are new tools that we  
15 didn't have before.

16 DR. APOSTOLAKIS: There are no performance  
17 indicators. They are planning to --

18 MR. GARDNER: No, sir. I think we haven't --  
19 we're not smart enough to figure out which ones would be  
20 relevant.

21 DR. POWERS: Great men have tried.

22 MR. GARDNER: That's right.

23 DR. APOSTOLAKIS: How about fires, the number of  
24 fires?

25 DR. POWERS: It just turns out to be meaningless.

1 MR. SIEBER: They're mostly wastebasket fires.

2 MR. GROBE: And they're fairly frequent. You'll  
3 have a couple of fires a year.

4 DR. SEALE: Any good performance indicator is  
5 something that is not so rare that, in itself, it's a  
6 catastrophic event. So, you want something that happens  
7 every once in a while as a performance indicator.

8 DR. POWERS: Yeah, but wastebasket fires just  
9 aren't going to do anything.

10 DR. SEALE: I agree with you. I'm saying the  
11 frequency is not the problem. It's the wastebasket.

12 MR. GARDNER: I think we're also concerned,  
13 though, that a low number might lull you into a false sense  
14 of security.

15 So, there's some danger on taking any number and  
16 saying that is going to make your determination as to  
17 whether you're there or not as far as defense-in-depth.

18 DR. POWERS: With NFPA, when they tried to do it,  
19 they ended up putting in this incredible core of Appendix R,  
20 essentially, kinds of inspections and deterministic  
21 activities, because there was no way to say, okay, if  
22 they're doing all this, this indicator will indicate that.

23 MR. GROBE: I think you could develop an indicator  
24 that could result in your ability to cut back in the  
25 classical fire protection inspection area, but this and the

1 SSDI are very design-oriented, and I can't think of any  
2 performance indicator that could result in you giving  
3 justification to cut back in this area, because this is  
4 focusing not just on ignition sources or initiating events,  
5 those kinds of things. I think we could develop an  
6 indicator in those areas. It's focusing on did your  
7 engineers do a good job designing it, in a very complex  
8 design.

9 DR. POWERS: And are your people maintaining it  
10 and subverting it inadvertently?

11 MR. CALDWELL: Right. In actuality, the  
12 performance indicator is the results of the inspections over  
13 a period of time.

14 DR. POWERS: Yeah, that may be it.

15 MR. PARKER: When we met in Region II to discuss  
16 inspection resources and how we were going to implement the  
17 new program and what is the appropriate estimated number of  
18 hours, there was discussion about the frequency of these  
19 inspections, and I think there was the recognition across  
20 the regions that the safety system design inspection and the  
21 fire protection inspection were -- the two inspections where  
22 probably the most risk-significant findings will emanate,  
23 and as a result, do you want to continue with that intrusive  
24 inspection, versus looking at performance indicators, and  
25 so, there was that discussion.

1 DR. POWERS: One question, in thinking about  
2 smoke, are you staying aware of these difficulties people  
3 are having with their assumptions on how well-sealed their  
4 control rooms are?

5 MR. GARDNER: You mean to keep the smoke out of  
6 the control room?

7 DR. POWERS: Yeah, leakage rates.

8 MR. CALDWELL: The control room habitability has  
9 been a problem as long as I've been in this agency.

10 DR. POWERS: We're seeing occasions of enormous  
11 discrepancies between what's assumed in the FSAR and what  
12 the actual tracer gas types of mixing are. I mean they're  
13 just not even close. I mean it wasn't even a good guess.  
14 And it's really because the FSAR is writing about what  
15 somebody drew up on a piece of paper.

16 MR. GROBE: That in-leakage is when the door is  
17 closed. If you have an event, that door is going to be  
18 opening and closing on a regular basis.

19 DR. POWERS: That's another question that comes up  
20 on the leakage test, is there's a lot of other things  
21 happening. The HVAC system gets manipulated around and  
22 changed, may be off, and whether the test actually relates  
23 to the environment during an accident, but over and above  
24 that, even with the test and the conditions you have, we're  
25 seeing huge discrepancies.

1 MR. SIEBER: Well, the duct work is like a furnace  
2 duct in your house, and it deteriorates, too. They use  
3 those Pittsburgh seams to hold them all together.

4 MR. GARDNER: Well, there's also an over-reliance  
5 on IEEE-383, I think, cable fire tests, to say that that's  
6 the end-all to say I won't catch fire.

7 In reality, all that does is raise the ignition  
8 temperature, but once it's ignited, it burns faster and  
9 hotter than a non-IEEE-383 cable.

10 DR. POWERS: I've heard that.

11 MR. GARDNER: It's true.

12 DR. POWERS: I have not seen the data, but that's  
13 definitely what I've heard.

14 MR. GARDNER: Yeah.

15 DR. POWERS: But on the other hand, we also find  
16 that aging cables are less combustible.

17 DR. SEALE: They've already evaporated.

18 DR. POWERS: It's actually a cross-linking thing  
19 and you get rid of the plasticizers, which are the real  
20 flammable part.

21 MR. GARDNER: It's the oxygen scavenging from the  
22 neutrons, yeah.

23 MR. GROBE: Any other questions?

24 Laura, you're on.

25 MS. COLLINS: We can be brief. We don't have that

1 many slides. I'll answer whatever questions you have.

2 DR. POWERS: If you haven't learned by now, the  
3 ACRS has an infinite supply of questions.

4 MS. COLLINS: I'm going to talk on the topic of  
5 risk associated with on-line maintenance, and we have a  
6 procedure in the new baseline inspection program that's  
7 carried out by the resident inspectors, and it's actually  
8 7111.13, titled "Maintenance Risk Assessments and Emergent  
9 Work."

10 Part of that inspection, we would sample between  
11 five to eight maintenance activities per quarter, and that's  
12 dependent on a unit size, and I'll say right up front that  
13 this is a lot more emphasis on reviewing these types of  
14 assessments than we had under the old core program.

15 The concept is to evaluate the effectiveness of  
16 the licensee's risk assessment and control of the  
17 maintenance activities.

18 That's the objective, and this was really  
19 developed because we knew (a)(4) was coming, (a)(4), the  
20 requirement of the maintenance rule, which, really, under  
21 (a)(3), we previously said they should do a risk assessment,  
22 and they were for the most part, but we didn't have -- it  
23 wasn't really a requirement, so now it's becoming a  
24 requirement.

25 Since we knew it was coming, we put it in a

1 baseline inspection program and we've been doing it kind of  
2 ever since then, but I will say, because of that, and  
3 because (a) (4) isn't fully in effect, we really anticipate  
4 more changes to this procedure.

5 We've had two throughout the pilot program. The  
6 guidance is changing. My understanding is that NRR is even  
7 going to come out to the region and do a temporary  
8 instruction, go out to the licensee's facility and really  
9 see what they're doing and what we should be looking at, to  
10 help us, I think, define what a finding is going to be in  
11 this area.

12 On the next slide, I've just written down the  
13 inspection objectives from the inspection procedure.

14 We looked at planned work. We also look at  
15 emergent work, and then the last bullet is verifying that  
16 the licensee has adequately identified and resolved problems  
17 in this area, and that's just a standard thing we have in  
18 all of our inspectable areas.

19 If they come up with some kind of problem in this  
20 area, we can select that and go in and see what they do  
21 about it to fix it.

22 MR. BONACA: Some of the emphasis in -- you know,  
23 in the rule is manage risk. Any consideration to limit the  
24 risk? That's a question which is somewhat open, because in  
25 absence of criteria and in absence of tools to quantify the

1 risk, I mean it seems to me like there is some option there.

2 We were shown yesterday that, you know, increasing  
3 risk from a baseline of about a factor up to 10 is not  
4 considered high enough increasing risk that you have to go  
5 to management for approval. It's a judgement. It depends  
6 on how low your baseline is.

7 So, any sense on how this is being implemented at  
8 the sites?

9 MS. COLLINS: Well, we can go on to the next  
10 slide, where I start to talk about our inspection  
11 techniques.

12 MR. BONACA: Okay.

13 DR. WALLIS: I was going to ask you -- I see  
14 you're evaluating effectiveness several times and you're  
15 looking at adequacy. Is there a lot of judgement involved  
16 in this?

17 MS. COLLINS: Absolutely.

18 DR. WALLIS: It's all judgement.

19 MS. COLLINS: It's all judgement at this point,  
20 and we're looking forward to new guidance and new  
21 information from NRR, as I said a minute ago, to what would  
22 be a finding in this area.

23 Even right now, we have preliminary information in  
24 our inspection procedure that I understand is from the NEI  
25 guidance which we're endorsing with our reg guide, and

1 there's different levels with increase in CDF and increase  
2 in CDP, and I had an inspector call me recently because I  
3 was in a pilot program and say, well, I'm here at this plant  
4 and they don't calculate increase in CDP, they only do CDF,  
5 what do we do about that?

6 I don't know what we do about it at this point.

7 You know, we're going to -- those are the kinds of  
8 questions and some of the feedback, I think, that we've been  
9 giving throughout the pilot program to the program office,  
10 that not only do we need guidance for licensees, but we need  
11 the guidance for the inspectors to say what is really an  
12 issue in this area?

13 DR. APOSTOLAKIS: Now, the NRC staff developed  
14 this upper bound on the CCDP of 5 10 to the minus 7, I  
15 believe. Why can't we use that here?

16 I mean instead of having a licensee say, well,  
17 gee, I'm really managing risk, because under exceptional  
18 circumstances, all I'm doing is raising the CDF by a factor  
19 of 3 and I'm already very low, but in the context of, what  
20 was it, allowed outage times, they came up with this number  
21 of 5 10 to the minus 7, which means about three hours you  
22 have a CDF of some value.

23 Can that be -- you know, lacking anything else,  
24 why can't that be a starting point for evaluating or  
25 verifying how the licensees manage the risk?

1 MR. PARKER: There are some thresholds in some of  
2 the documents. The problem I think Laura is pointing out is  
3 there's no requirement.

4 So, if the licensee were to exceed those and the  
5 residents and the SRAs or challenge the utility, what do we  
6 do with that and how do we address that?

7 DR. APOSTOLAKIS: The 5 10 to the minus 7 is one  
8 of the Region V risk-informed regulatory guides. It may not  
9 be a requirement here.

10 DR. POWERS: It's an allowed outage time.

11 DR. APOSTOLAKIS: Yeah. Well, it's an increase,  
12 an increase in CCDP.

13 MR. PARKER: But I think Laura's point is that  
14 this task group is looking at the maintenance rule,  
15 implementing procedures associated with (a)(4) here. We  
16 would assess that, you know, what is a finding.

17 If we identify that the licensee did a CCDP and  
18 determined it was greater than 5 times 10 to the minus 7, in  
19 what context do we put that on the table, what's our  
20 assessment of that, etcetera.

21 DR. APOSTOLAKIS: I'm not saying this is the  
22 answer. I'm saying at least there is a starting point there  
23 where somebody thought about it and came up with a footnote  
24 that is really very nice. We don't know what to do, but  
25 let's assume this.

1 MR. BONACA: Yeah, because -- in part, also, is  
2 because -- I mean the risk increases associated with how  
3 many components you're taking out of service and what kind  
4 it is.

5 Now, especially for those power plants that are on  
6 24-month cycles, they have plenty of time over two years to  
7 do maintenance on-line without taking multiple components  
8 out of service.

9 So, what does it mean, this managing risk? I mean  
10 does it mean that since I can go up to whatever I want, I  
11 can take five components out of service simultaneously.

12 There is a balancing act there that I don't think  
13 has been properly defined, and that's why I was asking those  
14 questions.

15 DR. APOSTOLAKIS: Maybe that will be the next  
16 round of refinement. We haven't really had a chance to  
17 think about these things.

18 MR. CALDWELL: First of all, at least there's a  
19 recognition that they have to put something in place to do  
20 an assessment of it.

21 I guess I'm a little removed from the inspection  
22 program, but what Laura is saying -- we don't have the  
23 criteria or guidelines yet to do an assessment of it. But  
24 at least we're requiring them to do an assessment.

25 As we get smarter, those licensees that -- they

1 actually know what is good and what's bad. Those licenses  
2 that -- because we don't have the tools yet or the whip or  
3 whatever, the lever -- that want to push the envelope will  
4 be the ones that we catch as we get smarter and come up with  
5 our criteria.

6 Those that are good and smart and know how to do  
7 this -- they'll already have set themselves a limit that  
8 will be within where we end up.

9 DR. APOSTOLAKIS: I think the staff, though, at  
10 headquarters should think a little bit about this, because  
11 this is very important.

12 Now, yesterday, as Dr. Bonaca said, we were shown  
13 some spikes in the core damage frequency, but I don't recall  
14 any discussion of the duration.

15 MR. BONACA: There was no duration.

16 DR. APOSTOLAKIS: There was no duration. It was  
17 just the core damage frequency went up, and then they said  
18 themselves, regions -- you know, we told them to change  
19 their names, but they call them now very high risk, high  
20 risk, and so on.

21 But they were prepared to go up by a factor of 10.

22 Now, you might say, well, gee, they're already  
23 starting at 5 10 to the minus -- no, 1.5 10 to the minus --  
24 so, why can't they go to 10 to the minus 4 or a little  
25 higher?

1 MR. BONACA: And they implied that they could  
2 higher if they get management approval.

3 DR. APOSTOLAKIS: I guess the issue you're raising  
4 is, even if the CDF goes up by some number, it's still not  
5 clear that adequate protection is still preserved.

6 MR. BONACA: Absolutely.

7 DR. APOSTOLAKIS: I mean that's even higher.

8 MR. BONACA: The other issue is, even if you stay  
9 within a certain limit, wouldn't just limiting the number of  
10 components you're taking out of service mean good  
11 management?

12 I mean there is the other issue that it doesn't  
13 say that you have the liberty to go wherever you want, as  
14 long as you don't meet a certain number. There is another  
15 way to do it, which is to only limit the number of  
16 components you're bringing out of service.

17 DR. APOSTOLAKIS: But then again, you are going  
18 back to the deterministic way. I would be reluctant to do  
19 that. I would like to explore the CDF and CCDP first.  
20 Instead of calculating probabilities of minimal cut-sets,  
21 count the number of events in there. So, let's be  
22 consistent in our evolutions.

23 I think we should explore the CDF and CCDP issues,  
24 see how far we can go with those, and if necessary, then  
25 we'll go back and limit it more.

1 MR. CALDWELL: For those licensees that have real  
2 strong management, that are interfacing with the plants on a  
3 day-to-day basis, they're no different than we are, and  
4 they're old school, too, deterministic approach.

5 For those licensees, they'll probably do that.  
6 The manager is going to say I don't want the diesel -- I  
7 don't want these six components being taken out at the same  
8 time, I don't care what it says, that doesn't feel good to  
9 me, and you know, until we have a better approach, we're  
10 going to have to rely a lot on licensee management in order  
11 to keep their plant safe.

12 MS. COLLINS: Some of them are pretty developed.  
13 I mean they already have these kinds of limits. The limit  
14 I've seen in the guidance that's coming out -- CDF -- it  
15 says something like 10 to the minus 3 should not normally be  
16 entered.

17 Well, the procedure I'm familiar with is not even  
18 close to that. So, they're already way far away from that.

19 The other thing that I think is kind of  
20 self-limiting is resources, taking these systems out of  
21 components. Oftentimes, they have LCOs that -- they don't  
22 have enough resources to take all this stuff out, equipment,  
23 so I think it's naturally limited that way.

24 DR. APOSTOLAKIS: Let me ask you a question. In  
25 your view, should the criteria be bounds on CCDP or CDF?

1 MR. PARKER: Our procedure has both in it.

2 MS. COLLINS: Yeah.

3 DR. APOSTOLAKIS: Very good.

4 MR. PARKER: It has a threshold of the ICCDP of  
5 less than 10 to the minus 5 and ICCF less than 10 to the  
6 minus 3.

7 So, it's asking the inspectors to look at that if  
8 they exceed either of those thresholds, because some  
9 utilities, like Laura pointed out, are using CDP, some are  
10 using CDF.

11 But you want to -- CDP, I believe, would be  
12 looking at the duration, and you want to factor that in  
13 there.

14 DR. APOSTOLAKIS: If you say that you have an  
15 ICCDP of 10 to the minus 5, that's almost two orders of  
16 magnitude greater than what the NRC staff had proposed.

17 Now, you are NRC staff, too. The other staff.

18 Yeah, we have to really work on those things and  
19 make sure that we have some consistency.

20 MR. PARKER: That's instantaneous, too.

21 DR. POWERS: When you look at these plants, do you  
22 find them taking out multiple systems at the same time?

23 MS. COLLINS: We do find that there are multiple  
24 systems or multiple components at the same time.

25 DR. APOSTOLAKIS: What's multiple?

1 MS. COLLINS: There could be two or three, but --

2 DR. APOSTOLAKIS: Two or three systems?

3 MS. COLLINS: Yeah.

4 MR. PARKER: Some plants may have divisional  
5 outages and take out all their divisional equipment or any  
6 maintenance on a particular division at a time.

7 MR. DAPAS: Train outages. They'll take out maybe  
8 RHR and the charging pump, let's say, associated with the  
9 same train.

10 DR. APOSTOLAKIS: But that doesn't defeat the  
11 whole system, does it?

12 MR. DAPAS: Sure.

13 MR. GROBE: Sure. They'll do maintenance on  
14 several systems on the same train.

15 MR. CALDWELL: Multiple systems within a given  
16 train.

17 DR. APOSTOLAKIS: Is it fair to say, Laura, that  
18 there is a need for guidance in all three bullets?

19 MS. COLLINS: Oh, yes, absolutely, and we know  
20 that there are major changes coming to this. I mean we  
21 already know that.

22 Of all the procedures that we have, this is  
23 probably the one that is sort of newest to the resident  
24 inspectors and where they need additional guidance, and I  
25 think that's a well-known fact.

1 DR. APOSTOLAKIS: Okay. Thank you.

2 MS. COLLINS: When we go to slide 70, though, and  
3 talk about inspection techniques, kind of the way -- what we  
4 do -- we would probably select a planned work week, a week  
5 or so in advance, or if it's emergent, you know, we don't  
6 have that time, and we focus on that work that does involve  
7 the risk-important systems and components.

8 We also tend to focus, I think, on unique  
9 activities or first-time evolutions, and then we take that  
10 safety assessment, we try to understand what the assumptions  
11 are, we talk about the licensee's PRA staff, and their  
12 operations staff, and the next week, perhaps when the work  
13 is going on, we evaluate the plan and the safety assessment  
14 against, really, the conduct of the work to make sure that  
15 it's consistent, and this also applies to shutdown risk  
16 assessments, where configuration of the plant is changing,  
17 and we try to know up front what the assumptions are, this  
18 has got to be back in service before we take this out.  
19 Those are the kinds of things we would go out and check.

20 MR. CALDWELL: Laura said something about we'd  
21 focus in on first-time evolutions.

22 I can tell you that once on-line risk started, the  
23 majority of the transients or events that were caused were  
24 because they transitioned from an activity they did while  
25 shut down to an activity while they were operating and

1 didn't fully evaluate how they were going to get there, and  
2 they either didn't tag out a component correctly or they  
3 operated a piece of equipment the wrong way or whatever that  
4 resulted in a transient.

5           So, it is a good area to focus on as they're  
6 moving to on-line risk.

7           DR. APOSTOLAKIS: Let's say you have a plant  
8 that's a 18-month cycle. If I look at a random -- at the  
9 plant at a random time during that 18-month period, is there  
10 a high probability that some on-line maintenance is going  
11 on?

12           MS. COLLINS: Yes, every week.

13           DR. APOSTOLAKIS: Every week.

14           MS. COLLINS: Yes.

15           DR. APOSTOLAKIS: So, I wonder, then, whether the  
16 -- what so-called baseline CDF is meaningful anymore. We  
17 should revise it to take into account this plant's on-line  
18 maintenance.

19           MR. DAPAS: Supposedly, the SDP accounts for that.

20           DR. APOSTOLAKIS: No, no, no, the baseline, the  
21 PRA itself.

22           MR. DAPAS: When you look at, if a component is  
23 out of service, what's the additional contribution to the  
24 baseline CDF, and there's some assumed amount of  
25 out-of-service time associated with that.

1 DR. APOSTOLAKIS: What I'm saying is you don't  
2 have a baseline. If your baseline is moved to the point  
3 where you have something --

4 MR. SIEBER: You already have assumed a certain  
5 amount of outage time per component.

6 DR. APOSTOLAKIS: Not with on-line maintenance.

7 MR. GROBE: With on-line maintenance, if you look  
8 at the fault tree, there's some component for equipment out  
9 of service time, which can be on-line, can be shutdown.

10 DR. POWERS: What George is saying, I think, is  
11 that that's gotten kind of averaged over the entire year,  
12 and in truth, it's peaked, it's spiked, and so, now he's  
13 moving from spike to spike with maybe a little trough in  
14 between or something like that.

15 DR. APOSTOLAKIS: What we used to call baseline  
16 CDF perhaps is not baseline anymore.

17 MR. DAPAS: It may not truly capture the risk  
18 posture of the plant at the time a piece of equipment is  
19 taken out of service.

20 DR. APOSTOLAKIS: This is a very interesting  
21 thing.

22 MR. BONACA: If they showed that they were  
23 integrating that value, as I've seen other plants do, to  
24 assure that you stay within the assumed unavailability in  
25 the IPE. So, I mean there is a self-controlling mode.

1 DR. APOSTOLAKIS: No, but what they showed us was  
2 that there was a line that said this is 1.5 10 to the minus  
3 5, our baseline, and here we had a spike because we did  
4 this, then we had another spike because we did something  
5 else.

6 Now, Laura is telling me that actually they should  
7 have spiked every week.

8 MR. PARKER: There are typically spikes every  
9 week, but I think you're right, they generally --

10 DR. APOSTOLAKIS: If you have a lot of spikes,  
11 then --

12 MR. PARKER: It has to balance out, because  
13 they're looking at the availability and the un-availability,  
14 and that all should be modeled appropriately within the  
15 scope of the PRA.

16 I understand what you're saying as far as the  
17 spikes, and we need to look at it in a different context.

18 MS. COLLINS: The other part of the maintenance  
19 rule is sort of their annual assessment where they're  
20 supposed to be looking at that, and we also go in -- and the  
21 concept of balancing the unavailability and reliability,  
22 which I guess we assume that, if they meet their performance  
23 criteria for those systems and components, that they've  
24 achieved that goal.

25 So, that's under a different inspection procedure

1 that's done by Division of Reactor Safety. They do that  
2 once a year.

3 DR. APOSTOLAKIS: Okay. I got the answer.

4 MS. COLLINS: Okay.

5 Page 70, the last bullet, I say consult with  
6 senior reactor analysts. If we have some kind of an issue  
7 -- and I say we haven't really decided what a finding in  
8 this area is -- the SDP doesn't apply to these findings.  
9 So, my understanding is that there is a SDP for these kinds  
10 of issues under development in NRR.

11 To date, we've just been using our best judgement  
12 and the judgement of the SRAs.

13 DR. POWERS: Your understanding is our  
14 understanding, and you've apparently seen just as much as we  
15 have.

16 MS. COLLINS: Okay. But I guess the good thing  
17 is, throughout the pilot program, we've seen pretty good  
18 programs with risk assessments, and we haven't identified  
19 what we believe to be any significant issues.

20 DR. POWERS: That does seem to be what we see.  
21 For these planned outages, they're doing good work, they're  
22 doing real good work, and there's an economic incentive,  
23 because people that do well-planned, well-thought-out work  
24 have short outages, costs less money to get more done.

25 The difficulty is what about unplanned and what

1 you call emergent events, and how well is that going to be  
2 done, and I don't have a handle on that.

3 MS. COLLINS: I think in our experience we've seen  
4 it done pretty well, but we don't know what's coming.

5 DR. POWERS: Your experience is extremely  
6 important to me, because you have an experience that I  
7 don't, and so, I take your word very sensitively.

8 MR. DAPAS: There is a spectrum of performance  
9 depending on the licensee.

10 DR. POWERS: I'm sure that's true, but I mean if  
11 the general feeling is, hey, they're doing a pretty good job  
12 here, then I'm going to worry a lot less about it than oh,  
13 my god, can I tell you some horror stories.

14 MS. COLLINS: There are a couple of areas that I  
15 think are of interest to us, and that is how the licensee  
16 might evaluate initiating event frequencies or  
17 probabilities, which is kind of what I'm seeing in the  
18 guidance.

19 Other than weather-related, impending weather kind  
20 of problems, I don't necessarily see a lot of that, and I'm  
21 not sure how that will be done. So that's another area that  
22 I think we'll explore.

23 On page 71, inspection observations, again, I said

24 --

25 DR. APOSTOLAKIS: Yeah, the second bullet -- would

1 you elaborate a little bit? We don't have to go through all  
2 of them.

3 MS. COLLINS: Right. We have seen where the  
4 duration of the maintenance exceeds the planned duration,  
5 but if it doesn't exceed an LCO, there isn't much  
6 involvement we have other than a comment.

7 DR. APOSTOLAKIS: But this is common? Is this a  
8 common occurrence?

9 MS. COLLINS: No, I wouldn't say it's common.

10 MR. BARTON: It happens occasionally, yes.

11 MS. COLLINS: But we've seen it.

12 MR. BARTON: Because you have a system outage  
13 scheduled for 36 hours and it ends up 42 for some kind of  
14 problem, and that happens not too infrequently.

15 MR. DAPAS: And I just wanted to comment -- this  
16 has brought to bear an issue where the procedure would ask  
17 us to assess is the actual time to execute the maintenance  
18 greater than planned, okay?

19 You're asked to look at that as part of the  
20 inspection procedure. Then what do you do with that,  
21 because does that really translate to an increase in risk,  
22 and they're within the LCO time and they may be within the  
23 time assumed as part of your baseline CDF.

24 What do you do with that, and that's one of the  
25 questions that we've been wrestling with with the program

1 office.

2 MR. BARTON: I think you understand why it is it  
3 happens, and if it's the same cause that always happens,  
4 then you've got an issue.

5 MR. DAPAS: You're right, but again, the result of  
6 that has to be some increase in CDF that crosses some  
7 threshold where you can land that issue with the licensee  
8 and engage them, versus an observation per se.

9 DR. POWERS: It's like drunk driving convictions.  
10 The penalties are very severe in New Mexico for the second  
11 one, but since they always excuse the first one, nobody ever  
12 has a second one.

13 MR. PARKER: We've seen that happen on occasion,  
14 and the SRAs have gotten involved on a few of the issues  
15 where the licensee's risk assessment assumed, let's say, 36  
16 hours on a 72-hour, and they had some bounding analysis, and  
17 now, because of parts availability or some additional  
18 concern, they might have went up to the 72-hour, and so,  
19 we've asked the residents, that this is a good opportunity  
20 to challenge the utility on their risk assessment and their  
21 bounding analysis and go back to risk assessment and see if  
22 the licensee is comfortable with the new numbers, where it's  
23 taken them.

24 DR. POWERS: It's also a good vehicle for asking  
25 them about the uncertainty in their analyses, what kinds of

1 things did they think about that might change their numbers?

2 DR. WALLIS: If this is a best estimate, then half  
3 the time the duration will exceed the plan, roughly  
4 speaking.

5 DR. POWERS: Based on the reports I see, I think  
6 most maintenance is less than the plan.

7 DR. WALLIS: Less than the planned time?

8 DR. POWERS: Yes.

9 DR. WALLIS: So, it isn't so bad that a few take  
10 longer.

11 MR. DAPAS: Getting back to Mr. Bonaca's point, I  
12 would offer that a licensee that is managing the risk would  
13 say, okay, if we run into a problem, then here is the risk  
14 if it takes 72 hours versus 20, and that's a sufficient  
15 increase, now we want to doubly insure we've got parts and  
16 we've, you know, done mock-up training or what have you to  
17 ensure the actual time is bounded.

18 DR. WALLIS: But surely all you're really  
19 interested in is the average over all the maintenance you  
20 do, and the fact that some may take longer and be a bit more  
21 risky doesn't matter, as long as it's compensated for  
22 throughout the year or whatever by the others that take less  
23 time.

24 MR. CALDWELL: We probably have a little more time  
25 than we anticipated. O'Hare is closed right now. So, we're

1 calling on your particular flights to find out what that  
2 actually means.

3 My secretary is going to call and check and see if  
4 it means they've been canceled, delayed, or whatever, and  
5 then we'll let you know.

6 MR. GROBE: We can give you a nice list of  
7 restaurants.

8 MR. CALDWELL: Flying out of O'Hare and into  
9 National, which is what we do when we go to headquarters,  
10 your chances of one of the two of them getting there is 100  
11 percent.

12 DR. POWERS: Now, I know why the risk analysts  
13 here are so busy. They're calculating the probability the  
14 boss is going to get back.

15 MR. GROBE: Other questions on 71?

16 [No response.]

17 MR. GROBE: Mike, do you want to go into a little  
18 bit of what you're doing?

19 MR. PARKER: Yeah. I just wanted to take a little  
20 time and go through some of the observations that Sonia and  
21 I had during our SRA site visits.

22 We went out to all the sites over the last --  
23 probably -- I think it was six months to a year ago, and we  
24 went to each one of the sites together as a team and tried  
25 to get a pretty good idea of what tools the licensee has,

1 how they're using them, and how they're integrating into the  
2 organization.

3 So, it was more of an observation visit to  
4 introduce ourselves, to go through the new inspection  
5 program, and how we're going to -- how we would like to deal  
6 with them on risk issues, but some of the things we found --  
7 on-line risk assessments -- most of the utilities were using  
8 a probabilistic risk assessment such as Safety Monitor,  
9 EOOS, or Sentinel.

10 There were a few outliers out there that are still  
11 using deterministic. In other words, they're still using a  
12 matrix or procedure to look at things, and it's more of a  
13 defense-in-depth-type approach, and some of them also have  
14 pre-solved cut-sets that they're using on some of their  
15 on-line monitors, but it looks like quite a few of them,  
16 including Commonwealth, is moving to some very good systems.  
17 They're going to Sentinel at the Commonwealth facilities.

18 So, most of the utilities are using risk programs,  
19 and there's, I think, one or two outliers right now in our  
20 region that are still using matrix procedures.

21 Shutdown risk assessments -- the majority or all  
22 of them at this time are deterministic. Several of them are  
23 matrix procedures with defense-in-depth, and I'd say the  
24 majority at this time are using an ORAM-type program, outage  
25 risk assessment matrix, and that's defense-in-depth.

1           We have seen a couple plants that are in the  
2 region -- I mentioned Perry as an example -- that are  
3 looking at developing shutdown models right now. So, that's  
4 going to be very interesting seeing a full-blown shutdown  
5 model and how they're using that and integrating it into the  
6 organization and into outage planning.

7           So, it will be a very good tool, but they're  
8 completing that. They expect to use it the next outage,  
9 which is in February, and they're hoping to use it for some  
10 of their pre-planning activities right now, and they're  
11 going to tie it back in to -- they need to do some  
12 conversion and put it into Safety Monitor.

13           So, that will be one of our first plants in our  
14 region.

15           I know several plants out west are using shutdown  
16 models.

17           So, that will be very interesting.

18           As far as risk assessments, most of the utilities,  
19 I think, are doing some very good risk assessments.  
20 Generally that's involved with the work week managers and  
21 not the PRA organizations.

22           Generally what we've seen is the PRA organization  
23 or the corporate staff develop the tools and put them in  
24 place and then it's turned over to the line organization to  
25 look at normal work activities, and it's not until they've

1 determined that they have a risk-significant configuration  
2 that they may have the PRA organization get involved and  
3 deal with the issue and look at the acceptability or  
4 challenge the model.

5 MR. BARTON: Well, don't they -- if they have any  
6 changes at all to that planned maintenance, don't they  
7 bounce that back off their PRA groups?

8 MR. PARKER: Right.

9 MR. BARTON: Okay.

10 MR. PARKER: But some of the organizations will  
11 have the line organization where they'll put it in the  
12 schedule and then run the program, and as long as the  
13 program is, let's say, a green baseline, they won't get  
14 involved.

15 So, to address George's question as far as what  
16 happens if they have a higher risk, do they try to balance  
17 that, some of the plants do, other plants will have like a  
18 12-week rolling average or rolling schedule, where they have  
19 certain equipment that comes out periodically, and they will  
20 try to stick with that equipment at that timeframe and to  
21 complete that 12-week cycle. So, they've looked at certain  
22 combinations of equipment that they would like to take out  
23 at the same time.

24 So, they'll try not to manipulate that equipment  
25 and put it into a following week.

1           As far as integrating risk assessments, I think  
2 Laura mentioned that, in general, the information we're  
3 familiar with is licensees are doing a pretty good job at  
4 integrating their emergent work with the pre-planned, and  
5 we've seen a lot of occasions where the licensee has  
6 pre-planned activities, some equipment to identify  
7 degradation. They'll put off or defer or cancel some of  
8 their pre-planned activities so as not to incur that  
9 additional risk, and so, we've seen some good indications of  
10 that, which makes us feel pretty comfortable.

11           Maintenance rule (a)(4) -- as Laura mentioned,  
12 that's not out yet. I think that's supposed to take effect  
13 in November.

14           There are some direction coming out NRR right now.

15           There's two visits planned for Region III.  
16 There's a visit, I think, in the next few weeks that's  
17 tentatively set up to go to Braidwood, and with the region's  
18 assistance, they want the SRAs, the regional inspector, and  
19 then headquarter involvement just to see how Braidwood does  
20 activities. I think Braidwood was picked because they  
21 indicated they think they have a pretty good program in  
22 place. So, that's a one-day visit.

23           And then the other activity that's being planned  
24 is more of a comprehensive V&V inspection, and that's  
25 planned for Clinton, and that would be more than likely --

1 and I'm somewhat speculating, but I think it's to actually  
2 have the draft TI and see how the utility does things. So,  
3 it would be somewhat of a pilot or just maybe go through the  
4 exercise and see how our procedures develop.

5 MR. DUNLOP: I just got off a phone call a little  
6 while ago about the (a)(4) rule. NRR is not really going to  
7 prepare a TI. What they're going to do is -- in the  
8 verification -- is re-validate the new Attachment 13.

9 So, during the first survey visit to Braidwood,  
10 they'll figure out what kind of -- and at all the other  
11 regions -- they're doing five surveys -- they'll go out,  
12 look at the different types of assessments that the  
13 licensees are doing, come up with a new or revised  
14 inspection program procedure, and then, during the four  
15 verifications -- ours is at Clinton -- verify that the new  
16 procedure will work and it will be acceptable.

17 That's one change that we just found out, that I  
18 had just found out today.

19 MR. PARKER: That's Andy Dunlop. He's with the  
20 maintenance rule in Region III.

21 One of the challenges I think we're going to have  
22 in the maintenance rule -- and like we said, we don't know  
23 where it's all going, but we have some thresholds, there's  
24 some thresholds in some of our reg guides and other  
25 guidance, but I don't know how we're going to deal with the

1 fact if the utilities exceed those thresholds and how they  
2 balance that and what tool do we have to encourage the  
3 licensee to reduce that overall risk, and so, those are  
4 questions that we have outstanding and we'll be involved  
5 with the development of these activities.

6 As far as risk assessments, I think, since the new  
7 inspection program, there's been significant implementation  
8 of the licensee evaluating risk.

9 In the past, as far as events, we've challenged  
10 the utilities, and we didn't see that they were truly  
11 assessing it.

12 So, I think the new revised oversight program has  
13 really forced the utility to look at some of those emergent  
14 work activities and the impact it has or transients, and  
15 we're seeing significant involvement on the part of the  
16 utility to assess that, and Sonia and I are actively  
17 involved in looking at the impact particular transients have  
18 on the plant, overall risk, and communicating that in our  
19 morning meetings and other avenues that we have.

20 We've also seen the utility and we've been  
21 strongly encouraging the utility to address the risk  
22 significance in LERs.

23 An LER asks the licensee to talk about safety  
24 significance of the event of interest, and we're seeing the  
25 utilities taking an opportunity to address what they

1 characterize as the overall risk significance of the  
2 activity as part of the safety significance.

3 So, I think that helps the region and anybody  
4 that's following that particular activity to put it in  
5 perspective. It gives the licensee their first shot, and  
6 then certainly the residents and the SRAs are evaluating the  
7 risk significance of LERs.

8 The last thing is -- Sonia has already talked  
9 about how we're involved with the SDP process in the phase  
10 two.

11 Is there any questions?

12 That's all I have.

13 MR. BARTON: I want to thank you all for a real  
14 informative session and thank you for the work you've put  
15 into it.

16 I think, of the visits we've made, this has  
17 probably been one of the best if not the best, from my  
18 perspective. I don't know how the other members feel, but  
19 it's been very informative and a good dialogue and we  
20 learned a lot.

21 DR. POWERS: Yeah, I'd say that the meeting far  
22 exceeded expectations. I think it was an extremely good  
23 discussion among colleagues in these areas, and we got some  
24 things for us to go puzzle about.

25 I reiterate my belief that the wealth of

1 experience that needs to be injected into this process,  
2 especially as we look to the next year of refining some of  
3 it, because you guys are really finding the rough edges, and  
4 I don't blame the people that put these new systems  
5 together.

6 They had millions of things to take into account,  
7 and they did a wonderful job doing as much as they did, and  
8 they knew they weren't going to get all the rough edges, and  
9 so, now, it's a process of making sure we find out about all  
10 those rough edges and do things, and what we just heard  
11 about on this maintenance rule business is something I  
12 hadn't anticipated.

13 We've clearly got to think about that a lot in the  
14 coming weeks.

15 So, it's starting to make me think. This is  
16 difficult, but I really appreciate it, and we had a  
17 fantastic visit out at Davis Bessie. They really pulled the  
18 stops out for us.

19 MR. CALDWELL: I thoroughly enjoyed this. I  
20 learned quite a bit.

21 I wanted to compliment the staff, those folks that  
22 are here. They did an excellent job, I thought, and Marc  
23 and Jack, and I certainly appreciate that, as I understand  
24 you did.

25 MR. BARTON: I think that's what was better. In

1 our past visits, we've heard from the management of the  
2 region, and I think what was great today is we really heard  
3 from the people that are out there involved in the process  
4 and doing the work and having the interface with the  
5 licensees.

6 MR. SINGH: I just want to thank you, especially  
7 to Bruce Burgess, for his hospitality here. He has been  
8 really helpful, and he has worked since last October to  
9 arrange all this.

10 So, I really appreciate his help.

11 MR. CALDWELL: I think I ought to tell Bruce I  
12 appreciate it, too, because I jerked him around a bunch  
13 today, and it came out relatively smooth.

14 MR. BARTON: On that note, the meeting is  
15 adjourned.

16 [Whereupon, at 3:08 p.m., the meeting was  
17 adjourned.]

---

**UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
REGION III**

---



VISIT OF THE ACRS SUBCOMMITTEES ON PLANT OPERATIONS  
AND FIRE PROTECTION  
JUNE 14, 2000



# **OPENING REMARKS**

---

**DANA A. POWERS**

Chairman, Advisory Committee on Reactor Safeguards  
Chair, ACRS Subcommittee on Fire Protection

**JOHN B. BARTON**

Chair, ACRS Subcommittee on Operations



# INTRODUCTION/ WELCOME

---



**JIM DYER**

Regional Administrator

Region III

# Region III

Lisle, Illinois



# REGION III ORGANIZATIONAL RESPONSIBILITIES

---

## REGIONAL ACCOMPLISHMENTS

- Completion of pilot program for Quad Cities and Prairie Island
- Smooth transition to the revised reactor oversight program
- Completed PPR reviews (end-of-cycle for Pilot Plants)
- Effectively implemented the revised enforcement process
- Established resource accounting focus group and corrected resource expenditure documentation errors
- Improved information technology support for region
- Improved communications (internal and external)
- Wrapping up IMC 0350 programs for region

# REACTOR PROGRAM IMPLEMENTATION

---

**MARC DAPAS**

Deputy Director, Division of Reactor Projects

**JACK GROBE**

Director, Division of Reactor Safety

# DIVISION OF REACTOR PROJECTS

---

- 24 operating reactors at 16 sites
- 75 professional and administrative staff
- Branches organized to provide additional oversight for D. C. Cook

# DIVISION OF REACTOR PROJECTS

---

- Inspection program management
- Continuous onsite inspection
- Residents are the focal point for agency interface with the licensee
- First responders for incident response


# DIVISION OF REACTOR PROJECTS

---

## SPECIFIC DRP INSPECTIONS

- Operations - observations of risk evolutions and event followup
- Maintenance - post maintenance testing and emergent work
- Surveillance testing
- Operability evaluations
  - ▶ 10 CFR 50.59 assessments
- Severe weather preparations
- Temporary modifications
  - 10 CFR 50.59 assessments
- Problem Identification and Resolution
- Performance Indicator Verification

# Division of Reactor Projects



# Division of Reactor Safety

---

- Engineering Inspections
- Safeguards Inspections
- Radiation Protection and Emergency Preparedness Inspections
- Operator Licensing
- Incident Response

# Division of Reactor Safety

---

## ENGINEERING INSPECTIONS

- Safety System Design
- Permanent Plant Modifications
- Maintenance of Licensing Basis
- Fire Protection
- Problem Identification and Resolution (DRP)
- Maintenance Rule
- Heat Sink
- Inservice Inspection
- Performance Indicator Verification

# Division of Reactor Safety

---

## SAFEGUARDS INSPECTIONS

- Contingency Response
- Access Authorization and Control
- Fitness for Duty and Behavioral Observation
- Problem Identification and Resolution
- Performance Indicator Verification

# Division of Reactor Safety

---

## RADIATION PROTECTION INSPECTIONS

- Operational Radiation Protection
- Radioactive Waste and Transportation
- Effluents and Environmental Radiation Protection
- Problem Identification and Resolution
- Performance Indicator Verification

# Division of Reactor Safety

---

## EMERGENCY PREPAREDNESS INSPECTIONS

- Emergency Exercise Evaluation
- Emergency Preparedness Program Review
- Problem Identification and Resolution
- Performance Indicator Verification

# Division of Reactor Safety

---

## OPERATOR LICENSING

- Initial Operator Examinations
- Senior Operator Examinations
- Operator Requalification Inspections
- Problem Identification and Resolution


# Division of Reactor Safety

---

## INCIDENT RESPONSE

- Maintain Facilities and Procedures
- Coordinate Exercises and Provide Training
- Interface with Federal, State, Local, and Tribal Counterparts

# Division of Reactor Safety



# **EXPERIENCE - NEW INSPECTION PROGRAM**

---

**MARC DAPAS**

Deputy Director

Division of Reactor Projects

**JACK GROBE**

Director

Division of Reactor Safety

# EXPERIENCE - NEW INSPECTION PROGRAM

---

## COMPARISON OF NEW TO OLD PROGRAM

1. Old: 33% core, 33% regional initiative, 33% special inspections

New: 95% baseline loaded, 3% supplemental, and 2% special inspections
2. Old: Greater flexibility in applying inspection resources -  
Inspection procedure could be closed using judgement on  
whether intent met

New: Increased structure - inspection procedure scope must be  
completed in its entirety - closely controlled inspection hours

# EXPERIENCE - NEW INSPECTION PROGRAM

---

## COMPARISON OF NEW TO OLD PROGRAM

3. Old: Followed deterministic process and enforcement policy regarding significance of inspection findings

New: Inspection findings processed through Significance Determination Process based on using probabilistic risk analyses

4. Old: More direct observation of plant activities

New: Increased emphasis on inspection preparation and in-office review

# EXPERIENCE - NEW INSPECTION PROGRAM

---

## COMPARISON OF NEW TO OLD PROGRAM

5. Old: 6 month inspection plan (strong emphasis on operations)
- New: 1 year inspection plan (balance between engineering and operations)
- Use of PIs - operations and maintenance
  - Design emphasis in engineering
6. Old: Inspection resources - flexibility in utilization (N+1, inspection scope, regional initiative)
- New: Extended absences or vacancy requires backfilling to complete program

# EXPERIENCE - NEW INSPECTION PROGRAM

---

## COMPARISON OF NEW TO OLD PROGRAM

7. Old: Limited public awareness

New: Greater opportunities for public awareness (PIs and inspection reports on Internet)

# EXPERIENCE - NEW INSPECTION PROGRAM

---

## DRP CHALLENGES

- Inspection planning
- Managing existing inspection resources/ fully staffing positions
- Feedback and dissemination of lessons-learned on inspection program (procedures)
- Initial implementation program review and self-assessment (April - 2001)

# EXPERIENCE - NEW INSPECTION PROGRAM

---

## DRS CHALLENGES

- Inspection planning
- Managing existing inspection resources / fully staffing positions
- Limited risk analysis resources
- Questionable value of some performance indicators (safeguards area)
- Different expertise required in engineering area
- Reduced focus on precursors to risk significant issues

# **SENIOR REACTOR ANALYST PROGRAM**

---

**SONIA BURGESS**  
Senior Reactor Analyst  
Division of Reactor Safety

# SENIOR REACTOR ANALYST PROGRAM

---

## KEY ROLES OF THE REGION III SRAs

- Support the new oversight program
- Provide focused risk perspectives in regulatory decisions
- Evaluate risk of events and inspection findings
- Provide risk insights for inspection planning
- SRA initiatives

# **SENIOR REACTOR ANALYST PROGRAM**

---

## **SUPPORT OF THE REACTOR OVERSIGHT PROGRAM**

- Aid the Region III staff in use of the Significance Determination Process (SDP)
- Perform the Level 3 SDP analyses
- Support the assessment and planning process

# **IMC 0350 PROCESS**

---

**JACK GROBE**

Director

Division of Reactor Safety

**MARC DAPAS**

Deputy Director

Division of Reactor Projects

# **IMC 0350 PROCESS**

---

## **RECENT REGION III 0350 PLANTS**

- Point Beach Units 1 & 2 (10 months 97-98)
- LaSalle Units 1 & 2 (26 months 97-99)
- Clinton (32 months 97-99)
- D. C. Cook Units 1 & 2 (33 months 97-00)

# IMC 0350 PROCESS

---

## **Purpose:**

- Establish Record of Regulatory and Technical Issue Resolutions
- Guidelines for Granting Restart Approval
- Provide Assurance of Safe Operations After Restart

# IMC 0350 PROCESS

---

## Objectives:

- Agency Coordination
- Coordination of Issue Resolution with Licensee
- Establish Oversight Plan
- Provide Method for Communicating to Public and External Stakeholders

# IMC 0350 PROCESS

---

## Oversight Panel Membership:

- Region Division Director (Chairman)
- Director NRR Project Directorate (Vice Chairman)
- Region Branch Chiefs
- NRR Project Manager, SRI, and SRA

# IMC 0350 PROCESS

---

## Panel Responsibilities:

- Review Reason for Shutdown
- Develop Plan & Restart Checklist
- Maintain Ongoing Overview of Licensee Performance
- Determine Inspection Scope
- Assess Readiness for Restart
- Brief Commission and NRC Management
- Meet with Licensee and Public
- Provide Written Basis for Restart Recommendation
- Regional Administrator Approves Restart Recommendation

# IMC 0350 PROCESS

---

## Post-Restart Activities

- Continued Panel Oversight
- Assure Safe Sustained Operations
- Review Post-Restart Issues

# **TRAINING ANALYSIS**

---

**JACK GROBE**

Director, Division of Reactor Safety

**MARC DAPAS**

Deputy Director, Division of Reactor Projects

**SONIA BURGESS**

Senior Reactor Analyst, Division of Reactor Safety

**DAVID HILLS**

Chief, Operator Licensing Branch, Division of Reactor Safety

**RON GARDNER**

Chief, Electrical Engineering Branch, Division of Reactor Safety

# TRAINING ANALYSIS

---

## ENGINEERING INSPECTORS

### Staffing Challenges:

- High turnover rate
- Evolving roles - changing expertise
- Long training period for qualification
- Pool of experienced resources limited (Engineering Firms, Utilities, Military)

# TRAINING ANALYSIS

---

## SAFETY SYSTEM DESIGN INSPECTION (SSDI)

- Multi-disciplinary team of 5 design engineers
  - ▶ Mechanical Engineers
  - ▶ Electrical Engineers
  - ▶ Instrumentation and Control System Engineers

# TRAINING ANALYSIS

---

## FIRE PROTECTION INSPECTION (FPI)

- Multi-disciplinary team of 3 appendix R engineers
  - ▶ Fire Protection Engineer
  - ▶ Instrumentation and Controls/ Electrical Engineer
  - ▶ Systems Operations Engineer

# TRAINING ANALYSIS

---

- **Staffing Accomplishments**
  - ▶ I&C Engineer (PhD - extensive digital experience)
  - ▶ I&C Engineer (extensive Appendix R experience)
  - ▶ Electrical Engineer (extensive industry and inspection experience)
  - ▶ Mechanical Engineer (extensive industry and inspection experience)
  
- Challenges - Mechanical Design Engineer

# TRAINING ANALYSIS

---

## CURRENT AND PLANNED TRAINING

- External Fire Protection/ Appendix R Course
- Internal Heat Sink/ Heat Exchanger Course
- OJT by experienced inspectors and contractors
- Exploring with TTC and other regions discipline specific courses

# TRAINING ANALYSIS

---

## RESIDENT INSPECTOR

### Staffing Challenges:

- High turnover rate (5-12 percent annually)
- Long training period for qualification
- Pool of experienced nuclear resources limited (Navy, Shipyard, Licensee)

# TRAINING ANALYSIS

---

## RESIDENT INSPECTOR

### Staffing Accomplishments:

- Fully staffed resident inspection program (only 1 site N+1)
- Aggressive hiring program for reactor engineer positions

# TRAINING ANALYSIS

---

## RESIDENT INSPECTOR

### Training Challenges:

- Chattanooga training courses limited
- Absence from site for extended periods
- OJT is a large part of training program

# TRAINING ANALYSIS

---

## RESIDENT INSPECTOR

### Training Accomplishments:

- Reduced training length through hiring of high quality individuals
- High quality OJT is provided
- Extensive cross-training

# TRAINING ANALYSIS

---

## SENIOR REACTOR ANALYST STAFFING/TRAINING

### Staffing

- Two Senior Reactor Analysts in Region III
- Consideration of additional risk trained staff

# TRAINING ANALYSIS

---

## SENIOR REACTOR ANALYST STAFFING/TRAINING

### Training

- 18 - 24 month training/certification program

**Classroom:**

- ▶ PWR/BWR technical training
- ▶ Statistics and PRA training
- ▶ SPAR - NRC PRA computer model training

**Rotation:** 9 months of rotational assignments in NRR/RES/Region

# TRAINING ANALYSIS

---

## SENIOR REACTOR ANALYST STAFFING/TRAINING

### Challenges:

- Succession planning for SRA position
- Extensive time needed for training/certification

# Training Analysis

---

## REGIONAL INSPECTOR RISK TRAINING

- P-111 “PRA Technology and Regulatory Perspectives”
- SDP training

# Training Analysis

---

## OPERATOR LICENSING STAFFING/ TRAINING

### Staffing Challenges:

- Difficulty in Retaining Certified Examiners
- Difficulty in Finding Qualified Individuals To Hire
- Long Lead Time in Certifying New Examiners
- Significant Increase In Examiner Work Load Starting in FY-2001

# Training Analysis

---

## OPERATOR LICENSING STAFFING/ TRAINING

### Staffing Accomplishments:

- Budgeted 9 Examiner FTE - Sufficient To Meet FY-2001 Demands
- Approved 3 Examiner Overages
- Hiring Progress

# Training Analysis

---

## OPERATOR LICENSING STAFFING/ TRAINING

### Training Challenges:

- Training and Certifying Several Examiners Simultaneously
- Scheduling of Cross-Certification Training
- Substantial Portion of Examiner Staff Is Relatively New To Examination Work

# Training Analysis

---

## OPERATOR LICENSING STAFFING/ TRAINING

### Training Accomplishments:

- Examiner Certification Progress
- Improved Examiner Proficiency

# **FIRE PROTECTION ISSUES**

---

**RONALD GARDNER**

Chief, Electrical Engineering Branch  
Division of Reactor Safety

# **FIRE PROTECTION ISSUES**

---

In many instances, fire risk is comparable to or exceeds total risk from internal events

# FIRE PROTECTION ISSUES

---

## INSPECTION BASES

### FIRE PROTECTION DEFENSE IN DEPTH:

- Prevent fires
- Rapidly detect, control, and extinguish fires
- Protect Safe Shutdown Capability
  - ▶ Barriers/ separation
  - ▶ Suppression/ detection
  - ▶ Procedures
  - ▶ Equipment/ systems

# FIRE PROTECTION ISSUES

---

## INSPECTION BASES

- No performance indicators currently exist
- New inspection program currently provides no inspection credit for self-assessment

# FIRE PROTECTION ISSUES

---

## RESIDENT INSPECTION

On a quarterly basis, residents tour 6-12 plant fire areas to observe:

- Combustibles/ ignition sources
  
- Fire protection systems, equipment, and features
  - ▶ Material condition
  - ▶ Operational lineup
  - ▶ Apparent operational effectiveness
  - ▶ Fire barriers

# FIRE PROTECTION ISSUES

---

## RESIDENT INSPECTION

On an annual basis, residents observe a fire brigade drill:

- Response time/ number of fire brigade members responding
- Protective clothing, breathing apparatus and fire fighting equipment
- Performance of supporting organizations

# FIRE PROTECTION ISSUES

---

## REGION BASED INSPECTION

Triennial Team Inspection Preparation:

- SRA Risk Insights:
  - ▶ Fire area risk rankings
  - ▶ Transient sequences
- 2-3 day full team information gathering visit
- Selection of three to five plant areas important to risk for the inspection plan

# FIRE PROTECTION ISSUES

---

## REGION BASED INSPECTION

Triennial Team Inspection Conduct:

- 200 hours direct inspection effort in 1-2 weeks
- Fire area boundary design
- Safe Shutdown system selection adequacy
- Systems separation evaluations against requirements of III.G.2 of Appendix R (Including area detection and suppression)

# FIRE PROTECTION ISSUES

---

## REGION BASED INSPECTION

Triennial Team Inspection Conduct:

- Fire suppression damage assessment for redundant trains of equipment
- Operator recovery actions
  - ▶ Smoke removal
  - ▶ Dewatering
  - ▶ Controlled re-energization
  - ▶ Return to service
- Manual Fire Fighting Capability Assessment

# FIRE PROTECTION ISSUES

---

## REGION BASED INSPECTION

Triennial Team Inspection Conduct:

- Circuit analysis (Fire-Induced Circuit Faults)
  - ▶ Common power supply concern
    - Multiple high impedance fault condition
    - Fuse/ breaker coordination

# FIRE PROTECTION ISSUES

---

## REGION BASED INSPECTION

Triennial Team Inspection Conduct:

- Circuit Analysis(Continued)
  - ▶ Common enclosure concern (Electrical fault protection from non-essential circuits)
  - ▶ Spurious signal concern
    - Hot shorts
    - Shorts to ground
    - Open circuits

# FIRE PROTECTION ISSUES

---

## BASELINE USE OF RISK INFORMATION

- Generic and plant specific risk information used to focus resident and triennial team inquiry on plant specific areas
- Fire protection Significance Determination Process (FP SDP) in IMC 0609, Appendix F

# FIRE PROTECTION ISSUES

---

## BASELINE USE OF RISK INFORMATION

- Resident Inspector applies FP SDP phase 1 screen only (May request regional office support)
- Inspection team applies FP SDP phase 1 and phase 2 while onsite
- NRC and/ or licensees refine FP SDP analyses as needed post-inspection

# **RISK ASSOCIATED WITH ONLINE MAINTENANCE**

---

**Laura Collins**

Project Engineer, Division of Reactor Projects

**Michael Parker**

Senior Risk Analyst, Division of Reactor Safety

# **RISK ASSOCIATED WITH ONLINE MAINTENANCE**

---

## **IP 1111.13 - MAINTENANCE RISK ASSESSMENTS AND EMERGENT WORK**

- Sample 5 to 8 maintenance activities per quarter
- Evaluate effectiveness of licensee's risk assessment and control of maintenance activities
- Maintenance rule requires risk assessment for online maintenance (a)(4)
- Future procedure revisions expected

# **RISK ASSOCIATED WITH ONLINE MAINTENANCE**

---

## **INSPECTION OBJECTIVES**

- Evaluate the effectiveness of the risk assessment and verify how the licensees manage the risk
- Verify the licensee has taken the necessary steps to plan and control emergent work
- Verify the licensee has adequately identified and resolved maintenance risk assessment and emergent work problems

# **RISK ASSOCIATED WITH ONLINE MAINTENANCE**

---

## **INSPECTION TECHNIQUES**

- Select work week/emergent work on risk-important SSCs
- Review safety assessment/discuss with licensee PRA staff
- Evaluate conduct of maintenance against the “plan”
- Consult with Senior Reactor Analysts

# **RISK ASSOCIATED WITH ONLINE MAINTENANCE**

---

## **INSPECTION OBSERVATIONS**

- Variety of Tools/Techniques Used
- Duration of maintenance exceeds planned duration
- Failure to Use Assessment Tool
- Inappropriate Credit for Operator Action to Maintain SSC Available

# RISK ASSOCIATED WITH ONLINE MAINTENANCE

---

## SRA'S ASSESSMENT OF LICENSEE RISK TOOLS AND SITE VISITS

### RISK ASSESSMENTS

- Online Risk Assessments - Probabilistic/Deterministic
- Shutdown Risk Assessments - Deterministic

### EMERGENT WORK

- Licensees Performing Risk Assessments
- Typically Performing Integrated Risk Assessments
- Maintenance Rule a.(4) Will Require Risk Assessments

# **RISK ASSOCIATED WITH ONLINE MAINTENANCE**

---

## **SRA'S ASSESSMENT OF LICENSEE RISK TOOLS AND SITE VISITS**

### **EVENT ASSESSMENTS**

- Trend Toward Licensees Performing Risk Assessments Of Events
- Typically Addressing Risk Significance In LERs

### **SRA INTERFACE WITH LICENSEES/INSPECTORS**

- Involved In SDP Process
- Assist Inspectors with Phase 2 and Conduct Phase 3 SDP Evaluations
- Interface with Licensee