July 07, 2000

Mr. S. E. Scace - Director Nuclear Oversight and Regulatory Affairs c/o Mr. David A. Smith Northeast Nuclear Energy Company P. O. Box 128 Waterford, CT 06385-0128

SUBJECT: EXEMPTION FROM THE REQUIREMENTS OF 10 CFR PART 50, APPENDIX R, MILLSTONE NUCLEAR POWER STATION, UNIT NO. 2 (TAC NO. MA8245)

Dear Mr. Scace:

By letter dated February 14, 2000, as supplemented by letters dated April 5 and May 31, 2000, you requested an exemption from the requirements of Title 10 of the <u>Code of Federal</u> <u>Regulations</u> Part 50, Appendix R, Section III.J to the extent that it requires emergency lighting units with at least 8-hour battery power supply to light all areas needed for operation of safe shutdown equipment and in access and egress routes thereto. In addition, the May 31, 2000, letter documented your plans to implement the design modification which prompted the need for the exemption request.

We find that granting the exemption is authorized by law, will not present an undue risk to public health and safety, and is consistent with the common defense and security, and that special circumstances as described in 10 CFR 50.12(a)(2)(ii) are present. Accordingly, your exemption request has been granted.

A copy of the exemption is enclosed. The exemption has been forwarded to the Office of the Federal Register for publication.

Sincerely,

/RA/

Jacob I. Zimmerman, Project Manager, Section 2 Project Directorate I Division of Licensing Project Management Office of Nuclear Reactor Regulation

Docket No. 50-336

Enclosure: Exemption

cc w/encl: See next page

Mr. S. E. Scace - Director July 07, 2000 Nuclear Oversight and Regulatory Affairs c/o Mr. David A. Smith Northeast Nuclear Energy Company P. O. Box 128 Waterford, CT 06385-0128

SUBJECT: EXEMPTION FROM THE REQUIREMENTS OF 10 CFR PART 50, APPENDIX R, MILLSTONE NUCLEAR POWER STATION, UNIT NO. 2 (TAC NO. MA8245)

Dear Mr. Scace:

By letter dated February 14, 2000, as supplemented by letters dated April 5 and May 31, 2000, you requested an exemption from the requirements of Title 10 of the <u>Code of Federal</u> <u>Regulations</u> Part 50, Appendix R, Section III.J to the extent that it requires emergency lighting units with at least 8-hour battery power supply to light all areas needed for operation of safe shutdown equipment and in access and egress routes thereto. In addition, the May 31, 2000, letter documented your plans to implement the design modification which prompted the need for the exemption request.

We find that granting the exemption is authorized by law, will not present an undue risk to public health and safety, and is consistent with the common defense and security, and that special circumstances as described in 10 CFR 50.12(a)(2)(ii) are present. Accordingly, your exemption request has been granted.

A copy of the exemption is enclosed. The exemption has been forwarded to the Office of the Federal Register for publication.

Sincerely, /RA/ Jacob I. Zimmerman, Project Manager, Section 2 Project Directorate I Division of Licensing Project Management Office of Nuclear Reactor Regulation

Docket No. 50-336

Enclosure: Exemption cc w/encl: See next page

DISTRIBUTION:	TClark	EWeiss	LBerry
OGC	GHill (2)	JShea	·
PUBLIC	ACRS	RUrban, RI	
PDI-2 R/F	JClifford	JLinville, RI	
JZimmerman	PQualls	EAdensam (EGA1)

*SE Input provided on 2/25/00 w/no major changes **See previous concurrence

OFFICE	PDI-2/PM	PDI-2/LA	SPLB*	OGC**	PDI-2/SC	LPDI/D	DLPM/D	
NAME	JZimmerman:hbb	TClark	EWeiss	RHoefling	BBucley for JClifford	EAdensam	JZwolinski	
DATE	6/21/00	6/21/00	02/25/00	06/14/00	6 /27/00	6/27/00	7/7/00	

DOCUMENT NAME: C:\exmpMA8245.wpd

UNITED STATES OF AMERICA

NUCLEAR REGULATORY COMMISSION

In the Matter of NORTHEAST NUCLEAR ENERGY COMPANY, et al.

Docket No. 50-336

(Millstone Nuclear Power Station, Unit 2)

EXEMPTION

١.

Northeast Nuclear Energy Company, et al., is the holder of Facility Operating License No. DPR-65 which authorizes operation of Millstone Nuclear Power Station, Unit 2. Millstone Nuclear Power Station, Unit 2 is a pressurized water reactor located in Waterford, Connecticut. The license provides, among other things, that the facility is subject to all rules, regulations, and orders of the U.S. Nuclear Regulatory Commission (the Commission or NRC) now or hereafter in effect.

Π.

Appendix R, "Fire Protection Program for Nuclear Power Facilities Operating Prior to January 1, 1979," to Title 10 of the <u>Code of Federal Regulations</u> (10 CFR) Part 50, establishes fire protection features required to satisfy General Design Criterion 3, "Fire protection," of Appendix A to 10 CFR Part 50, with respect to certain generic issues for nuclear power plants licensed to operate prior to January 1, 1979. By letter dated February 14, 2000, as supplemented by letters dated April 5 and May 31, 2000, Northeast Nuclear Energy Company, (NNECO), the licensee for Millstone Nuclear Power Station, Unit No. 2, requested an exemption from the technical requirements of 10 CFR Part 50, Appendix R, Section III.J to the extent that it requires emergency lighting units with at least an 8-hour battery power supply to light all areas needed for operation of safe shutdown equipment and in access and egress routes thereto. NNECO proposed to credit the security lighting system currently installed at the plant for access and egress route emergency lighting in lieu of providing separate emergency lighting units with an 8-hour battery supply in the Unit 3 yard area.

III.

As a result of the decommissioning of Unit 1, the existing tie to Unit 1 Vital Electrical Bus 14H will be disconnected. The licensee will credit a new 4160-volt electrical tie to the Unit 3 Alternate AC diesel generator as the alternate AC power source for Unit 2 to comply with Appendix R. Access to the Unit 3 Alternate AC diesel generator and associated switchgear enclosures so that Unit 3 operators could start the diesel generator and make the necessary electrical ties to the Unit 2 bus requires travel through the Unit 3 yard area.

The outdoor access and egress route to the Unit 3 Alternate AC diesel generator and switchgear enclosures extends from the west entrance of Millstone Unit 3 Building 323 (grade elevation), north through a paved area to a service road, following the road generally to the east and then south to the enclosures.

The licensee proposes to credit the security lighting system for access and egress route emergency lighting in lieu of an 8-hour battery supply in the yard area. The basis for this is as follows:

- 2 -

- 1. The security lighting system illuminates the required access and egress routes;
- The security lighting power supply is backed by a security diesel generator with fuel storage capacity to ensure operation greater than or equal to 8 hours;
- The security generator, components, and circuits are independent from the postulated fire areas which require access to the 4160-volt Bus 14H enclosure, Intake Structure, or RWST pipe chase.

These actions will ensure that the Appendix R, Section III.J requirement to the extent that emergency lighting units with at least an 8-hour supply are met.

There are also portable lighting units dedicated for operations department use that would provide additional defense-in-depth for ensuring adequate lighting is available. The equipment is administratively controlled and located inside the Millstone Unit 3 Control Room Complex.

IV.

The underlying purpose of Section III.J of Appendix R is to ensure that fixed lighting of sufficient duration and reliability is provided to allow operation of equipment required for postfire, safe shutdown of the reactor. Lighting for access/egress associated with the equipment is also required.

Large area applications will typically impose electrical load requirements which are beyond the normal limits of battery units. The security lighting system illuminates the required access and egress routes. The power supply is backed by a security diesel generator with fuel storage capacity to ensure operation with at least an 8-hour supply. The security generator, components and circuits are independent from the postulated fire areas which require access to the Unit 3 Alternate AC diesel generator and consistent with the defense-in-depth approach to fire protection. Based on the availability and reliability of the security lighting of sufficient duration and the availability of portable lighting, there is reasonable assurance that the access/egress routes through the yard area that are relied on for safe shutdown of the facility can be accessed in the event of a fire.

On the basis of its evaluation, the NRC staff has concluded that the application of the regulation, pursuant to 10 CFR 50.12(a)(2)(ii), in this special circumstance is not necessary to achieve the underlying purpose of the rule.

V.

The Commission has determined that, pursuant to 10 CFR 50.12(a), an exemption to allow use of security lighting is authorized by law, will not present an undue risk to the public health and safety, and is consistent with the common defense and security. Further, special circumstances are present, as set forth in 10 CFR 50.12(a)(2)(ii). Therefore, the Commission hereby grants an exemption from the requirements of 10 CFR, Part 50, Appendix R, Section III.J.

Pursuant to 10 CFR 51.32, the Commission has determined that this exemption will not have a significant effect on the quality of the human environment (65 FR 41738).

This exemption is effective upon issuance.

Dated at Rockville, Maryland, this 7th day of July 2000.

FOR THE U.S. NUCLEAR REGULATORY COMMISSION

/RA/

John A. Zwolinski, Director Division of Licensing Project Management Office of Nuclear Reactor Regulation Millstone Nuclear Power Station Unit 2

CC:

Ms. L. M. Cuoco Senior Nuclear Counsel Northeast Utilities Service Company P. O. Box 270 Hartford, CT 06141-0270

Edward L. Wilds, Jr., Ph.D. Director, Division of Radiation Department of Environmental Protection 79 Elm Street Hartford, CT 06106-5127

Regional Administrator, Region I U.S. Nuclear Regulatory Commission 475 Allendale Road King of Prussia, PA 19406

First Selectmen Town of Waterford 15 Rope Ferry Road Waterford, CT 06385

Charles Brinkman, Manager Washington Nuclear Operations ABB Combustion Engineering 12300 Twinbrook Pkwy, Suite 330 Rockville, MD 20852

Senior Resident Inspector Millstone Nuclear Power Station c/o U.S. Nuclear Regulatory Commission P.O. Box 513 Niantic, CT 06357

Mr. F. C. Rothen Vice President - Nuclear Operations Northeast Nuclear Energy Company P. O. Box 128 Waterford, CT 06385

Ernest C. Hadley, Esquire 1040 B Main Street P.O. Box 549 West Wareham, MA 02576

Mr. J. T. Carlin Vice President - Human Services - Nuclear Northeast Nuclear Energy Company P. O. Box 128 Waterford, CT 06385 Mr. Allan Johanson, Assistant Director
Office of Policy and Management
Policy Development and Planning
Division
450 Capitol Avenue - MS# 52ERN
P. O. Box 341441
Hartford, CT 06134-1441

Mr. M. H. Brothers Vice President - Nuclear Operations Northeast Nuclear Energy Company P.O. Box 128 Waterford, CT 06385

Mr. L. J. Olivier
Senior Vice President and Chief
Nuclear Officer - Millstone
Northeast Nuclear Energy Company
P.O. Box 128
Waterford, CT 06385

Mr. C. J. Schwarz Station Director Northeast Nuclear Energy Company P.O. Box 128 Waterford, CT 06385

Mr. B. D. Kenyon President and CEO - NNECO Northeast Nuclear Energy Company P.O. Box 128 Waterford, CT 06385

Mr. R. P. Necci Vice President - Nuclear Technical Services Northeast Nuclear Energy Company P. O. Box 128 Waterford, CT 06385 Millstone Nuclear Power Station Unit 2 cc:

Citizens Regulatory Commission ATTN: Ms. Geri Winslow P. O. Box 199 Waterford, CT 06385 Deborah Katz, President Citizens Awareness Network P. O. Box 83 Shelburne Falls, MA 03170

Ms. Terry Concannon Co-Chair Nuclear Energy Advisory Council 41 South Buckboard Lane Marlborough, CT 06447

Mr. Evan W. Woollacott Co-Chair Nuclear Energy Advisory Council 128 Terry's Plain Road Simsbury, CT 06070

Attorney Nicholas J. Scobbo, Jr. Ferriter, Scobbo, Caruso, Rodophele, PC 75 State Street, 7th Floor Boston, MA 02108-1807

Mr. D. A. Smith Manager - Regulatory Affairs Northeast Nuclear Energy Company P. O. Box 128 Waterford, CT 06385

Ms. Nancy Burton 147 Cross Highway Redding Ridge, CT 00870

Mr. G. D. Hicks Director - Nuclear Training Services Northeast Nuclear Energy Company P.O. Box 128 Waterford, CT 06385