June 28, 2000

Mr. William T. Cottle President and Chief Executive Officer STP Nuclear Operating Company South Texas Project Electric Generating Station P. O. Box 289 Wadsworth, TX 77483

## SUBJECT: SOUTH TEXAS PROJECT, UNITS 1 AND 2 - REVISION TO TECHNICAL SPECIFICATION BASES (TAC NO. MA5334 AND MA5335)

Dear Mr. Cottle:

By letter dated April 19, 1999, as supplemented May 30, 2000, STP Nuclear Operating Company (STPNOC) provided the NRC with changes to Technical Specification (TS) Bases Sections 3.8.1.1, "Electrical Power Systems" to correct the description of separation and independence of offsite AC electrical power sources.

As you are aware, the TS Bases are not part of the TS as defined by 10 CFR 50.36. Changes to the TS Bases may voluntarily be made in accordance with the provisions of 10 CFR 50.59. Should the proposed change involve an unreviewed safety question pursuant to 10 CFR 50.59(a)(2), or involve a change in the interpretation of implementation of the TS (i.e., constitute a TS change), then the proposed change is to be provided to the staff pursuant to the provisions of 10 CFR 50.59(c) and 10 CFR 50.90 for prior NRC review and approval.

The TS Bases you provided are hereby returned to you and should be inserted in the TS to ensure the NRC staff and STPNOC have identical TS Bases pages. The staff did not perform an evaluation of your TS Bases revisions and staff concurrence with the revisions is not implied by this letter. The staff may review the evaluations that support these TS Bases revisions during inspection of the South Texas Project, Units 1 and 2, implementation of 10 CFR 50.59.

Sincerely,

### /RA/

John A. Nakoski, Senior Project Manager, Section 1 Project Directorate IV & Decommissioning Division of Licensing Project Management Office of Nuclear Reactor Regulation

Docket Nos. 50-498 and 50-499

Enclosure: Bases pages B 3/4 8-3

cc w/encl: See next page

Mr. William T. Cottle President and Chief Executive Officer STP Nuclear Operating Company South Texas Project Electric Generating Station P. O. Box 289 Wadsworth, TX 77483

# SUBJECT: SOUTH TEXAS PROJECT, UNITS 1 AND 2 - REVISION TO TECHNICAL SPECIFICATION BASES (TAC NO. MA5334 AND MA5335)

Dear Mr. Cottle:

By letter dated April 19, 1999, as supplemented May 30, 2000, STP Nuclear Operating Company (STPNOC) provided the NRC with changes to Technical Specification (TS) Bases Sections 3.8.1.1, "Electrical Power Systems" to correct the description of separation and independence of offsite AC electrical power sources.

As you are aware, the TS Bases are not part of the TS as defined by 10 CFR 50.36. Changes to the TS Bases may voluntarily be made in accordance with the provisions of 10 CFR 50.59. Should the proposed change involve an unreviewed safety question pursuant to 10 CFR 50.59(a)(2), or involve a change in the interpretation of implementation of the TS (i.e., constitute a TS change), then the proposed change is to be provided to the staff pursuant to the provisions of 10 CFR 50.59(c) and 10 CFR 50.90 for prior NRC review and approval.

The TS Bases you provided are hereby returned to you and should be inserted in the TS to ensure the NRC staff and STPNOC have identical TS Bases pages. The staff did not perform an evaluation of your TS Bases revisions and staff concurrence with the revisions is not implied by this letter. The staff may review the evaluations that support these TS Bases revisions during inspection of the South Texas Project, Units 1 and 2, implementation of 10 CFR 50.59.

Sincerely,

/RA/ John A. Nakoski, Senior Project Manager, Section 1 Project Directorate IV & Decommissioning Division of Licensing Project Management Office of Nuclear Reactor Regulation

Docket Nos. 50-498 and 50-499

Enclosure: Bases pages B 3/4 8-3

cc w/encl: See next page

DISTRIBUTION:

PUBLIC	RidsNrrDlpmLpdiv (S.Richards)	RidsNrrPMJNakoski
PDIV-1 r/f	RidsNrrDlpmLpdiv1 (R.Gramm)	RidsNrrLACJamerson
G. Hill (4)	RidsNrrDripRtsb (W.Beckner)	RidsAcrsAcnwMailCenter
RidsRgn4Mail	Center (J. Tapia, L. Hurley, D. Bujol)	RidsOgcRp

### ACCESSION NUMBER: ML003727424

OFFICE	PDIV-1/PM	PDIV-D/LA	PDIV-1/SC
NAME	JNakoski	CJamerson	RGramm
DATE	6/23/00	6/27/00	6/28/00
		OFFICIAL RECORD COPY	

cc:

Mr. Cornelius F. O'Keefe Senior Resident Inspector U.S. Nuclear Regulatory Commission P. O. Box 910 Bay City, TX 77414

A. Ramirez/C. M. Canady City of Austin Electric Utility Department 721 Barton Springs Road Austin, TX 78704

Mr. M. T. Hardt Mr. W. C. Gunst City Public Service Board P. O. Box 1771 San Antonio, TX 78296

Mr. G. E. Vaughn/C. A. Johnson Central Power and Light Company P. O. Box 289 Mail Code: N5012 Wadsworth, TX 74483

INPO Records Center 700 Galleria Parkway Atlanta, GA 30339-3064

Regional Administrator, Region IV U.S. Nuclear Regulatory Commission 611 Ryan Plaza Drive, Suite 400 Arlington, TX 76011

D. G. Tees/R. L. Balcom Houston Lighting & Power Co. P. O. Box 1700 Houston, TX 77251

Judge, Matagorda County Matagorda County Courthouse 1700 Seventh Street Bay City, TX 77414 A. H. Gutterman, Esq. Morgan, Lewis & Bockius 1800 M Street, N.W. Washington, DC 20036-5869

Mr. J. J. Sheppard, Vice President Engineering & Technical Services STP Nuclear Operating Company P. O. Box 289 Wadsworth, TX 77483

S. M. Head, Supervisor, Licensing Quality & Licensing Department STP Nuclear Operating Company P. O. Box 289 Wadsworth, TX 77483

Office of the Governor ATTN: John Howard, Director Environmental and Natural Resources Policy P. O. Box 12428 Austin, TX 78711

Jon C. Wood Matthews & Branscomb One Alamo Center 106 S. St. Mary's Street, Suite 700 San Antonio, TX 78205-3692

Arthur C. Tate, Director Division of Compliance & Inspection Bureau of Radiation Control Texas Department of Health 1100 West 49th Street Austin, TX 78756

Jim Calloway Public Utility Commission of Texas Electric Industry Analysis P. O. Box 13326 Austin, TX 78711-3326

### ELECTRICAL POWER SYSTEMS

#### BASES

A.C. SOURCES, D.C. SOURCES, and ONSITE POWER DISTRIBUTION (Continued) Each offsite circuit must be capable of maintaining rated frequency and voltage, and accepting required loads during an accident, while connected to the ESF busses.

Each DG must be capable of starting, accelerating to rated speed and voltage, and connecting to its respective ESF bus on detection of bus undervoltage. This will be accomplished within [10] seconds. Each DG must also be capable of accepting required loads within the assumed loading sequence intervals, and continue to operate until offsite power can be restored to the ESF busses. These capabilities are required to be met from a variety of initial conditions such as DG in standby with the engine hot, DG in standby conditions, and DG operating in parallel test mode.

The AC sources in one train must be separate and independent (to the extent possible) of the AC sources in the other train. For the DGs, separation and independence are complete.

For the offsite AC sources, separation and independence are to the extent practical. Separation of the on-site circuits is accomplished by connecting each 4.16 kV ESF bus to a separate 13.8 kV standby or auxiliary bus. No 13.8 kV standby or auxiliary bus normally feeds more than one 4.16 kV bus.

#### APPLICABILITY

The AC sources are required to be OPERABLE in MODES 1, 2, 3, and 4 to ensure that:

- a. Acceptable fuel design limits and reactor coolant pressure boundary limits are not exceeded as a result of anticipated operational occurrences (AOOs) or abnormal transients; and
- b. Adequate core cooling is provided and containment OPERABILITY and other vital functions are maintained in the event of a postulated DBA.

The AC power requirements for Modes 5 and 6 are covered in LCO 3.8.2, "AC Sources-Shutdown."

3.8.1.1 Action a.

To ensure a highly reliable power source remains with one offsite circuit inoperable, it is necessary to verify the OPERABILITY of the remaining

SOUTH TEXAS - UNITS 1 & 2 B 3/4 8-3 Unit 1 - Amendment No. 68 Unit 2 - Amendment No. 57 Feb 2 1995 Revised by NRC letter dated June 28, 2000 <del>5488-99</del>, 5563-99