

July 27, 2000

MEMORANDUM TO: BiWeekly Notice Coordinator

FROM: Patrick D. Milano, Senior Project Manager, Section I  
Project Directorate I  
Division of Licensing Project Management

SUBJECT: REQUEST FOR PUBLICATION IN BIWEEKLY FR NOTICE -  
NOTICE OF ISSUANCE OF AMENDMENT TO FACILITY  
OPERATING LICENSE (TAC NO. MA6955)

Consolidated Edison Company of New York, Docket No. 50-247, Indian Point Nuclear

Generating Unit No. 2, Westchester County, New York

Date of application for amendment: November 18, 1999, incorporating supporting analyses provided by letter dated October 8, 1999, as supplemented by letters dated February 14, March 21, April 6, April 13, and May 11, 2000.

Brief description of amendment: The proposed amendment would remove the requirement for charcoal filters and high efficiency particulate filters in the containment fan cooler system, revise the time requirement for subcriticality prior to core alterations from 174 hours to 100 hours, revise flow rate requirements for containment fan coolers and control room ventilation units to be consistent with the design basis, state that the control room ventilation system, in the post-accident mode, will be operated with filtered intake of outside air, allow containment personnel access doors to be open during refueling operations, and allow an administrative substitution of "monthly" in place of "every 31 days" in various surveillance requirements.

Date of issuance: July 27, 2000

Effective date: As of the date of issuance to be implemented within 30 days.

Amendment No.: 211

Facility Operating License No. DPR-26: Amendment revised the Technical Specifications.

Date of initial notice in FEDERAL REGISTER: January 20, 2000 (65 FR 3256)

The February 14, March 21, April 6, April 13, and May 11, 2000, submittals contained supplemental information that did not change the original no significant hazards consideration determination.

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated July 27, 2000.

No significant hazards consideration comments received: No

July 27, 2000

Date of initial notice in FEDERAL REGISTER: January 20, 2000 (65 FR 3256)

The February 14, March 21, April 6, April 13, and May 11, 2000, submittals contained supplemental information that did not change the original no significant hazards consideration determination.

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated July 27, 2000.

No significant hazards consideration comments received: No

**DISTRIBUTION:**

PDI-1 R/F  
P. Milano  
M. Gamberoni  
S. Little  
OGC

ACCESSION NO. ML003727506

**To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy**

OFFICE	PM:PDI-1	E	LA:PDI-1		SC:PDI-1		OGC*		
NAME	PMilano		SLittle		MGamberoni		RWeisman		
DATE	06/21/00		06/28/00		06/29/00		06/23/00		

Official Record Copy