

3/4.9 REFUELING OPERATIONS

3/4.9.1 BORON CONCENTRATION

LIMITING CONDITION FOR OPERATION

3.9.1.1 The boron concentration of all filled portions of the Reactor Coolant System and the refueling canal shall be maintained uniform and sufficient to ensure that the more restrictive of the following reactivity conditions is met; either:

- a. A K_{eff} of 0.95 or less, or
- b. A boron concentration of greater than or equal to 2600 ppm.

Additionally, the CVCS valves of Specification 4.1.1.2.2 shall be closed and secured in position.

APPLICABILITY: MODE 6.*

ACTION:

- a. With the requirements of the above specification not satisfied, immediately suspend all operations involving CORE ALTERATIONS or positive reactivity changes and initiate and continue boration at greater than or equal to 33 gpm of a solution containing greater than or equal to 6600 ppm boron or its equivalent until K_{eff} is reduced to less than or equal to 0.95 or the boron concentration is restored to greater than or equal to 2600 ppm, whichever is the more restrictive.
- b. With any of the CVCS valves of Specification 4.1.1.2.2 not closed** and secured in position, immediately close and secure the valves.

SURVEILLANCE REQUIREMENTS

4.9.1.1.1 The more restrictive of the above two reactivity conditions shall be determined prior to:

- a. Removing or unbolting the reactor vessel head, and
- b. Withdrawal of any full-length control rod in excess of 3 feet from its fully inserted position within the reactor vessel.

4.9.1.1.2 The boron concentration of the Reactor Coolant System and the refueling canal shall be determined by chemical analysis at least once per 72 hours.

4.9.1.1.3 The CVCS valves of Specification 4.1.1.2.2 shall be verified closed and locked at least once per 31 days.

*The reactor shall be maintained in MODE 6 whenever fuel is in the reactor vessel with the vessel head closure bolts less than fully tensioned or with the head removed.

**Except those opened under administrative control.