

July 3, 2000

Mr. Charles M. Dugger
Vice President Operations
Entergy Operations, Inc.
17265 River Road
Killona, LA 70066-0751

SUBJECT: WATERFORD STEAM ELECTRIC STATION, UNIT 3 - REQUEST FOR
ADDITIONAL INFORMATION RELATED TO TECHNICAL SPECIFICATION
CHANGE REQUEST REGARDING THE EMERGENCY FEEDWATER SYSTEM
(TAC NO. MA2189)

Dear Mr. Dugger:

By letter dated May 5, 1998, as supplemented by letter dated January 31, 2000, Entergy Operations, Inc. proposed changes to Waterford Steam Electric Station, Unit 3, Technical Specification 3.7.1.2 and Surveillance Requirement 4.7.1.2 for the Emergency Feedwater System.

After reviewing your request, the Nuclear Regulatory Commission (NRC) staff has determined that additional information is required to complete the review. On June 27, 2000, NRC staff discussed this required additional information with your staff during a telephone conference call. As discussed on the telephone, please provide your response to the enclosed questions by July 19, 2000.

Should you need further information, please call me at (301) 415-1480.

Sincerely,

/RA/

N. Kalyanam, Project Manager, Section 1
Project Directorate IV & Decommissioning
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-382

Enclosure: As stated

cc w/encl: See next page

July 3, 2000

Mr. Charles M. Dugger
Vice President Operations
Entergy Operations, Inc.
17265 River Road
Killona, LA 70066-0751

SUBJECT: WATERFORD STEAM ELECTRIC STATION, UNIT 3 - REQUEST FOR
ADDITIONAL INFORMATION RELATED TO TECHNICAL SPECIFICATION
CHANGE REQUEST REGARDING THE EMERGENCY FEEDWATER SYSTEM
(TAC NO. MA2189)

Dear Mr. Dugger:

By letter dated May 5, 1998, as supplemented by letter dated January 31, 2000, Entergy Operations, Inc. proposed changes to Waterford Steam Electric Station, Unit 3, Technical Specification 3.7.1.2 and Surveillance Requirement 4.7.1.2 for the Emergency Feedwater System.

After reviewing your request, the Nuclear Regulatory Commission (NRC) staff has determined that additional information is required to complete the review. On June 27, 2000, NRC staff discussed this required additional information with your staff during a telephone conference call. As discussed on the telephone, please provide your response to the enclosed questions by July 19, 2000.

Should you need further information, please call me at (301) 415-1480.

Sincerely,
/RA/

N. Kalyanam, Project Manager, Section 1
Project Directorate IV & Decommissioning
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-382

Enclosure: As stated

cc w/encl: See next page

DISTRIBUTION

PUBLIC

PDIV-1 r/f

RidsNrrDlpm (SBlack)

Rids OgcRp

RidsAcrcsAcnwACRS

RidsNrrDlpmLpdiv1 (RGramm)

RidsNrrPMNKalyanam

RidsNrrLADJohnson

LBerry

RidsRgn4MailCenter (KBrockman)

Accession No: ML003728389

OFFICE	PDIV-1/PM	PDIV-1/LA	PDIV-1/SC
NAME	NKalyanam	DJohnson	RGramm
DATE	06/29/00	06/29/00	06/29/00

OFFICIAL RECORD COPY

WATERFORD STEAM ELECTRIC STATION, UNIT 3 (WATERFORD 3)

REQUEST FOR ADDITIONAL INFORMATION

(TAC NO. MA2189)

Reference: Enclosure Two to Waterford 3 letter dated January 31, 2000, Technical Specification Change Request NPF-38-206, Revision 1.

1. Second paragraph of Answer #1
 - 1a. What is the meaning of "greater" in "greater than 13 minutes?" - how much greater than 13 minutes?
 - 1b. American National Standards Institute/American Nuclear Society (ANSI/ANS) Standard ANSI/ANS-58.8-1984 shows a minimum of 10 minutes for Time Test #1 (Plant Condition 3, Loss of Off-site Power (LOOP)). Added to that would be a minimum of four minutes for Time Test #2 (PC 3, LOOP, one manipulation). Added to that would be one minute per additional operator manipulation. Added to that would be equipment process time. Assuming only one manipulation and no equipment process time, the result is already at 14 minutes. Please explain how you arrived at a time delay of from two to six minutes using the referenced standard.
 - 1c. How many isolation valves must be closed? How many operator manipulations per valve?
 - 1d. Describe process for reducing emergency feedwater (EFW) flow. How many operator manipulations are required?
2. Third paragraph of Answer #1
 - 2a. What is the meaning of "more" in "more than 8 minutes?" - how much greater than eight minutes?
3. Should you plan to take exception to the time criteria of ANSI/ANS-58.8-1984, it is necessary to justify the exception by developing operator action times based on a task analysis and an independent data base. Please provide the justification for this exception.
4. Please provide a time criteria in accordance with the provisions of ANSI/ANS-58.8-1984 with the maximum EFW flow of 2300 gallons per minute to a single steam generator during a main steam line break.

Enclosure

Waterford Generating Station 3

cc:

Administrator
Louisiana Department of Environmental Quality
P. O. Box 82215
Baton Rouge, LA 70884-2215

Vice President, Operations Support
Entergy Operations, Inc.
P. O. Box 31995
Jackson, MS 39286

Director
Nuclear Safety Assurance
Entergy Operations, Inc.
17265 River Road
Killona, LA 70066-0751

Wise, Carter, Child & Caraway
P. O. Box 651
Jackson, MS 39205

General Manager Plant Operations
Waterford 3 SES
Entergy Operations, Inc.
17265 River Road
Killona, LA 70066-0751

Licensing Manager
Entergy Operations, Inc.
17265 River Road
Killona, LA 70066-0751

Winston & Strawn
1400 L Street, N.W.
Washington, DC 20005-3502

Resident Inspector/Waterford NPS
P. O. Box 822
Killona, LA 70066-0751

Regional Administrator, Region IV
U. S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 1000
Arlington, TX 76011

Parish President Council
St. Charles Parish
P. O. Box 302
Hahnville, LA 70057

Executive Vice-President
and Chief Operating Officer
Entergy Operations, Inc.
P. O. Box 31995
Jackson, MS 39286-1995

Chairman
Louisiana Public Services Commission
Baton Rouge, LA 70825-1697