

July 6, 2000

Mr. Ted C. Feigenbaum
Executive Vice President and
Chief Nuclear Officer
North Atlantic Energy Service Corporation
c/o Mr. James M. Peschel
P.O. Box 300
Seabrook, NH 03874

SUBJECT: SEABROOK STATION, UNIT 1 - CORRECTION LETTER FOR
TECHNICAL SPECIFICATION AMENDMENT NO. 70

Dear Mr. Feigenbaum:

Technical Specification (TS) Amendment No. 70 was issued on May 22, 2000. The TS amendment made several editorial and administrative changes to the Seabrook Station, Unit 1 TS. Section 3.7 on page 4 of the Safety Evaluation (SE) enclosed with Amendment 70 discussed TS 6.4.3.9c, on records for the Nuclear Safety Audit Review Committee (NSARC), by approving the change of a reference from TS 6.4.2.8 to TS 6.4.3.8. The May 22, 2000, letter also enclosed a copy of revised TS page 6-11 which recorded the change to TS 6.4.3.9c. This change was requested by the licensee in their application dated December 16, 1998; however, this TS section was subsequently requested to be relocated to the Quality Assurance Program located in the Updated Final Safety Analysis Report (UFSAR) in the licensee's letter dated November 19, 1999.

TS page 6-11 should not have been changed under Amendment 70. This change was made in error in that TS 6.4.3.9c had been relocated to the Quality Assurance Program under TS Amendment No. 67, dated April 11, 2000, in accordance with the licensee's request of November 19, 1999.

T. Fiegenbaum

- 2 -

Enclosed please find a copy of TS page 6-11, as it was issued in Amendment 67 and a revised page 4 of the SE deleting Section 3.7 which discussed the TS reference change from TS 6.4.2.8 to 6.4.3.8. The revised page 4 contains a margin line indicating the area of change.

Sincerely,

/RA/

Robert M. Pulsifer, Project Manager, Section 2
Project Directorate I
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-443

Enclosures: 1. Revised TS Page 6-11
2. Revised SE Page 4

cc w/encl.: See next page

Enclosed please find a copy of TS page 6-11, as it was issued in Amendment 67 and a revised page 4 of the SE deleting Section 3.7 which discussed the TS reference change from TS 6.4.2.8 to 6.4.3.8. The revised page 4 contains a margin line indicating the area of change.

Sincerely,

/RA/

Robert M. Pulsifer, Project Manager, Section 2
Project Directorate I
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-443

- Enclosures: 1. Revised TS Page 6-11
- 2. Revised SE Page 4

cc w/encl.: See next page

DISTRIBUTION:

PUBLIC	JClifford	OGC	TQuay
PDI-2 Rdg.	RPulsifer	ACRS	GHill (2)
EAdensam (EGA1)	TClark	JLinville, RGN-I	WBeckner

FILENAME: G:\PDI-2\Seabrook\correction.wpd

OFFICE	PDI-2/PM	PDI-2/LA	OGC	PDI-2/SC
NAME	RPulsifer	TClark	HMcGurren	JClifford
DATE	06/14/ 00	06/14/00	06/20/00	06/22/00

OFFICIAL RECORD COPY

Seabrook Station, Unit No. 1

cc:

Lillian M. Cuoco, Esq.
Senior Nuclear Counsel
Northeast Utilities Service Company
P.O. Box 270
Hartford, CT 06141-0270

Mr. Peter Brann
Assistant Attorney General
State House, Station #6
Augusta, ME 04333

Resident Inspector
U.S. Nuclear Regulatory Commission
Seabrook Nuclear Power Station
P.O. Box 1149
Seabrook, NH 03874

Town of Exeter
10 Front Street
Exeter, NH 03823

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Office of the Attorney General
One Ashburton Place
20th Floor
Boston, MA 02108

Board of Selectmen
Town of Amesbury
Town Hall
Amesbury, MA 01913

Mr. Dan McElhinney
Federal Emergency Management Agency
Region I
J.W. McCormack P.O. &
Courthouse Building, Room 401
Boston, MA 02109

Mr. Stephen McGrail, Director
ATTN: James Muckerheide
Massachusetts Emergency Management
Agency
400 Worcester Road
Framingham, MA 01702-5399

Philip T. McLaughlin, Attorney General
Steven M. Houran, Deputy Attorney
General
33 Capitol Street
Concord, NH 03301

Mr. Woodbury Fogg, Director
New Hampshire Office of Emergency
Management
State Office Park South
107 Pleasant Street
Concord, NH 03301

Mr. Roy E. Hickok
Nuclear Training Manager
Seabrook Station
North Atlantic Energy Service Corp.
P.O. Box 300
Seabrook, NH 03874

Mr. James M. Peschel
Manager - Regulatory Programs
Seabrook Station
North Atlantic Energy Service Corp.
P.O. Box 300
Seabrook, NH 03874

Mr. W. A. DiProffio
Station Director
Seabrook Station
North Atlantic Energy Service Corporation
P.O. Box 300
Seabrook, NH 03874

Mr. Frank W. Getman, Jr.
President and Chief Executive Officer
BayCorp Holdings, LTD
Suite 301
Portsmouth, NH 03801-6809

Mr. B. D. Kenyon
President and Chief Executive Officer
Northeast Utilities Service Company
P.O. Box 270
Hartford, CT 06141-0270

Mr. Steve Allen
Polestar Applied Technology, Inc.
77 Franklin Street, Suite 507
Boston, MA 02110

3.4 Index Page vi Figures 3.4-2 and 3.4-3

This editorial change corrects TSs Index Page vi to indicate that the service period, as shown on TS Figures 3.4-2 and 3.4-3 for the Reactor Coolant System (RCS) Heatup/Cooldown Limitation curves, is applicable up to 11.1 effective full power years (EFPY). This change was inadvertently omitted from the submittal of LAR 92-06, "Revised RCS Pressure/Temperature Limits", dated August 17, 1992, when the service period for RCS heatup and cooldown rate curves was revised from 16 EFPY to 11.1 EFPY. The staff approved this change to the service period by License Amendment 19, issued April 7, 1993. The staff agrees that this change is editorial in nature and, therefore, the proposed TS change is acceptable.

3.5 Index Page xv 6.0 Administrative Controls

This editorial change is to TS Index Page xv. This change will add a reference to TS 6.15, Containment Leakage Rate Testing Program in the index. TS 6.15 was previously approved in License Amendment 49, issued February 24, 1997. The reference was inadvertently omitted from the submittal of LAR 96-05, "Implementation of 10 CFR 50 Appendix J, Option B, Containment Leakage Rate Testing (TAC M95312)," dated June 4, 1996. Inclusion of TS 6.15 in the TSs Index is for completeness and will allow the user an easy method of locating TS 6.15 within the TSs Manual. The staff agrees that the proposed change is an editorial change for reference purposes only and, therefore, the proposed TS change is acceptable.

3.6 TS 4.2.4.2b Determination of Quadrant Power Tilt Ratio

This editorial change is to Quadrant Power Tilt Ratio Surveillance Requirement (SR) 4.2.4.2b to change the current reference from TS 3.3.3.2 to Technical Requirement TR20-3.3.3.2. LAR 96-02, "Relocation of Selected TSs to Licensee Controlled Documents - Incore Detector System, Seismic Instrumentation, Meteorological Instrumentation and Turbine Overspeed Protection (TAC M96723)", dated October 17, 1996, and subsequently approved as License Amendment 50, issued March 12, 1997, relocated Incore Detector System TS 3.3.3.2 from TSs to the Seabrook Station Technical Requirements (SSTR) Manual. Therefore, TS 3.3.3.2 is no longer in the TSs. This change inadvertently omitted the change in reference in SR 4.2.4.2b to reflect that the TS section had been relocated. The staff agrees that this change is editorial in nature and, therefore, is acceptable.

3.7 This section has been deleted.

3.8 TS 6.8.1.6.b.1 Core Operating Limits Report

This editorial change is to TS 6.8.1.6.b.1. to revise the date of issue of WCAP-11524-A and issued addenda. The correct issue is WCAP-11524-A, Rev. 2 with Addenda, March 1987. Both issues of the report describe the large break loss-of-coolant-accident (LOCA) methodology used to prepare the LOCA Safety Analysis Report supplied by Westinghouse via letter 93NA*-G-0037, August 31, 1993. This report was submitted in support for the approval of License Amendment 33, issued November 23, 1994, to the TSs. There has been no change in