



Carolina Power & Light Company
P.O. Box 10429
Southport, NC 28461-0429

JUN 28 2000

SERIAL: BSEP 00-0055

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555-0001

BRUNSWICK STEAM ELECTRIC PLANT, UNIT NO. 1
DOCKET NO. 50-325/LICENSE NO. DPR-71
INSERVICE INSPECTION PROGRAM RELIEF REQUEST - SERVICE WATER SYSTEM
PIPING NON-CODE REPAIR

Gentlemen:

The purpose of this letter is to withdraw a request for relief involving a temporary, non-Code repair of service water piping for the Brunswick Steam Electric Plant (BSEP), Unit No. 1. By letter dated August 25, 1999 (Serial: BSEP 99-0130), Carolina Power & Light (CP&L) Company requested relief from the American Society of Mechanical Engineers (ASME) Boiler and Pressure Vessel Code, Section XI, in accordance with 10 CFR 50.55a(g)(5)(iii) and NRC Generic Letter 90-05, "Guidance For Performing Temporary Non-Code Repair of ASME Code Class 1, 2, and 3 Piping." This request for relief related to a through-wall leak identified on the Service Water system vital header 1-SW-110-6-157.

Repair of line 1-SW-110-6-157, in accordance with the ASME Code, Section XI, was completed during BSEP Unit 1 Refueling Outage 12 (i.e., B113R1) by base metal repair of the affected elbow. A copy of Form NIS-2A, "Repair/Replacement Certification Record," for the repair is enclosed. Based on completion of this repair, CP&L withdraws the relief request dated August 25, 1999.

Please refer any questions regarding this submittal to Mr. Leonard R. Beller, Supervisor - Licensing, at (910) 457-2073.

Sincerely,

Warren J. Dorman
Manager - Regulatory Affairs
Brunswick Steam Electric Plant

A047

Document Control Desk
BSEP 00-0055 / Page 2

WRM/wrm

Enclosure: Form NIS-2A, "Repair/Replacement Certification Record"

cc (with enclosure):

U. S. Nuclear Regulatory Commission, Region II
ATTN: Mr. Luis A. Reyes, Regional Administrator
Sam Nunn Atlanta Federal Center
61 Forsyth Street, SW, Suite 23T85
Atlanta, GA 30303-8931

U. S. Nuclear Regulatory Commission
ATTN: Mr. Theodore A. Easlick, NRC Senior Resident Inspector
8470 River Road
Southport, NC 28461-8869

U. S. Nuclear Regulatory Commission
ATTN: Mr. Allen G. Hansen (Mail Stop OWFN 8G9)
11555 Rockville Pike
Rockville, MD 20852-2738

Ms. Jo A. Sanford
Chair - North Carolina Utilities Commission
P.O. Box 29510
Raleigh, NC 27626-0510

Division of Boiler and Pressure Vessel
North Carolina Department of Labor
ATTN: Mr. Jack Given, Assistant Director of Boiler & Pressure Vessels
4 West Edenton Street
Raleigh, NC 27601-1092

ENCLOSURE

BRUNSWICK STEAM ELECTRIC PLANT, UNIT NO. 1
DOCKET NO. 50-325/LICENSE NO. DPR-71
INSERVICE INSPECTION PROGRAM RELIEF REQUEST - SERVICE WATER SYSTEM
PIPING NON-CODE REPAIR

Form NIS-2A, "Repair/Replacement Certification Record"

ATTACHMENT 2
Page 1 of 1
NIS-2A Form

FORM NIS-2A REPAIR/REPLACEMENT CERTIFICATION RECORD

OWNER'S CERTIFICATE OF CONFORMANCE

I certify that the replacement & repair represent by Repair/Replacement
repair or replacement

Plan number 99AFCY1 conforms to the requirements of Section XI. Code Case N-532
 Code Case N-416-1

Type Code Symbol Stamp N/A

Certification of Authorization No. N/A Expiration Date N/A

Signed *James W. Cook* Program Manager Date 3/23/00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and

the State or Province of North Carolina and employed by H.S.B. I. & I. Co. of
Hartford, Ct. have inspected the items described in Repair/Replacement

Plan number 99AFCY1 during the period 2/29/00 to 4/17/00 and state that

to the best of my knowledge and belief, the Owner has performed all the activities described in the Repair/Replacement Plan
in accordance with the requirements of Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning
the activities described in the Repair/Replacement Plan. Furthermore, neither the inspector nor his employer shall be liable in
any manner for any personal injury or property damage or loss of any kind arising from or connected with this inspection.

Raymond W. Peart Commissions NB-9557 - ANIBC, NC-1433
Inspector's Signature National Board, State, Province, and Endorsements

Date 4/17/00

This form (E00126) may be obtained from the Order Dept., ASME, 22 Law Drive, Box 2300, Fairfield, NJ 07007-2300.