



Carolina Power & Light Company
PO Box 1551
Raleigh NC 27602

William S. Orser
Executive Vice President
Energy Supply

JUL 5 2000

SERIAL: HNP-00-096
10CFR50.90

United States Nuclear Regulatory Commission
ATTENTION: Document Control Desk
Washington, DC 20555

SHEARON HARRIS NUCLEAR POWER PLANT
DOCKET NO. 50-400/LICENSE NO. NPF-63
REVISED PAGE FOR LICENSE AMENDMENT REQUEST
REVISION TO TECHNICAL SPECIFICATION 6.2.2.e – OPERATIONS MANAGEMENT
LICENSE REQUIREMENTS

Dear Sir or Madam:

Carolina Power & Light Company (CP&L) requested a revision to Technical Specification (TS) 6.2.2.e concerning Operations management license requirements for the Harris Nuclear Plant (HNP) by letters dated August 2, 1999 and April 7, 2000. Based on discussions with Nuclear Regulatory Commission staff, CP&L is hereby modifying our most recent submittal to include a requirement for a specific individual to hold a senior reactor operator license and be designated to supervise shift work and licensed activities if the Manager-Operations does not hold a senior reactor operator license. This change is consistent with HNP current TS. The proposed Technical Specification page, revised per our discussions, is enclosed.

This change does not affect the conclusions of either the 10 CFR 50.92 evaluation or the Environmental Considerations previously submitted.

Please refer any questions regarding this submittal to Mr. E. McCartney at (919) 362-2661.

Sincerely,

ONW/onw

Enclosure

A001

William S. Orser, having been first duly sworn, did depose and say that the information contained herein is true and correct to the best of his information, knowledge and belief, and the sources of his information are employees, contractors, and agents of Carolina Power & Light Company.


Kathleen Morton Curtis
Notary (Seal)

My commission expires: 11/10/2003

c: Mr. J. B. Brady, NRC Sr. Resident Inspector
Mr. Mel Fry, Director, N.C. DENR
Mr. Rich Laufer, NRC Project Manager
Mr. L. A. Reyes, NRC Regional Administrator

ENCLOSURE TO SERIAL: HNP-00-096

SHEARON HARRIS NUCLEAR POWER PLANT
DOCKET NO. 50-400/LICENSE NO. NPF-63
REVISED PAGE FOR LICENSE AMENDMENT REQUEST
REVISION TO TECHNICAL SPECIFICATION 6.2.2.e – OPERATIONS MANAGEMENT
LICENSE REQUIREMENT

REVISED TECHNICAL SPECIFICATION PAGE

6-1a

ADMINISTRATIVE CONTROLS

UNIT STAFF

6.2.2 The unit organization shall be subject to the following:

- a. Each on-duty shift shall be composed of at least the minimum shift crew composition shown in Table 6.2-1;
- b. At least one licensed Operator shall be in the control room when fuel is in the reactor. In addition, while the unit is in MODE 1, 2, 3, or 4, at least one licensed Senior Operator shall be in the control room;
- c. An individual qualified as a Radiation Control Technician* shall be on site when fuel is in the reactor;
- d. All CORE ALTERATIONS shall be observed and directly supervised by either a licensed Senior Operator or licensed Senior Operator Limited to Fuel Handling who has no other concurrent responsibilities during this operation;
- e. The Manager-Operations shall meet one of the following:
 - (1) Hold a Senior Operator License or,
 - (2) Have held a Senior Operator License for a similar unit, or
 - (3) Have been certified for equivalent senior operator knowledge for a similar unit.

If the Manager-Operations does not hold a Senior Reactor Operator License, an off-shift Operations superintendent who reports directly to the Manager-Operations and holds a Senior Reactor Operator License shall be designated to supervise shift work and licensed activities.

* The Radiation Control Technician composition may be less than the minimum requirements for a period of time not to exceed 2 hours, in order to accommodate unexpected absence, provided immediate action is taken to fill the required positions.

ADMINISTRATIVE CONTROLS

UNIT STAFF

6.2.2 The unit organization shall be subject to the following:

- a. Each on-duty shift shall be composed of at least the minimum shift crew composition shown in Table 6.2-1;
- b. At least one licensed Operator shall be in the control room when fuel is in the reactor. In addition, while the unit is in MODE 1, 2, 3, or 4, at least one licensed Senior Operator shall be in the control room;
- c. An individual qualified as a Radiation Control Technician* shall be on site when fuel is in the reactor;
- d. All CORE ALTERATIONS shall be observed and directly supervised by either a licensed Senior Operator or licensed Senior Operator Limited to Fuel Handling who has no other concurrent responsibilities during this operation;

- e. ~~The Manager-Operations shall either hold a Senior Reactor Operator License or have at one time held a Senior Reactor Operator License for a similar unit. If the Manager-Operations does not hold a Senior Reactor Operator License, an off-shift Operations superintendent who reports directly to the Manager-Operations and holds a Senior Reactor Operator License shall be designated to supervise shift work and licensed activities.~~

meet one of the following:

- (1) Hold a Senior Operator License, or
- (2) Have held a Senior Operator License for a similar unit, or
- (3) Have been certified for equivalent senior operator knowledge for a similar unit.

Add

* The Radiation Control Technician composition may be less than the minimum requirements for a period of time not to exceed 2 hours, in order to accommodate unexpected absence, provided immediate action is taken to fill the required positions.