

July 6, 2000

Mr. James Davis  
Nuclear Energy Institute  
1776 Eye Street, N.W.  
Suite 300  
Washington, DC 20006-2496

Dear Mr. Davis:

This is to inform you that disposition has been made on thirty-eight travelers containing proposed changes to the Standard Technical Specification (STS) NUREGs made by the NEI Technical Specification Task Force (TSTF). Those travelers that were approved between the period of August 1999 to present, are as follows: TSTFs - 017, R.2; - 036, R.4; - 037, R.2; - 051, R.2; - 052, R.3; - 125, R.1; - 207, R.5; - 212, R.1 - 239; - 276, R.2; - 283, R.3; - 286, R.2; - 306, R.2; - 308, R.1; - 324, R.1; - 339, R.2; - 340, R.3; - 348; - 349, R.1; - 350; - 351; - 352, R.1; - 353; - 361, R.1; - 362; - 363; - 364 and - 365. The following TSTF's had approved edits incorporated: - 242, R.1; - 273, R.2; - 297, R.1 and 322, R.2.

TSTF 330, R.1 was modified after discussion with WOG and NRC Plant Systems Branch which recommends the following:

1. adding a suggested explanation to the traveler regarding the conditions that a licensee must confirm in order to adopt the revised action requirements;
2. adding a required action to verify temperature within the upper UHS temperature limit with a one-hour periodic completion time;
3. modify the Condition statement to omit the upper temperature limit, which is now addressed by the added action requirement; and
4. editorial changes to both the action table, the reviewer's note, and the associated Bases.

Mr. J. Davis

- 2 -

July 6, 2000

Enclosed are NRC modifications for traveler -330, R.1. Please contact me at (301) 415-1161 or e-mail [wdb@nrc.gov](mailto:wdb@nrc.gov) if you have any questions or need further information on these dispositions.

Sincerely,

***/RA/***

William D. Beckner, Chief  
Technical Specifications Branch  
Office of Nuclear Reactor Regulation

Enclosure: As stated

cc: J. Arbuckle, BWROG  
T. Weber, CEOG  
N. Clarkson, BWOOG  
S. Wideman, WOG  
D. Hoffman, EXCEL

Mr. J. Davis

- 2 -

July 6, 2000

Enclosed are NRC modifications for traveler -330, R.1. Please contact me at (301) 415-1161 or e-mail [wdb@nrc.gov](mailto:wdb@nrc.gov) if you have any questions or need further information on these dispositions.

Sincerely,

**/RA/**

William D. Beckner, Chief  
Technical Specifications Branch  
Office of Nuclear Reactor Regulation

Enclosure: As stated

cc: J. Arbuckle, BWROG  
T. Weber, CEOG  
N. Clarkson, BWOOG  
S. Wideman, WOG  
D. Hoffman, EXCEL

DISTRIBUTION:

ADAMS PUBLIC RTSB r/f

E-mail:  
WDBeckner  
TSB Staff  
DMatthews/CAder

DOCUMENT NAME:C:\TSTF Disposition Letter Jul~.wpd

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	RTSB/DRIP:NRR	RTSB/DRIP:NRR	SC:RTSB/DRIP:NRR	C:RTSB/DRIP:NRR
NAME	LAHill <b>LAH</b>	TRTjader <b>TRT</b>	RLDennig <b>RLD</b>	WDBeckner <b>WDB</b>
DATE	07/06/00	07/06/00	07/06/00	07/06/00

OFFICIAL RECORD COPY