

REFUELING OPERATIONS
FUEL HANDLING AREA VENTILATION SYSTEM
LIMITING CONDITION FOR OPERATION

=====

3.9.12 The Fuel Handling Area Ventilation System shall be OPERABLE.

APPLICABILITY: Whenever irradiated fuel is in the storage pool.

ACTION:

- a. With no Fuel Handling Area Ventilation System OPERABLE, suspend all operations involving movement of fuel within the storage pool or crane operation with loads over the storage pool until the Fuel Handling Area Ventilation System is restored to OPERABLE status.
- b. The provisions of Specifications 3.0.3 and 3.0.4 are not applicable.

SURVEILLANCE REQUIREMENTS

=====

4.9.12 The above required ventilation system shall be demonstrated OPERABLE:

- a.1 At least once per 31 days by initiating flow through the HEPA filter and charcoal adsorber train and verifying that the train operates for at least 15 minutes.
- a.2 Prior to and during movement of irradiated fuel assemblies or crane operation over the storage pool in the Fuel Handling Building:
 - 1. Both exhaust fans and one supply fan must be OPERABLE and operating with flow being directed through the HEPA and charcoal filters.
 - 2. All dampers required to divert the entire airflow through the HEPA/charcoal filter train are OPERABLE and in the position required to divert full exhaust flow through the HEPA/charcoal filter train.
 - 3. Ductwork, dampers and housings which will ensure all post-accident exhausted air is processed through the HEPA/charcoal filter train are intact.
 - 4. The fuel handling area is maintained at a negative pressure equal to or more negative than 1/8 inch water gauge relative to the outside atmosphere, and
 - 5. At least once per 24 hours thereafter verify both exhaust fans and one supply fan operating with the entire flow being directed through the HEPA and charcoal filters.
- b. At least once per 18 months or (1) after any structural maintenance on the HEPA filter or charcoal adsorber housings, or (2) following painting, fire or chemical release in any ventilation zone communicating with the system, by:

REFUELING OPERATIONS
SURVEILLANCE REQUIREMENTS (Continued)

=====

1. Verifying that with the ventilation system operating at a flow rate of 19,490 cfm \pm 10% and exhausting through the HEPA filters and charcoal adsorbers, the total bypass flow of the ventilation system to the facility vent, including leakage through the ventilation system diverting valves, is \leq 1% when the ventilation system is tested by admitting cold DOP at the storage pool ventilation system intake.
 2. Verifying that the charcoal adsorbers remove \geq 99% of a halogenated hydrocarbon refrigerant test gas when they are tested in-place while operating the ventilation system at a flow rate of 19,490 cfm \pm 10%.
 3. Verifying that the HEPA filter banks remove \geq 99% of the DOP when they are tested in-place while operating the ventilation system at a flow rate of 19,490 cfm \pm 10%.
 4. Verifying within 31 days after removal that a laboratory analysis of a carbon sample from either at least one test canister or at least two carbon samples from one of the charcoal adsorbers demonstrates a removal efficiency of \geq 90% for radioactive methyl iodide when the sample is tested at 130°C, 95% R. H. The carbon samples not obtained from test canisters shall be prepared by either:
 - (a) Emptying one entire bed from a removed adsorber tray, mixing the adsorbent thoroughly, and obtaining samples at least two inches in diameter and with a length equal to the thickness of the bed, or
 - (b) Emptying a longitudinal sample from an adsorber tray, mixing the adsorbent thoroughly, and obtaining samples at least two inches in diameter and with a length equal to the thickness of the bed.
 5. Verifying a system flow rate of 19,490 cfm, \pm 10% during system operation.
- c. After every 720 hours of charcoal adsorber operation by either:
1. Verifying within 31 days after removal that a laboratory analysis of a carbon sample obtained from a test canister demonstrates a removal efficiency of \geq 90% for radioactive methyl iodide when the sample is tested at 130°C, 95% R.H.; or
 2. Verifying within 31 days after removal that a laboratory analysis of at least two carbon samples demonstrate a removal efficiency of \geq 90% for radioactive methyl iodide when the samples are tested at 130°C, 95% R.H. and the samples are prepared by either:
 - a) Emptying one entire bed from a removed adsorber tray, mixing the adsorbent thoroughly, and obtaining samples at least two inches in diameter and with a length equal to the thickness of the bed, or
 - b) Emptying a longitudinal sample from an adsorber tray, mixing the adsorbent thoroughly, and obtaining samples at least two inches in diameter and with a length equal to the thickness of the bed.

**REFUELING OPERATIONS
SURVEILLANCE REQUIREMENTS (Continued)**

Subsequent to reinstalling the adsorber tray used for obtaining the carbon sample, the system shall be demonstrated OPERABLE by also:

- a) Verifying that the charcoal adsorbers remove $\geq 99\%$ of a halogenated hydrocarbon refrigerant test gas when they are tested in-place while operating the ventilation system at a flow rate of 19,490 cfm $\pm 10\%$, and
 - b) Verifying that the HEPA filter banks remove $\geq 99\%$ of the DOP when they are tested in-place while operating the ventilation system at a flow rate of 19,490 cfm $\pm 10\%$.
- d. At least once per 18 months by:
1. Verifying that the pressure drop across the combined HEPA filters and charcoal adsorber banks is ≤ 4 inches Water Gauge while operating the ventilation system at a flow rate of 19,490 cfm $\pm 10\%$.
 2. Verifying that the air flow distribution is uniform within 20% across HEPA filters and charcoal adsorbers.
 3. Deleted.
 4. Verifying that the ventilation system maintains the spent fuel storage pool area at a negative pressure of $\geq 1/8$ inches Water Gauge relative to the outside atmosphere during system operation.
- e. After each complete or partial replacement of a HEPA filter bank by verifying that the HEPA filter banks remove $\geq 99\%$ of the DOP when they are tested in-place while operating the filter train at a flow rate of 19,490 cfm $\pm 10\%$.
- f. After each complete or partial replacement of a charcoal absorber bank by verifying that the charcoal adsorbers remove $\geq 99\%$ of a halogenated hydrocarbon refrigerant test gas when they are tested in-place while operating the filter train at a flow rate of 19,490 cfm $\pm 10\%$.

This page left intentionally blank

REFUELING OPERATIONS BASES

=====

=====

A listing of the active (air/motor operated) valves in the affected flow path to be locked open or disabled.

Note that four filled reactor coolant loops, with at least two steam generators with at least their secondary side water level greater than or equal to 5% (narrow range), may be substituted for one residual heat removal loop. This ensures that a single failure does not cause a loss of decay heat removal.

With the reactor vessel head removed and 23 feet of water above the reactor pressure vessel flange, a large heat sink is available for core cooling. Thus, in the event of a failure of the operating RHR loop, adequate time is provided to initiate emergency procedures to cool the core.

3/4.9.9 CONTAINMENT PURGE AND PRESSURE-VACUUM RELIEF ISOLATION SYSTEM

The OPERABILITY of this system ensures that the containment vent and purge penetrations will be automatically isolated upon detection of high radiation levels within the containment. The OPERABILITY of this system is required to restrict the release of radioactive material from the containment atmosphere to the environment.

3/4.9.10 and 3/4.9.11 WATER LEVEL - REACTOR VESSEL AND STORAGE POOL

The restrictions on minimum water level ensure that sufficient water depth is available to remove 99% of the assumed 10% iodine gap activity released from the rupture of an irradiated fuel assembly. The minimum water depth is consistent with the assumptions of the accident analysis.

3/4.9.12 FUEL HANDLING AREA VENTILATION SYSTEM

The limitations on the fuel handling area ventilation system ensure that all radioactive material released from a dropped irradiated fuel assembly will be filtered through the HEPA filters and charcoal adsorber prior to discharge to the atmosphere. The OPERABILITY of this system and the resulting iodine removal capacity are consistent with the assumptions of the accident analyses.

The operability of the Fuel Handling Area Ventilation System during movement of irradiated fuel ensures all building exhaust flow is processed through the HEPA/charcoal filter train whenever a Fuel Handling Accident is possible. This will minimize offsite doses following the postulated Fuel Handling Accident.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

PUBLIC SERVICE ELECTRIC & GAS COMPANY

PHILADELPHIA ELECTRIC COMPANY

DELMARVA POWER AND LIGHT COMPANY

ATLANTIC CITY ELECTRIC COMPANY

DOCKET NO. 50-311

SALEM NUCLEAR GENERATING STATION, UNIT NO. 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 211
License No. DPR-75

1. The Nuclear Regulatory Commission (the Commission or the NRC) has found that:
 - A. The application for amendment filed by the Public Service Electric & Gas Company, Philadelphia Electric Company, Delmarva Power and Light Company and Atlantic City Electric Company (the licensees) dated April 14, 1999, as supplemented by letter dated March 2, 2000, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-75 is hereby amended to read as follows:

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 211 , are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance and shall be implemented within 60 days.

FOR THE NUCLEAR REGULATORY COMMISSION

Bartholomew C. Buckley for

James W. Clifford, Chief, Section 2
Project Directorate I
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical
Specifications

Date of Issuance: June 14, 2000

ATTACHMENT TO LICENSE AMENDMENT NO. 211

FACILITY OPERATING LICENSE NO. DPR-75

DOCKET NO. 50-311

Replace the following pages of the Appendix A, Technical Specifications, with the attached revised pages as indicated. The revised pages are identified by amendment number and contain marginal lines indicating the areas of change. Overleaf pages have been provided.

Remove Pages

3/4 9-13

3/4 9-14

B 3/4 9-4

Insert Pages

3/4 9-13

3/4 9-14

B 3/4 9-4

REFUELING OPERATIONS

3/4.9.12 FUEL HANDLING AREA VENTILATION SYSTEM

LIMITING CONDITION FOR OPERATION

3.9.12 The Fuel Handling Area Ventilation System shall be OPERABLE.

APPLICABILITY: Whenever irradiated fuel is in the storage pool.

ACTION:

- a. With no Fuel Handling Area Ventilation System OPERABLE, suspend all operations involving movement of fuel within the storage pool or crane operation with loads over the storage pool until the Fuel Handling Area Ventilation System is restored to OPERABLE status.
- b. The provisions of Specifications 3.0.3 and 3.0.4 are not applicable.

SURVEILLANCE REQUIREMENTS

4.9.12 The above required ventilation system shall be demonstrated OPERABLE:

- a.1. At least once per 31 days by initiating flow through the HEPA filter and charcoal adsorber train and verifying that the train operates for at least 15 minutes.
- a.2. Prior to and during movement of irradiated fuel assemblies or crane operation over the storage pool in the Fuel Handling Building:
 1. Both exhaust fans and one supply fan must be OPERABLE and operating with flow being directed through the HEPA and charcoal filters.
 2. All dampers required to divert the entire airflow through the HEPA/charcoal filter train are OPERABLE and in the position required to divert full exhaust flow through the HEPA/charcoal filter train.
 3. Ductwork, dampers and housings which will ensure all post-accident exhausted air is processed through the HEPA/charcoal filter train are intact.
 4. The fuel handling area is maintained at a negative pressure equal to or more negative than 1/8 inch water gauge relative to the outside atmosphere, and
 5. At least once per 24 hours thereafter verify both exhaust fans and one supply fan operating with the entire flow being directed through the HEPA and charcoal filters.
- b. At least once per 18 months or (1) after any structural maintenance on the HEPA filter or charcoal adsorber housings, or (2) following painting, fire or chemical release in any ventilation zone communicating with the system, by:

REFUELING OPERATIONS
SURVEILLANCE REQUIREMENTS (Continued)

=====

1. Verifying that with the ventilation system operating at a flow rate of 19,490 cfm \pm 10% and exhausting through the HEPA filters and charcoal adsorbers, the total bypass flow of the ventilation system to the facility vent, including leakage through the ventilation system diverting valves, is \leq 1% when the ventilation system is tested by admitting cold DOP at the storage pool ventilation system intake.
 2. Verifying that the charcoal adsorbers remove \geq 99% of a halogenated hydrocarbon refrigerant test gas and that the HEPA filter banks remove \geq 99% of the DOP when they are tested in-place using the test procedure guidance of Regulatory Positions C.5.a, C.5.c and C.5.d of Regulatory Guide 1.52, Revision 2, March 1978 (except for the provisions of ANSI N510 Sections 8 and 9), and the system flow rate is 19,490 cfm \pm 10%.
 3. Verifying within 31 days after removal that a laboratory analysis of a representative carbon sample obtained in accordance with Regulatory Position C.6.b of Regulatory Guide 1.52, Revision 2, March 1978, meets the laboratory testing criteria of Regulatory Position C.6.a of Regulatory Guide 1.52, Revision 2, March 1978.
 4. Verifying a system flow rate of 19,490 cfm \pm 10% during system operation.
- c. After every 720 hours of charcoal adsorber operation by verifying within 31 days after removal that a laboratory analysis of a representative carbon sample obtained in accordance with Regulatory Position C.6.b of Regulatory Guide 1.52, Revision 2, March 1978, meets the laboratory testing criteria of Regulatory Position C.6.a of Regulatory Guide 1.52, Revision 2, March 1978.
- d. At least once per 18 months by:
1. Verifying that the pressure drop across the combined HEPA filters and charcoal adsorber banks is less than or equal to 4 inches Water Gauge while operating the system at a flow rate of 19,490 cfm \pm 10%.
 2. Deleted.
 3. Verifying that the system maintains the spent fuel storage pool area at a negative pressure of greater than or equal to 1/8 inches Water Gauge relative to the outside atmosphere during system operation.

REFUELING OPERATIONS BASES

A listing of the active (air/motor operated) valves in the affected flow path to be locked open or disable.

Note that four filled reactor coolant loops, with at least two steam generators with at least their secondary side water level greater than or equal to 5% (narrow range), may be substituted for one residual heat removal loop. This ensures that single failure does not cause a loss of decay heat removal.

With the reactor vessel head removed and 23 feet of water above the reactor pressure vessel flange, a large heat sink is available for core cooling. Thus, in the event of a failure of the operating RHR loop, adequate time is provided to initiate emergency procedures to cool the core.

3/4.9.9 CONTAINMENT PURGE AND PRESSURE-VACUUM RELIEF ISOLATION SYSTEM

The OPERABILITY of this system ensures that the containment vent and purge penetrations will be automatically isolated upon detection of high radiation levels within the containment. The OPERABILITY of this system is required to restrict the release of radioactive material from the containment atmosphere to the environment.

3/4.9.10 and 3/4/9/11 WATER LEVEL - REACTOR VESSEL AND STORAGE POOL

The restrictions on minimum water level ensure that sufficient water depth is available to remove 99% of the assumed 10% iodine gap activity released from the rupture of an irradiated fuel assembly. The minimum water depth is consistent with the assumptions of the accident analysis.

3/4.9.12 FUEL HANDLING AREA VENTILATION SYSTEM

The limitations on the fuel handling area ventilation system ensure that all radioactive material released from a dropped irradiated fuel assembly will be filtered through the HEPA filters and charcoal adsorber prior to discharge to the atmosphere. The OPERABILITY of this system and the resulting iodine removal capacity are consistent with the assumptions of the accident analyses.

The operability of the Fuel Handling Area Ventilation System during movement of irradiated fuel ensures all building exhaust flow is processed through the HEPA/charcoal filter train whenever a Fuel Handling Accident is possible. This will minimize offsite doses following the postulated Fuel Handling Accident.