

July 17, 2000

Mr. John K. Wood
Vice President - Nuclear, Perry
FirstEnergy Nuclear Operating Company
P.O. Box 97, A200
Perry, OH 44081

SUBJECT: PERRY NUCLEAR POWER PLANT, UNIT 1 - ISSUANCE OF CORRECTION
LETTER TO AMENDMENT NO. 112 (TAC NO. MA6459)

Dear Mr. Wood:

By letter dated June 1, 2000, the U.S. Nuclear Regulatory Commission issued Amendment No. 112 to Facility Operating License No. NPF-58 for the Perry Nuclear Power Plant, Unit 1. This amendment increased the 100 percent authorized rated thermal power level from 3579 megawatts thermal to 3758 megawatts thermal. This represented a power level increase of five percent for the Perry Nuclear Power Plant.

Due to an administrative oversight, the staff did not exercise proper signature authority when issuing Amendment No. 112. Therefore, the staff is reissuing the enclosed amendment page.

We apologize for any inconvenience this may have caused.

Sincerely,

/RA/

Douglas V. Pickett, Sr. Project Manager, Section 2
Project Directorate III
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-440

Enclosure: Amendment No. 112 to
License No. NPF-58

cc w/encl: See next page

July 17, 2000

Mr. John K. Wood
Vice President - Nuclear, Perry
FirstEnergy Nuclear Operating Company
P.O. Box 97, A200
Perry, OH 44081

DISTRIBUTION:

PUBLIC
PD3-2 r/f
ACRS
OGC
WBeckner, TSB
GGrant, RIII

SUBJECT: PERRY NUCLEAR POWER PLANT, UNIT 1 - ISSUANCE OF CORRECTION LETTER TO AMENDMENT NO. 112 (TAC NO. MA6459)

Dear Mr. Wood:

By letter dated June 1, 2000, the U.S. Nuclear Regulatory Commission issued Amendment No. 112 to Facility Operating License No. NPF-58 for the Perry Nuclear Power Plant, Unit 1. This amendment increased the 100 percent authorized rated thermal power level from 3579 megawatts thermal to 3758 megawatts thermal. This represented a power level increase of five percent for the Perry Nuclear Power Plant.

Due to an administrative oversight, the staff did not exercise proper signature authority when issuing Amendment No. 112. Therefore, the staff is reissuing the enclosed amendment page.

We apologize for any inconvenience this may have caused.

Sincerely,

/RA/

Douglas V. Pickett, Sr. Project Manager, Section 2
Project Directorate III
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-440

Enclosure: Amendment No. 112 to
License No. NPF-58

cc w/encl: See next page
ACCESSION NO: ML003733150

OFFICE	PM:LPD3	LA:LPD3	SC:LPD3	PD:LPD3	D:DLPM
NAME	DPickett	THarris	GDick for AMendiola	SBajwa	JZwolinski
DATE	7/13/00	7/13/00	7/13/00	7/13/00	7/14/00
OFFICE	NRR:ADPT	NRR:D			
NAME	BSheron	SCollins			
DATE	7/14/00	7/16/00			

OFFICIAL RECORD COPY

J. Wood
FirstEnergy Nuclear Operating Company

Perry Nuclear Power Plant, Units 1 and 2

cc:

Mary E. O'Reilly
FirstEnergy Corporation
76 South Main St.
Akron, OH 44308

James R. Williams, Executive Director
Ohio Emergency Management Agency
2855 West Dublin Granville Road
Columbus, OH 43235-7150

Resident Inspector's Office
U.S. Nuclear Regulatory Commission
P.O. Box 331
Perry, OH 44081-0331

Mayor, Village of Perry
P.O. Box 100
Perry, OH 44081-0100

Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
801 Warrenville Road
Lisle, IL 60532-4531

Harvey B. Brugger, Supervisor
Radiological Assistance Section
Bureau of Radiation Protection
Ohio Department of Health
P.O. Box 118
Columbus, OH 43266-0118

Sue Hiatt
OCRE Interim Representative
8275 Munson
Mentor, OH 44060

Ohio Environmental Protection
Agency
DERR--Compliance Unit
ATTN: Mr. Zack A. Clayton
P.O. Box 1049
Columbus, OH 43266-0149

Gregory A. Dunn
Manager - Regulatory Affairs
FirstEnergy Nuclear Operating Company
Perry Nuclear Power Plant
P.O. Box 97, A210
Perry, OH 44081

Chairman
Perry Township Board of Trustees
3750 Center Road, Box 65
Perry, OH 44081

William R. Kanda, Jr., Plant Manager
FirstEnergy Nuclear Operating Company
Perry Nuclear Power Plant
P.O. Box 97, SB306
Perry, OH 44081

State of Ohio
Public Utilities Commission
East Broad Street
Columbus, OH 43266-0573

Mayor, Village of North Perry
North Perry Village Hall
4778 Lockwood Road
North Perry Village, OH 44081

Donna Owens, Director
Ohio Department of Commerce
Division of Industrial Compliance
Bureau of Operations & Maintenance
6606 Tussing Road
P. O. Box 4009
Reynoldsburg, OH 43068-9009

FIRSTENERGY NUCLEAR OPERATING COMPANY

DOCKET NO. 50-440

PERRY NUCLEAR POWER PLANT, UNIT 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 112
License No. NPF-58

1. The U.S. Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by the FirstEnergy Nuclear Operating Company (the licensee) dated September 9, 1999, as supplemented by submittals dated March 1, March 13, and May 11, 2000, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. NPF-58 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A and the Environmental Protection Plan contained in Appendix B, as revised through Amendment No.112 are hereby incorporated into this license. The FirstEnergy Nuclear Operating Company shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of its date of issuance and shall be implemented not later than 45 days after completion of the next scheduled refuel outage.

FOR THE NUCLEAR REGULATORY COMMISSION

/RA/

Samuel J. Collins, Director
Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical
Specifications

Date of Issuance: June 1, 2000