

July 10, 2000  
(NMP95126)

United States Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, DC 20555

RE: Nine Mile Point Unit 2  
Docket No. 50-410  
NPF-69

Subject: Monthly Operating Report for June 2000

Dear Sir:

Submitted herewith is the Operating Data Report, the Unit Shutdowns, and Summary of Operating Experience for June 2000.

Very truly yours,



M. F. Peckham  
Plant Manager - NMP2

/db

Attachments

xc: H.J. Miller, Regional Administrator, Region I  
G.K. Hunegs, Senior Resident Inspector  
Records Management

IE24

**NIAGARA MOHAWK POWER CORPORATION**  
**NINE MILE POINT NUCLEAR STATION UNIT #2**  
**SUMMARY OF OPERATING EXPERIENCE**

Nine Mile Point Unit Two operated with a capacity factor (MDC) of 100.84% and an availability factor of 100.00% for the month of **June 2000**.

On June 10, 2000 at 0053 hours Nine Mile Point Unit Two commenced a down power to 62% to perform a control rod sequence exchange and to repair a steam leak on the moisture separator reheater drain line level switch 2DSR-LS67A. The unit returned to 100% of rated core thermal power on June 11, 2000 at 0441 hours.

There were no challenges to the safety relief valves during this period.

**OPERATING DATA REPORT**

**DOCKET NO.: 50-410**

**DATE: 000707**

**PREPARED BY: C. Caroccio**

**TELEPHONE: (315) 349-4615**

**OPERATING STATUS**

<b>Unit Name:</b>	<b>Nine Mile Point Unit #2</b>
<b>Reporting Period:</b>	<b>June 2000</b>
<b>1. Design Electrical Rating (MWe)</b>	<b>1143.3</b>
<b>2. Maximum Dependable Capacity (Net MWe):</b>	<b>1123.4</b>

	<u><b>This Month</b></u>	<u><b>Yr-to-Date</b></u>	<u><b>Cumulative</b></u>
<b>3. Number of Hours Reactor was Critical</b>	<b>720.0</b>	<b>3,262.7</b>	<b>83,015.6</b>
<b>4. Hours Generator On-Line</b>	<b>720.0</b>	<b>3,212.6</b>	<b>80,421.8</b>
<b>5. Reactor Reserve Shutdown Hours</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>
<b>6. Net Electrical Energy Gen. (MWH)</b>	<b>815,617.3</b>	<b>3,589,734.8</b>	<b>82,787,699.4</b>

# UNIT SHUTDOWNS

DOCKET NO: 50-410

UNIT NAME: NMP#2

DATE: 000707

PREPARED BY: C. Caroccio

TELEPHONE: (315) 349-4615

## APPENDIX B REPORTING PERIOD - JUNE 2000

No.	Date	Type F: Forced S: Scheduled	Duration (Hours)	Reasons <sup>1</sup>	Method of Shutting Down <sup>2</sup>	Cause & Corrective Actions Comments
NONE						

<sup>1</sup>

**Reason:**

- A-Equipment Failure (Explain)
- B-Maintenance or Test
- C-Refueling
- D-Regulatory Restriction
- E-Operator Training & License Exam
- F-Administrative
- G-Operational Error (Explain)
- H-Other (Explain)

<sup>2</sup>

**Method:**

- 1-Manual
- 2-Manual Trip/Scram
- 3-Automatic Trip/Scram
- 4-Continuation
- 5-Other (Explain)