



A PECO Energy/British Energy Company

Clinton Power Station

P.O. Box 678
Clinton, IL 61727
Phone: 217 935-8881

U-603395

8E.100c

July 14, 2000

Docket No. 50-461

10CFR50.36

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

Subject: Clinton Power Station, Unit 1
Facility Operating License NPF-62
June 2000 Monthly Operating Report

Dear Madam or Sir:

Please find in Attachment 1 the Monthly Operating Report for Clinton Power Station, Unit 1, for the period ending June 30, 2000.

Sincerely yours,

Michael A. Reandeau
Director-Licensing

MJS/blf

Attachments

cc: NRC Region III Regional Administrator
Illinois Department of Nuclear Safety
NRC Resident Office, V-690
Resident IDNS Inspector, T-31Z

JEAY

CHALLENGES TO MAIN STEAM SAFETY/RELIEF VALVES

Month June 2000

None

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-461
UNIT Clinton 1
DATE 06/30/00
COMPLETED BY M. J. Sloan
TELEPHONE (217)935-8881-X3280

MONTH June 2000

1	<u>929</u>	17	<u>932</u>
2	<u>843</u>	18	<u>930</u>
3	<u>12</u>	19	<u>930</u>
4	<u>0</u>	20	<u>928</u>
5	<u>0</u>	21	<u>929</u>
6	<u>31</u>	22	<u>929</u>
7	<u>673</u>	23	<u>928</u>
8	<u>930</u>	24	<u>929</u>
9	<u>929</u>	25	<u>928</u>
10	<u>930</u>	26	<u>926</u>
11	<u>918</u>	27	<u>928</u>
12	<u>929</u>	28	<u>929</u>
13	<u>928</u>	29	<u>929</u>
14	<u>928</u>	30	<u>928</u>
15	<u>929</u>		
16	<u>929</u>		

OPERATING DATA REPORT

DOCKET NO. 50-461
UNIT Clinton 1
DATE 06/30/00
COMPLETED BY M. J. Sloan
TELEPHONE (217)935-8881-X3280

OPERATING STATUS

1. REPORTING PERIOD: June 2000 GROSS HOURS IN REPORT PERIOD: 720
2. CURRENTLY AUTHORIZED POWER LEVEL (MWt): 2894
MAX. DEPEND. CAPACITY (MDC) (MWe-Net): 930
DESIGN ELECTRICAL RATING (MWe-NET): 933
3. POWER LEVEL TO WHICH RESTRICTED (IF ANY) (MWe-Net): None
4. REASONS FOR RESTRICTION (IF ANY): N/A

	THIS MONTH	YR TO DATE	CUMULATIVE
5. NUMBER OF HOURS REACTOR WAS CRITICAL.....	<u>664.8</u>	<u>4,189.6</u>	<u>68,663.7</u>
6. REACTOR RESERVE SHUTDOWN HOURS.....	<u>0.0</u>	<u>0.0</u>	<u>0.0</u>
7. HOURS GENERATOR ON LINE.....	<u>632.3</u>	<u>4,110.6</u>	<u>66,783.3</u>
8. UNIT RESERVE SHUTDOWN HOURS.....	<u>0.0</u>	<u>0.0</u>	<u>4.0</u>
9. GROSS THERMAL ENERGY GENERATED (MWH).....	<u>1,794.593</u>	<u>11,772,781</u>	<u>181,140,869.6</u>
10. GROSS ELECTRICAL ENERGY GENERATED (MWH).....	<u>597.930</u>	<u>3,941,201</u>	<u>59,970,994</u>
11. NET ELECTRICAL ENERGY GENERATED (MWH).....	<u>572,193</u>	<u>3,786,684</u>	<u>57,188,037</u>
12. REACTOR SERVICE FACTOR.....	<u>92.3%</u>	<u>95.9%</u>	<u>62.1%</u>
13. REACTOR AVAILABILITY FACTOR.....	<u>92.3%</u>	<u>95.9%</u>	<u>62.1%</u>
14. UNIT SERVICE FACTOR.....	<u>87.8%</u>	<u>94.1%</u>	<u>60.4%</u>
15. UNIT AVAILABILITY FACTOR.....	<u>87.8%</u>	<u>94.1%</u>	<u>60.4%</u>
16. UNIT CAPACITY FACTOR (Using MDC).....	<u>85.5%</u>	<u>93.2%</u>	<u>55.7%</u>
17. UNIT CAPACITY FACTOR (Using Design MWe).....	<u>85.2%</u>	<u>92.9%</u>	<u>55.5%</u>
18. UNIT FORCED OUTAGE RATE.....	<u>0.0%</u>	<u>3.9%</u>	<u>8.2%</u>

19. SHUTDOWNS SCHEDULED OVER NEXT SIX MONTHS (TYPE, DATE, DURATION OF EACH):

RF-7 Refueling Outage 7 (scheduled October 15, 2000) with a 26 day window.

20. IF SHUT DOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF STARTUP: N/A

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-461

UNIT Clinton 1

DATE 06/30/00

COMPLETED BY M. J. Sloan

REPORT MONTH June 2000

NO.	DATE	TYPE		DURATION (HOURS)	REASON (1)	METHOD OF SHUTTING DOWN THE REACTOR OR REDUCING POWER (2)	CORRECTIVE ACTIONS/COMMENTS
		F: S:	FORCED SCHEDULED				
	00/06/02		S	87.7	B	1	REACTOR SHUTDOWN FOR MO-9

- (1) Reason
A - Equipment Failure (explain), B - Maintenance or Test, C - Refueling, D - Regulatory Restriction
E - Operator training & License Examination, F - Administrative, G - Operational Error (explain)
- (2) Method
1 - Manual, 2 - Manual Scram, 3 - Automatic Scram, 4 - Other (explain)