

Dave Morey
Vice President
Farley Project

**Southern Nuclear
Operating Company**
P.O. Box 1295
Birmingham, Alabama 35201
Tel 205.992.5131

July 13, 2000

Docket Nos.: 50-348
50-364



Energy to Serve Your WorldSM

NEL-00-0178

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D. C. 20555-0001

Joseph M. Farley Nuclear Plant
Monthly Operating Report

Ladies and Gentlemen:

Enclosed are the June 2000 Monthly Operating Reports for Joseph M. Farley Nuclear Plant Units 1 and 2, as required by Section 5.6.4 of the Technical Specifications.

If you have any questions, please advise.

Respectfully submitted,

A handwritten signature in black ink that reads "Dave Morey".

Dave Morey

RWC:mor

Enclosures:

1. June Monthly Operating Report for Plant Farley Unit 1
2. June Monthly Operating Report for Plant Farley Unit 2

IE24

Page 2

U. S. Nuclear Regulatory Commission

cc: Southern Nuclear Operating Company
Mr. L. M. Stinson, General Manager

U. S. Nuclear Regulatory Commission, Washington, D. C.
Mr. L. M. Padovan, Licensing Project Manager – Farley

U. S. Nuclear Regulatory Commission, Region II
Mr. L. A. Reyes, Regional Administrator
Mr. T. P. Johnson, Senior Resident Inspector – Farley

OPERATING DATA REPORT

DOCKET NO.: 50-348
UNIT NAME: J. M. Farley - Unit 1
DATE: July 6, 2000
COMPLETED BY: W. L. Marlar
TELEPHONE: (334) 814-4554

OPERATING STATUS

1. Reporting Period: JUNE 2000
 2. Design Electrical Rating (Net MWe): 854
 3. Maximum Dependable Capacity (Net MWe): 828

	<u>This Month</u>	<u>Year to Date</u>	<u>Cumulative</u>
4. Number Of Hours Reactor Was Critical:	<u>720.0</u>	<u>2,395.3</u>	<u>160,020.7</u>
5. Hours Generator On-line:	<u>720.0</u>	<u>2,358.9</u>	<u>157,814.2</u>
6. Unit Reserve Shutdown Hours:	<u>0.0</u>	<u>0.0</u>	<u>0.0</u>
7. Net Electrical Energy Generated (MWH):	<u>559,711.0</u>	<u>1,522,924.0</u>	<u>124,283,757.0</u>

CHALLENGES TO PRESSURIZER PORV OR PRESSURIZER SAFETY VALVES

Date	Tag No.	Event Description
		There were no challenges to Pressurizer PORV or Pressurizer Safety Valves.

UNIT SHUTDOWNS

DOCKET NO.: 50-348

UNIT NAME: J. M. Farley - Unit 1

DATE: July 6, 2000

COMPLETED BY: W. L. Marlar

TELEPHONE: (334) 814-4554

REPORTING PERIOD: JUNE 2000

No.	Date	Type F: Forced S: Scheduled	Duration (Hours)	Reason (1)	Method of Shutting Down (2)	Cause/Corrective Actions Comments
						<p>There were no unit shutdowns during the month.</p> <p>May 2000 report comment stated "LER Pending". LER 2000-006-00 was submitted on 000623. It attributed the 000528 reactor trip to (1) governor valve cycling due to inappropriate procedural guidance selection and use, and (2) Inadequate documentation in a turbine control software change.</p>

(1) REASON:

- A - Equipment Failure (Explain)
- B - Maintenance or Test
- C - Refueling
- D - Regulatory Restriction
- E - Operator Training/License Examination
- F - Administrative
- G - Operational Error (Explain)
- H - Other (Explain)

(2) METHOD:

- 1 - Manual
- 2 - Manual Trip/Scram
- 3 - Automatic Trip/Scram
- 4 - Continuation
- 5 - Other (Explain)

CAUSE/CORRECTIVE ACTION/COMMENTS

NARRATIVE REPORT

At 0000 on 000601 the unit was at 49.4% power following a scheduled refueling outage and an unplanned reactor trip on 000528 as reported in the May 2000 narrative. The unit was returned to 100% power at 0239 on 000603.

At 0306 on 000623 the unit was ramped down to approximately 60% power because of a structural failure of a cooling tower cell. Later that day the unit's power was increased to approximately 80% power where it remained for the remainder of this reporting period. Repairs to the cooling tower were still in progress at the end of this reporting period.

OPERATING DATA REPORT

DOCKET NO.: 50-364
UNIT NAME: J. M. Farley - Unit 2
DATE: July 6, 2000
COMPLETED BY: W. L. Marlar
TELEPHONE: (334) 814-4554

OPERATING STATUS

1. Reporting Period:	JUNE 2000
2. Design Electrical Rating (Net MWe):	855
3. Maximum Dependable Capacity (Net MWe):	838

	<u>This Month</u>	<u>Year to Date</u>	<u>Cumulative</u>
4. Number Of Hours Reactor Was Critical:	720.0	4,367.0	144,125.8
5. Hours Generator On-line:	720.0	4,367.0	142,254.8
6. Unit Reserve Shutdown Hours:	0.0	0.0	0.0
7. Net Electrical Energy Generated (MWH):	606,987.0	3,696,827.0	113,149,355.0

CHALLENGES TO PRESSURIZER PORV OR PRESSURIZER SAFETY VALVES

Date	Tag No.	Event Description
		There were no challenges to Pressurizer PORV or Pressurizer Safety Valves.

UNIT SHUTDOWNS

DOCKET NO.: 50-364

UNIT NAME: J. M. Farley - Unit 2

DATE: July 6, 2000

COMPLETED BY: W. L. Marlar

TELEPHONE: (334) 814-4554

REPORTING PERIOD: JUNE 2000

No.	Date	Type F: Forced S: Scheduled	Duration (Hours)	Reason (1)	Method of Shutting Down (2)	Cause/Corrective Actions Comments
						There were no unit shutdowns during the month.

(1) REASON:

- A - Equipment Failure (Explain)
- B - Maintenance or Test
- C - Refueling
- D - Regulatory Restriction
- E - Operator Training/License Examination
- F - Administrative
- G - Operational Error (Explain)
- H - Other (Explain)

(2) METHOD:

- 1 - Manual
- 2 - Manual Trip/Scram
- 3 - Automatic Trip/Scram
- 4 - Continuation
- 5 - Other (Explain)

CAUSE/CORRECTIVE ACTION/COMMENTS

NARRATIVE REPORT

There were no significant power reductions this period.