

Commonwealth Edison Company
Quad Cities Generating Station
22710 206th Avenue North
Cordova, IL 61242-9740
Tel 309-654-2241



July 12, 2000

SVP-00-116

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555-0001


Quad Cities Nuclear Power Station, Units 1 and 2
Facility Operating License Nos. DPR-29 and DPR-30
NRC Docket Nos. 50-254 and 50-265

Subject: Monthly Operating Report

In accordance with Generic Letter 97-02 and Technical Specification 6.9.5, "Monthly Operating Reports," we are submitting the Monthly Operating Report for Quad Cities Nuclear Power Station, Units 1 and 2. This report covers the period of June 1, 2000 to June 30, 2000.

Should you have any questions concerning this letter, please contact Mr. C.C. Peterson at (309) 654-2241, extension 3609.

Respectfully,


Joel P. Dimmette, Jr.
Site Vice President
Quad Cities Nuclear Power Station

Attachment

cc: Regional Administrator – NRC Region III
NRC Senior Resident Inspector – Quad Cities Nuclear Power Station

JE24

ATTACHMENT

QUAD CITIES NUCLEAR POWER STATION UNITS 1 AND 2
MONTHLY OPERATING REPORT

COMMONWEALTH EDISON COMPANY

AND

MIDAMERICAN ENERGY COMPANY

FACILITY OPERATING LICENSE NOS. DPR-29 AND DPR-30

NRC DOCKET NOS. 50-254 AND 50-265

TABLE OF CONTENTS

- I. Introduction
- II. Summary of Operating Experience
 - A. Unit One
 - B. Unit Two
- III. Operating Data Statistics
 - A. Operating Data Report for June - Quad Cities Unit One
 - B. Operating Data Report for June - Quad Cities Unit Two
- IV. Unit Shutdowns
 - A. Unit One Shutdowns
 - B. Unit Two Shutdowns
- V. Amendments to Facility License or Technical Specifications
- VI. Unique Reporting Requirements
 - A. Main Steam Relief Valve Operations

I. INTRODUCTION

Quad Cities Nuclear Power Station is composed of two Boiling Water Reactors and Steam Turbine/Generators, each with a Maximum Dependable Capacity of 769 MWe Net, located in Cordova, Illinois. The Station is jointly owned by Commonwealth Edison Company and MidAmerican Energy Company. The Nuclear Steam Supply Systems are General Electric Company Boiling Water Reactors. The Architect/ Engineer was Sargent & Lundy, Incorporated, and the primary construction contractor was United Engineers & Constructors. The Mississippi River is the condenser cooling water source. The plant is subject to license numbers DPR-29 and DPR-30, issued October 1, 1971, and March 21, 1972, respectively; pursuant to Docket Numbers 50-254 and 50-265. The date of initial Reactor criticalities for Units One and Two, respectively were October 18, 1971, and April 26, 1972. Commercial generation of power began on March 18, 1973 for Unit One and March 10, 1973 for Unit Two.

This report was compiled by Lynne Hamilton and Debra Kelley, telephone number 309-654-2241, extensions 3114 and 2240, respectively.

II. SUMMARY OF OPERATING EXPERIENCE

A. Unit One

Quad Cities Unit One began the month of June operating at full power. Unit One operated throughout the month at full power with minor down power operations for normal maintenance and surveillance testing.

B. Unit Two

Quad Cities Unit Two began the month of June operating at full power. On June 4, 2000, load was dropped to perform a rod pattern shuffle, work on the feedwater heater, scram timing, and turbine testing. Unit Two operated throughout the remainder of the month at full power with minor down power operations for normal maintenance and surveillance testing.

III. OPERATING DATA STATISTICS

A. Unit One Operating Data Report for June 2000

DOCKET NO.: 50-254
 DATE: July 11, 2000
 COMPLETED BY: Lynne Hamilton
 TELEPHONE: (309) 654-2241

OPERATING STATUS

0000 060100

1. REPORTING PERIOD: 2400 063000 GROSS HOURS IN REPORTING PERIOD: 720
2. CURRENTLY AUTHORIZED POWER LEVEL (MWt): 2511 MAX. DEPEND. CAPACITY: 769
 DESIGN ELECTRICAL RATING (MWe-NET): 789

UNIT ONE	THIS MONTH	YTD	CUMULATIVE
3. NUMBER OF HOURS THE REACTOR WAS CRITICAL	720.00	4367.00	189409.30
4. REACTOR RESERVE SHUTDOWN HOURS	0.00	0.00	3421.90
5. HOURS GENERATOR ON-LINE	720.00	4367.00	184172.60
6. UNIT RESERVE SHUTDOWN HOURS	0.00	0.00	909.20
7. GROSS THERMAL ENERGY GENERATED (MWH)	1806664.56	10928524.32	407112242.76
8. GROSS ELECTRICAL ENERGY GENERATED (MWH)	580451.00	3541234.00	131744746.00
9. NET ELECTRICAL ENERGY GENERATED (MWH)	554468.00	3387970.00	119023412.00
10. REACTOR SERVICE FACTOR	100.00	100.00	76.57
11. REACTOR AVAILABILITY FACTOR	100.00	100.00	77.95
12. UNIT SERVICE FACTOR	100.00	100.00	74.45
13. UNIT AVAILABILITY FACTOR	100.00	100.00	74.82
14. UNIT CAPACITY FACTOR (Using MDC)	100.14	100.89	62.57
15. UNIT CAPACITY FACTOR (Using Design MWe)	97.60	98.33	60.98
16. UNIT FORCED OUTAGE RATE	0.00	0.00	6.66

III. OPERATING DATA STATISTICS

B. Unit Two Operating Data Report for June 2000

DOCKET NO.: 50-265
 DATE: July 11, 2000
 COMPLETED BY: Lynne Hamilton
 TELEPHONE: (309) 654-2241

OPERATING STATUS

0000 060100

1. REPORTING PERIOD: 2400 063000 GROSS HOURS IN REPORTING PERIOD: 720
2. CURRENTLY AUTHORIZED POWER LEVEL (Mwt): 2511 MAX. DEPEND. CAPACITY: 769
 DESIGN ELECTRICAL RATING (MWe-NET): 789

UNIT TWO	THIS MONTH	YTD	CUMULATIVE
3. NUMBER OF HOURS THE REACTOR WAS CRITICAL	720.00	3820.20	182048.60
4. REACTOR RESERVE SHUTDOWN HOURS	0.00	0.00	2985.80
5. HOURS GENERATOR ON-LINE	720.00	3773.10	177377.15
6. UNIT RESERVE SHUTDOWN HOURS	0.00	0.00	702.90
7. GROSS THERMAL ENERGY GENERATED (MWH)	1793724.00	9151799.04	391248506.94
8. GROSS ELECTRICAL ENERGY GENERATED (MWH)	584935.00	2985994.00	125593509.00
9. NET ELECTRICAL ENERGY GENERATED (MWH)	561602.00	2865078.00	119228810.00
10. REACTOR SERVICE FACTOR	100.00	87.48	74.06
11. REACTOR AVAILABILITY FACTOR	100.00	87.48	75.28
12. UNIT SERVICE FACTOR	100.00	86.40	72.16
13. UNIT AVAILABILITY FACTOR	100.00	86.40	72.45
14. UNIT CAPACITY FACTOR (Using MDC)	101.43	85.32	63.08
15. UNIT CAPACITY FACTOR (Using Design MWe)	98.86	83.15	61.48
16. UNIT FORCED OUTAGE RATE	0.00	1.75	10.32

IV. UNIT SHUTDOWNS

A. Unit One Shutdowns for June 2000

DOCKET NO.: 50-254
DATE: July 11, 2000
COMPLETED BY: Lynne Hamilton
TELEPHONE: (309) 654-2241

No.	DATE	TYPE F OR S	DURATION (HOURS)	REASON	METHOD OF SHUTTING DOWN REACTOR	CORRECTIVE ACTIONS/COMMENTS
						None for the month of June.

Legend:

(1) Reason

- A - Equipment Failure (Explain)
- B - Maintenance or Test
- C - Refueling
- D - Regulatory Restriction
- E - Operator Training/License Examination
- F - Administrative
- G - Operational Error (Explain)
- H - Other (Explain)

(2) Method

- 1 - Manual
- 2 - Manual Trip/Scram
- 3 - Automatic Trip/Scram
- 4 - Continuation
- 5 - Other (Explain)

IV. UNIT SHUTDOWNS

B. Unit Two Shutdowns for June 2000

DOCKET NO.: 50-265
 DATE: July 11, 2000
 COMPLETED BY: Lynne Hamilton
 TELEPHONE: (309) 654-2241

No.	DATE	TYPE F OR S	DURATION (HOURS)	REASON	METHOD OF SHUTTING DOWN REACTOR	CORRECTIVE ACTIONS/COMMENTS
						None for the month of June.

Legend:

(1) Reason

- A - Equipment Failure (Explain)
- B - Maintenance or Test
- C - Refueling
- D - Regulatory Restriction
- E - Operator Training/License Examination
- F - Administrative
- G - Operational Error (Explain)
- H - Other (Explain)

(2) Method

- 1 - Manual
- 2 - Manual Trip/Scram
- 3 - Automatic Trip/Scram
- 4 - Continuation
- 5 - Other (Explain)

V. AMENDMENTS TO FACILITY LICENSE OR TECHNICAL SPECIFICATIONS

There were no Amendments to the Facility License or Technical Specifications for the reporting period.

VI. UNIQUE REPORTING REQUIREMENTS

The following items are included in this report based on the requirements set forth in Technical Specification 6.9.A.5.

A. Main Steam Relief Valve Operations

There were no Relief Valve Operations during the reporting period.