

August 1, 2000

Mr. Otto L. Maynard
President and Chief Executive Officer
Wolf Creek Nuclear Operating Corporation
Post Office Box 411
Burlington, KS 66839

SUBJECT: WOLF CREEK GENERATING STATION - CORRECTION TO AMENDMENT 134
(TAC NO. MA8573)

Dear Mr. Maynard:

The Commission issued Amendment No. 134 to Facility Operating License No. NPF-42 for the Wolf Creek Generating Station in its letter dated July 14, 2000. The amendment consisted of changes to the Technical Specifications (TSs) in response to your application dated March 31, 2000 (ET 00-0018), as supplemented July 7, 2000 (WO 00-0030).

The letter for Amendment No. 134 incorrectly stated that the new Action A for Limiting Condition for Operation (LCO) 3.7.9, "Ultimate Heat Sink (UHS)," allows the plant to operate with the plant inlet water temperature of the UHS above 90°F, if "the required cooling capacity is verified within 4 hours ..." The letter should have stated that the new action allows the plant to operate above the 90°F, if "the required main cooling lake level is verified within an hour." No changes are needed in the TS pages and safety evaluation that were enclosed with the letter.

We apologize for any inconvenience this may have caused.

Sincerely,

/RA/

Jack Donohew, Senior Project Manager, Section 2
Project Directorate IV & Decommissioning
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-482

cc: See next page

August 1, 2000

Mr. Otto L. Maynard
President and Chief Executive Officer
Wolf Creek Nuclear Operating Corporation
Post Office Box 411
Burlington, KS 66839

SUBJECT: WOLF CREEK GENERATING STATION - CORRECTION TO AMENDMENT 134
(TAC NO. MA8573)

Dear Mr. Maynard:

The Commission issued Amendment No. 134 to Facility Operating License No. NPF-42 for the Wolf Creek Generating Station in its letter dated July 14, 2000. The amendment consisted of changes to the Technical Specifications (TSs) in response to your application dated March 31, 2000 (ET 00-0018), as supplemented July 7, 2000 (WO 00-0030).

The letter for Amendment No. 134 incorrectly stated that the new Action A for Limiting Condition for Operation (LCO) 3.7.9, "Ultimate Heat Sink (UHS)," allows the plant to operate with the plant inlet water temperature of the UHS above 90°F, if "the required cooling capacity is verified within 4 hours ..." The letter should have stated that the new action allows the plant to operate above the 90°F, if "the required main cooling lake level is verified within an hour." No changes are needed in the TS pages and safety evaluation that were enclosed with the letter.

We apologize for any inconvenience this may have caused.

Sincerely,

/RA/

Jack Donohew, Senior Project Manager, Section 2
Project Directorate IV & Decommissioning
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-482

cc: See next page

DISTRIBUTION

PUBLIC
PDIV-2 Reading
SRichards (RidsNrrDlpmLpdiv)
RidsAcrsAcnwMailCenter
RidsOgcMailCenter
JHannon (RidsNrrDssaSplb)
WBeckner
JTatum
WJohnson, RIV

GHill (2)
LHurley, RIV
DBujol, RIV

Accession Number: ML003736620

OFFICE	PDIV-2/PM	PDIV-2/LA	PDIV-2/SC
NAME	JDonohew:lcc	EPeyton	SRichards for SDembek
DATE	07/31/2000	07/31/00	07/31/00

OFFICIAL RECORD COPY

Wolf Creek Generating Station

cc:

Jay Silberg, Esq.
Shaw, Pittman, Potts & Trowbridge
2300 N Street, NW
Washington, D.C. 20037

Vice President & Chief Operating Officer
Wolf Creek Nuclear Operating Corporation
P. O. Box 411
Burlington, KS 66839

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 1000
Arlington, TX 76011

Superintendent Licensing
Wolf Creek Nuclear Operating Corporation
P.O. Box 411
Burlington, KS 66839

Senior Resident Inspector
U.S. Nuclear Regulatory Commission
P. O. Box 311
Burlington, KS 66839

U.S. Nuclear Regulatory Commission
Resident Inspectors Office
8201 NRC Road
Steedman, MO 65077-1032

Chief Engineer
Utilities Division
Kansas Corporation Commission
1500 SW Arrowhead Road
Topeka, KS 66604-4027

Office of the Governor
State of Kansas
Topeka, KS 66612

Attorney General
Judicial Center
301 S.W. 10th
2nd Floor
Topeka, KS 66612

County Clerk
Coffey County Courthouse
Burlington, KS 66839

Vick L. Cooper, Chief
Radiation Control Program, RCP
Kansas Department of Health
and Environment
Bureau of Air and Radiation
Forbes Field Building 283
Topeka, KS 66620