



Omaha Public Power District  
444 South 16th Street Mall  
Omaha, Nebraska 68102-2247

July 28, 2000  
LIC-00-0073

U. S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Mail Station P1-137  
Washington, DC 20555

References: 1. Docket No. 50-285  
2. Letter from OPPD (S. K. Gambhir) to NRC (Document Control Desk),  
dated May 26, 2000 (LIC-00-0051)

**SUBJECT: Cancellation of Licensee Event Report 2000-002 for the Fort Calhoun Station**

This letter constitutes notification of the cancellation of Fort Calhoun's Licensee Event Report (LER) 2000-002. As committed in the LER, an evaluation was completed of the capability of the auxiliary feedwater pump (FW-10) to complete its safety function with the condition observed. The evaluation concluded that FW-10 was capable of performing its required safety function during the condition noted in the LER. FW-10 was operable during the condition and therefore the condition was not reportable. If you have any questions, please contact me.

Sincerely,

S. K. Gambhir  
Division Manager  
Nuclear Operations

EPM/epm

Attachment

c: E. W. Merschoff, NRC Regional Administrator, Region IV  
L. R. Wharton, NRC Project Manager  
W. C. Walker, NRC Senior Resident Inspector  
INPO Records Center  
Winston and Strawn

*TE22*