



**Northeast  
Nuclear Energy**

Rope Ferry Rd. (Route 156), Waterford, CT 06385

Millstone Nuclear Power Station  
Northeast Nuclear Energy Company  
P.O. Box 128  
Waterford, CT 06385-0128  
(860) 447-1791  
Fax (860) 444-4277

The Northeast Utilities System

**JUL 31 2000**

Docket No. 50-423  
B18157

Re: 10 CFR 2.790  
10 CFR 50.90

U.S. Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, DC 20555

Millstone Nuclear Power Station, Unit No. 3  
License Amendment Related to the Supplementary Leakage Collection and  
Release System (PLAR 3-98-5), Supplemental Information

This letter contains proprietary information provided by Stone & Webster Engineering Corporation (S&W). Pursuant to 10 CFR 2.790, it is requested that the report entitled "Analysis of Containment Mixing Rate During a Design Basis LOCA," (see Attachment 5) describing the S&W mixing model, be withheld from public disclosure. Upon separation of Attachment 5 from this letter, this letter may be decontrolled.

Background

In a letter dated June 6, 1998,<sup>(1)</sup> Northeast Nuclear Energy Company (NNECO) applied for an amendment to the Millstone Unit No. 3 Operating License to reflect changes in the licensing basis for post-accident operation of the Supplementary Leakage Collection and Release System (SLCRS) as described in the Final Safety Analysis Report (FSAR).

The Nuclear Regulatory Commission (NRC) staff requested additional information via letters dated August 20, 1998,<sup>(2)</sup> and January 25, 1999.<sup>(3)</sup> NNECO provided that

---

(1) M. H. Brothers letter to the U.S. Nuclear Regulatory Commission, "Millstone Nuclear Power Station, Unit No. 3 - Proposed License Amendment Request SLCRS Bypass Leakage (PLAR 3-98-5)," dated June 6, 1998.

(2) J. W. Andersen (USNRC) letter to M. L. Bowling, Jr., "Millstone Nuclear Power Station, Unit No. 3 - Request for Additional Information (TAC No. MA2035)," dated August 20, 1998.

(3) J. W. Andersen (USNRC) letter to M. L. Bowling, Jr., "Millstone Nuclear Power Station, Unit No. 3 - Request for Additional Information (TAC No. MA2035)," dated January 25, 1999.

AP01

information in a letter dated April 5, 1999,<sup>(4)</sup> with additional supplemental information provided in a letter dated April 19, 2000.<sup>(5)</sup>

### Discussion

The NRC staff provided a draft request for additional clarification on NNECO's last response in a facsimile transmission dated May 24, 2000.<sup>(6)</sup> On June 13, 2000, a telephone conference call between the NRC staff, NNECO staff, and appropriate S&W staff, was conducted to ensure that all parties had a clear understanding of the information being requested by the NRC staff.

The ultimate results of that telephone conference eliminated questions 2, 3, and 4 of the facsimile transmission of the draft request, and generated a request for Verified Revisions of the following calculations;

- WM(B)-01 Normalized X/Q at the Unit 3 Control Room for Releases From the Unit 3 MSVB and ESFB
- WM(B)-02 Normalized X/Q at the Unit 3 Control Room for Releases From the Unit 1 Stack
- WM(B)-04 Normalized X/Q at the Unit 3 Control Room for Releases From the Unit 3 Containment and Turbine Bldg.

Another telephone conference between the same groups occurred on June 29, 2000, and the NRC staff requested some editorial changes to Enclosure 1 of the April 19, 2000, letter. The changes requested would make the Enclosure much easier to understand for future potential readers. S&W considers the material provided in the original Enclosure to be proprietary information, and requested that it be exempt from public disclosure for commercial reasons. The edited version provided as Attachment 5 to this letter is also considered proprietary information by S&W, and the same request is made.

Also requested at the same telephone conference was a copy of a table containing spray zone data, and a diagram of the containment identifying the mixing zones. This is provided in Attachment 6.

---

<sup>(4)</sup> R. P. Necci letter to the U.S. Nuclear Regulatory Commission, "Millstone Nuclear Power Station, Unit No. 3 - License Amendment Related to the Supplementary Leakage Collection and Release System (PLAR 3-98-5), Response to Request for Additional Information," dated April 5, 1999.

<sup>(5)</sup> M. H. Brothers letter to the U.S. Nuclear Regulatory Commission, "Millstone Nuclear Power Station, Unit No. 3 - License Amendment Related to the Supplementary Leakage Collection and Release System (PLAR 3-98-5) Supplemental Information," dated April 19, 2000.

<sup>(6)</sup> Jacob I. Zimmerman facsimile to Ravi Joshi, "Draft RAI Associated with Supplementary Leakage Collection and Release System, Millstone Unit No. 3 (TAC No. MA2035)," dated May 24, 2000.

In response to the NRC staff request in the facsimile transmission and the two telephone conferences, the following information is provided:

1. Attachment 1 - Response to Requests for Additional Information
2. Attachment 2 - Calculation WM(B)-01
3. Attachment 3 - Calculation WM(B)-02
4. Attachment 4 - Calculation WM(B)-04
5. Attachment 5 - Affidavit from S&W to withhold proprietary information and an edited revision of "Analysis of Containment Mixing Rate During a Design Basis LOCA"
6. Attachment 6 - "Containment Spray Zone Description and Data" and "Identification of Mixing Zones Within Containment"

There are no regulatory commitments contained within this letter.

If you have any questions or comments regarding this submittal, please contact Mr. David W. Dodson at (860) 447-1791, extension 2346.

Very truly yours,

NORTHEAST NUCLEAR ENERGY COMPANY



Raymond P. Necci  
Vice President - Nuclear Technical Services

Subscribed and sworn to before me

this 31<sup>st</sup> day of July, 2000

  
Notary Public

Date Commission Expires: \_\_\_\_\_

**SANDRA J. ANTON  
NOTARY PUBLIC  
COMMISSION EXPIRES  
MAY 31, 2005**

cc: See next page

Attachments (6): Response to Requests for Additional Information  
Calculation WM(B)-01  
Calculation WM(B)-02  
Calculation WM(B)-04  
Affidavit from Stone & Webster Engineering Corp. to Withhold  
Proprietary Information  
Containment Spray Zone Description and Data and Identification of  
Mixing Zones Within Containment

cc: H. J. Miller, Region I Administrator  
V. Nerses, NRC Senior Project Manager, Millstone Unit No. 3  
A. C. Cerne, Senior Resident Inspector, Millstone Unit No. 3

Docket No. 50-423  
B18157

Attachment 1

Millstone Nuclear Power Station, Unit No. 3

License Amendment Related to the Supplementary Leakage Collection  
Release System (PLAR 3-98-5)  
Response to Requests for Additional Information

**License Amendment Related to the Supplementary Leakage Collection  
Release System (PLAR 3-98-5)  
Response to Requests for Additional Information**

**Question 1**

**The sprayed region of Zone 3 is added to the “effectively sprayed volume” of Zones 1 and 2 for the mixing model. What fraction of the total containment volume is the unsprayed region in Zone 3? It is our understanding that this unsprayed region in Zone 3 is a slow mixing region due to structural interferences in the region. Assuming the volume of the unsprayed region in Zone 3 is not negligible or even substantial, was a qualitative or quantitative estimation or actual calculation of the mixing rate for this region done?**

**Response**

The unsprayed region in Zone 3 represents approximately 47 percent of the containment net volume. The mixing rate for this region was obtained by actual calculation.

**Question 2**

**Do the final mixing rates (time-dependent) include any correction(s) contributed by the Zone 3 unsprayed region for its slow mixing rate(s)? If not, please provide a brief discussion.**

**Response**

This question was withdrawn per the telephone conference conducted on June 13, 2000, between the Nuclear Regulatory Commission (NRC) staff, Northeast Nuclear Energy Company (NNECO) staff, and Stone and Webster (S&W) staff.

**Question 3**

**Is there any qualitative relationship or a discussion representing a relationship between the mixing rate and other removal coefficients by spray for first order elemental iodine? Please provide a brief discussion.**

**Response**

This question was withdrawn per the telephone conference conducted on June 13, 2000, between the NRC staff, NNECO staff, and S&W staff.

#### **Question 4**

**Insert G in the submittal dated April 19, 2000, contains a list of parameters used in determining removal rates of elemental and particulate iodine from the post-accident containment atmosphere. We would like to know how did you arrive at the values of the following iodine removal coefficients ( $\lambda$ ). Please, provide a description of the method and the values of input parameters used in calculation:**

- **Elemental iodine coefficient by plate out in the sprayed region of containment**
- **Particulate iodine removal coefficients by sprays in the sprayed region of containment**

#### **Response**

This question was withdrawn per the telephone conference conducted on June 13, 2000, between the NRC staff, NNECO staff, and S&W staff.

#### **Question 5**

**Stone and Webster calculation dated May 27, 1998, on X/Qs from the Unit 3 main steam building (MSVB) states that the postulated effluent release for the MSVB bypass scenario does not meet the Murphy-Campe criteria for using the diffuse source equation. However, a general statement is made that because of multiple flow disruptions due to buildings both upwind and downwind of the release, it is reasonable to assume that this equation may be used to estimate resultant X/Q values. The calculation assumes that the release occurs from the vent closest to the control room intake and mixes in the wake of the MSVB.**

#### **Response**

S&W calculation WM(B)-01, dated May 27, 1998, calculates the X/Q from the Unit No. 3 Main Steam Valve Building (MSVB) to the MP3 control room using the diffuse source equation of Murphy-Campe. The diffuse source equation was used to estimate the X/Q even though the elevation difference between the MSVB release point and the control room intake meet the criteria of the point source - point receptor technique of Murphy - Campe. The justification for using the diffuse source equation is based upon the aerodynamic obstacles encountered by the plume in the straight line pathway between the two points. Figures 1 and 2 depict the postulated flow path that the plume would have to travel from the MSVB to the Unit 3 control room intake.

The MSVB has two exhaust vents as shown in Figure 2. These vents (elev. 85.9') are physically located between the containment structure and the Aux. Bay/Ventilation Enclosure structures. The MSVB vents discharge downward. The closest vent to the

control room intake is considered in the X/Q calculation. The prevailing wind necessary to transport postulated radioactivity released from the MSVB to the control room intake would need to flow around the containment structure, entrain the MSVB effluent discharged downward, flow up and over the Ventilation Enclosure roof (elev. 100'), be effected by the turbulent flow created by skirting the turbine building corner (elev. 132') at approximately a 45 degree angle, then decrease in elevation to the control room intake (elev. 94.6'). The accumulated affect of containment structure building wake and complex aerodynamic forces and obstacles encountered in the pathway between the source point and receptor, were justification for using the diffuse source equation of Murphy-Campe for this pathway.



Figure 1 - Plant Isometric





Figure 2 - Unit 3 Plot Plan



Both figures were obtained from Dwg. No. 12179-EA-200A-1 (Conceptual Design)

Docket No. 50-423  
B18157

Attachment 2

Millstone Nuclear Power Station, Unit No. 3

Calculation WM(B)-01  
Normalized X/Q at the Unit 3 Control Room for  
Releases From the MSVB and ESFB



CALCULATION TITLE PAGE

Total Number of Pages: 56

Normalized X/Q at the Unit 3 Control Room For Releases From the Unit 3 MSVB and ESFB

TITLE	TITLE	TITLE
CALCULATION #	REVISION No.	SYSTEM NAME
N/A	0	RBVS/SLCRS
WM(B)-01	CB,MS,ES	N/A
VENDOR CALCULATION NUMBER	Structure	System Number

<b>NUCLEAR INDICATOR:</b> <input checked="" type="checkbox"/> CAT1 <input type="checkbox"/> RWQA <input type="checkbox"/> SBOQA <input type="checkbox"/> FPQA <input type="checkbox"/> ATWSQA <input type="checkbox"/> NON-QA		<b>Calc. Supports DCR/MMOD?</b> <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	<b>Calc. Supports Ind. Analysis?</b> <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	N/A
			Component	

↓                                  ↓

M3-98-029	N/A
<b>DCR/MMOD No.</b>	<b>Reference</b>

**INCORPORATES:**

CCN NO:	AGAINST REV.
N/A	N/A
_____	_____
_____	_____

**Executive Summary**  
 THIS IS FORMAL APPROVAL OF A QA APPROVED VENDOR CALCULATION. NO (NU) IR IS REQUIRED.

REC'D 6-8-98  
 ON HOLD \_\_\_\_\_  
 CDS 6/17/98  
 CDS QC 6/25/98  
 NRP ✓ TJ

Verified Revision \_\_\_\_\_  
 Initial jm Date 6/13/98

Approvals (Print & Sign Name)		
Preparer: James L. Wheeler <u>[Signature]</u>	Discipline:	Date: <u>5/27/98</u>
Interdiscipline Reviewer: N/A	Discipline:	Date:
Interdiscipline Reviewer: N/A	Discipline:	Date:
Independent Reviewer: N/A		Date:
Supervisor: William Eakin <u>[Signature]</u>	Discipline:	Date: <u>5/27/98</u>
<b>Installation Verification</b>		
<input checked="" type="checkbox"/> Calculation accurately reflects plant configuration, OR		
<input type="checkbox"/> N/A does not affect plant configuration)		
Preparer/Designer Engineer: JAMES L. WHEELER <u>[Signature]</u>		Date: <u>5/27/98</u>



PassPort DATABASE INPUTs

CH #4

Page 1B of 56

Calculation Number: N/A N/A N/A Revision: N/A  
(prefix) (sequence no.) (suffix)

Vendor Calculation Number/Other: WM(B)-01 Revision: 0

CCN # N/A QA  Yes  No Calc Voided:  Yes  No

Superseded By: N/A Supersedes Calc: N/A

Discipline (Up to 10) Z

Unit	Project Reference (EWA)	Component Id	Computer Code	Rev. No./ Level No.
3	N/A	N/A	EN-200	0/0

PMMS CODES*				
Structure	System	Component	Reference Calculation	Rev No.
N/A	N/A	N/A	ENVR-W223	0

\*The codes required must be alpha codes designed for structure, system and component.

Reference Drawing	Sheet	Rev. No.
25212-10002	<del>A</del>	11
25212-24114-00001	<del>N</del> 01	13
25212-24118-00001	<del>S</del> 01	11
25212-14045	<del>B</del>	15
25212-24215-00001	<del>L</del> 01	14

Comments:  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

**Table of Contents**

Title page	1A
CTP Database	1B
Table of Contents	1C
Vendor Calculation Pages	1 thru 13
Appendix 1	20 pages
Appendix 2	20 pages
Total number of pages	56

STONE & WEBSTER ENGINEERING CORPORATION  
CALCULATION TITLE PAGE

5010.65

CLIENT & PROJECT: NORTHEAST UTILITIES - MILLSTONE UNIT 3				PAGE 1 of 13 Total Pages: 53 w/attachments pages		
CALCULATION TITLE: Normalized Concentrations (X/Qs) at Unit 3 Control Room Air Intake for Releases from the Unit 3 Main Steam Valve Bldg. & Engineered Safety Features Bldg.				QA CATEGORY (✓) <input checked="" type="checkbox"/> I <input type="checkbox"/> II		
CALCULATION IDENTIFICATION NUMBER				OPTIONAL WORK PACKAGE NO.		
JOB ORDER NO. 03703.7002	DISCIPLINE WM(B)	CURRENT CALC NO. 01 <i>RCV0</i>	OPTIONAL TASK CODE			
APPROVALS - SIGNATURE & DATE			REVISION NO. OR NEW CALCULATION NO. 0	SUPERSEDES CALCULATION NO. OR REVISION NO.	CONFIRMATION REQUIRED (✓)	
PREPARES(S) / DATE(S)	REVIEWER(S) / DATES(S)	INDEPENDENT REVIEWER(S) / DATE(S)			YES	NO
Stephen A. Vigeant <i>Stephen A. Vigeant</i> 5/21/98	Carl A. Mazzola <i>Carl A. Mazzola</i> 5/21/98	Carl A. Mazzola <i>Carl A. Mazzola</i> 5/21/98				✓
DISTRIBUTION						
GROUP	NAME & LOCATION	COPY SENT (✓)	GROUP	NAME & LOCATION	COPY SENT (✓)	
Record Mgmt. File (or Fire File if none) Lead Radiological Specialist	S. Ferguson Boston - 6	cc				
	Stephen A. Vigeant Boston - 3	cc				
<del>Project Files</del>	<del>Charlie Cronan Boston - 7</del>					
NU. RAD PROT	RJ Schmidt New Britain	cc				
NUNDS	MP3 site	original				

STONE & WEBSTER ENGINEERING CORPORATION  
CALCULATION SHEET

5010.65

CALCULATION IDENTIFICATION NUMBER

JOB ORDER NO. 037037002	DISCIPLINE WM(B)	CALCULATION NO. 01 <i>RW0</i>	OPTIONAL TASK CODE	PAGE 2 OF 13
----------------------------	---------------------	----------------------------------	--------------------	-----------------

CHANGE HISTORY PAGE

REVISION NO.	DESCRIPTION OF CHANGES	PAGES REVISED	PAGES ADDED	PAGES REPLACED
0	0	N/A	N/A	N/A

STONE & WEBSTER ENGINEERING CORPORATION  
CALCULATION SHEET

5010.65

CALCULATION IDENTIFICATION NUMBER

JOB ORDER NO.	DISCIPLINE	CALCULATION NO.	OPTIONAL TASK CODE	PAGE
037037002	WM(B)	01 <i>REV 0</i>		3 OF 13

TABLE OF CONTENTS

COVER PAGE..... 1

CHANGE HISTORY PAGE..... 2

TABLE OF CONTENTS..... 3

OBJECTIVE ..... 4

METHODOLOGY ..... 4

ASSUMPTIONS ..... 5

EQUATIONS ..... 5

DATA..... 6

CALCULATION..... 6

CONCLUSIONS ..... 7

REFERENCES ..... 7

ATTACHMENTS.....8

APPENDICES.....8



STONE & WEBSTER ENGINEERING CORPORATION  
CALCULATION SHEET

5010.65

CALCULATION IDENTIFICATION NUMBER

JOB ORDER NO.	DISCIPLINE	CALCULATION NO.	OPTIONAL TASK CODE	PAGE
037037002	WM(B)	01 <i>REV0</i>		4 OF 13

**OBJECTIVE**

To calculate the normalized atmospheric dispersion values (X/Qs) at the Millstone Unit 3 control room air intake for gaseous radiological releases from the Unit 3 Main Steam Valve Building (MSVB) and from the Engineered Safety Features Building (ESFB). These X/Q values will apply to the 0-2 hour through 30-day period for the MSVB and ESFB ground level releases. The specific release-receptor combinations for which X/Q values are calculated are as follows:

1. Unit 3 MSVB to Unit 3 Control Room Air Intake
2. Unit 3 ESFB to Unit 3 Control Room Air Intake

**METHODOLOGY**

The control room X/Q values are calculated using the methodology described in Murphy and Campe (Ref. 1). The radiological releases are from vents which are essentially point sources. The difference in elevation between the MSVB release point and the control room air intake is less than 30 percent of the MSVB and the difference in elevation between the ESFB release point and the control room air intake is greater than 30 percent of the ESFB height (see Data Section, p. 6). Reference 1 recommends that the point source - point receptor technique for X/Q calculation be used when the elevation difference between the release and receptor is less than or equal to 30 percent of the building height. Otherwise, the diffuse source - point receptor technique for X/Q calculation is recommended.

Although the MSVB release point does not meet the 30 percent elevation difference criterion for use of the diffuse source - point receptor technique, the wind flow transporting the release to the control room air intake must first flow around the containment structure and the MSVB along with other structures between the MSVB and control room air intake. Therefore, it is reasonable to use the diffuse source - point receptor technique for X/Q calculation from Section V(B)(1)(b) of Murphy and Campe (Ref. 1) for both release points given the multiple flow disruptions caused by the aerodynamic obstacles on the MSVB release, effectively making it a diffuse source. The X/Q equation is as follows:

$$X/Q = [u(\pi\sigma_y\sigma_z + A/(K+2))]^{-1}$$

where:

X/Q is relative concentration (sec/m<sup>3</sup>)

$\sigma_y, \sigma_z$  are horizontal and vertical dispersion coefficients based on stability class and horizontal distance between the source and receptor (m)

u = wind speed at 10-meter (33-ft) elevation (m/sec)

A = projected building area (m<sup>2</sup>)

k = 3/(s/d)<sup>1.4</sup>

s = source to receptor distance (m)

d = building width (m)

The above relationship is used to calculate the 0 - 2 hour X/Q value based on onsite meteorological data, selecting the condition that represents the 5 percentile dispersion condition at the site. In this case, 1974 to 1981 onsite meteorological data (Ref. 2) are used. This period of record (i.e., 8 years) is temporally representative of the meteorological conditions encountered at the site. From earlier control room X/Q calculations (Ref. 3), the 5 percentile site stability class is F stability.

The corresponding 5 percentile wind speed is determined from the onsite meteorological data considering only those wind directions resulting in receptor exposure (i.e., influencing wind directions). The number of wind direction sectors to be considered for each source-receptor relationship is determined using Figure 2 of Ref. 1 which is based on the ratio of the distance (s) between the source and receptor to the diameter (d) or width of the building from which the release emanates (i.e., s/d ratio). The dispersion coefficients ( $\sigma_y, \sigma_z$ ) are determined from Ref. 4.

The intermediate averaging time X/Qs (8-24 hours, 1-4 days, and 4-30 days) are determined from the 0-2 hour X/Q value multiplying by occupancy, wind speed, and wind direction factors in accordance with Ref. 1. These factors are as follows:

STONE & WEBSTER ENGINEERING CORPORATION  
CALCULATION SHEET

5010.65

CALCULATION IDENTIFICATION NUMBER

JOB ORDER NO. 037037002	DISCIPLINE WM(B)	CALCULATION NO. 01 <i>PURQ</i>	OPTIONAL TASK CODE	PAGE 5 OF 13
----------------------------	---------------------	-----------------------------------	--------------------	-----------------

<u>Averaging Time</u>	<u>Occupancy Factor</u>	<u>Wind Speed Factor</u>	<u>Wind Direction Factor</u>
0 - 2 Hours	1	1	1
8 - 24 Hours	1	5%/10% wind speed	0.75 + F/4
1 - 4 Days	0.6	5%/20% wind speed	0.50 + F/2
4 - 30 Days	0.4	5%/40% wind speed	F

F is the fraction of time the wind blows the activity toward the receptor for the wind azimuth range of influence.

The frequency of wind directions blowing in the appropriate range and at certain wind speeds is determined from the on-site meteorological data base (Ref. 2) using Stone & Webster computer program EN-200, "Distribution of Two Parameters" (Ref. 5).

**ASSUMPTIONS**

1. It is conservatively assumed that each plume centerline is transported directly over the Unit 3 control room intake and that the plume dispersion is not aerodynamically affected by the containment building which is adjacent to or very near the release points.
2. For purposes of determining the appropriate dispersion equation to use in the analysis, the elevation differences between the release points and the control room air intake are compared to the height of the buildings from which the releases occur (MSVB and ESFB). Although the release-receptor elevation difference of 30 percent of the building height criterion is not met, the MSVB release is assumed to be a diffuse source given the multiple flow disruptions encountered by the release due to the aerodynamic interference of buildings both upwind and downwind of the release point.
3. It is assumed that the Unit 3 control room air intake X/Q values are representative of the X/Q values for the center of the Unit 3 control room given that the distances and directions from the release to these receptors are very similar.

**EQUATIONS**

$$X/Q = [u(\pi\sigma_y\sigma_z + A/(K+2))]^{-1} \text{ (Ref. 1)}$$

where:

X/Q is relative concentration (sec/m<sup>3</sup>) for point source - point receptor configurations

$\sigma_y, \sigma_z$  are horizontal and vertical dispersion coefficients (m) (Ref. 4)

u = wind speed at 10-meter elevation (m/sec)

A = projected building area (m<sup>2</sup>)

k = 3/(s/d)<sup>1.4</sup>

s = source to receptor distance (m)

d = building width (m)

**Determination of Influencing Wind Directions (Ref. 1)**

s = source to receptor distance (m)

d = release point diameter or width (m)

Calculate s/d ratio and use Figure 2 from Ref. 1 to determine the appropriate number of influencing wind directions.

STONE & WEBSTER ENGINEERING CORPORATION  
CALCULATION SHEET

5010.65

CALCULATION IDENTIFICATION NUMBER

JOB ORDER NO. 037037002	DISCIPLINE WM(B)	CALCULATION NO. 01 <i>REV 0</i>	OPTIONAL TASK CODE	PAGE 6 OF 13
----------------------------	---------------------	------------------------------------	--------------------	-----------------

Determination of Intermediate Period Factors (Ref. 1)

<u>Averaging Time</u>	<u>Occupancy Factor</u>	<u>Wind Speed Factor</u>	<u>Wind Direction Factor</u>
0 - 2 Hours	1	1	1
8 - 24 Hours	1	5%/10% wind speed	0.75 + F/4
1 - 4 Days	0.6	5%/20% wind speed	0.50 + F/2
4 - 30 Days	0.4	5%/40% wind speed	F

F is the fraction of time the wind blows the activity toward the receptor, within the influencing wind direction azimuthal range.

**DATA**

**1. Unit 3 MSVB to Unit 3 Control Room Air Intake**

Distance from nearest MSVB vent to Unit 3 control room air intake = 68.2 m (Ref. 6 )  
 Wind direction from nearest MSVB vent to Unit 3 control room air intake = 120 deg (Ref. 6 )  
 d = MSVB diagonal width = 74.0 ft or 22.56 m (Ref. 7)  
 MSVB vent elevation = 85.9 ft (Ref. 7)  
 Unit 3 control room air intake elevation = 94.6 ft (Ref. 9)  
 MSVB vent-control room air intake elevation difference = 85.9 ft - 94.6 ft = -8.7 ft  
 MSVB height (top elevation - grade elevation) = 83.9 ft - 24.0 ft = 59.9 ft (Ref. 6 )  
 Percentage difference in elevations = 8.7 ft/ 59.9 ft = 14.5 percent  
 A = MSVB projected area = diagonal width x height = 74.0 ft x 59.9 ft = 4432.6 ft<sup>2</sup> or 411.8 m<sup>2</sup>

**2. Unit 3 ESFB to Unit 3 Control Room Air Intake**

Distance from ESFB vent to Unit 3 control room center = 120.5 m (Ref. 6 )  
 Wind direction from ESFB vent to Unit 3 control room center = 90 deg (Ref. 6 )  
 d = ESFB diagonal width = 144.0 ft = 43.9 m (Ref. 6)  
 ESFB vent elevation = 39.5 ft (Ref. 8)  
 Unit 3 control room air intake elevation = 94.6 ft (Ref. 9)  
 ESFB vent-control room air intake elevation difference = 94.6 ft - 39.5 ft = 55.1 ft  
 ESFB height (top elevation - grade elevation) = 56.8 ft - 24.0 ft = 32.8 ft (Ref. 8 )  
 Percentage difference in elevations = 55.1 ft/ 32.8 ft = 168 percent  
 A = ESFB projected area = diagonal width x height = 144.0 ft x 32.8 ft = 4723.2 ft<sup>2</sup> or 438.8 m<sup>2</sup>

**CALCULATION**

**1. Unit 3 MSVB to Unit 3 Control Room Air Intake**

s = 68.2 m (Ref. 6)  
 direction = 120 deg (Ref. 6)  
 d = 22.56 m (Ref. 7)  
 s/d = 68.2 m/22.56 m = 3.02 or 3 sectors (3 x 22.5° = 68° or 120° - 34° = 86° to 120° + 34° = 154°)  
 A = 411.8 m<sup>2</sup>  
 $k = 3/(s/d)^{1.4} = 3/(3.02)^{1.4} = 0.64$   
 $\sigma_y$  @ 68.2m for F stability class = 3.27 m (Reference 4)  
 $\sigma_z$  @ 68.2m for F stability class = 1.65 m (Reference 4)  
 u(5%) = 2.2 mph (1.0 m/sec) (Appendix 1, p. 12)  
 u(10%) = 3.1 mph (1.4 m/sec) (Appendix 1, p. 13)  
 u(20%) = 4.5 mph (2.0 m/sec) (Appendix 1, p. 14)  
 u(40%) = 6.7 mph (3.0 m/sec) (Appendix 1, p. 16)  
 F = 8,266/66,332 = 0.12 (Appendix 1, p. 19)

STONE & WEBSTER ENGINEERING CORPORATION  
CALCULATION SHEET

5010.65

CALCULATION IDENTIFICATION NUMBER

JOB ORDER NO. 037037002	DISCIPLINE WM(B)	CALCULATION NO. 01 <i>Ref 0</i>	OPTIONAL TASK CODE	PAGE 7 OF 13
----------------------------	---------------------	------------------------------------	--------------------	-----------------

**Short-Term X/Q Value for Unit 3 Intake (0 - 2 Hours)**

$$X/Q = \{ (1.0 \text{ m/sec}) [ (3.14159275...) (3.27\text{m}) (1.65 \text{ m}) + (411.8 \text{ m}^2) / (0.64 + 2) ] \}^{-1}$$

**X/Q = 5.78 E- 3 sec/m<sup>3</sup>**

**Intermediate Period X/Q Value for Unit 3 Intake**

Averaging Period	Occupancy Factor	Wind Speed Factor	Wind Direction Factor	X/Q (sec/m <sup>3</sup> )
0 - 8 hours	1	1	1	5.78 E- 3
8 - 24 hours	1	2.2/3.1 = 0.71	0.75 + 0.12/4 = 0.78	3.20 E- 3
1 - 4 days	0.6	2.2/4.5 = 0.49	0.50 + 0.12/2 = 0.56	9.52 E- 4
4 - 30 days	0.4	2.2/6.7 = 0.33	0.12	9.16 E- 5

**2. Unit 3 ESFB to Unit 3 Control Room Air Intake**

s = 120.5 m (Ref. 6)

direction = 90 deg (Ref. 6)

d = 43.9 m (Ref. 8)

s/d = 120.5 m/43.9 m = 2.74 or 3 sectors (3 x 22.5° = 68° or 90° - 34° = 56° to 90° + 34° = 124°)

A = 1439.7 m<sup>2</sup>

$$k = 3/(s/d)^{1.4} = 3/(2.74)^{1.4} = 0.73$$

$\sigma_y$  @ 120.5m for F stability class = 5.47 m (Reference 4)

$\sigma_z$  @ 120.5m for F stability class = 2.63 m (Reference 4)

u(5%) = 2.2 mph (1.0 m/sec) (Appendix 2, p. 12)

u(10%) = 3.1 mph (1.4 m/sec) (Appendix 2, p. 13)

u(20%) = 4.5 mph (2.0 m/sec) (Appendix 2, p. 14)

u(40%) = 7.6 mph (3.4 m/sec) (Appendix 2, p. 17)

F = 7,922/66,332 = 0.12 (Appendix 2, p. 19)

**Short-Term X/Q Value for Unit 3 Intake (0 - 2 Hours)**

$$X/Q = \{ (1.0 \text{ m/sec}) [ (3.14159275...) (5.47\text{m}) (2.63 \text{ m}) + (438.8 \text{ m}^2) / (0.73 + 2) ] \}^{-1}$$

**X/Q = 4.86 E- 3 sec/m<sup>3</sup>**

**Intermediate Period X/Q Value for Unit 3 Intake**

Averaging Period	Occupancy Factor	Wind Speed Factor	Wind Direction Factor	X/Q (sec/m <sup>3</sup> )
0 - 8 hours	1	1	1	4.86 E- 3
8 - 24 hours	1	2.2/3.1 = 0.71	0.75 + 0.12/4 = 0.78	2.69 E- 3
1 - 4 days	0.6	2.2/4.5 = 0.49	0.50 + 0.12/2 = 0.56	8.00 E- 4
4 - 30 days	0.4	2.2/7.6 = 0.29	0.12	6.77 E- 5

**CONCLUSIONS**

The Unit 3 control room X/Qs are summarized in the body of the calculation. The Unit 3 control room air intake X/Q values are representative of the X/Q values for the center of the Unit 3 control room given that the distances and directions from the release to these receptors are very similar. The Unit 3 control room air intake X/Q values are also conservative when applied to the Technical Support Center which is located at a farther distance from the releases than the control room.

STONE & WEBSTER ENGINEERING CORPORATION  
CALCULATION SHEET

5010.65

CALCULATION IDENTIFICATION NUMBER

JOB ORDER NO. 037037002	DISCIPLINE WM(B)	CALCULATION NO. 01 <i>Rev 0</i>	OPTIONAL TASK CODE	PAGE 8 OF 13
----------------------------	---------------------	------------------------------------	--------------------	-----------------

**REFERENCES**

1. Murphy, K.G. and K.M. Campe., "Nuclear Power Plant Control Room Ventilation System Design for Meeting General Design Criterion 19". Presented at the 13<sup>th</sup> AEC Air Cleaning Conference, August, 1974.
2. Millstone onsite meteorological data for the period 1974 - 1981 provided by H. L. Chamberlain, Jr. of Northeast Utilities, April 28, 1998. The data are hourly values represented by one 15-minute average value per hour. See Attachment 5 for transmittal letter.
3. Stone & Webster Calculation No. 12179.12-ENVR-W223, dated 11/29/82
4. U. S. Nuclear Regulatory Commission, Subroutine "POLYN", Horizontal and Vertical Dispersion Coefficients as a Function of Downwind Distance (see Attachment 5 for F-stability values).
5. EN-200, Version 0, Level 0. SWEC computer code "Distribution of Two Parameters". Output is provided in Appendices 1 and 2.
6. Stone & Webster Drawing No. 12179-EM-1A-11, Rev. 11, "Plot Plan", Millstone Unit 3. See Attachment 1.
7. Stone & Webster Drawing No. 12179-EB-15N-13, "Ventilation Main Steam Valve Building", Millstone Unit 3, Rev. 13, 6/9/94. See Attachment 2.
8. Stone & Webster Drawing No. 12179-EB-15S-11, Rev. 11, 10/14/87, "Heating Vent & Air Cond ENG Safety Features Bldg SH-4". See Attachment 3.
9. Stone & Webster Drawing Nos. 12179-EA-1B-15 and 12179-EB-39L-14.

**ATTACHMENTS**



1. Stone & Webster Drawing No. 12179-EM-1A-11, Rev. 11, "Plot Plan", Millstone Unit 3
2. Stone & Webster Drawing No. 12179-EB-15N-13, "Ventilation Main Steam Valve Building", Millstone Unit 3, Rev. 13, 6/9/94.
3. Stone & Webster Drawing No. 12179-EB-15S-11, Rev. 11, 10/14/87, "Heating Vent & Air Cond ENG Safety Features Bldg SH-4".
4. Subroutine "POLYN", Horizontal and Vertical Dispersion Coefficients as a Function of Downwind Distance (F-stability).
5. Millstone onsite meteorological data transmittal letter from H. L. Chamberlain to J. Creamer, April 28, 1998.

**APPENDICES (40 pages)**

1. EN-200 Wind Speed/Wind Direction Distribution Computer Output:

<u>Release/Receptor Combination</u>	<u>Wind Direction Range</u>	<u>Job No.</u>
Unit 3 MSVB to Unit 3 Control Room Air Intake	86 - 154 degrees	09666
2. EN-200 Wind Speed/Wind Direction Distribution Computer Output:

<u>Release/Receptor Combination</u>	<u>Wind Direction Range</u>	<u>Job No.</u>
Unit 3 ESFB to Unit 3 Control Room Air Intake	56 - 124 degrees	09668



NOTE:  
SCALE: 1/4"=1'-0" AND AS NOTED.

REFERENCE DWG:  
CONSTRUCTION AREA-KEY PLAN E4-18 (1000)  
ARRANGEMENT-TANKAGE WARD AREA E4-18 (1000)  
FOR CONT. OF REF. SEE E4-18 (1000)

LEGEND:  
S SEISMIC CATEGORY I STRUCTURES AND COMPONENTS  
M INDICATES EQUIPMENT WHICH IS PART OF NUCLEAR SAFETY FEATURE SYSTEM

RELEASED FROM  
GFR CONTROL

NUCLEAR SAFETY RELATED  
QA, CAT I, II & III


11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17

THE MILLESTONE FORT COMPANY  
a subsidiary of  
NORTHEAST UTILITIES

MILLESTONE NUCLEAR POWER STATION-WH-100  
PLOT PLAN

DATE: 11/11/78  
DRAWN: 30A  
CHECKED: [Signature]  
SCALE: AS SHOWN  
PROJECT: MILLESTONE NUCLEAR POWER STATION






FIGURE



- ① 3/8\"/>
- ② 1/4\"/>
- ③ 2\"/>
- ④ FLEXIBLE MATERIAL AS SPECIFIED
- ⑤ SPECIFIED REINFORCING ANGLE (3\"/>
- ⑥ LOCKWASHER (1/4\"/>
- ⑦ NUT
- ⑧ BOLT CENTERS ON THE LEGS OF THE ANGLE SHALL BE STRAGGERED WITH RESPECT TO BOLT CENTERS ON OTHER LEGS
- ⑨ DSA SUPPORT FOR HEATING COIL & MOD
- ⑩ HEATING COIL
- ⑪ MOD
- ⑫ 1/4\"/>

HEATING COIL DIMENSION

MARK NO	A	B	C
3HVY-CHIA	4'-2"	6'-3"	9'-2"
3HVY-CHB	4'-2"	6'-3"	9'-2"




- LEGEND  
 S&W STDs M8H-1002-1-1, 1002-2-2 & 1002-3-3
- NOTES  
 1. DUCT CONNECTIONS TO FANS OR OTHER EQUIPMENT SHALL BE FABRICATED TO SUIT EQUIPMENT FURNISHED.  
 2. FOR DUCT SUPPORTS (BASE DETAILS) SEE 88-315F.  
 3. AN ASTERISK (\*) WILL REPLACE THE DASH (-) IN THE PREFIX FOR EQUIPMENT OR INSTRUMENTS WHICH ARE A PART OF THE NUCLEAR SAFETY FEATURES SYSTEMS.
- REFERENCES  
 LIGHTING: E-67H (3500H)  
 FLOW DIAGRAM: FSR-22 18  
 VENT SPEC: 210 435-588  
 CONG. PLANS DETS ELEV&V SECTIONS: EC-31A (R) (10205-1211) (1017)  
 CONG. PLANS DETS ELEV&V SECTIONS: EC-31A (R) (10205-11922)  
 STL FRAMING PLANS & DETAILS: F-11 (10205-10148)  
 PIPING FLOW FANS SPEC: F-170-275-140  
 PIPING FLOW FANS SPEC: F-111 (10205-12217-22219)  
 AIR AND MOTOR OPERATED AIR DMP SPEC: A-77-200-39-4  
 VESSEL AND DRUM RESTRAINTS: V-110 (10205-22253-22259)  
 BLDG VENT FLOOR DRAINAGE: F-111 (10205-10148)  
 BLDG VENT FLOOR DRAINAGE: F-111 (10205-10148)  
 P&ID ESP & MSV BLDGS VENTILATION: EN-526 (10205-2142)



NUCLEAR SAFETY RELATED  
 QA CAT I & II  
 RENUMBERED FROM 25212-24114  
 THE HILLSTONE POINT COMPANY  
 SUBSIDIARY OF  
 NORTHEAST UTILITIES  
 TITLE: HILLSTONE POINT NUCLEAR POWER STATION UNIT NO. 3  
 VENTILATION  
 MAIN STEAM VALVE BLDG  
 STONE & WEBSTER ENGINEERING CORPORATION  
 BOSTON, MASS.  
 28212-24114 SH-1  
 S & W DWG. NO. 12179-EB-15N.13

P.11  
 03703.7002  
 WH(B)-01  
 Rev 0



Release Point

Q.A

NUCLEAR SAFETY RELATED  
 Q.A CAT I II & III

NO.	REVISION	DESCRIPTION
1	AS SHOWN	ISSUED FOR CONSTRUCTION
2	REVISED	REVISED DUCT WORK TO AGREE WITH PLAN
3	REVISED	REVISED DUCT WORK TO AGREE WITH PLAN
4	REVISED	REVISED DUCT WORK TO AGREE WITH PLAN
5	REVISED	REVISED DUCT WORK TO AGREE WITH PLAN
6	REVISED	REVISED DUCT WORK TO AGREE WITH PLAN
7	REVISED	REVISED DUCT WORK TO AGREE WITH PLAN
8	REVISED	REVISED DUCT WORK TO AGREE WITH PLAN
9	REVISED	REVISED DUCT WORK TO AGREE WITH PLAN
10	REVISED	REVISED DUCT WORK TO AGREE WITH PLAN

NO.	DATE	BY	CHKD	APP'D	DESCRIPTION
1	6-7-77	...	...	...	...
2	6-7-77	...	...	...	...
3	6-7-77	...	...	...	...
4	6-7-77	...	...	...	...
5	6-7-77	...	...	...	...
6	6-7-77	...	...	...	...
7	6-7-77	...	...	...	...
8	6-7-77	...	...	...	...
9	6-7-77	...	...	...	...
10	6-7-77	...	...	...	...

THE HILLSTONE POINT COMPANY  
 HEATING, VENT & AIR COND ENG  
 SAFETY FEATURES BLDG SH-4

STONE & WEBSTER ENGINEERING CORPORATION  
 BOSTON, MASS.

S & W DWG. NO. 12179-EB-155-11  
 V. J. ROONEY  
 CHECKED BY: M. MAH





**Northeast  
Utilities System**

107 Selden Street, Berlin, CT 06037

Northeast Utilities Service Company  
P.O. Box 270  
Hartford, CT 06141-0270  
(860) 665-5000

P.13  
0370 3,700-  
WM(B)-01  
ew-0

April 28, 1998

Mr. Joseph Creamer  
Stone and Webster  
245 Summer Street, 7th Floor  
Boston, MA 02210

Dear Mr. Creamer:

**Millstone Nuclear Power Station  
Meteorological Data**

Accompanying this memo are four computer diskettes containing the meteorological data from 1974 through 1981, for your use in the Millstone Unit 3 X/Q calculations. Each diskette contains two years of data, as noted on the labels. The year of data is represented in each dataset name.

Each line of the datasets represents one hour of data. There is a nine character "time stamp" on each line; columns 1 and 2 are the year, columns 3 through 5 are the Julian day, and columns 6 through 9 are the time (military time, always on Eastern Standard Time). Columns 10 through 54 are, in order, the AT033, WS033, WD033, WS142, WD142, DT142, WS374, WD374, & DT374 (AT = air temperature, WS = wind speed, WD = wind direction, DT = delta-temperature, and numbers are instrument height). These are all in "F5.1" format. Missing data are represented by "999.0."

The data generated by our meteorological monitoring system consist of four fifteen-minute averages per hour. However, the attached datasets only contain one fifteen-minute average per hour. Historically, most of our analyses involving meteorological data, including Category 1 X/Q calculations, have been based on one fifteen-minute average representing an entire hour of data. It was found that this methodology introduced very small errors into the analyses results, compared to calculating an average of the available fifteen-minute averages for each hour.

If you have any questions, please call me, at (860) 665-3183.

Very truly yours,

H. L. Chamberlain, Jr.  
Environmental Services

Enclosures

10 MAR 1981

DISPERSION COEFFICIENTS AS A FUNCTION OF DOWNWIND DISTANCE  
PASQUILL STABILITY CLASS (F)

PAGE 41

DOWNWIND DISTANCE (METERS)	STONE & WEBSTER		POLYN (LONG)		POLYN (DESERT)		POLYN (XOQDOQ)	
	SIGMA Y	SIGMA Z	SIGMA Y	SIGMA Z	SIGMA Y	SIGMA Z	SIGMA Y	SIGMA Z
10.	0.4739	0.1971	0.4014	0.1395	2.4230	1.6073	0.5776	0.3454
20.	0.8969	0.4437	0.8020	0.3243	4.5718	1.9981	1.0802	0.6072
30.	1.3054	0.6928	1.2022	0.5313	6.6281	2.2694	1.5578	0.8446
40.	1.7048	0.9383	1.6022	0.7540	8.6265	2.4839	2.0200	1.0675
50.	2.0977	1.1786	2.0021	0.9893	10.5829	2.6642	2.4710	1.2801
60.	2.4855	1.4134	2.4019	1.2351	12.5064	2.8212	2.9133	1.4849
70.	2.8691	1.6427	2.8015	1.4900	14.4031	2.9611	3.3485	1.6834
80.	3.2490	1.8667	3.2011	1.7530	16.2771	3.0879	3.7776	1.8767
90.	3.6259	2.0857	3.6006	2.0232	18.1315	3.2043	4.2016	2.0655
100.	4.0000	2.3000	4.0000	2.3000	19.9686	3.3120	4.6210	2.2472
110.	4.3716	2.5090	4.3994	2.5829	21.7903	3.4126	5.0364	2.4369
120.	4.7409	2.7153	4.7987	2.7365	23.5981	3.5072	5.4481	2.6223
130.	5.1032	2.9169	5.1979	2.8894	25.3933	3.5964	5.8565	2.8037
140.	5.4736	3.1146	5.5971	3.0416	27.1769	3.6811	6.2619	2.9815
150.	5.8372	3.3088	5.9963	3.1930	28.9499	3.7617	6.6645	3.1560
160.	6.1991	3.4995	6.3954	3.3437	30.7129	3.8387	7.0644	3.3275
170.	6.5595	3.6870	6.7945	3.4937	32.4667	3.9125	7.4620	3.4962
180.	6.9184	3.8714	7.1936	3.6430	34.2119	3.9834	7.8573	3.6624
190.	7.2759	4.0528	7.5926	3.7916	35.9489	4.0516	8.2505	3.8261
200.	7.6321	4.2314	7.9916	3.9395	37.6782	4.1174	8.6417	3.9877
210.	7.9871	4.4073	8.3905	4.0867	39.4003	4.1809	9.0309	4.1472
220.	8.3409	4.5806	8.7895	4.2332	41.1156	4.2424	9.4184	4.3047
230.	8.6935	4.7514	9.1884	4.3790	42.8242	4.3021	9.8042	4.4603
240.	9.0451	4.9198	9.5872	4.5241	44.5267	4.3599	10.1884	4.6143
250.	9.3956	5.0860	9.9861	4.6685	46.2232	4.4162	10.5710	4.7665
260.	9.7451	5.2499	10.3825	4.8123	47.9140	4.4709	10.9521	4.9172
270.	10.0936	5.4117	10.6986	4.9553	49.5994	4.5242	11.3319	5.0664
280.	10.4412	5.5714	11.0542	5.0977	51.2795	4.5762	11.7102	5.2141
290.	10.7878	5.7292	11.4095	5.2395	52.9546	4.6269	12.0873	5.3605
300.	11.1337	5.8850	11.7643	5.3805	54.6248	4.6764	12.4631	5.5056
310.	11.4786	6.0390	12.1188	5.5209	56.2904	4.7248	12.8377	5.6494
320.	11.8228	6.1912	12.4729	5.6607	57.9515	4.7721	13.2111	5.7920
330.	12.1661	6.3416	12.8266	5.7997	59.6082	4.8185	13.5833	5.9335
340.	12.5007	6.4903	13.1799	5.9382	61.2607	4.8638	13.9546	6.0738
350.	12.8350	6.6374	13.5328	6.0759	62.9091	4.9083	14.3247	6.2131
360.	13.1691	6.7830	13.8854	6.2131	64.5535	4.9519	14.6938	6.3513
370.	13.5032	6.9269	14.2375	6.3496	66.1942	4.9947	15.0619	6.4886
380.	13.8371	7.0694	14.5893	6.4854	67.8311	5.0367	15.4291	6.6249
390.	14.1710	7.2104	14.9407	6.6206	69.4644	5.0780	15.7953	6.7603
400.	14.5049	7.3500	15.2917	6.7552	71.0942	5.1185	16.1606	6.8947
410.	14.8388	7.4882	15.6424	6.8892	72.7205	5.1583	16.5250	7.0283
420.	15.1727	7.6251	15.9927	7.0225	74.3436	5.1975	16.8886	7.1611
430.	15.5064	7.7607	16.3426	7.1552	75.9634	5.2360	17.2513	7.2930
440.	15.8393	7.8949	16.6921	7.2872	77.5800	5.2740	17.6132	7.4242
450.	16.1731	8.0280	17.0413	7.4187	79.1935	5.3113	17.9743	7.5545
460.	16.5063	8.1598	17.3901	7.5496	80.8041	5.3481	18.3347	7.6841
470.	16.8395	8.2904	17.7385	7.6798	82.4117	5.3843	18.6943	7.8130
480.	17.1727	8.4199	18.0865	7.8094	84.0164	5.4201	19.0531	7.9412
490.	17.5061	8.5482	18.4342	7.9384	85.6184	5.4553	19.4112	8.0687

POLYN Dispersion  
Coefficients

03703.700  
WM(B)-01  
WR-0  
P.12

JES2 JOB LOG -- SYSTEM C168 -- NODE JES2B0S

11.33.37 JOB09666 IRR010I USERID VIG7988 IS ASSIGNED TO THIS JOB.  
11.33.39 JOB09666 ICH70001I VIG7988 LAST ACCESS AT 11:21:00 ON FRIDAY, MAY 1, 1998  
11.33.39 JOB09666 \$HASP373 DISTRIB STARTED - INIT 8 - CLASS A - SYS C168  
11.33.45 JOB09666 +IH0002I STOP .1  
11.33.46 JOB09666 \$HASP395 DISTRIB ENDED

----- JES2 JOB STATISTICS -----

01 MAY 1998 JOB EXECUTION DATE

37 CARDS READ

840 SYSOUT PRINT RECORDS

0 SYSOUT PUNCH RECORDS

34 SYSOUT SPOOL KBYTES

0.12 MINUTES EXECUTION TIME

APPENDIX 1  
DISTRIBUTION Program Output  
Unit 3 MSVB to Unit 3 Control Room Air Intake

P. 1  
03703.7002  
WM(B)-01

*12/20*

01-MAY-98JOB09666

```
1 //DISTRIB JOB (0031,3),'VIGEANT-SA',
  // MSGLEVEL=2,MSGCLASS=A
  //* RJETRA.VIG7988.DATA(DISTRIB)
  /*JOBPARM ROOM=3
2 //METRDISK EXEC METRPROC
9 //DISK DD DISP=SHR,DSN=ENVIRONH.METDATA.MILSTONE.YR7481
12 //SYSIN DD * GENERATED STATEMENT
13 //DISTRIB EXEC PGM=DISTRB00,REGION=284K,TIME=1
14 //STEPLIB DD DSN=ENVIRONH.DISTRIB,DISP=SHR
15 //GO.FT06F001 DD DCB=PRINT1,SYSOUT=*
16 //GO.FT10F001 DD UNIT=DISK,DISP=(OLD,DELETE),DSN=&SAMPLE
17 //GO.FT05F001 DD *
18 //IMBLIST EXEC PGM=IMBLIST
19 //SYSPRINT DD SYSOUT=*
20 //SYSLIB DD DSN=ENVIRONH.DISTRIB,DISP=SHR
21 //SYSIN DD * GENERATED STATEMENT
```

JOB09666

APPENDIX 1  
DISTRIBUTION Program Output  
Unit 3 MSVB to Unit 3 Control Room Air Intake

P. 2  
03703.7002  
WM(B)-01 *llr*

STMT NO. MESSAGE  
 2 IEF001I PROCEDURE METRPROC WAS EXPANDED USING SYSTEM LIBRARY SYS1.USER.PROCLIB  
 ICH70001I VIG7988 LAST ACCESS AT 11:21:00 ON FRIDAY, MAY 1, 1998  
 IEF236I ALLOC. FOR DISTRIB METRPROC METROISK  
 IGD103I SMS ALLOCATED TO DDNAME STEPLIB  
 IEF237I JES2 ALLOCATED TO FT06F001  
 IEF237I JES2 ALLOCATED TO SYSPRINT  
 IGD103I SMS ALLOCATED TO DDNAME SYS010  
 IGD101I SMS ALLOCATED TO DDNAME (SYS011 )  
 DSN (SYS98121.T113339.RA000.DISTRIB.SAMPLE.H01 )  
 STORCLAS (TEMP) MGMTCLAS ( ) DATACLAS ( )  
 VOL SER NOS= VIO

IEF237I JES2 ALLOCATED TO FT05F001  
 IEF142I DISTRIB METRPROC METROISK - STEP WAS EXECUTED - COND CODE 0000  
 IGD104I ENVIRONM.METODOLOGY RETAINED, DDNAME=STEPLIB  
 IEF285I VIG7988.DISTRIB.JOB09666.D0000104.? SYSOUT  
 IEF285I VIG7988.DISTRIB.JOB09666.D0000105.? SYSOUT  
 IGD104I ENVIRONM.METDATA.MILSTONE.YR7481 RETAINED, DDNAME=SYS010  
 IGD106I SYS98121.T113339.RA000.DISTRIB.SAMPLE.H01 PASSED, DDNAME=SYS011  
 IEF285I VIG7988.DISTRIB.JOB09666.D0000101.? SYSIN

.....  
 .JOB - DISTRIB , SUBMITTER - VIGEANT-SA , FLOOR - 3 , READER TIME, DATE - 11.33.37, 05/01/98 V09  
 .STEP NUMBER - 1, STEP NAME - METRPROC, PROGRAM NAME - METWR01 , RAN FROM 11.33.39 TO 11.33.41  
 .ENDING CONDITION - RETURN CODE 0, REGION USED - 380K, PERFORMANCE GROUP - 20, SHAPS - 0  
 .PAGEINS - 0, PAGEOUTS - 0, VIO PAGEINS - 0, VIO PAGEOUTS - 0  
 .CPU TIME - .50 VECTOR TIME - .00 SECS, EXCPS -( 352 NON-VIO, 1,169 VIO), CPU UNITS - 1.87 SECS  
 .SYSIN RECORDS - 3, OPENS - ( 0 TAPE, 0 TEMP, 0 PERM), COST = \$3.12  
 .EXCPS/DDNAME - 9/STEPLIB 343/SYS010 1,169/SYS011  
 .....

IEF373I STEP/METRPROC/START 1998121.1133  
 IEF374I STEP/METRPROC/STOP 1998121.1133 CPU 0MIN 00.46SEC SRB 0MIN 00.02SEC VIRT 88K SYS 292K EXT 4K SYS 10132K  
 IEF236I ALLOC. FOR DISTRIB DISTRIB  
 IGD103I SMS ALLOCATED TO DDNAME STEPLIB  
 IEF237I JES2 ALLOCATED TO FT06F001  
 IGD103I SMS ALLOCATED TO DDNAME FT10F001  
 IEF237I JES2 ALLOCATED TO FT05F001  
 IEF142I DISTRIB DISTRIB - STEP WAS EXECUTED - COND CODE 0001  
 IGD104I ENVIRONM.DISTRIB RETAINED, DDNAME=STEPLIB  
 IEF285I VIG7988.DISTRIB.JOB09666.D0000106.? SYSOUT  
 IGD105I SYS98121.T113339.RA000.DISTRIB.SAMPLE.H01 DELETED, DDNAME=FT10F001  
 IEF285I VIG7988.DISTRIB.JOB09666.D0000102.? SYSIN

.....  
 .JOB - DISTRIB , SUBMITTER - VIGEANT-SA , FLOOR - 3 , READER TIME, DATE - 11.33.37, 05/01/98 V09  
 .STEP NUMBER - 2, STEP NAME - DISTRIB , PROGRAM NAME - DISTRB00, RAN FROM 11.33.41 TO 11.33.45  
 .ENDING CONDITION - RETURN CODE 1, REGION USED - 340K, PERFORMANCE GROUP - 20, SHAPS - 0  
 .PAGEINS - 0, PAGEOUTS - 0, VIO PAGEINS - 0, VIO PAGEOUTS - 0  
 .CPU TIME - 2.35 VECTOR TIME - .00 SECS, EXCPS -( 8 NON-VIO, 1,170 VIO), CPU UNITS - 3.41 SECS  
 .SYSIN RECORDS - 16, OPENS - ( 0 TAPE, 0 TEMP, 0 PERM), COST = \$5.68  
 .EXCPS/DDNAME - 8/STEPLIB 1,170/FT10F001  
 .....

IEF373I STEP/DISTRIB /START 1998121.1133  
 IEF374I STEP/DISTRIB /STOP 1998121.1133 CPU 0MIN 02.34SEC SRB 0MIN 00.01SEC VIRT 64K SYS 276K EXT 4K SYS 10140K  
 IEF236I ALLOC. FOR DISTRIB IMBLIST  
 IEF237I JES2 ALLOCATED TO SYSPRINT  
 IGD103I SMS ALLOCATED TO DDNAME SYSLIB  
 IEF237I JES2 ALLOCATED TO SYSIN  
 IEF142I DISTRIB IMBLIST - STEP WAS EXECUTED - COND CODE 0008  
 IEF285I VIG7988.DISTRIB.JOB09666.D0000107.? SYSOUT  
 IGD104I ENVIRONM.DISTRIB RETAINED, DDNAME=SYSLIB

APPENDIX 1  
 DISTRIBUTION Program Output  
 Unit 3 MSVB to Unit 3 Control Room Air Intake

P. 3  
 03703.7002  
 WM(B)-01  
 201  
 0

IEF285I VIG7988.DISTRIB.JOB09666.D0000103.?

SYSIN

.....  
.JOB - DISTRIB , SUBMITTER - VIGEANT-SA , FLOOR - 3 , READER TIME, DATE - 11.33.37, 05/01/98 V09 .  
.STEP NUMBER - 3, STEP NAME - IMBLIST , PROGRAM NAME - IMBLIST , RAN FROM 11.33.45 TO 11.33.46 .  
.ENDING CONDITION - RETURN CODE 8, REGION USED - 428K, PERFORMANCE GROUP - 20, SHAPS - 0 .  
.PAGEINS - 0, PAGEOUTS - 0, VIO PAGEINS - 0, VIO PAGEOUTS - 0 .  
.CPU TIME - .03 VECTOR TIME - .00 SECS, EXCPS -( 0 NON-VIO, 0 VIO), CPU UNITS - .03 SECS .  
.SYSIN RECORDS - 1, OPENS - ( 0 TAPE, 0 TEMP, 0 PERM), COST = \$0.05 .  
.....

IEF373I STEP/IMBLIST /START 1998121.1133  
IEF374I STEP/IMBLIST /STOP 1998121.1133 CPU OMIN 00.03SEC SRB OMIN 00.00SEC VIRT 156K SYS 272K EXT 4K SYS 10044K  
IEF375I JOB/DISTRIB /START 1998121.1133  
IEF376I JOB/DISTRIB /STOP 1998121.1133 CPU OMIN 02.83SEC SRB OMIN 00.03SEC

.....  
.TOTAL CPU TIME - 2.88 SECS, TOTAL VECTOR TIME - .00 SECS, TOTAL CPU UNITS - 5.31 SECS .  
.TOTAL EXCPS -( 360 NON-VIO, 2,339 VIO) .  
.TOTAL JOB COST EXCLUDING PRINT CHARGES = \$8.85 CHARGED TO AUTH = 0031 , JO/HO = 022685067 .  
.....

APPENDIX 1  
DISTRIBUTION Program Output  
Unit 3 MSVB to Unit 3 Control Room Air Intake

P. 4  
03703.7002  
WMB(B)-01 *ll*



STONE & WEBSTER ENGINEERING CORPORATION  
ENVIRONMENTAL ENGINEERING DIVISION

COMPUTER CODE IDENTIFICATION

PROGRAM NAME: SITE DATA RETREIVAL PROGAM

VERSION OF PROGRAM: 00

LINK EDIT DATE (JULIAN): 80.184

DATE OF RUN (MO/DAY/YR): 5/01/98

JOB NAME OF RUN: DISTRIB

LIBRARY REFERENCE NUMBER: EN-112

LEVEL OF PROGRAM: 01

LINK EDIT TIME (HRS.MINS.SECONDS): 14.21.36

TIME OF RUN (MILITARY): 1133

JOB09666

APPENDIX 1  
DISTRIBUTION Program Output  
Unit 3 MSVB to Unit 3 Control Room Air Intake

P. 5  
03703.7002  
WM(B)-01  
*W-0*

INPUT DATA TRACEBACK

DATA SUBMITTED ON DEVICE: 5

```
CARD#  -----1-----2-----3-----4-----5-----6-----7-----8
      1         2
      2   111 112
      3  74001   81365
CARD#  -----1-----2-----3-----4-----5-----6-----7-----8
```

\*\*\*\*\* END OF INPUT ON DEVICE 5 \*\*\*\*\*

APPENDIX 1  
DISTRIBUTION Program Output  
Unit 3 MSVB to Unit 3 Control Room Air Intake

P. 6  
03703.7002  
WM(B)-01  
*Re W/O*



INPUT TO METOWER PROGRAM

2

111 112  
74001 81365

EOF OF INPUT DATA REACHED

NUMBER OF CARDS SELECTED = 5844

NUMBER OF DAYS SELECTED = 2922

APPENDIX 1  
DISTRIBUTION Program Output  
Unit 3 MSVB to Unit 3 Control Room Air Intake

P. 7  
03703.7002  
WM(B)-01  
REV 0



STONE & WEBSTER ENGINEERING CORPORATION  
ENVIRONMENTAL ENGINEERING DIVISION

COMPUTER CODE IDENTIFICATION

PROGRAM NAME: FREQ OF OCCUR OF TWO PARAMETERS

VERSION OF PROGRAM: 00

LOAD MODULE: ENVIRONM.DISTRIB

LINK EDIT DATE (JULIAN): 81.182

DATE OF RUN (MO/DAY/YR): 5/01/98

JOB NAME OF RUN: DISTRIB

LIBRARY REFERENCE NUMBER: EN-200

LEVEL OF PROGRAM: 00

MEMBER (PGM): DISTRB00

LINK EDIT TIME (HRS.MINS.SECONDS): 12.11.26

TIME OF RUN (MILITARY): 1133

JOB09666

APPENDIX 1  
DISTRIBUTION Program Output  
Unit 3 MSVB to Unit 3 Control Room Air Intake

P. 8  
03703.7002  
WM(B)-01

*Rev 0*

INPUT DATA TRACEBACK

DATA SUBMITTED ON DEVICE: 5

```

CARD#  -----1-----2-----3-----4-----5-----6-----7-----8
1      2
2      Stat HILLSTONE NUCLEAR POWER STATION 1974 - 1981 ONSITE DATA
3      Stat 33-FT WIND DIRECTION VS. 33-FT WIND SPEED DISTRIBUTION
4      Stat WIND DIRECTION (DEGREES)           3     0 999
5      Stat 154 360
6      0
7      WIND SPEED      (MPH)      (TENTHS)           99     0 1000
8      5   6   7   8   9  10  11  12  13  14  15  16  17  18  19  20  21  22  23  24
9      25  26  27  28  29  30  31  32  33  34  35  36  37  38  39  40  41  42  43  44
10     45  46  47  48  49  50  51  52  53  54  55  56  57  58  59  60  61  62  63  64
    
```

```

CARD#  -----1-----2-----3-----4-----5-----6-----7-----8
11     65  66  67  68  69  70  71  72  73  74  75  76  77  78  79  80  81  82  83  84
12     85  86  87  88  89  90  91  92  93  94  95  96  97  98  99  100 110 120 130 140
13     1 999
14     74
15     7400181365      0     0
16     112      0.0     0.0  111      0.0      0.0
    
```

```

CARD#  -----1-----2-----3-----4-----5-----6-----7-----8
    
```

\*\*\*\*\* END OF INPUT ON DEVICE 5 \*\*\*\*\*

APPENDIX 1  
 DISTRIBUTION Program Output  
 Unit 3 MSVB to Unit 3 Control Room Air Intake

P. 9  
 03703.7002  
 WM(B)-01  
*Ret D*

\*\*\*\*\* SITE WEATHER DATA \*\*\*\*\*

FIRST YEAR = 1974, JSYR = 74001, JNYR = 81365, JM01 = 0, JM02 = 0

TOP PARAMETER CODE = 112      MULT = 1.00000      ADD = 0.0

SIDE PARAMETER CODE = 111      MULT = 1.00000      ADD = 0.0

FIRST DATE RETURNED = 74001

LAST DATE RETURNED = 81365

APPENDIX 1  
DISTRIBUTION Program Output  
Unit 3 MSVB to Unit 3 Control Room Air Intake

P. 10  
03703.7002  
WM(B)-01  
*WVO*

MILLSTONE NUCLEAR POWER STATION 1974 - 1981 ONSITE DATA  
 33-FT WIND DIRECTION VS. 33-FT WIND SPEED DISTRIBUTION

WIND SPEED (MPH) (TENTHS)	WIND DIRECTION (DEGREES)				TOTAL
	0- 85	86- <u>154</u>	155- 360	361- 999	
0 - 5	0	0	0	87	87
PCT CLASS	0.0	0.0	0.0	100.00	100.00
PCT TOTAL	0.0	0.0	0.0	0.13	0.13
6 - 6	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
7 - 7	0	0	0	123	123
PCT CLASS	0.0	0.0	0.0	100.00	100.00
PCT TOTAL	0.0	0.0	0.0	0.19	0.19
8 - 8	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
9 - 9	0	0	0	237	237
PCT CLASS	0.0	0.0	0.0	100.00	100.00
PCT TOTAL	0.0	0.0	0.0	0.36	0.36
10 - 10	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
11 - 11	0	0	0	367	367
PCT CLASS	0.0	0.0	0.0	100.00	100.00
PCT TOTAL	0.0	0.0	0.0	0.55	0.55
12 - 12	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
13 - 13	182	75	264	14	535
PCT CLASS	34.02	14.02	49.35	2.62	100.00
PCT TOTAL	0.27	0.11	0.40	0.02	0.81
14 - 14	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
15 - 15	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0

APPENDIX 1  
 DISTRIBUTION Program Output  
 Unit 3 MSVB to Unit 3 Control Room Air Intake

P. 11  
 03703.7002  
 WM(B)-01  
*lec*

WIND SPEED (MPH) (TENTHS)	WIND DIRECTION (DEGREES)				TOTAL
	0-85	86-154	155-360	361-999	
16 - 16	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
17 - 17	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
18 - 18	262	89	359	11	721
PCT CLASS	36.34	12.34	49.79	1.53	100.00
PCT TOTAL	0.39	0.13	0.54	0.02	1.09
19 - 19	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
20 - 20	281	101	426	13	821
PCT CLASS	34.23	12.30	51.89	1.58	100.00
PCT TOTAL	0.42	0.15	0.64	0.02	1.24
21 - 21	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
22 - 22	247	93	327	6	673
PCT CLASS	36.70	13.82	48.59	0.89	100.00
PCT TOTAL	0.37	0.14	0.49	0.01	1.01
23 - 23	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
24 - 24	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
25 - 25	308	130	549	11	998
PCT CLASS	30.86	13.03	55.01	1.10	100.00
PCT TOTAL	0.46	0.20	0.83	0.02	1.50
26 - 26	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
27 - 27	0	0	1	0	1
PCT CLASS	0.0	0.0	100.00	0.0	100.00
PCT TOTAL	0.0	0.0	0.00	0.0	0.00

86° → 154°  
 ← Cumulative Hours = 358  
 Total Hours = 8266  
 358/8266 = 4.3%

APPENDIX 1  
 DISTRIBUTION Program Output  
 Unit 3 MSVB to Unit 3 Control Room Air Intake

P. 12  
 03703.7002  
 WM(B)-01  
 RDD

WIND SPEED (MPH) (TENTHS)	WIND DIRECTION (DEGREES)				TOTAL
	0- 85	86- 154	155- 360	361- 999	
28 - 28	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
29 - 29	372	166	625	8	1171
PCT CLASS	31.77	14.18	53.37	0.68	100.00
PCT TOTAL	0.56	0.25	0.94	0.01	1.77
30 - 30	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
<u>31 - 31</u>	345	169	640	6	1160
PCT CLASS	29.74	14.57	55.17	0.52	100.00
PCT TOTAL	0.52	0.25	0.96	0.01	1.75
32 - 32	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
33 - 33	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
34 - 34	374	165	732	10	1281
PCT CLASS	29.20	12.88	57.14	0.78	100.00
PCT TOTAL	0.56	0.25	1.10	0.02	1.93
35 - 35	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
36 - 36	390	176	792	11	1369
PCT CLASS	28.49	12.86	57.85	0.80	100.00
PCT TOTAL	0.59	0.27	1.19	0.02	2.06
37 - 37	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
38 - 38	1	0	1	0	2
PCT CLASS	50.00	0.0	50.00	0.0	100.00
PCT TOTAL	0.00	0.0	0.00	0.0	0.00
39 - 39	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0

86° → 154°  
 ← Cumulative Hours = 82.3  
 Total Hours = 8266  
 823/8266 = 10.0%

APPENDIX 1  
 DISTRIBUTION Program Output  
 Unit 3 MSVB to Unit 3 Control Room Air Intake

P. 13  
 03703.7002  
 WM(B)-01  
 RDD

WIND SPEED (MPH) (TENTHS)	WIND DIRECTION (DEGREES)				TOTAL
	0- 85	86- 154	155- 360	361- 999	
40 - 40	336	173	805	8	1322
PCT CLASS	25.42	13.09	60.89	0.61	100.00
PCT TOTAL	0.51	0.26	1.21	0.01	1.99
41 - 41	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
42 - 42	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
43 - 43	371	201	864	7	1443
PCT CLASS	25.71	13.93	59.88	0.49	100.00
PCT TOTAL	0.56	0.30	1.30	0.01	2.18
44 - 44	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
<u>45 - 45</u>	240	112	579	7	938
PCT CLASS	25.59	11.94	61.73	0.75	100.00
PCT TOTAL	0.36	0.17	0.87	0.01	1.41
46 - 46	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
47 - 47	361	185	914	9	1469
PCT CLASS	24.57	12.59	62.22	0.61	100.00
PCT TOTAL	0.54	0.28	1.38	0.01	2.21
48 - 48	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
49 - 49	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
50 - 50	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
51 - 51	342	202	868	9	1421
PCT CLASS	24.07	14.22	61.08	0.63	100.00
PCT TOTAL	0.52	0.30	1.31	0.01	2.14

86° → 154°

← Cumulative Hours = 1,650  
 Total Hours = 8,266  
 $1,650 / 8,266 = 20.0\%$

APPENDIX 1  
 DISTRIBUTION Program Output  
 Unit 3 MSVB to Unit 3 Control Room Air Intake

P. 14  
 03703.7002  
 WM(B)-01  
 BVO



WIND SPEED (MPH) (TENTHS)	WIND DIRECTION (DEGREES)				TOTAL
	0- 85	86- 154	155- 360	361- 999	
52 - 52	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
53 - 53	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
54 - 54	301	211	901	6	1419
PCT CLASS	21.21	14.87	63.50	0.42	100.00
PCT TOTAL	0.45	0.32	1.36	0.01	2.14
55 - 55	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
56 - 56	318	208	900	13	1439
PCT CLASS	22.10	14.45	62.54	0.90	100.00
PCT TOTAL	0.48	0.31	1.36	0.02	2.17
57 - 57	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
58 - 58	336	199	901	5	1441
PCT CLASS	23.32	13.81	62.53	0.35	100.00
PCT TOTAL	0.51	0.30	1.36	0.01	2.17
59 - 59	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
60 - 60	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
61 - 61	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
62 - 62	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
63 - 63	302	193	912	6	1413
PCT CLASS	21.37	13.66	64.54	0.42	100.00
PCT TOTAL	0.46	0.29	1.37	0.01	2.13

APPENDIX 1  
DISTRIBUTION Program Output  
Unit 3 MSVB to Unit 3 Control Room Air Intake

P. 15  
03703.7002  
WM(B)-01  
2000

WIND SPEED (MPH) (TENTHS)	WIND DIRECTION (DEGREES)				TOTAL
	0- 85	86- 154	155- 360	361- 999	
64 - 64	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
65 - 65	293	208	969	8	1478
PCT CLASS	19.82	14.07	65.56	0.54	100.00
PCT TOTAL	0.44	0.31	1.46	0.01	2.23
66 - 66	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
67 - 67	205	153	651	5	1014
PCT CLASS	20.22	15.09	64.20	0.49	100.00
PCT TOTAL	0.31	0.23	0.98	0.01	1.53
68 - 68	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
69 - 69	282	223	975	10	1490
PCT CLASS	18.93	14.97	65.44	0.67	100.00
PCT TOTAL	0.43	0.34	1.47	0.02	2.25
70 - 70	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
71 - 71	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
72 - 72	1	1	0	0	2
PCT CLASS	50.00	50.00	0.0	0.0	100.00
PCT TOTAL	0.00	0.00	0.0	0.0	0.00
73 - 73	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
74 - 74	280	207	968	10	1465
PCT CLASS	19.11	14.13	66.08	0.68	100.00
PCT TOTAL	0.42	0.31	1.46	0.02	2.21
75 - 75	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0

86° → 154°

Cumulative Hours = 3,209

Total Hours = 8,266

3,209 / 8,266 = 38.8%

APPENDIX 1  
 DISTRIBUTION Program Output  
 Unit 3 MSVB to Unit 3 Control Room Air Intake

Rev 0  
 P. 16  
 03703.7002  
 WM(B)-01

WIND SPEED (MPH) (TENTHS)	WIND DIRECTION (DEGREES)				TOTAL
	0- 85	86- 154	155- 360	361- 999	
76 - 76	276	181	967	8	1432
PCT CLASS	19.27	12.64	67.53	0.56	100.00
PCT TOTAL	0.42	0.27	1.46	0.01	2.16
77 - 77	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
78 - 78	286	176	880	8	1350
PCT CLASS	21.19	13.04	65.19	0.59	100.00
PCT TOTAL	0.43	0.27	1.33	0.01	2.04
79 - 79	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
80 - 80	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
81 - 81	225	193	911	8	1337
PCT CLASS	16.83	14.44	68.14	0.60	100.00
PCT TOTAL	0.34	0.29	1.37	0.01	2.02
82 - 82	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
83 - 83	0	2	2	0	4
PCT CLASS	0.0	50.00	50.00	0.0	100.00
PCT TOTAL	0.0	0.00	0.00	0.0	0.01
84 - 84	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
85 - 85	238	202	898	6	1344
PCT CLASS	17.71	15.03	66.82	0.45	100.00
PCT TOTAL	0.36	0.30	1.35	0.01	2.03
86 - 86	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
87 - 87	244	180	942	4	1370
PCT CLASS	17.81	13.14	68.76	0.29	100.00
PCT TOTAL	0.37	0.27	1.42	0.01	2.07

APPENDIX 1  
DISTRIBUTION Program Output  
Unit 3 MSVB to Unit 3 Control Room Air Intake

P. 17  
03703.7002  
WM(B)-01

*Rec'd*

HIND SPEED (MPH) (TENTHS)	HIND DIRECTION (DEGREES)				TOTAL
	0- 85	86- 154	155- 360	361- 999	
88 - 88	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
89 - 89	168	118	635	5	926
PCT CLASS	18.14	12.74	68.57	0.54	100.00
PCT TOTAL	0.25	0.18	0.96	0.01	1.40
90 - 90	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
91 - 91	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
92 - 92	208	152	870	5	1235
PCT CLASS	16.84	12.31	70.45	0.40	100.00
PCT TOTAL	0.31	0.23	1.31	0.01	1.86
93 - 93	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
94 - 94	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
95 - 95	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
96 - 96	222	176	876	6	1280
PCT CLASS	17.34	13.75	68.44	0.47	100.00
PCT TOTAL	0.33	0.27	1.32	0.01	1.93
97 - 97	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
98 - 98	219	158	935	7	1319
PCT CLASS	16.60	11.98	70.89	0.53	100.00
PCT TOTAL	0.33	0.24	1.41	0.01	1.99
99 - 99	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0

APPENDIX 1  
DISTRIBUTION Program Output  
Unit 3 MSVB to Unit 3 Control Room Air Intake

P. 18  
03703.7002  
WM(B)-01  
*Rev D*

WIND SPEED (MPH) (TENTHS)	WIND DIRECTION (DEGREES)				TOTAL
	0- 85	86- 154	155- 360	361- 999	
100 - 100	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
101 - 110	734	528	3406	14	4682
PCT CLASS	15.68	11.28	72.75	0.30	100.00
PCT TOTAL	1.11	0.80	5.13	0.02	7.06
111 - 120	437	303	2125	8	2873
PCT CLASS	15.21	10.55	73.96	0.28	100.00
PCT TOTAL	0.66	0.46	3.20	0.01	4.33
121 - 130	474	418	2820	20	3732
PCT CLASS	12.70	11.20	75.56	0.54	100.00
PCT TOTAL	0.71	0.63	4.25	0.03	5.63
131 -1000	1392	1839	12778	139	16148
PCT CLASS	8.62	11.39	79.13	0.86	100.00
PCT TOTAL	2.10	2.77	19.26	0.21	24.34
TOTAL	11853	8266	44968	1245	66332
PCT CLASS	17.87	12.46	67.79	1.88	100.00
PCT TOTAL	17.87	12.46	67.79	1.88	100.00

← Total Valid Observations (All Sectors)

Total Observations (86° → 154°)

APPENDIX 1  
DISTRIBUTION Program Output  
Unit 3 MSVB to Unit 3 Control Room Air Intake

P. 19  
03703.7002  
WM(B)-01  
McCB

OBSERVATIONS READ = 70128

CHECKED = 70128

USED = 66332

APPENDIX 1  
DISTRIBUTION Program Output  
Unit 3 MSVB to Unit 3 Control Room Air Intake

P. 20  
03703.7002  
WM(B)-01

*WVO*

JES2 JOB LOG -- SYSTEM C168 -- NODE JES2BOS

11.34.03 JOB09668 IRR010I USERID VIG7988 IS ASSIGNED TO THIS JOB.  
11.34.04 JOB09668 ICH70001I VIG7988 LAST ACCESS AT 11:33:39 ON FRIDAY, MAY 1, 1998  
11.34.04 JOB09668 \$HASP373 DISTRIB STARTED - INIT 8 - CLASS A - SYS C168  
11.34.09 JOB09668 +IH0002I STOP 1  
11.34.09 JOB09668 \$HASP395 DISTRIB ENDED

----- JES2 JOB STATISTICS -----

01 MAY 1998 JOB EXECUTION DATE

37 CARDS READ

840 SYSOUT PRINT RECORDS

0 SYSOUT PUNCH RECORDS

34 SYSOUT SPOOL KBYTES

0.09 MINUTES EXECUTION TIME

APPENDIX 2  
DISTRIBUTION Program Output  
Unit 3 ESFB to Unit 3 Control Room Air Intake

P. 1  
03703.7002  
WMM(B)-01  
*Revo*

01-MAY-98JOB09668

```
1 //DISTRIB JOB (0031,3),'VIGEANT-SA',
  // MSGLEVEL=2,MSGCLASS=A
  //* RJETRAN.VIG7988.DATA(DISTRIB)
  /*JOBPARM ROOM=3
2 //METRODISK EXEC METRPROC
9 //DISK DD DISP=SHR,DSN=ENVIRONM.METDATA.MILSTONE.YR7481
12 //SYSIN DD * GENERATED STATEMENT
13 //DISTRIB EXEC PGM=DISTRB00,REGION=284K,TIME=1
14 //STEPLIB DD DSN=ENVIRONM.DISTRIB,DISP=SHR
15 //GO.FT06F001 DD DCB=PRINT1,SYSOUT=*,
16 //GO.FT10F001 DD UNIT=DISK,DISP=(OLD,DELETE),DSN=&SAMPLE
17 //GO.FT05F001 DD *
18 //IMBLIST EXEC PGM=IMBLIST
19 //SYSPRINT DD SYSOUT=*
20 //SYSLIB DD DSN=ENVIRONM.DISTRIB,DISP=SHR
21 //SYSIN DD * GENERATED STATEMENT
```

JOB09668

APPENDIX 2  
DISTRIBUTION Program Output  
Unit 3 ESFB to Unit 3 Control Room Air Intake

*Delvo*

P. 2  
03703.7002  
WM(B)-01



STHT NO. MESSAGE

2 IEF001I PROCEDURE METRPROC WAS EXPANDED USING SYSTEM LIBRARY SYS1.USER.PROCLIB

ICH70001I VIG7988 LAST ACCESS AT 11:33:39 ON FRIDAY, MAY 1, 1998

IEF236I ALLOC. FOR DISTRIB METRPROC METRDISK

IGD103I SMS ALLOCATED TO DDNAME STEPLIB

IEF237I JES2 ALLOCATED TO FT06F001

IEF237I JES2 ALLOCATED TO SYSPRINT

IGD103I SMS ALLOCATED TO DDNAME SYS010

IGD101I SMS ALLOCATED TO DDNAME (SYS011 )  
DSN (SYS98121.T113403.RA000.DISTRIB.SAMPLE.H01 )

STORCLAS (TEMP) MGMTCLAS ( ) DATACLAS ( )

VOL SER NOS= VIO

IEF237I JES2 ALLOCATED TO FT05F001

IEF142I DISTRIB METRPROC METRDISK - STEP WAS EXECUTED - COND CODE 0000

IGD104I ENVIRONM.METODOLOGY RETAINED, DDNAME=STEPLIB

IEF285I VIG7988.DISTRIB.JOB09668.D0000104.? SYSOUT

IEF285I VIG7988.DISTRIB.JOB09668.D0000105.? SYSOUT

IGD104I ENVIRONM.METDATA.MILSTONE.YR7481 RETAINED, DDNAME=SYS010

IGD106I SYS98121.T113403.RA000.DISTRIB.SAMPLE.H01 PASSED, DDNAME=SYS011

IEF285I VIG7988.DISTRIB.JOB09668.D0000101.? SYSIN

```

.....
.JOB - DISTRIB , SUBMITTER - VIGEANT-SA , FLOOR - 3 , READER TIME, DATE - 11.34.03, 05/01/98 V09
.STEP NUMBER - 1, STEP NAME - METRPROC, PROGRAM NAME - METHR01 , RAN FROM 11.34.04 TO 11.34.06
.ENDING CONDITION - RETURN CODE 0, REGION USED - 380K, PERFORMANCE GROUP - 20, SHAPS - 0
.PAGEINS - 0, PAGEOUTS - 0, VIO PAGEINS - 0, VIO PAGEOUTS - 0
.CPU TIME - .49 VECTOR TIME - .00 SECS, EXCPS -( 352 NON-VIO, 1,169 VIO), CPU UNITS - 1.86 SECS
.SYSIN RECORDS - 3, OPENS - ( 0 TAPE, 0 TEMP, 0 PERM), COST = $3.10
.EXCPS/DDNAME - 9/STEPLIB 343/SYS010 1,169/SYS011
.....

```

```

IEF373I STEP/METRPROC/START 1998121.1134
IEF374I STEP/METRPROC/STOP 1998121.1134 CPU OMIN 00.46SEC SRB OMIN 00.02SEC VIRT 88K SYS 292K EXT 4K SYS 10132K

```

IEF236I ALLOC. FOR DISTRIB DISTRIB

IGD103I SMS ALLOCATED TO DDNAME STEPLIB

IEF237I JES2 ALLOCATED TO FT06F001

IGD103I SMS ALLOCATED TO DDNAME FT10F001

IEF237I JES2 ALLOCATED TO FT05F001

IEF142I DISTRIB DISTRIB - STEP WAS EXECUTED - COND CODE 0001

IGD104I ENVIRONM.DISTRIB RETAINED, DDNAME=STEPLIB

IEF285I VIG7988.DISTRIB.JOB09668.D0000106.? SYSOUT

IGD105I SYS98121.T113403.RA000.DISTRIB.SAMPLE.H01 DELETED, DDNAME=FT10F001

IEF285I VIG7988.DISTRIB.JOB09668.D0000102.? SYSIN

```

.....
.JOB - DISTRIB , SUBMITTER - VIGEANT-SA , FLOOR - 3 , READER TIME, DATE - 11.34.03, 05/01/98 V09
.STEP NUMBER - 2, STEP NAME - DISTRIB , PROGRAM NAME - DISTRB00, RAN FROM 11.34.06 TO 11.34.09
.ENDING CONDITION - RETURN CODE 1, REGION USED - 340K, PERFORMANCE GROUP - 20, SHAPS - 0
.PAGEINS - 0, PAGEOUTS - 0, VIO PAGEINS - 0, VIO PAGEOUTS - 0
.CPU TIME - 2.35 VECTOR TIME - .00 SECS, EXCPS -( 8 NON-VIO, 1,170 VIO), CPU UNITS - 3.41 SECS
.SYSIN RECORDS - 16, OPENS - ( 0 TAPE, 0 TEMP, 0 PERM), COST = $5.68
.EXCPS/DDNAME - 8/STEPLIB 1,170/FT10F001
.....

```

```

IEF373I STEP/DISTRIB /START 1998121.1134
IEF374I STEP/DISTRIB /STOP 1998121.1134 CPU OMIN 02.34SEC SRB OMIN 00.01SEC VIRT 64K SYS 276K EXT 4K SYS 10140K

```

IEF236I ALLOC. FOR DISTRIB IMBLIST

IEF237I JES2 ALLOCATED TO SYSPRINT

IGD103I SMS ALLOCATED TO DDNAME SYSLIB

IEF237I JES2 ALLOCATED TO SYSIN

IEF142I DISTRIB IMBLIST - STEP WAS EXECUTED - COND CODE 0008

IEF285I VIG7988.DISTRIB.JOB09668.D0000107.? SYSOUT

IGD104I ENVIRONM.DISTRIB RETAINED, DDNAME=SYSLIB

APPENDIX 2  
DISTRIBUTION Program Output  
Unit 3 ESFB to Unit 3 Control Room Air Intake

P. 3  
03703.7002  
WM(B)-01

IEF285I VIG7988.DISTRIB.JOB09668.D0000103.?

SYSIN

.....  
.JOB - DISTRIB , SUBMITTER - VIGEANT-SA , FLOOR - 3 , READER TIME, DATE - 11.34.03, 05/01/98 V09 .  
.STEP NUMBER - 3, STEP NAME - IMBLIST , PROGRAM NAME - IMBLIST , RAN FROM 11.34.09 TO 11.34.09 .  
.ENDING CONDITION - RETURN CODE 8, REGION USED - 428K, PERFORMANCE GROUP - 20, SHAPS - 0 .  
.PAGEINS - 0, PAGEOUTS - 0, VIO PAGEINS - 0, VIO PAGEOUTS - 0 .  
.CPU TIME - .03 VECTOR TIME - .00 SECS, EXCPS -( 0 NON-VIO, 0 VIO), CPU UNITS - .03 SECS .  
.SYSIN RECORDS - 1, OPENS - ( 0 TAPE, 0 TEMP, 0 PERM), COST = \$0.05 .  
.....

IEF373I STEP/IMBLIST /START 1998121.1134  
IEF374I STEP/IMBLIST /STOP 1998121.1134 CPU 0MIN 00.03SEC SRB 0MIN 00.00SEC VIRT 156K SYS 272K EXT 4K SYS 10044K  
IEF375I JOB/DISTRIB /START 1998121.1134  
IEF376I JOB/DISTRIB /STOP 1998121.1134 CPU 0MIN 02.83SEC SRB 0MIN 00.03SEC

.....  
.TOTAL CPU TIME - 2.87 SECS, TOTAL VECTOR TIME - .00 SECS, TOTAL CPU UNITS - 5.30 SECS .  
.TOTAL EXCPS -( 360 NON-VIO, 2,339 VIO) .  
.TOTAL JOB COST EXCLUDING PRINT CHARGES = \$8.83 CHARGED TO AUTH = 0031 , JO/HO = 022685067 .  
.....

APPENDIX 2  
DISTRIBUTION Program Output  
Unit 3 ESFB to Unit 3 Control Room Air Intake

*Revo*

P. 4  
03703.7002  
WM(B)-01



STONE & WEBSTER ENGINEERING CORPORATION  
ENVIRONMENTAL ENGINEERING DIVISION

COMPUTER CODE IDENTIFICATION

PROGRAM NAME: SITE DATA RETREIVAL PROGAM  
VERSION OF PROGRAM: 00  
LINK EDIT DATE (JULIAN): 80.184  
DATE OF RUN (MO/DAY/YR): 5/01/98  
JOB NAME OF RUN: DISTRIB

LIBRARY REFERENCE NUMBER: EN-112  
LEVEL OF PROGRAM: 01  
LINK EDIT TIME (HRS.MINS.SECONDS): 14.21.36  
TIME OF RUN (MILITARY): 1134  
JOB09668

APPENDIX 2  
DISTRIBUTION Program Output  
Unit 3 ESFB to Unit 3 Control Room Air Intake

P. 5  
03703.7002  
WM(B)-01  
*Revo*

INPUT DATA TRACEBACK

DATA SUBMITTED ON DEVICE: 5

```
CARD# 1-----2-----3-----4-----5-----6-----7-----8
      1      2
      2 111 112
      3 74001 81365
CARD# 1-----2-----3-----4-----5-----6-----7-----8
```

\*\*\*\*\* END OF INPUT ON DEVICE 5 \*\*\*\*\*

APPENDIX 2  
DISTRIBUTION Program Output  
Unit 3 ESFB to Unit 3 Control Room Air Intake

P. 6  
03703.7002  
WM(B)-01

*Leve*

INPUT TO METOWER PROGRAM

2  
111.112  
74001 81365

EOF OF INPUT DATA REACHED

NUMBER OF CARDS SELECTED = 5844

NUMBER OF DAYS SELECTED = 2922

APPENDIX 2  
DISTRIBUTION Program Output  
Unit 3 ESFB to Unit 3 Control Room Air Intake

P. 7  
03703.7002  
WM(B)-01  
*Ward*



STONE & WEBSTER ENGINEERING CORPORATION  
ENVIRONMENTAL ENGINEERING DIVISION

COMPUTER CODE IDENTIFICATION

PROGRAM NAME: FREQ OF OCCUR OF THO PARAMETERS  
VERSION OF PROGRAM: 00  
LOAD MODULE: ENVIRONM.DISTRIB  
LINK EDIT DATE (JULIAN): 81.182  
DATE OF RUN (MO/DAY/YR): 5/01/98  
JOB NAME OF RUN: DISTRIB

LIBRARY REFERENCE NUMBER: EN-200  
LEVEL OF PROGRAM: 00  
MEMBER (PGM): DISTRB00  
LINK EDIT TIME (HRS.MINS.SECONDS): 12.11.26  
TIME OF RUN (MILITARY): 1134  
JOB09668

APPENDIX 2  
DISTRIBUTION Program Output  
Unit 3 ESFB to Unit 3 Control Room Air Intake

P. 8  
03703.7002  
WM(B)-01

*PCW*

INPUT DATA TRACEBACK

DATA SUBMITTED ON DEVICE: 5

```

CARD#  ---+---1---+---2---+---3---+---4---+---5---+---6---+---7---+---8
1      2
2      MILLSTONE NUCLEAR POWER STATION 1974 - 1981 ONSITE DATA
3      33-FT WIND DIRECTION VS. 33-FT WIND SPEED DISTRIBUTION
4      56 WIND DIRECTION (DEGREES)          3      0 999
5      59 124 360
6      0
7      WIND SPEED      (MPH)      (TENTHS)          99      0 1000
8      5  6  7  8  9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24
9      25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44
10     45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60 61 62 63 64
    
```

```

CARD#  ---+---1---+---2---+---3---+---4---+---5---+---6---+---7---+---8
11     65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80 81 82 83 84
12     85 86 87 88 89 90 91 92 93 94 95 96 97 98 99 100 110 120 130 140
13     1 999
14     74
15     7400181365      0      0
16     112      0.0      0.0 111      0.0      0.0
CARD#  ---+---1---+---2---+---3---+---4---+---5---+---6---+---7---+---8
    
```

\*\*\*\*\* END OF INPUT ON DEVICE 5 \*\*\*\*\*

APPENDIX 2  
 DISTRIBUTION Program Output  
 Unit 3 ESFB to Unit 3 Control Room Air Intake

P. 9  
 03703.7002  
 WM(B)-01  
*Per-O*

\*\*\*\*\* SITE WEATHER DATA \*\*\*\*\*

FIRST YEAR = 1974, JSYR = 74001, JNYR = 81365, JM01 = 0, JM02 = 0

TOP PARAMETER CODE = 112      MULT = 1.00000      ADD = 0.0

SIDE PARAMETER CODE = 111      MULT = 1.00000      ADD = 0.0

FIRST DATE RETURNED = 74001

LAST DATE RETURNED = 81365

APPENDIX 2  
DISTRIBUTION Program Output  
Unit 3 ESFB to Unit 3 Control Room Air Intake

P. 10  
03703.7002  
WM(B)-01  
*RR0*

1  
11



MILLSTONE NUCLEAR POWER STATION 1974 - 1981 ONSITE DATA  
 33-FT WIND DIRECTION VS. 33-FT WIND SPEED DISTRIBUTION



WIND DIRECTION (DEGREES)

WIND SPEED (MPH) (TENTHS)	WIND DIRECTION (DEGREES)				TOTAL
	0- 55	56- 124	125- 360	361- 999	
0 - 5	0	0	0	87	87
PCT CLASS	0.0	0.0	0.0	100.00	100.00
PCT TOTAL	0.0	0.0	0.0	0.13	0.13
6 - 6	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
7 - 7	0	0	0	123	123
PCT CLASS	0.0	0.0	0.0	100.00	100.00
PCT TOTAL	0.0	0.0	0.0	0.19	0.19
8 - 8	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
9 - 9	0	0	0	237	237
PCT CLASS	0.0	0.0	0.0	100.00	100.00
PCT TOTAL	0.0	0.0	0.0	0.36	0.36
10 - 10	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
11 - 11	0	0	0	367	367
PCT CLASS	0.0	0.0	0.0	100.00	100.00
PCT TOTAL	0.0	0.0	0.0	0.55	0.55
12 - 12	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
13 - 13	136	83	302	14	535
PCT CLASS	25.42	15.51	56.45	2.62	100.00
PCT TOTAL	0.21	0.13	0.46	0.02	0.81
14 - 14	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
15 - 15	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0

APPENDIX 2  
 DISTRIBUTION Program Output  
 Unit 3 ESFB to Unit 3 Control Room Air Intake

P. 11  
 03703.7002  
 WM(B)-01  
*220*

WIND SPEED (MPH) (TENTHS)	WIND DIRECTION (DEGREES)				TOTAL
	0- 55	56- <u>124</u>	125- 360	361- 999	
16 - 16	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
17 - 17	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
18 - 18	193	122	395	11	721
PCT CLASS	26.77	16.92	54.79	1.53	100.00
PCT TOTAL	0.29	0.18	0.60	0.02	1.09
19 - 19	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
20 - 20	217	119	472	13	821
PCT CLASS	26.43	14.49	57.49	1.58	100.00
PCT TOTAL	0.33	0.18	0.71	0.02	1.24
21 - 21	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
<u>22 - 22</u>	187	106	374	6	673
PCT CLASS	27.79	15.75	55.57	0.89	100.00
PCT TOTAL	0.28	0.16	0.56	0.01	1.01
23 - 23	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
24 - 24	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
25 - 25	244	121	622	11	998
PCT CLASS	24.45	12.12	62.32	1.10	100.00
PCT TOTAL	0.37	0.18	0.94	0.02	1.50
26 - 26	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
27 - 27	0	0	1	0	1
PCT CLASS	0.0	0.0	100.00	0.0	100.00
PCT TOTAL	0.0	0.0	0.00	0.0	0.00

56° → 124°

Cumulative Hours = 430 Total Hours = 7,922  
 $430 / 7,922 = 5.4\%$

APPENDIX 2  
 DISTRIBUTION Program Output  
 Unit 3 ESFB to Unit 3 Control Room Air Intake

P. 12  
 03703.7002  
 WM(B)-01  
 Rev 0

WIND SPEED (MPH) (TENTHS)	WIND DIRECTION (DEGREES)				TOTAL
	0- 55	56- 124	125- 360	361- 999	
28 - 28	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
29 - 29	299	150	714	8	1171
PCT CLASS	25.53	12.81	60.97	0.68	100.00
PCT TOTAL	0.45	0.23	1.08	0.01	1.77
30 - 30	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
31 - 31	276	140	738	6	1160
PCT CLASS	23.79	12.07	63.62	0.52	100.00
PCT TOTAL	0.42	0.21	1.11	0.01	1.75
32 - 32	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
33 - 33	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
34 - 34	315	129	827	10	1281
PCT CLASS	24.59	10.07	64.56	0.78	100.00
PCT TOTAL	0.47	0.19	1.25	0.02	1.93
35 - 35	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
36 - 36	319	137	902	11	1369
PCT CLASS	23.30	10.01	65.89	0.80	100.00
PCT TOTAL	0.48	0.21	1.36	0.02	2.06
37 - 37	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
38 - 38	0	1	1	0	2
PCT CLASS	0.0	50.00	50.00	0.0	100.00
PCT TOTAL	0.0	0.00	0.00	0.0	0.00
39 - 39	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0

56° → 124°  
 ← Cumulative Observations = 841  
 Total Observations = 7,922  
 841 / 7,922 = 10.6%

APPENDIX 2  
 DISTRIBUTION Program Output  
 Unit 3 ESFB to Unit 3 Control Room Air Intake

P. 13  
 03703.7002  
 WM(B)-01  
*Rev D*

WIND SPEED (MPH) (TENTHS)	WIND DIRECTION (DEGREES)				TOTAL
	0- 55	56- 124	125- 360	361- 999	
40 - 40	266	154	894	8	1322
PCT CLASS	20.12	11.65	67.62	0.61	100.00
PCT TOTAL	0.40	0.23	1.35	0.01	1.99
41 - 41	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
42 - 42	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
43 - 43	311	149	976	7	1443
PCT CLASS	21.55	10.33	67.64	0.49	100.00
PCT TOTAL	0.47	0.22	1.47	0.01	2.18
44 - 44	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
45 - 45	198	102	631	7	938
PCT CLASS	21.11	10.87	67.27	0.75	100.00
PCT TOTAL	0.30	0.15	0.95	0.01	1.41
46 - 46	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
47 - 47	309	141	1010	9	1469
PCT CLASS	21.03	9.60	68.75	0.61	100.00
PCT TOTAL	0.47	0.21	1.52	0.01	2.21
48 - 48	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
49 - 49	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
50 - 50	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
51 - 51	282	150	980	9	1421
PCT CLASS	19.85	10.56	68.97	0.63	100.00
PCT TOTAL	0.43	0.23	1.48	0.01	2.14

$56^\circ \rightarrow 124^\circ$   
 ← Cumulative Hours = 1,513  
 Total Hours = 7,922  
 $1,513 / 7,922 = \underline{19.0\%}$

APPENDIX 2  
 DISTRIBUTION Program Output  
 Unit 3 ESFB to Unit 3 Control Room Air Intake

P. 14  
 03703.7002  
 WM(B)-01  
*Rvd*

WIND SPEED (MPH) (TENTHS)	WIND DIRECTION (DEGREES)				TOTAL
	0- 55	56- 124	125- 360	361- 999	
52 - 52	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
53 - 53	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
54 - 54	257	155	1001	6	1419
PCT CLASS	18.11	10.92	70.54	0.42	100.00
PCT TOTAL	0.39	0.23	1.51	0.01	2.14
55 - 55	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
56 - 56	272	153	1001	13	1439
PCT CLASS	18.90	10.63	69.56	0.90	100.00
PCT TOTAL	0.41	0.23	1.51	0.02	2.17
57 - 57	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
58 - 58	265	174	997	5	1441
PCT CLASS	18.39	12.07	69.19	0.35	100.00
PCT TOTAL	0.40	0.26	1.50	0.01	2.17
59 - 59	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
60 - 60	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
61 - 61	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
62 - 62	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
63 - 63	243	165	999	6	1413
PCT CLASS	17.20	11.68	70.70	0.42	100.00
PCT TOTAL	0.37	0.25	1.51	0.01	2.13

APPENDIX 2  
 DISTRIBUTION Program Output  
 Unit 3 ESFB to Unit 3 Control Room Air Intake

P. 15  
 03703.7002  
 WM(B)-01

*RR*

WIND SPEED (MPH) (TENTHS)	WIND DIRECTION (DEGREES)				TOTAL
	0- 55	56- 124	125- 360	361- 999	
64 - 64	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
65 - 65	251	148	1071	8	1478
PCT CLASS	16.98	10.01	72.46	0.54	100.00
PCT TOTAL	0.38	0.22	1.61	0.01	2.23
66 - 66	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
67 - 67	176	121	712	5	1014
PCT CLASS	17.36	11.93	70.22	0.49	100.00
PCT TOTAL	0.27	0.18	1.07	0.01	1.53
68 - 68	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
69 - 69	233	177	1070	10	1490
PCT CLASS	15.64	11.88	71.81	0.67	100.00
PCT TOTAL	0.35	0.27	1.61	0.02	2.25
70 - 70	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
71 - 71	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
72 - 72	0	2	0	0	2
PCT CLASS	0.0	100.00	0.0	0.0	100.00
PCT TOTAL	0.0	0.00	0.0	0.0	0.00
73 - 73	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
74 - 74	225	176	1054	10	1465
PCT CLASS	15.36	12.01	71.95	0.68	100.00
PCT TOTAL	0.34	0.27	1.59	0.02	2.21
75 - 75	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0

APPENDIX 2  
 DISTRIBUTION Program Output  
 Unit 3 ESFB to Unit 3 Control Room Air Intake

P. 16  
 03703.7002  
 WMM(B)-01  
*ALL*

WIND SPEED (MPH) (TENTHS)	WIND DIRECTION (DEGREES)				TOTAL
	0- 55	56- 124	125- 360	361- 999	
<u>76 - 76</u>	208	185	1031	8	1432
PCT CLASS	14.53	12.92	72.00	0.56	100.00
PCT TOTAL	0.31	0.28	1.55	0.01	2.16
77 - 77	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
78 - 78	225	162	955	8	1350
PCT CLASS	16.67	12.00	70.74	0.59	100.00
PCT TOTAL	0.34	0.24	1.44	0.01	2.04
79 - 79	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
80 - 80	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
81 - 81	180	158	991	8	1337
PCT CLASS	13.46	11.82	74.12	0.60	100.00
PCT TOTAL	0.27	0.24	1.49	0.01	2.02
82 - 82	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
83 - 83	0	2	2	0	4
PCT CLASS	0.0	50.00	50.00	0.0	100.00
PCT TOTAL	0.0	0.00	0.00	0.0	0.01
84 - 84	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
85 - 85	187	182	969	6	1344
PCT CLASS	13.91	13.54	72.10	0.45	100.00
PCT TOTAL	0.28	0.27	1.46	0.01	2.03
86 - 86	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
87 - 87	182	171	1013	4	1370
PCT CLASS	13.28	12.48	73.94	0.29	100.00
PCT TOTAL	0.27	0.26	1.53	0.01	2.07

56° → 124°  
 ← Cumulative Hours = 3,260  
 Total Hours = 7,922  
 3,260 / 7,922 = 41.2%

APPENDIX 2  
 DISTRIBUTION Program Output  
 Unit 3 ESFB to Unit 3 Control Room Air Intake

P. 17  
 03703.7002  
 WM(B)-01  
*Revo*

WIND SPEED (MPH) (TENTHS)	WIND DIRECTION (DEGREES)				TOTAL
	0- 55	56- 124	125- 360	361- 999	
88 - 88	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
89 - 89	128	115	678	5	926
PCT CLASS	13.82	12.42	73.22	0.54	100.00
PCT TOTAL	0.19	0.17	1.02	0.01	1.40
90 - 90	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
91 - 91	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
92 - 92	169	132	929	5	1235
PCT CLASS	13.68	10.69	75.22	0.40	100.00
PCT TOTAL	0.25	0.20	1.40	0.01	1.86
93 - 93	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
94 - 94	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
95 - 95	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
96 - 96	176	164	934	6	1280
PCT CLASS	13.75	12.81	72.97	0.47	100.00
PCT TOTAL	0.27	0.25	1.41	0.01	1.93
97 - 97	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
98 - 98	165	154	993	7	1319
PCT CLASS	12.51	11.68	75.28	0.53	100.00
PCT TOTAL	0.25	0.23	1.50	0.01	1.99
99 - 99	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0

APPENDIX 2  
DISTRIBUTION Program Output  
Unit 3 ESFB to Unit 3 Control Room Air Intake

P. 18  
03703.7002  
WM(B)-01

*Rev 0*



WIND SPEED (MPH) (TENTHS)	WIND DIRECTION (DEGREES)				TOTAL
	0- 55	56- 124	125- 360	361- 999	
100 - 100	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
101 - 110	558	536	3574	14	4682
PCT CLASS	11.92	11.45	76.33	0.30	100.00
PCT TOTAL	0.84	0.81	5.39	0.02	7.06
111 - 120	312	348	2205	8	2873
PCT CLASS	10.86	12.11	76.75	0.28	100.00
PCT TOTAL	0.47	0.52	3.32	0.01	4.33
121 - 130	326	465	2921	20	3732
PCT CLASS	8.74	12.46	78.27	0.54	100.00
PCT TOTAL	0.49	0.70	4.40	0.03	5.63
131 - 1000	761	2073	13175	139	16148
PCT CLASS	4.71	12.84	81.59	0.86	100.00
PCT TOTAL	1.15	3.13	19.86	0.21	24.34
TOTAL	9051	7922	48114	1245	66332
PCT CLASS	13.64	11.94	72.54	1.88	100.00
PCT TOTAL	13.64	11.94	72.54	1.88	100.00

← Total Valid Observations (All Sectors)

Total Observations (56° → 124°)

APPENDIX 2  
DISTRIBUTION Program Output  
Unit 3 ESFB to Unit 3 Control Room Air Intake

P. 19  
03703.7002  
WM(B)-01

*Net 0*

CHECKED = 70128

USED = 66332

APPENDIX 2  
DISTRIBUTION Program Output  
Unit 3 ESFB to Unit 3 Control Room Air Intake

P. 20  
03703.7002  
WM(B)-01

*RWD*

Attachment 3

Millstone Nuclear Power Station, Unit No. 3

Calculation WM(B)-02  
Normalized X/Q at the Unit 3 Control Room for  
Releases From the Unit 1 Stack



CALCULATION TITLE PAGE

Total Number of Pages: 30

Normalized X/Q at the Unit 3 Control Room For Releases From the Unit 1 Stack

TITLE		
N/A	0	RBVS/SLCRS
CALCULATION #	REVISION No.	SYSTEM NAME
WM(B)-02	CB	3314I
VENDOR CALCULATION NUMBER	Structure	System Number

NUCLEAR INDICATOR: <input checked="" type="checkbox"/> CATI <input type="checkbox"/> RWQA <input type="checkbox"/> SBOQA <input type="checkbox"/> FPQA <input type="checkbox"/> ATWSQA <input type="checkbox"/> NON-QA	Calc. Supports DCR/MMOD? <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	Calc. Supports Ind. Analysis? <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	N/A
			Component
↓		↓	
M3-98-029		N/A	
DCR/MMOD No.		Reference	

INCORPORATES:

CCN NO:                      AGAINST REV.

N/A                              N/A

Executive Summary

THIS IS FORMAL APPROVAL OF A QA APPROVED VENDOR CALCULATION. NO (NU) IR IS REQUIRED.

REC'D. 6-8-98  
 ON HOLD  
 CDS 6/17/98  
 CDS QC 6/23/98  
 NRP ✓ TJ

Veri. _____	Date 6/13/00
Initial <i>gw</i>	

<b>Approvals</b> (Print & Sign Name)		
Preparer: James L. Wheeler <i>JL Wheeler</i>		Date: 5/27/98
Interdiscipline Reviewer: N/A	Discipline:	Date:
Interdiscipline Reviewer: N/A	Discipline:	Date:
Independent Reviewer: N/A		Date:
Supervisor: William Eakin <i>W Eakin</i>		Date: 5/27/98
<b>Installation Verification</b>		
<input checked="" type="checkbox"/> Calculation accurately reflects plant configuration, OR		
<input type="checkbox"/> N/A does not affect plant configuration)		
Preparer/Designer Engineer: JAMES L. WHEELER <i>JL Wheeler</i>		Date: 5/27/98

C #



PassPort DATABASE INPUTs

CH #4

Page 1B of 30

Calculation Number: N/A (prefix) N/A (sequence no.) N/A (suffix) Revision: N/A

Vendor Calculation Number/Other: 03703.7002-WM(B)-02 Revision: 0

CCN # N/A QA [X] Yes [ ] No Calc Voided: [ ] Yes [X] No

Superseded By: N/A Supersedes Calc: N/A

Discipline (Up to 10) N,A,Z

Table with 5 columns: Unit, Project Reference (EWA), Component Id, Computer Code, Rev. No./ Level No. Row 1: 3, N/A, N/A, EN-113, 6/8

Table with 5 columns: Structure, System, Component, Reference Calculation, Rev No. Header: PMMS CODES\*. Row 1: CB, RBV, N/A, N/A, N/A

\*The codes required must be alpha codes designed for structure, system and component.

Table with 3 columns: Reference Drawing, Sheet, Rev. No. Row 1: 25212-10002, A, 11. Row 2: 25212-11000, A, 9

Comments:

Horizontal lines for entering comments

**Table of Contents**

Title page	1A
CTP Database	1B
Table of Contents	1C
Vendor Calculation Pages	1 thru 12
Appendix 1	15 pages
Total number of pages	30

STONE & WEBSTER ENGINEERING CORPORATION  
CALCULATION TITLE PAGE

5010.65

PAGE 1 of 12

Total Pages: 27  
w/attachments pages

CLIENT & PROJECT:  
NORTHEAST UTILITIES - MILLSTONE UNIT 3

CALCULATION TITLE:  
Normalized Concentrations (X/Q) at Unit 3 Control Room Air Intake for Gaseous Releases from the Top of the Unit 1 Stack Under Fumigation and Non-Fumigation Conditions

QA CATEGORY (✓)

1

CALCULATION IDENTIFICATION NUMBER

OPTIONAL  
WORK PACKAGE NO.

JOB ORDER NO.	DISCIPLINE	CURRENT CALC NO	OPTIONAL TASK CODE
037037002	WM(B)	02 REV 0	

APPROVALS - SIGNATURE & DATE

REVISION NO. OR  
NEW CALCULATION NO.

SUPERSEDES CALCULATION  
NO. OR REVISION NO.

CONFIRMATION  
REQUIRED (✓)

PREPARES(S) / DATE(S)	REVIEWER(S) / DATES(S)	INDEPENDENT REVIEWER(S) / DATE(S)	REVISION NO. OR NEW CALCULATION NO.	SUPERSEDES CALCULATION NO. OR REVISION NO.	CONFIRMATION REQUIRED (✓)	
					YES	NO
S. A. Vigeant <i>Stephen A. Vigeant</i> 5/21/98	C. A. Mazzola <i>Carl A. Mazzola</i> 5/21/98	C. A. Mazzola <i>Carl A. Mazzola</i> 5/21/98	0			✓

DISTRIBUTION

GROUP	NAME & LOCATION	COPY SENT (✓)	GROUP	NAME & LOCATION	COPY SENT (✓)
Record Mgmt. File (or Fire File if none)					
<del>Lead</del> Environmental Specialist	<del>Carl A. Mazzola</del> Atlanta				
	Steven A. Vigeant Boston	CC			
Project Files	<del>Charlie Cronan</del> Boston				
NU RAD PROT	RJ Schmidt New Britain	CC			
NUNDS	MP3 Site	ORIGINAL			
SWEC Rad Prot	S Ferguson (Boston)	CC			

STONE & WEBSTER ENGINEERING CORPORATION  
CALCULATION SHEET

5010.65

CALCULATION IDENTIFICATION NUMBER

JOB ORDER NO. 037037002	DISCIPLINE WM(B)	CALCULATION NO. 02 <i>RW-0</i>	OPTIONAL TASK CODE	PAGE 2 OF 12
----------------------------	---------------------	-----------------------------------	--------------------	-----------------

CHANGE HISTORY PAGE

REVISION NO.	DESCRIPTION OF CHANGES	PAGES REVISED	PAGES ADDED	PAGES REPLACED
0	0	N/A		



STONE & WEBSTER ENGINEERING CORPORATION  
CALCULATION SHEET

5010.65

CALCULATION IDENTIFICATION NUMBER

JOB ORDER NO.	DISCIPLINE	CALCULATION NO.	OPTIONAL TASK CODE	PAGE
037037002	WM(B)	02 <i>RW0</i>		3 OF 12

TABLE OF CONTENTS

COVER PAGE..... 1

CHANGE HISTORY PAGE..... 2

TABLE OF CONTENTS..... 3

OBJECTIVE ..... 4

METHODOLOGY ..... 4

ASSUMPTIONS ..... 4

DATA..... 4

EQUATION..... 5

CALCULATION..... 5

CONCLUSIONS ..... 5

REFERENCES ..... 6

ATTACHMENTS..... 6

APPENDICES..... 6

STONE & WEBSTER ENGINEERING CORPORATION  
CALCULATION SHEET

5010.65

CALCULATION IDENTIFICATION NUMBER

JOB ORDER NO.	DISCIPLINE	CALCULATION NO.	OPTIONAL TASK CODE	PAGE
037037002	WM(B)	02 <i>Rev 0</i>		4 OF 12

**OBJECTIVE**

To calculate the normalized atmospheric dispersion (X/Q) values at the Unit 3 Control Room air intake for a gaseous release from the top of the Unit 1 stack under fumigation conditions for the 0 - 4 hour period and under non-fumigation conditions for the remaining averaging periods of 4-8 hours, 8-24 hours, 1-4 days, and 4-30 days.

**METHODOLOGY**

The applicable methodology is identified in Regulatory Guide 1.145 (Ref. 1). The fumigation X/Q is used for the first 4 hours of the accident. The non-fumigation X/Qs for the longer averaging times are derived from the log-log interpolation between the 2-hour and annual average value obtained from Ref. 3 using 1974 to 1981 on-site meteorological data (Ref. 4). The highest annual average X/Q from among the affected downwind sectors is taken Ref. 3. The affected downwind sectors (W, WNW, NW, and NNW) are determined using the "s/d" method from Ref. 9 (see Data Section).

**ASSUMPTIONS**

1. It is conservatively assumed that the sea breeze fumigation condition is occurring simultaneously with the onset of an accident condition with the wind direction moving the plume centerline towards the Unit 3 CR intake located on the control building.
2. It is conservatively assumed that the NRC recommended wind speed of 2.0 meters per second in Regulatory Guide 1.145 is representative of the fumigation layer. Fumigation most frequently occurs at higher wind speeds (Ref. 5). The top of the fumigation layer is located at the centerline of the elevated plume, while the bottom of the fumigation layer is conservatively located at the shortest roof height in the control building complex (Ref. 8) rather than ground level. The stack effluent is uniformly mixed in the vertical fumigation layer which normally extends from stack top to ground level.
3. It is conservatively assumed that the effective stack height is the same as the actual stack height. Therefore, no credit is taken for plume rise that can occur due to either thermal buoyancy, where the plume is warmer than the ambient air it is being released into, or mechanical rise due to its efflux velocity.
4. The sea breeze fumigation condition is assumed to persist for the 0-4 hour period which is consistent with the NRC recommendation in Ref. 1 for off-site calculations. Although sea breeze fumigation can persist for longer periods of time, the point of fumigation moves with time due to sea breeze inland penetration and backing due to the Coriolis effect forming a helical track down the coastline (Ref. 5).
5. It is assumed that the Unit 3 control room air intake X/Q values are representative of the X/Q values for the center of the Unit 3 control room given that the distances and directions from the release to these receptors are very similar.

**DATA**

Top of stack = plant elevation 389.0 ft MSL (Ref. 6)  
 Bottom of stack = plant elevation 14.0 ft MSL (Ref. 6)  
 Height of lowest roof top in control building complex = plant elevation 64.5 ft MSL (Ref. 8)  
 $h_e$  = Height from stack top to bottom of fumigation layer = 389.0 ft - 64.5 ft = 324.5 ft = 98.9 m  
 $u_{he}$  = Wind speed representative of the fumigation layer = 2.0 m/sec (Ref. 1)  
 Distance (s) from stack to Unit 3 control room air intake = 1165 ft = 355 m (Ref. 7)  
 Direction from stack to Unit 3 control room air intake = 130° (Ref. 7)  
 Diameter (d) of stack top = 7.0 ft = 2.1 m (Ref. 6)  
 $s/d = 355 \text{ m} / 2.1 \text{ m} = 169.1$  or 3 sectors ( $3 \times 22.5^\circ = 68^\circ$  or  $130^\circ - 34^\circ = 96^\circ$  to  $130^\circ + 34^\circ = 164^\circ$ ) (Ref. 9)  
 Wind directions 96° to 164° include the 22.5° downwind sectors of W, WNW, NW, and NNW  
 $\sigma_y @ 355 \text{ m}$  for F-stability class = 14.51 m (Ref. 2)

STONE & WEBSTER ENGINEERING CORPORATION  
CALCULATION SHEET

5010.65

CALCULATION IDENTIFICATION NUMBER

JOB ORDER NO. 037037002	DISCIPLINE WM(B)	CALCULATION NO. 02 <i>hwo</i>	OPTIONAL TASK CODE	PAGE 5 OF 12
----------------------------	---------------------	----------------------------------	--------------------	-----------------

**EQUATION**

$$X/Q = [(2\pi)^{1/2} (u_{ho}) \sigma_y (h_e)]^{-1} \quad (\text{Ref. 1})$$

**CALCULATION**

**Unit 1 Stack to Unit 3 Control Room Air Intake**

$u_{ho} = 2.0$  m/sec (Ref. 1)  
 $\sigma_y @ 355$  m for F-stability class = 14.51 m (Ref. 2)  
 $h_e = 98.9$  m

**Short-Term X/Q Value for Unit 3 Intake (0 - 4 Hours)**

$$X/Q = [(2.5066) (2 \text{ m/sec})(14.51\text{m})(98.9 \text{ m})]^{-1}$$

**X/Q = 1.39 E-4 sec/m<sup>3</sup>**

**CONCLUSIONS**

The fumigation X/Q applicable to the Unit 3 intake for the 0-4 hour period of the accident is 1.39 E-4 sec/m<sup>3</sup>. The non-fumigation X/Qs for the longer averaging times are derived from the log-log interpolation between the 2-hour and annual average value obtained from Ref. 3 using 1974 to 1981 on-site meteorological data (Ref. 4). This period of record (8 years) is temporally representative of the meteorological conditions encountered at the site. The highest annual average X/Q from among the affected downwind sectors is taken Ref. 3 (see Appendix 1, p. 15). The affected downwind sectors (W, WNW, NW, and NNW) are determined using the "s/d" method from Ref. 9 (see Data Section). The X/Q values are as follows:

Period (Hours after Accident)	Logarithmic Interpolation Point (Hr)	X/Q (sec/m <sup>3</sup> )
4-8	8	3.23 E- 5
8-24	16	1.56 E- 5
24-96	72	3.20 E- 6
96-720	624	3.30 E- 7
Annual	8760	2.05 E- 8

The intermediate period X/Q values are calculated according to the expression:

$$X/Q_t = \exp \{ \ln(X/Q_2) + [ \{ (\ln(X/Q_a) - \ln(X/Q_2)) / [\ln(8760) - \ln(2)] \} ] [\ln(t) - \ln(2)] \}$$

where t is the time period in hours, X/Q<sub>t</sub> is the X/Q value for time t, X/Q<sub>2</sub> is the 2-hour X/Q value, X/Q<sub>a</sub> is the annual average X/Q value, and 8760 is the number of hours in a year.

The Unit 3 control room air intake X/Q values are representative of the X/Q values for the center of the Unit 3 control room given that the distances and directions from the release to these receptors are very similar. The Unit 3 control room air intake X/Q values are also representative of those for the Technical Support Center which is located adjacent to the control room.

STONE & WEBSTER ENGINEERING CORPORATION  
CALCULATION SHEET

5010.65

CALCULATION IDENTIFICATION NUMBER

JOB ORDER NO.	DISCIPLINE	CALCULATION NO.	OPTIONAL TASK CODE	PAGE
037037002	WM(B)	02 <i>W-0</i>		6 OF 12

**REFERENCES**

1. US Nuclear Regulatory Commission, Office of Standards Development, Regulatory Guide 1.145, "Atmospheric Dispersion Models for Potential Accident Consequence Assessments at Nuclear Power Plants", August, 1979.
2. U. S. Nuclear Regulatory Commission, Subroutine "POLYN", Horizontal and Vertical Dispersion Coefficients as a Function of Downwind Distance (see Attachment 1 for F-stability values), 1974.
3. Stone & Webster computer program EN-113, Version 6, Level 8. See output in Appendix 1.
4. On-site meteorological data for the period 1974 - 1981 provided by Northeast Utilities. The data are hourly values represented by one 15-minute average value per hour (see Attachment 2).
5. Lyons, W. A., "Turbulent Diffusion and Pollutant Transport in Shoreline Environments" from Lectures on Air Pollution and Environmental Impact Analyses, American Meteorological Society, Boston, Massachusetts, September 29 to October 3, 1975, pp. 182-194.
6. Telecopier transmittal from Bill Jones, Northeast Utilities to Joe Creamer, Stone & Webster dated 4/23/98 providing Millstone Unit 1 stack dimensions (see Attachment 3).
7. Stone & Webster Drawing No. 12179-EY-16A-7, Rev. 7, 8/18/81, "Station Plan" (see Attachment 4)
8. Stone & Webster Drawing No. 12179-EM-1A-11. (see Attachment 5)
9. Murphy, K.G. and K.M. Campe., "Nuclear Power Plant Control Room Ventilation System Design for Meeting General Design Criterion 19". Presented at the 13<sup>th</sup> AEC Air Cleaning Conference, August, 1974.

**ATTACHMENTS**

1. "POLYN" Horizontal and Vertical Dispersion Coefficient Values as a Function of Downwind Distance (F-stability).
2. Letter from Northeast Utilities transmitting onsite meteorological data for the period 1974 - 1981.
3. Telecopier transmittal from Bill Jones, Northeast Utilities to Joe Creamer, Stone & Webster dated 4/23/98 providing Millstone Unit 1 stack dimensions
4. Stone & Webster Drawing No. 12179-EY-16A-7, Rev. 7, 8/18/81, "Station Plan"
5. Stone & Webster Drawing No. 12179-EM-1A-11, "Plot Plan".

**APPENDICES (15 pages)**

1. EN-113 computer output, Job No. 04820 dated 4/29/98.

10 MAR 1981

DISPERSION COEFFICIENTS AS A FUNCTION OF DOWNWIND DISTANCE  
PASQUILL STABILITY CLASS (F)

DOWNWIND DISTANCE (METERS)	STONE & WEBSTER		POLYN (LONG)		POLYN (DESERT)		POLYN (X00000)	
	SIGMA Y	SIGMA Z	SIGMA Y	SIGMA Z	SIGMA Y	SIGMA Z	SIGMA Y	SIGMA Z
10.	0.4739	0.1971	0.4014	0.1395	2.4230	1.6073	0.5776	0.3454
20.	0.8969	0.4437	0.8020	0.3243	4.5718	1.9901	1.0802	0.6072
30.	1.3054	0.6928	1.2022	0.5313	6.6281	2.2694	1.5578	0.8446
40.	1.7048	0.9383	1.6022	0.7540	8.6265	2.4839	2.0200	1.0675
50.	2.0977	1.1786	2.0021	0.9893	10.5829	2.6642	2.4710	1.2801
60.	2.4855	1.4134	2.4019	1.2351	12.5064	2.8212	2.9133	1.4849
70.	2.8691	1.6427	2.8015	1.4900	14.4031	2.9611	3.3485	1.6834
80.	3.2490	1.8667	3.2011	1.7530	16.2771	3.0879	3.7776	1.8767
90.	3.6259	2.0857	3.6006	2.0232	18.1315	3.2043	4.2016	2.0655
100.	4.0000	2.3000	4.0000	2.3000	19.9686	3.3120	4.6210	2.2472
110.	4.3716	2.5098	4.3994	2.5829	21.7903	3.4126	5.0364	2.4369
120.	4.7409	2.7153	4.7987	2.7365	23.5981	3.5072	5.4481	2.6223
130.	5.1082	2.9169	5.1979	2.8894	25.3933	3.5964	5.8565	2.8037
140.	5.4736	3.1146	5.5971	3.0416	27.1769	3.6811	6.2619	2.9815
150.	5.8372	3.3088	5.9963	3.1930	28.9499	3.7617	6.6645	3.1560
160.	6.1991	3.4995	6.3954	3.3437	30.7129	3.8387	7.0644	3.3275
170.	6.5595	3.6870	6.7945	3.4937	32.4667	3.9125	7.4620	3.4962
180.	6.9184	3.8714	7.1936	3.6430	34.2119	3.9834	7.8573	3.6624
190.	7.2759	4.0528	7.5926	3.7916	35.9489	4.0516	8.2505	3.8261
200.	7.6321	4.2314	7.9916	3.9395	37.6782	4.1174	8.6417	3.9877
210.	7.9871	4.4073	8.3905	4.0867	39.4003	4.1809	9.0309	4.1472
220.	8.3409	4.5806	8.7895	4.2332	41.1156	4.2424	9.4184	4.3047
230.	8.6935	4.7514	9.1884	4.3790	42.8242	4.3021	9.8042	4.4603
240.	9.0451	4.9198	9.5872	4.5241	44.5267	4.3599	10.1894	4.6143
250.	9.3956	5.0860	9.9861	4.6685	46.2232	4.4162	10.5710	4.7665
260.	9.7451	5.2499	10.3425	4.8123	47.9140	4.4709	10.9521	4.9172
270.	10.0936	5.4117	10.6986	4.9553	49.5994	4.5242	11.3319	5.0664
280.	10.4412	5.5714	11.0542	5.0977	51.2795	4.5762	11.7102	5.2141
290.	10.7878	5.7292	11.4095	5.2395	52.9546	4.6269	12.0873	5.3605
300.	11.1337	5.8850	11.7643	5.3805	54.6248	4.6764	12.4631	5.5056
310.	11.4786	6.0390	12.1188	5.5209	56.2904	4.7248	12.8377	5.6494
320.	11.8228	6.1912	12.4729	5.6607	57.9515	4.7721	13.2111	5.7920
330.	12.1661	6.3416	12.8266	5.7997	59.6082	4.8185	13.5833	5.9335
340.	12.5087	6.4903	13.1799	5.9382	61.2607	4.8638	13.9546	6.0738
350.	12.8505	6.6374	13.5328	6.0759	62.9091	4.9083	14.3247	6.2131
360.	13.1916	6.7830	13.8854	6.2131	64.5535	4.9519	14.6938	6.3513
370.	13.5320	6.9269	14.2375	6.3496	66.1942	4.9947	15.0619	6.4886
380.	13.8718	7.0694	14.5893	6.4854	67.8311	5.0367	15.4291	6.6249
390.	14.2107	7.2104	14.9407	6.6206	69.4644	5.0780	15.7953	6.7603
400.	14.5491	7.3500	15.2917	6.7552	71.0942	5.1185	16.1606	6.8947
410.	14.8868	7.4882	15.6424	6.8892	72.7205	5.1583	16.5250	7.0283
420.	15.2239	7.6251	15.9927	7.0225	74.3436	5.1975	16.8886	7.1611
430.	15.5604	7.7607	16.3426	7.1552	75.9634	5.2360	17.2513	7.2930
440.	15.8963	7.8949	16.6921	7.2872	77.5800	5.2740	17.6132	7.4242
450.	16.2316	8.0280	17.0413	7.4187	79.1935	5.3113	17.9743	7.5545
460.	16.5663	8.1598	17.3901	7.5496	80.8041	5.3481	18.3347	7.6841
470.	16.9005	8.2904	17.7385	7.6798	82.4117	5.3843	18.6943	7.8130
480.	17.2340	8.4199	18.0865	7.8094	84.0164	5.4201	19.0531	7.9412
490.	17.5670	8.5482	18.4342	7.9384	85.6184	5.4553	19.4112	8.0687

"POLYN" Dispersion Coefficients

BW-0

WM(B)-02

03703.7002

P 7



**Northeast  
Utilities System**

107 Selden Street, Berlin, CT 06037

Northeast Utilities Service Company  
P.O. Box 270  
Hartford, CT 06141-0270  
(860) 665-5000

P. 8  
03703,7012  
WM(B)-02  
NW-0

April 28, 1998

Mr. Joseph Creamer  
Stone and Webster  
245 Summer Street, 7th Floor  
Boston, MA 02210

Dear Mr. Creamer:

**Millstone Nuclear Power Station  
Meteorological Data**

Accompanying this memo are four computer diskettes containing the meteorological data from 1974 through 1981, for your use in the Millstone Unit 3 X/Q calculations. Each diskette contains two years of data, as noted on the labels. The year of data is represented in each dataset name.

Each line of the datasets represents one hour of data. There is a nine character "time stamp" on each line; columns 1 and 2 are the year, columns 3 through 5 are the Julian day, and columns 6 through 9 are the time (military time, always on Eastern Standard Time). Columns 10 through 54 are, in order, the AT033, WS033, WD033, WS142, WD142, DT142, WS374, WD374, & DT374 (AT = air temperature, WS = wind speed, WD = wind direction, DT = delta-temperature, and numbers are instrument height). These are all in "F5.1" format. Missing data are represented by "999.0."

The data generated by our meteorological monitoring system consist of four fifteen-minute averages per hour. However, the attached datasets only contain one fifteen-minute average per hour. Historically, most of our analyses involving meteorological data, including Category 1 X/Q calculations, have been based on one fifteen-minute average representing an entire hour of data. It was found that this methodology introduced very small errors into the analyses results, compared to calculating an average of the available fifteen-minute averages for each hour.

If you have any questions, please call me, at (860) 665-3183.

Very truly yours,


H. L. Chamberlain, Jr.  
Environmental Services

Enclosures



CO. 44-128 888-1

R. 10  
03703.701;  
E LADDER  
WH(B)  
02  
Rev 0




3 1/8" PA 78.718

AS BUILT

PER SKIM


AS BUILT

EMASCC





P.11  
03703  
WMCB  
RWD



12179-EY-16A-7

APPROXIMATE LOCATION  
ROCKFILL & SLOPE  
PROTECTION MATERIALS

NIANTIC BAY



Stanley S. Jacob  
REGISTERED PROFESSIONAL ENGINEER  
STATE OF CONNECTICUT

QA CAT. III

NO.	DESCRIPTION	BY	DATE



NO.	DESCRIPTION	DATE	BY	CHKD.	APP.
7	SEE RCD OF DWG CHNG	12/17/77			
6	RE-DRAWN-SUPERSEDES	12/17/77			
5	DWG EY-16AVD-5	12/17/77			
4	DWG VOIDED & RETURNED	12/17/77			
3	DWG VOIDED EY-16AVD-5	12/17/77			
2	GENERAL REVISIONS	12/17/77			

THE MILLSTONE POINT COMPANY  
SUBSIDIARY OF  
NORTHEAST UTILITIES  
MILLSTONE NUCLEAR POWER STATION-UNIT NO. 3  
**STATION PLAN**  
SCALE: 1" = 100'  
DATE: 12/17/77  
25212-11000  
STONE & BEAUFORT ENGINEERING CORPORATION  
BOSTON, MASS.

THIS INFORMATION ON THIS DRAWING MAY NOT BE  
COPIED OR USED FOR OTHER THAN THE CONSTRUCTION  
OR MAINTENANCE OF PARTS OF THE PLANT FACILITY  
DESCRIBED IN THE TITLE BLOCK.

1707 TKB

S & W DWG. NO. 12179-EY-16A-7



NOTE:  
SCALE: 1"=40'-0" AND AS NOTED.

REFERENCE DWG:  
CONSTRUCTION AREAS-KEY PLAN EM-18 (10003)  
ARRANGEMENT-TANKAGE WARD AREA EM-18A (21730)  
FOR CONT. OF REF. SEE EM-18 (10003)

LEGEND:  
--- SEISMIC CATEGORY I STRUCTURES AND COMPONENTS.  
--- INDICATES EQUIPMENT WHICH IS PART OF NUCLEAR SAFETY FEATURE SYSTEM

RELEASED FROM  
GFR CONTROL  
NUCLEAR SAFETY RELATED  
QA CAT I II & III

NO.	DATE	DESCRIPTION	BY	CHKD
1	7-11-72	ISSUED FOR CONSTRUCTION	...	...
2	7-11-72	REVISIONS	...	...
3	7-11-72	REVISIONS	...	...
4	7-11-72	REVISIONS	...	...
5	7-11-72	REVISIONS	...	...
6	7-11-72	REVISIONS	...	...
7	7-11-72	REVISIONS	...	...
8	7-11-72	REVISIONS	...	...
9	7-11-72	REVISIONS	...	...
10	7-11-72	REVISIONS	...	...

THE MILLSTONE POINT COMPANY  
SUBSIDIARY OF  
NORTHEAST UTILITIES  
MILLSTONE NUCLEAR POWER STATION-UNIT NO. 2  
PLOT PLAN

DATE: 7-11-72  
DRAWN: ...  
CHECKED: ...  
SCALE: 1"=40'-0"  
SHEET NO. 25212-10002  
SHEET TOTAL: 2

86 W. DWG. NO. 12179-EM-1A-11  
DRAWN: ...  
CHKD: ...

FIGURE 1.2-2 MAY 1992

P.12  
03703700  
WM(B)-02  
Rev 0

JES2 JOB LOG -- SYSTEM C168 -- NODE JES2B0S

10.02.03 JOB04820 IRR010I USERID VIG7988 IS ASSIGNED TO THIS JOB.  
10.02.37 JOB04820 ICH70001I VIG7988 LAST ACCESS AT 10:01:36 ON WEDNESDAY, APRIL 29, 1998  
10.02.37 JOB04820 \$HASP373 CQ68       STARTED - INIT   10 - CLASS A - SYS C168  
10.02.47 JOB04820 IEC137I TRACK OVERFLOW RESET FOR FT11F001  
10.03.06 JOB04820 IEC137I TRACK OVERFLOW RESET FOR FT10F001  
10.03.10 JOB04820 IEC137I TRACK OVERFLOW RESET FOR FT16F001  
10.03.10 JOB04820 IEC137I TRACK OVERFLOW RESET FOR FT31F001  
10.05.13 JOB04820 +IH0002I STOP           1  
10.05.14 JOB04820 \$HASP395 CQ68       ENDED

----- JES2 JOB STATISTICS -----

29 APR 1998 JOB EXECUTION DATE

59 CARDS READ

1,971 SYSOUT PRINT RECORDS

0 SYSOUT PUNCH RECORDS

148 SYSOUT SPOOL KBYTES

2.62 MINUTES EXECUTION TIME

APPENDIX 1  
EN-113 Program Output  
Unit 1 Stack to Unit 3 Control Room Air Intake

P. 1  
03703.7002  
WM(B)-02  
*MR O*

29-APR-98JOB04820

```
1 //CQ68 JOB (0031,3), 'VIGEANT-SA',
  // MSGLEVEL=2,MSGCLASS=A
  //* RJETRAN.VIG7988.DATA(CQ68EL)
  /*JOBPARM ROOM=3
2 //METRDISK EXEC METRPROC
9 //DISK DD DISP=SHR,DSN=ENVIRONM.METDATA.MILSTONE.YR7481
12 //SYSIN DD * GENERATED STATEMENT
13 //CHIQ68 EXEC PGM=CHIQ68,REGION=700K,TIME=20
14 //STEPLIB DD DSN=ENVIRONM.HXLOADLB,DISP=SHR
15 //GO.FT06F001 DD DCB=PRINT1,SYSOUT=*
16 //GO.FT08F001 DD DUMMY
17 //GO.FT09F001 DD DCB=PRINT1,SYSOUT=*
18 //GO.FT10F001 DD UNIT=DISK,SPACE=(19982,(100,10)),DISP=(,PASS),
  // DCB=(RECFM=VBST,LRECL=X,BLKSIZE=19982)
19 //GO.FT11F001 DD UNIT=DISK,SPACE=(19982,(100,10)),DISP=(,PASS),
  // DCB=(RECFM=VBST,LRECL=X,BLKSIZE=19982)
20 //GO.FT12F001 DD UNIT=DISK,DISP=(OLD,DELETE),DSN=&SAMPLE
21 //GO.FT16F001 DD UNIT=DISK,SPACE=(32760,(70,10)),DISP=(,PASS),
  // DCB=(RECFM=VST,LRECL=X,BLKSIZE=32760,BUFNO=1)
22 //GO.FT31F001 DD UNIT=DISK,SPACE=(32760,(70,10)),DISP=(,PASS),
  // DCB=(RECFM=VST,LRECL=X,BLKSIZE=32760,BUFNO=1)
23 //GO.FT05F001 DD *
24 //IMBLIST EXEC PGM=IMBLIST
25 //SYSPRINT DD SYSOUT=*
26 //SYSLIB DD DSN=ENVIRONM.HXLOADLB,DISP=SHR
27 //SYSIN DD * GENERATED STATEMENT
```

JOB04820

APPENDIX 1  
EN-113 Program Output  
Unit 1 Stack to Unit 3 Control Room Air Intake

P. 2  
03703.7002  
WM(B)-02  
*WUC*

STMT NO. MESSAGE  
 2 IEFC001I PROCEDURE METRPROC WAS EXPANDED USING SYSTEM LIBRARY SYS1.USER.PROCLIB  
 ICH70001I VIG7988 LAST ACCESS AT 10:01:36 ON WEDNESDAY, APRIL 29, 1998  
 IEF236I ALLOC. FOR CQ68 METRPROC METRDISK  
 IGD103I SMS ALLOCATED TO DDNAME STEPLIB  
 IEF237I JES2 ALLOCATED TO FT06F001  
 IEF237I JES2 ALLOCATED TO SYSPRINT  
 IGD103I SMS ALLOCATED TO DDNAME SYS010  
 IGD101I SMS ALLOCATED TO DDNAME (SYS011 )  
 DSN (SYS98119.T100237.RA000.CQ68.SAMPLE.H01 )  
 STORCLAS (TEMP) MGMTCLAS ( ) DATACLAS ( )  
 VOL SER NOS= VIO

IEF237I JES2 ALLOCATED TO FT05F001  
 IEF142I CQ68 METRPROC METRDISK - STEP WAS EXECUTED - COND CODE 0000  
 IGD104I ENVIRONM.METODOGY RETAINED, DDNAME=STEPLIB  
 IEF285I VIG7988.CQ68.JOB04820.D0000104.? SYSOUT  
 IEF285I VIG7988.CQ68.JOB04820.D0000105.? SYSOUT  
 IGD104I ENVIRONM.METDATA.MILSTONE.YR7481 RETAINED, DDNAME=SYS010  
 IGD106I SYS98119.T100237.RA000.CQ68.SAMPLE.H01 PASSED, DDNAME=SYS011  
 IEF285I VIG7988.CQ68.JOB04820.D0000101.? SYSIN

.....  
 .JOB - CQ68 , SUBMITTER - VIGEANT-SA , FLOOR - 3 , READER TIME, DATE - 10.02.02, 04/29/98 V09  
 .STEP NUMBER - 1, STEP NAME - METRPROC, PROGRAM NAME - METHR01 , RAN FROM 10.02.37 TO 10.02.44  
 .ENDING CONDITION - RETURN CODE 0, REGION USED - 380K, PERFORMANCE GROUP - 20, SHAPS - 0  
 .PAGEINS - 0, PAGEOUTS - 0, VIO PAGEINS - 0, VIO PAGEOUTS - 0  
 .CPU TIME - .60 VECTOR TIME - .00 SECS, EXCPS - ( 354 NON-VIO, 1,754 VIO), CPU UNITS - 2.50 SECS  
 .SYSIN RECORDS - 3, OPENS - ( 0 TAPE, 0 TEMP, 0 PERM), COST = \$4.17  
 .EXCPS/DDNAME - 9/STEPLIB 345/SYS010 1,754/SYS011  
 .....

IEF373I STEP/METRPROC/START 1998119.1002  
 IEF374I STEP/METRPROC/STOP 1998119.1002 CPU OMIN 00.56SEC SRB OMIN 00.02SEC VIRT 88K SYS 292K EXT 4K SYS 10120K  
 IEF236I ALLOC. FOR CQ68 CHI068  
 IGD103I SMS ALLOCATED TO DDNAME STEPLIB  
 IEF237I JES2 ALLOCATED TO FT06F001  
 IEF237I DMY ALLOCATED TO FT08F001  
 IEF237I JES2 ALLOCATED TO FT09F001  
 IGD101I SMS ALLOCATED TO DDNAME (FT10F001)  
 DSN (SYS98119.T100237.RA000.CQ68.R0110984 )  
 STORCLAS (TEMP) MGMTCLAS ( ) DATACLAS ( )  
 VOL SER NOS= VIO  
 IGD101I SMS ALLOCATED TO DDNAME (FT11F001)  
 DSN (SYS98119.T100237.RA000.CQ68.R0110985 )  
 STORCLAS (TEMP) MGMTCLAS ( ) DATACLAS ( )  
 VOL SER NOS= VIO  
 IGD103I SMS ALLOCATED TO DDNAME FT12F001  
 IGD101I SMS ALLOCATED TO DDNAME (FT16F001)  
 DSN (SYS98119.T100237.RA000.CQ68.R0110986 )  
 STORCLAS (TEMP) MGMTCLAS ( ) DATACLAS ( )  
 VOL SER NOS= VIO  
 IGD101I SMS ALLOCATED TO DDNAME (FT31F001)  
 DSN (SYS98119.T100237.RA000.CQ68.R0110987 )  
 STORCLAS (TEMP) MGMTCLAS ( ) DATACLAS ( )  
 VOL SER NOS= VIO  
 IEF237I JES2 ALLOCATED TO FT05F001  
 IEC137I TRACK OVERFLOW RESET FOR FT11F001  
 IEC137I TRACK OVERFLOW RESET FOR FT10F001  
 IEC137I TRACK OVERFLOW RESET FOR FT16F001  
 IEC137I TRACK OVERFLOW RESET FOR FT31F001  
 IEF142I CQ68 CHI068 - STEP WAS EXECUTED - COND CODE 0001

*WMI*

```

IGD104I ENVIRONM.HXLOADLB          RETAINED, DDNAME=STEPLIB
IEF285I VIG7988.CQ68.JOB04820.D0000106.? SYSOUT
IEF285I VIG7988.CQ68.JOB04820.D0000107.? SYSOUT
IGD106I SYS98119.T100237.RA000.CQ68.R0110984 PASSED, DDNAME=FT10F001
IGD106I SYS98119.T100237.RA000.CQ68.R0110985 PASSED, DDNAME=FT11F001
IGD105I SYS98119.T100237.RA000.CQ68.SAMPLE.H01 DELETED, DDNAME=FT12F001
IGD106I SYS98119.T100237.RA000.CQ68.R0110986 PASSED, DDNAME=FT16F001
IGD106I SYS98119.T100237.RA000.CQ68.R0110987 PASSED, DDNAME=FT31F001
IEF285I VIG7988.CQ68.JOB04820.D0000102.? SYSIN

```

```

.....
.JOB - CQ68 , SUBMITTER - VIGEANT-SA , FLOOR - 3 , READER TIME, DATE - 10.02.02, 04/29/98 V09
.STEP NUMBER - 2, STEP NAME - CHIQ68 , PROGRAM NAME - CHIQ68 , RAN FROM 10.02.44 TO 10.05.14
.ENDING CONDITION - RETURN CODE 1, REGION USED - 864K, PERFORMANCE GROUP - 20, SHAPS - 0
.PAGEINS - 0, PAGEOUTS - 0, VIO PAGEINS - 0, VIO PAGEOUTS - 0
.CPU TIME - 21.02 VECTOR TIME - .00 SECS, EXCPS -( 30 NON-VIO, 10,311 VIO), CPU UNITS - 30.33 SECS
.SYSIN RECORDS - 28, OPENS - ( 0 TAPE, 0 TEMP, 0 PERM), COST = $50.55
.EXCPS/DDNAME - 30/STEPLIB 228/FT10F001 228/FT11F001 1,755/FT12F001
. 4,050/FT16F001 4,050/FT31F001
.....

```

```

IEF373I STEP/CHIQ68 /START 1998119.1002
IEF374I STEP/CHIQ68 /STOP 1998119.1005 CPU OMIN 20.98SEC SRB OMIN 00.03SEC VIRT 556K SYS 308K EXT 4K SYS 10404K
IEF236I ALLOC. FOR CQ68 IMBLIST
IEF237I JES2 ALLOCATED TO SYSPRINT
IGD103I SMS ALLOCATED TO DDNAME SYSLIB
IEF237I JES2 ALLOCATED TO SYSIN
IEF142I CQ68 IMBLIST - STEP HAS EXECUTED - COND CODE 0008
IEF285I VIG7988.CQ68.JOB04820.D0000108.? SYSOUT
IGD104I ENVIRONM.HXLOADLB          RETAINED, DDNAME=SYSLIB
IEF285I VIG7988.CQ68.JOB04820.D0000103.? SYSIN

```

```

.....
.JOB - CQ68 , SUBMITTER - VIGEANT-SA , FLOOR - 3 , READER TIME, DATE - 10.02.02, 04/29/98 V09
.STEP NUMBER - 3, STEP NAME - IMBLIST , PROGRAM NAME - IMBLIST , RAN FROM 10.05.14 TO 10.05.14
.ENDING CONDITION - RETURN CODE 8, REGION USED - 428K, PERFORMANCE GROUP - 20, SHAPS - 0
.PAGEINS - 0, PAGEOUTS - 0, VIO PAGEINS - 0, VIO PAGEOUTS - 0
.CPU TIME - .03 VECTOR TIME - .00 SECS, EXCPS -( 0 NON-VIO, 0 VIO), CPU UNITS - .03 SECS
.SYSIN RECORDS - 1, OPENS - ( 0 TAPE, 0 TEMP, 0 PERM), COST = $0.05
.....

```

```

IEF373I STEP/IMBLIST /START 1998119.1005
IEF374I STEP/IMBLIST /STOP 1998119.1005 CPU OMIN 00.03SEC SRB OMIN 00.00SEC VIRT 156K SYS 272K EXT 4K SYS 10116K
IGD105I SYS98119.T100237.RA000.CQ68.R0110984 DELETED, DDNAME=FT10F001
IGD105I SYS98119.T100237.RA000.CQ68.R0110985 DELETED, DDNAME=FT11F001
IGD105I SYS98119.T100237.RA000.CQ68.R0110986 DELETED, DDNAME=FT16F001
IGD105I SYS98119.T100237.RA000.CQ68.R0110987 DELETED, DDNAME=FT31F001
IEF375I JOB/CQ68 /START 1998119.1002
IEF376I JOB/CQ68 /STOP 1998119.1005 CPU OMIN 21.57SEC SRB OMIN 00.05SEC

```

```

.....
.TOTAL CPU TIME - 21.65 SECS, TOTAL VECTOR TIME - .00 SECS, TOTAL CPU UNITS - 32.85 SECS
.TOTAL EXCPS -( 384 NON-VIO, 12,065 VIO)
.TOTAL JOB COST EXCLUDING PRINT CHARGES = $54.77 CHARGED TO AUTH = 0031 , JO/HO = 022685067
.....

```

APPENDIX 1  
 EN-113 Program Output  
 Unit 1 Stack to Unit 3 Control Room Air Intake

P. 4  
 03703.7002  
 WM(B)-02  
*WVC*



STONE & WEBSTER ENGINEERING CORPORATION  
ENVIRONMENTAL ENGINEERING DIVISION

COMPUTER CODE IDENTIFICATION

PROGRAM NAME: SITE DATA RETREIVAL PROGAM  
VERSION OF PROGRAM: 00  
LINK EDIT DATE (JULIAN): 80.184  
DATE OF RUN (MO/DAY/YR): 4/29/98  
JOB NAME OF RUN: CQ68

LIBRARY REFERENCE NUMBER: EN-112  
LEVEL OF PROGRAM: 01  
LINK EDIT TIME (HRS.MINS.SECONDS): 14.21.36  
TIME OF RUN (MILITARY): 1002  
JOB04820

APPENDIX 1  
EN-113 Program Output  
Unit 1 Stack to Unit 3 Control Room Air Intake

P. 5  
03703.7002  
WM(B)-02  
*RM*

INPUT DATA TRACEBACK

DATA SUBMITTED ON DEVICE: 5

CARD#	-----1-----2-----3-----4-----5-----6-----7-----8
1	3
2	131 132 135
3	74001 81365
CARD#	-----1-----2-----3-----4-----5-----6-----7-----8

\*\*\*\*\* END OF INPUT ON DEVICE 5 \*\*\*\*\*

APPENDIX 1  
EN-113 Program Output  
Unit 1 Stack to Unit 3 Control Room Air Intake

P. 6  
03703.7002  
WM(B)-02

*NR 0*



INPUT TO METOHER PROGRAM

3  
131 132 135  
74001 81365

EOF OF INPUT DATA REACHED

NUMBER OF CARDS SELECTED = 8766

NUMBER OF DAYS SELECTED = 2922

APPENDIX 1  
EN-113 Program Output  
Unit 1 Stack to Unit 3 Control Room Air Intake

P. 7  
03703.7002  
WM(B)-02

*W-0*



STONE & WEBSTER ENGINEERING CORPORATION  
ENVIRONMENTAL ENGINEERING DIVISION

COMPUTER CODE IDENTIFICATION

PROGRAM NAME: ATMOSPHERIC DISPERSION FACTORS

VERSION OF PROGRAM: 06

LOAD MODULE: ENVIRONM.WXLOADLB

LINK EDIT DATE (JULIAN): 82.263

DATE OF RUN (MO/DAY/YR): 4/29/98

JOB NAME OF RUN: CQ68

LIBRARY REFERENCE NUMBER: EN-113

LEVEL OF PROGRAM: 08

MEMBER (PGM): CHIOQ68

LINK EDIT TIME (HRS.MINS.SECONDS): 12.40.03

TIME OF RUN (MILITARY): 1002

JOB04820

APPENDIX 1  
EN-113 Program Output  
Unit 1 Stack to Unit 3 Control Room Air Intake

P. 8  
03703.7002  
WM(B)-02

*W-0*

INPUT DATA TRACEBACK

DATA SUBMITTED ON DEVICE: 5

```

CARD#  -----1-----2-----3-----4-----5-----6-----7-----8
1  MILLSTONE NUCLEAR POWER STATION - UNIT 3   037037002
2  ONSITE METDATA (1974-1981)
3  7400181365 2922      3 341      2
4  131 132      0 0      0 135      0 0 0 0 0
5  0.1 0 0 0 0 0.1 0 0 0 0 0 0 0 0
6  2 ELEVATED RELEASE (355 M)
7  1      0 389      0 0      0 0      00 2 0 0 0
8  1 0 0 0 16 3 0 0 0 0 0 0 0 0 0
9  1 0 0 0 0 1000 8 0 1.1 0.6 0.0 0.0
10 35599999
    
```

```

CARD#  -----1-----2-----3-----4-----5-----6-----7-----8
11 35199999
12
13 1 64.5 64.5
14 2 64.5 64.5
15 3 64.5 64.5
16 4 64.5 64.5
17 5 64.5 64.5
18 6 64.5 64.5
19 7 64.5 64.5
20 8 64.5 64.5
    
```

```

CARD#  -----1-----2-----3-----4-----5-----6-----7-----8
21 9 64.5 64.5
22 10 64.5 64.5
23 11 64.5 64.5
24 12 64.5 64.5
25 13 64.5 64.5
26 14 64.5 64.5
27 15 64.5 64.5
28 16 64.5 64.5
    
```

\*\*\*\*\* END OF INPUT ON DEVICE 5 \*\*\*\*\*

APPENDIX 1  
 EN-113 Program Output  
 Unit 1 Stack to Unit 3 Control Room Air Intake

P. 9  
 03703.7002  
 WMM(B)-02  
*WMO*

\*\*\*\*\* PROGRAM OPTIONS AVAILABLE IN THE LOAD MODULE (ENVIRONM.WXLOADLB(CHIOQ68)) \*\*\*\*\*

METSTB - METHOD OF DETERMINING STABILITY CLASS. - ALL METHODS  
IREDIS - REDISTRIBUTION OF CALMS - ALL  
TPGRAD - SPECIFIED TEMPERATURE GRADIENTS FOR STABILITY CLASS DETERMINATION  
IRETYP - RELEASE POINT AND CALCULATION TYPE  
ISTTYP - STATION TYPE - NUCLEAR OR FOSSIL, - BOTH  
HLID - LIMITED MIXING LID HEIGHT  
ISTRNLN - CALCULATE TIME PERIOD AVERAGES USING STRAIGHT LINE  
ICALM - RESET WIND SPEED TO CALM SPEED IF WIND SPEED FALLS BELOW CALM SPEED  
UCU - UNSTABLE AND NETURAL WIND SPEED CORRECTION FACTOR  
UCS - STABLE WIND SPEED HEIGHT CORRECTION FACTOR  
ISECVG - SECTOR AVERAGING CORRECTION  
MESHT - WIND SPEED MODIFICATION WITH HEIGHT (ASME)  
IAECG - DISPERSION COEFFICIENTS (SIGMA Y AND SIGMA Z), AEC, AEC DESERT AND S+W (TURNER'S)  
IBWFEFF - BUILDING WAKE EFFECT (SHORT TERM) - ALL  
ITOPD - TOPOGRAPHIC DATA INPUT CONTROL  
ITERIN - TERRAIN ADJUSTMENT FACTOR - ALL  
ISIGMA - SIGMA VALUE PRINTOUT CONTROL  
ISTABY - HORIZONTAL DISPERSION COEFFICIENT SELECTION ARRAY  
ISTABZ - VERTICAL DISPERSION COEFFICIENT SELECTION ARRAY  
NHR72 - 72 HOUR SLIDING AVERAGE HOURS TO BE SLID CONTROL  
NHR624 - 624 HOUR SLIDING AVERAGE HOURS TO BE SLID CONTROL  
LIMXQR - X/Q - D/Q WRITE LIMIT CONTROL  
PRGHR - NUMBER OF PURGE HOURS  
RFCHSP - WIND SPEED BELOW WHICH TERRAIN RECIRCULATION FRACTION WILL BE APPLIED  
JHRARY - TIME PERIOD CONTROL  
IPLMEQ - PLUME RISE EQUATION CONTROL (14 METHODS)  
BHT - BUILDING HEIGHT WAKE EFFECT (LONG TERM)  
SPDBHE - GROUND TO ELEVATED RELEASE SHIFT AND DOHNBASH CONTROL  
IAJDIR - ADJACENT DOWNWIND SECTOR DISTANCE SELECTION SWITCH

APPENDIX 1  
EN-113 Program Output  
Unit 1 Stack to Unit 3 Control Room Air Intake

P. 10  
03703.7002  
WM(B)-02

*W-0*

CALCULATION NUMBER  
ONSITE METDATA (1974-1981)

037037002

MILLSTONE NULCEAR POWER STATION - UNIT 3  
ELEVATED RELEASE (355 M)

\*\*\*\*\* READ1 (6.8) INPUT DATA \*\*\*\*\*

CLIENT(11)  
MILLSTONE NULCEAR POWER STATION - UNIT 3  
SITE(11)

JOBNO(3)  
037037002  
CALCNU(5)

ONSITE METDATA (1974-1981)

ISTART ISTOP NDYSOT METSTB DHT IREDIS  
74001 81365 2922 3 341.0 2

SPEED DIR TEMP RANGE STD DEV DELTA T  
131 132 0 0 0 135  
0.10 1.00 1.00 1.00 1.00 0.10

ELEVATED CONDITIONS

SPEED DIR TEMP ISPUNT ITPUNT  
0 0 0 0 0  
1.00 1.00 1.00 0.0 0.0

TPGRAD(6)  
0.0 0.0 0.0 0.0

\*\*\*\*\* READ2 (6.8) INPUT DATA \*\*\*\*\*

IRETYP  
2 ELEVATED RELEASE (355 M)  
ISTTYP HFLUE STKHT STKDIA GASVEL TS HLID HFUEL HVALUE ISTRLN ICALM UCU UCS  
1 0. 389.00 0.0 0.0 0. 0. 0. 0. 0 2 0 0.0 0.0  
ISECVG MESHT IAECSG IBWHEFF ITOPO ITERIN ISIGMA ISTABY ISTABZ NHR72 NHR624 LIMXQR PRGHRF RFCHSP  
1 0 0 0 16 3 0 0000000 0000000 0 0 0 0.0 0.0  
1 0 0 0 0 1000 8 0.0 1.1 0.6 0.0 0.0 IAJDIR  
0

DISITE(16)  
355.0 355.0 355.0 355.0 355.0 355.0 355.0 355.0 355.0 355.0 355.0 355.0 355.0 355.0 355.0  
DISLPZ(16)  
351.0 351.0 351.0 351.0 351.0 351.0 351.0 351.0 351.0 351.0 351.0 351.0 351.0 351.0 351.0  
IDSLP  
0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0

IDR TOPOHT(16,12)  
1 64.5 64.5  
2 64.5 64.5  
3 64.5 64.5  
4 64.5 64.5  
5 64.5 64.5  
6 64.5 64.5  
7 64.5 64.5  
8 64.5 64.5  
9 64.5 64.5  
10 64.5 64.5  
11 64.5 64.5  
12 64.5 64.5  
13 64.5 64.5  
14 64.5 64.5  
15 64.5 64.5  
16 64.5 64.5

\*\*\*\*\* TERRAIN ADJUSTMENT FACTORS USED \*\*\*\*\*

IDR FACTORS ( 2)  
1 4.000 4.000  
2 4.000 4.000  
3 4.000 4.000  
4 4.000 4.000  
5 4.000 4.000  
6 4.000 4.000  
7 4.000 4.000  
8 4.000 4.000

APPENDIX 1  
EN-113 Program Output  
Unit 1 Stack to Unit 3 Control Room Air Intake

*Handwritten signature*

P. 11  
03703.7002  
WM(B)-02

9	4.000	4.000
10	4.000	4.000
11	4.000	4.000
12	4.000	4.000
13	4.000	4.000
14	4.000	4.000
15	4.000	4.000
16	4.000	4.000

APPENDIX 1  
EN-113 Program Output  
Unit 1 Stack to Unit 3 Control Room Air Intake

P. 12  
03703.7002  
WM(B)-02

*W S*

MILLSTONE NUCLEAR POWER STATION - UNIT 3  
 ELEVATED RELEASE (355 M)  
 CHI/Q CALCULATION  
 RELEASE TYPE - ELEVATED NUCLEAR  
 STABILITY DETERMINED BY DELTA TEMPERATURE  
 WIND SPEED ASSIGNED TO CALM OBSERVATIONS = 1.10 MPH  
 DISPERSION COEFFICIENTS (AEC GIFFORD'S)

CALCULATION NUMBER  
 ONSITE METDATA (1974-1981) 037037002

1 HOUR PERIOD 1/01/74 - 12/31/81  
 ZERO PLUME RISE  
 TOPOGRAPHY USED - YES  
 CALM REDISTRIBUTION - PROP TO 1.5 MPS H/S CLASS DIR FREQ

\*\*\*\*\* CHI/Q VALUES \*\*\*\*\*

DOWNWIND SECTOR	DOWNWIND DISTANCE (M)	MAXIMUM VALUE	ARITHMETIC MEAN	50 PERCENT VALUE	50 PC EQUAL RISK VALUE	5 PERCENT VALUE	5 PC EQUAL RISK VALUE	8 PC EQUAL RISK VALUE									
S	355.	0.8356E-05	0.5924E-07	0.5133E-14	0.7795E-23	0.5092E-07	0.2730E-07	0.1641E-13									
SSW	355.	0.2051E-04	0.4650E-07	0.5191E-14	0.4313E-14	0.2850E-07	0.1945E-07	0.1641E-13									
SW	355.	0.9601E-05	0.3937E-07	0.5966E-14	0.3547E-14	0.2850E-07	0.2964E-13	0.1641E-13									
WSW	355.	0.7780E-05	0.7870E-08	0.6336E-14	0.3178E-59	0.2297E-13	0.1641E-13	0.1209E-13									
W	355.	0.4600E-05	0.1766E-07	0.3995E-14	0.1626E-23	0.2552E-13	0.1413E-13	0.9571E-14									
WNW	355.	0.8058E-05	0.3805E-07	0.4836E-14	0.9035E-59	0.2158E-07	0.1641E-13	0.1178E-13									
NW	355.	0.1126E-04	0.7589E-07	0.7362E-23	0.1491E-59	0.4594E-13	0.1641E-13	0.1209E-13									
NNW	355.	0.4102E-04	0.1217E-06	0.3118E-23	0.1000E-70	0.2137E-13	0.1371E-13	0.9987E-14									
N	355.	0.1128E-04	0.6439E-07	0.2409E-23	0.1031E-23	0.1955E-13	0.1458E-13	0.1134E-13									
NNE	355.	0.1456E-04	0.6309E-07	0.2120E-23	0.2409E-23	0.1458E-13	0.1641E-13	0.1134E-13									
NE	355.	0.1253E-04	0.3063E-07	0.2120E-23	0.2648E-14	0.1242E-13	0.2042E-13	0.1242E-13									
ENE	355.	0.2507E-04	0.2092E-07	0.2366E-23	0.4313E-14	0.1413E-13	0.1763E-07	0.1701E-13									
E	355.	0.1003E-04	0.1550E-07	0.3797E-14	0.4940E-14	0.1407E-07	0.1970E-07	0.3675E-13									
ESE	355.	0.2507E-04	0.3352E-07	0.5280E-14	0.6336E-14	0.2605E-07	0.6124E-07	0.2255E-07									
SE	355.	0.9199E-05	0.8219E-07	0.5535E-14	0.8587E-14	0.4819E-06	0.8363E-06	0.5440E-06									
SSE	355.	0.2256E-04	0.8636E-07	0.5405E-14	0.6425E-14	0.5326E-06	0.6571E-06	0.4306E-06									
DIRECTION INDEPENDENT		0.4102E-04	0.4872E-07	0.4065E-14		0.2385E-07											
OBSERVATIONS EXAMINED	70128		GOOD OBSERVATIONS	65563		PERCENT DATA RECOVERY	93.49										
GOOD DATA PERIODS	65563																
NUMBER CHI/Q = 0.0	62538	62314	62719	63469	63066	63362	63430	63523	62782	61111	58971	58276	59875	60166	57739	60104	0
	95.39	95.04	95.66	96.81	96.19	96.64	96.75	96.89	95.76	93.21	89.95	88.89	91.32	91.77	88.07	91.67	0.0
NON ZERO TOTAL	3025	3249	2844	2094	2497	2201	2133	2040	2781	4452	6592	7287	5688	5397	7824	5459	65563

APPENDIX 1  
 EN-113 Program Output  
 Unit 1 Stack to Unit 3 Control Room Air Intake

P. 13  
 03703.7002  
 WMB(B)-02  
 RW 0

CALCULATION NUMBER

\*\*\*\*\* CUMULATIVE FREQUENCY SUMMARY \*\*\*\*\*

DOWNHIND SECTOR	S	SSW	SW	WSW	W	HNW	NH	NNH	N	NNE	NE	ENE	E	ESE	SE	SSE	DIRECTION
DOWNHIND DISTANCE (M)	355.	355.	355.	355.	355.	355.	355.	355.	355.	355.	355.	355.	355.	355.	355.	355.	INDEPENDENT
TOPOGRAPHIC HEIGHT	65.	65.	65.	65.	65.	65.	65.	65.	65.	65.	65.	65.	65.	65.	65.	65.	
CHI/Q RANGE																	
GTE LT																	
0.10E-08	2792	3034	2672	2057	2411	2083	2039	1983	2710	4357	6448	7041	5383	4908	6610	4823	61351
0.10E-08 0.39E-08	92.30	93.38	93.95	98.23	96.56	94.64	95.59	97.21	97.45	97.87	97.82	96.62	94.64	90.94	84.48	88.35	93.58
0.40E-08 0.69E-08	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
0.70E-08 0.99E-08	92.30	93.38	93.95	98.23	96.56	94.64	95.59	97.21	97.45	97.87	97.82	96.62	94.64	90.94	84.48	88.35	93.58
0.10E-07 0.39E-07	69	85	63	12	31	37	14	5	6	9	38	116	188	278	536	235	1722
0.40E-07 0.69E-07	94.58	96.00	96.17	98.81	97.80	96.32	96.25	97.45	97.66	98.07	98.39	98.22	97.94	96.09	91.33	92.65	96.20
0.70E-07 0.99E-07	30	37	31	12	9	22	22	5	10	15	20	14	2	7	40	41	317
0.10E-06 0.39E-06	95.57	97.14	97.26	99.38	98.16	97.32	97.28	97.70	98.02	98.41	98.70	98.41	97.98	96.22	91.85	93.41	96.69
0.40E-06 0.69E-06	4	10	10	1	6	5	3	5	2	1	1	2	2	0	1	2	55
0.70E-06 0.99E-06	95.70	97.45	97.61	99.43	98.40	97.55	97.42	97.94	98.09	98.43	98.71	98.44	98.01	96.22	91.86	93.44	96.77
0.10E-05 0.29E-05	3	8	5	4	2	6	6	2	2	1	7	33	47	68	121	14	329
0.30E-05 0.49E-05	99.80	97.69	97.78	99.62	98.48	97.82	97.70	98.04	98.17	98.45	98.82	98.89	98.84	97.48	93.40	93.70	97.27
0.40E-05 0.69E-05	46	15	15	2	16	12	2	0	0	4	16	38	45	90	265	155	721
0.50E-05 0.89E-05	97.32	98.15	98.31	99.71	99.12	98.36	97.80	98.04	98.17	98.54	99.06	99.41	99.63	99.15	96.79	96.54	98.37
0.60E-05 0.99E-05	33	23	21	3	13	11	5	2	2	5	18	7	3	7	63	64	280
0.70E-05 0.11E-04	98.41	98.86	99.05	99.86	99.64	98.86	98.03	98.14	98.24	98.65	99.33	99.51	99.68	99.28	97.60	97.71	98.80
0.80E-05 0.31E-04	35	23	16	2	6	18	21	12	28	23	20	26	15	34	164	102	545
0.90E-05 0.51E-04	99.57	99.57	99.61	99.95	99.88	99.68	99.02	98.73	99.24	99.17	99.64	99.86	99.95	99.91	99.69	99.58	99.63
1.00E-05 0.71E-04	10	9	6	0	3	5	11	8	8	11	9	5	1	3	23	15	127
1.10E-05 0.91E-04	99.90	99.85	99.82	99.95	100.00	99.91	99.53	99.12	99.53	99.42	99.77	99.93	99.96	99.96	99.99	99.85	99.82
1.20E-05 0.11E-03	0	3	2	0	0	1	5	6	7	15	9	3	1	0	0	5	57
1.30E-05 0.31E-03	99.90	99.94	99.89	99.95	100.00	99.95	99.77	99.41	99.78	99.75	99.91	99.97	99.98	99.96	99.99	99.95	99.91
1.40E-05 0.51E-03	3	1	2	1	0	1	3	5	3	7	2	1	0	0	0	1	30
1.50E-05 0.71E-03	100.00	99.97	99.96	100.00	100.00	100.00	100.00	99.91	99.66	99.89	99.91	99.94	99.99	99.98	99.96	99.99	99.96
1.60E-05 0.91E-03	0	0	1	0	0	0	2	3	3	2	3	0	1	1	1	1	18
1.70E-05 0.11E-02	100.00	99.97	100.00	100.00	100.00	100.00	100.00	99.80	100.00	99.96	99.98	99.99	100.00	99.98	100.00	99.98	99.98
1.80E-05 0.31E-02	0	1	0	0	0	0	0	3	0	2	1	1	0	1	0	1	10
1.90E-05 0.51E-02	100.00	100.00	100.00	100.00	100.00	100.00	100.00	99.95	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00
2.00E-05 0.71E-02	0	0	0	0	0	0	0	1	0	0	0	0	0	0	0	0	1
2.10E-05 0.91E-02	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

APPENDIX 1  
EN-113 Program Output  
Unit 1 Stack to Unit 3 Control Room Air Intake

P. 14  
03703.7002  
WM(B)-02  
*W*



MILLSTONE NUCLEAR POWER STATION - UNIT 3  
 ELEVATED RELEASE (355 M)  
 CHI/Q CALCULATION ANNUAL 1/01/74 - 12/31/81  
 RELEASE TYPE - ELEVATED NUCLEAR ZERO PLUME RISE  
 STABILITY DETERMINED BY DELTA TEMPERATURE TOPOGRAPHY USED - YES  
 WIND SPEED ASSIGNED TO CALM OBSERVATIONS = 0.60 MPH CALM REDISTRIBUTION - PROP TO 1.5 MPS W/S CLASS DIR FREQ  
 DISPERSION COEFFICIENTS (AEC GIFFORD'S)  
 RECIRCULATION FACTORS APPLIED (PLAIN (CURVE))  
 HEIGHT OF ELEVATED RELEASE 389.0 FEET ( 118.6 METERS)

\*\*\*\*\* ANNUAL CHI/Q AVERAGES \*\*\*\*\* UNDECAYED UNDEPLETED CHI/Q VALUES.

DOWNWIND SECTOR DOWNWIND DISTANCE (M) AND CHI/Q AVERAGES

SECTOR	355	351	
S	0.133E-07	0.129E-07	
SSW	0.112E-07	0.108E-07	
SW	0.809E-08	0.782E-08	
WSW	0.118E-08	0.114E-08	
W	<del>0.299E-08</del>	0.286E-08	← 259° - 281°
WNW	0.628E-08	0.611E-08	← 282° - 305°
NW	0.126E-07	0.124E-07	← 306° - 329°
NNW	0.205E-07	0.202E-07	← 330° - 353°
N	0.138E-07	0.134E-07	
NNE	0.224E-07	0.220E-07	
NE	0.159E-07	0.156E-07	
ENE	0.116E-07	0.113E-07	
E	0.642E-08	0.622E-08	
ESE	0.133E-07	0.129E-07	
SE	0.484E-07	0.471E-07	
SSE	0.358E-07	0.349E-07	

OBSERVATIONS EXAMINED 70128 GOOD OBSERVATIONS 65563 PERCENT DATA RECOVERY 93.49

Maximum Value 2.05 x 10<sup>-8</sup>

APPENDIX 1  
EN-113 Program Output  
Unit 1 Stack to Unit 3 Control Room Air Intake

P. 15  
03703.7002  
WM(B)-02  
*WMO*

Attachment 4

Millstone Nuclear Power Station, Unit No. 3

Calculation WM(B)-04  
Normalized X/Q at the Unit 3 Control Room  
Releases From the Unit 3 Containment and Turbine Bldg.



CALCULATION TITLE PAGE

Total Number of Pages: 49

Normalized X/Q at the Unit 3 Control Room For Releases From the Unit 3 Containment and Turbine Bldg

TITLE		
N/A	0	RBVS/SLCRS
CALCULATION #	REVISION No.	SYSTEM NAME
WM(B)-04	CB,CE,TB	N/A
VENDOR CALCULATION NUMBER	Structure	System Number

NUCLEAR INDICATOR:			Calc. Supports DCR/MMOD?	Calc. Supports Ind. Analysis?	N/A Component
<input checked="" type="checkbox"/> CAT1	<input type="checkbox"/> RWQA	<input type="checkbox"/> SBOQA			
<input type="checkbox"/> FPQA	<input type="checkbox"/> ATWSQA	<input type="checkbox"/> NON-QA			

↓	↓
M3-98-029	N/A
DCR/MMOD No.	Reference

**INCORPORATES:**

CCN NO:	AGAINST REV.
N/A	N/A
_____	_____
_____	_____

**Executive Summary**

THIS IS FORMAL APPROVAL OF A QA APPROVED VENDOR CALCULATION. NO (NU) IR IS REQUIRED.

REC'D 6-8-98  
 ON HOLD \_\_\_\_\_  
 CDS 6/17/98  
 CDS QC 6/25/98  
 NRP ✓

Verified Revision ✓  
 Initial JW Date 6/13/00

Approvals (Print & Sign Name)		
Preparer: James L. Wheeler	<i>[Signature]</i>	Date: <u>5/27/98</u>
Interdiscipline Reviewer: N/A	Discipline:	Date:
Interdiscipline Reviewer: N/A	Discipline:	Date:
Independent Reviewer: N/A		Date:
Supervisor: William Eakin	<i>[Signature]</i>	Date: <u>5/27/98</u>
Installation Verification		
<input checked="" type="checkbox"/> Calculation accurately reflects plant configuration, OR		
<input type="checkbox"/> N/A does not affect plant configuration)		
Preparer/Designer Engineer: JAMES L. WHEELER	<i>[Signature]</i>	Date: <u>5/22/98</u>



PassPort DATABASE INPUTs

CH #4

Page 1B of 49

Calculation Number: N/A N/A N/A Revision: N/A  
 (prefix) (sequence no.) (suffix)

Vendor Calculation Number/Other: 03703.7002-WM(B)-04 Revision: 0

CCN # N/A QA  Yes  No Calc Voided:  Yes  No

Superseded By: N/A Supersedes Calc: N/A

Discipline (Up to 10) N,A,Z

Unit	Project Reference (EWA)	Component Id	Computer Code	Rev. No./ Level No.
3	N/A	N/A	EN-200	0/0

PMMS CODES*				
Structure	System	Component	Reference Calculation	Rev No.
CB	RBV	N/A	ENVR-W210	0
CE			ENVR-W228	0
TB				

\*The codes required must be alpha codes designed for structure, system and component.

Reference Drawing	Sheet	Rev. No.
25212-14045	B	15
25212-24215	01	14

Comments:

---



---



---

**Table of Contents**

Title page	1A
CTP Database	1B
Table of Contents	1C
Vendor Calculation Pages	1 thru 10
Appendix 1	18 pages
Appendix 2	18 pages
Total number of pages	49

STONE & WEBSTER ENGINEERING CORPORATION  
CALCULATION TITLE PAGE

5010.65

CLIENT & PROJECT: NORTHEAST UTILITIES - MILLSTONE UNIT 3				PAGE 1 of 10 Total Pages: 46 w/attachments pages			
CALCULATION TITLE: Normalized Concentrations (X/Qs) at Unit 3 Control Room Air Intake for Releases from the Unit 3 Containment Structure and Turbine Bldg. Vent				QA CATEGORY (✓) <input checked="" type="checkbox"/> I <input type="checkbox"/> II			
CALCULATION IDENTIFICATION NUMBER				OPTIONAL WORK PACKAGE NO.			
JOB ORDER NO. 03703.7002	DISCIPLINE WM(B)	CURRENT CALC NO. 04 <i>new</i>	OPTIONAL TASK CODE				
APPROVALS - SIGNATURE & DATE			REVISION NO. OR NEW CALCULATION NO. 0	SUPERSEDES CALCULATION NO. OR REVISION NO.	CONFIRMATION REQUIRED (✓)		
PREPARES(S) / DATE(S) Stephen A. Vigeant <i>Stephen A. Vigeant</i> 5/21/98	REVIEWER(S) / DATES(S) Carl A. Mazzola <i>Carl A. Mazzola</i> 5/21/98	INDEPENDENT REVIEWER(S) / DATE(S) Carl A. Mazzola <i>Carl A. Mazzola</i> 5/21/98			YES	NO <input checked="" type="checkbox"/>	

DISTRIBUTION

GROUP	NAME & LOCATION	COPY SENT (✓)	GROUP	NAME & LOCATION	COPY SENT (✓)
Record Mgmt. File (or Fire File if none) Lead Radiological Specialist	S. Ferguson Boston - 6	cc			
Project Files	Stephen A. Vigeant Boston - 3	cc			
NU RAD <del>PROT</del> PROT	Charlotte Cronan Boston - 7				
NUNDS	Schmidt, R.J. New Britain	cc			
	MP3 Site	original e			

STONE & WEBSTER ENGINEERING CORPORATION  
CALCULATION SHEET

5010.65

CALCULATION IDENTIFICATION NUMBER

JOB ORDER NO. 037037002	DISCIPLINE WM(B)	CALCULATION NO. 04 <i>Rev 0</i>	OPTIONAL TASK CODE	PAGE 2 OF 10
----------------------------	---------------------	------------------------------------	--------------------	-----------------

CHANGE HISTORY PAGE

REVISION NO.	DESCRIPTION OF CHANGES	PAGES REVISED	PAGES ADDED	PAGES REPLACED
0	0	N/A	N/A	N/A

STONE & WEBSTER ENGINEERING CORPORATION  
CALCULATION SHEET

5010.65

CALCULATION IDENTIFICATION NUMBER

JOB ORDER NO.	DISCIPLINE	CALCULATION NO.	OPTIONAL TASK CODE	PAGE
037037002	WM(B)	04 <i>new</i>		3 OF 10

TABLE OF CONTENTS

COVER PAGE..... 1

CHANGE HISTORY PAGE..... 2

TABLE OF CONTENTS..... 3

OBJECTIVE ..... 4

METHODOLOGY ..... 4

ASSUMPTIONS ..... 5

EQUATIONS ..... 5

DATA..... 6

CALCULATION..... 6

CONCLUSIONS ..... 7

REFERENCES ..... 8

ATTACHMENTS.....8

APPENDICES.....8



STONE & WEBSTER ENGINEERING CORPORATION  
CALCULATION SHEET

5010.65

CALCULATION IDENTIFICATION NUMBER

JOB ORDER NO. 037037002	DISCIPLINE WM(B)	CALCULATION NO. 04 <i>nwo</i>	OPTIONAL TASK CODE	PAGE 4 OF 10
----------------------------	---------------------	----------------------------------	--------------------	-----------------

**OBJECTIVE**

To calculate the normalized atmospheric dispersion values (X/Qs) at the Millstone Unit 3 control room air intake for gaseous radiological releases from the Unit 3 Containment Structure and Turbine Building Vent. These X/Q values will apply to the 0-2 hour through 30-day period for the containment and turbine building vent ground level release.

**METHODOLOGY**

The control room X/Q values are calculated using the methodology described in Murphy and Campe (Ref. 1). Given that the radiological releases are from the containment surface and from a point source (turbine bldg. vent) with a large elevation difference relative to the control room intake (see Data Section, p. 6), the diffuse source - point receptor technique for X/Q calculation from Section V(B)(1)(b) of Murphy and Campe (Ref. 1) is used. The X/Q equation is as follows:

$$X/Q = [u(\pi\sigma_y\sigma_z + A/(K+2))]^{-1}$$

where:

X/Q is relative concentration (sec/m<sup>3</sup>)

$\sigma_y, \sigma_z$  are horizontal and vertical dispersion coefficients based on stability class and horizontal distance (m)

u = wind speed at 10-meter elevation (m/sec)

A = projected building area (m<sup>2</sup>)

k = 3/(s/d)<sup>1.4</sup>

s = source to receptor difference (m)

d = building width (m)

The above relationship is used to calculate the 0 - 2 hour X/Q value based on site meteorological data, selecting the condition that represents the 5 percentile worst dispersion condition at the site. In this case, 1974 to 1981 on-site meteorological data (Ref. 2) are used. From earlier control room X/Q calculations (Ref. 3), the 5 percentile worst site stability class is F stability. The corresponding 5 percentile low wind speed is determined from the on-site meteorological data considering only those wind directions resulting in receptor exposure. The number of wind direction sectors to be considered for each source-receptor relationship is determined using Figure 2 of Ref. 1 which is based on the ratio of the distance (s) between the source and receptor to the diameter (d) or width of the building from which the release emanates (s/d ratio). The dispersion coefficients ( $\sigma_y, \sigma_z$ ) are determined from Ref. 4.

The intermediate averaging time X/Qs (8-24 hours, 1-4 days, and 4-30 days) are determined from the 0-2 hour X/Q value multiplying by occupancy, wind speed, and wind direction factors in accordance with Ref. 1. These factors are as follows:

<u>Averaging Time</u>	<u>Occupancy Factor</u>	<u>Wind Speed Factor</u>	<u>Wind Direction Factor</u>
0 - 2 Hours	1	1	1
8 - 24 Hours	1	5%/10% wind speed	0.75 + F/4
1 - 4 Days	0.6	5%/20% wind speed	0.50 + F/2
4 - 30 Days	0.4	5%/40% wind speed	F

F is the fraction of time the wind blows the activity toward the receptor.

The frequency of wind directions blowing in the appropriate range and at individual wind speeds is determined from the on-site meteorological data base (Ref. 2) using Stone & Webster computer program "Distribution of Two Parameters" (Ref. 5).

STONE & WEBSTER ENGINEERING CORPORATION  
CALCULATION SHEET

5010.65

CALCULATION IDENTIFICATION NUMBER

JOB ORDER NO. 037037002	DISCIPLINE WM(B)	CALCULATION NO. 04 <i>Revised</i>	OPTIONAL TASK CODE	PAGE 5 OF 10
----------------------------	---------------------	--------------------------------------	--------------------	-----------------

**ASSUMPTIONS**

1. It is conservatively assumed that each plume centerline is transported directly over the Unit 3 control room intake and that the plume dispersion is affected by the containment structure (containment release) and turbine building (turbine building vent).
2. For purposes of determining the appropriate dispersion equation to use in the analysis, the nature of the release and elevation difference between the release point and the control room air intake is compared to the appropriate building height. Point sources with elevation differences that are greater than 30 percent of the building height are evaluated using the diffuse source - point receptor equation from Ref. 1.
3. It is assumed that the Unit 3 control room air intake X/Q values are representative of the X/Q values for the center of the Unit 3 control room given that the distances and directions from the releases to these receptors are very similar.

**EQUATIONS**

$$X/Q = [u(\pi\sigma_y\sigma_z + A/(K+2))]^{-1} \quad (\text{Ref. 1})$$

where:

X/Q is relative concentration (sec/m<sup>3</sup>) for point source - point receptor configurations

$\sigma_y, \sigma_z$  are horizontal and vertical dispersion coefficients (m) (Ref. 4)

u = wind speed at 10-meter elevation (m/sec)

A = projected building area (m<sup>2</sup>)

k = 3/(s/d)<sup>1.4</sup>

Determination of Influencing Wind Directions (Ref. 1)

s = source to receptor distance (m)

d = release point diameter or width (m)

Calculate s/d ratio and use Figure 2 from Ref. 1

Determination of Intermediate Period Factors (Ref. 1)

<u>Averaging Time</u>	<u>Occupancy Factor</u>	<u>Wind Speed Factor</u>	<u>Wind Direction Factor</u>
0 - 2 Hours	1	1	1
8 - 24 Hours	1	5%/10% wind speed	0.75 + F/4
1 - 4 Days	0.6	5%/20% wind speed	0.50 + F/2
4 - 30 Days	0.4	5%/40% wind speed	F

F is the fraction of time the wind blows the activity toward the receptor.

STONE & WEBSTER ENGINEERING CORPORATION  
CALCULATION SHEET

5010.65

CALCULATION IDENTIFICATION NUMBER

JOB ORDER NO. 037037002	DISCIPLINE WM(B)	CALCULATION NO. 04 <i>UWA</i>	OPTIONAL TASK CODE	PAGE 6 OF 10
----------------------------	---------------------	----------------------------------	--------------------	-----------------

**DATA**

**1. Unit 3 Containment to Unit 3 Control Room Air Intake**

Distance (s) from containment to Unit 3 control room air intake = 72.0 m (Ref. 6 )  
 Wind direction from containment to Unit 3 control room air intake = 108 deg (Ref. 6 )  
 Unit 3 control room air intake elevation = 94.6 ft (Ref. 8)  
 Containment structure enclosure height (top elevation - grade elevation) = 186.2 ft - 24.0 ft = 162.2 ft (Ref. 6 )  
 Containment structure enclosure width (d) = 47.2 m (Ref. 6)  
 Containment structure enclosure area = 2336.4 m<sup>2</sup> (Ref. 6)

**2. Unit 3 Turbine Bldg. to Unit 3 Control Room Air Intake**

Distance from turbine bldg. vent to Unit 3 control room center = 38.1 m (Ref. 7 )  
 Wind direction from turbine bldg. vent to Unit 3 control room center = 128 deg (Ref. 7 )  
 d = turbine bldg. width = 36 m (Ref. 7)  
 Turbine bldg. vent elevation = 157 ft (Ref. 7)  
 Turbine bldg. roof height above grade = 113 ft (Ref. 7)  
 Unit 3 control room air intake elevation = 94.6 ft (Ref. 8)  
 Turbine bldg. vent-control room air intake elevation difference = 157 ft - 94.6 ft = 62.4 ft  
 Percentage difference in elevations = 62.4 ft/113 ft = 55 percent

**CALCULATION**

**1. Unit 3 Containment to Unit 3 Control Room Air Intake**

s = 72.0 m (Ref. 6)  
 direction = 108 deg (Ref. 6)  
 d = 47.2 m (Ref. 6)  
 s/d = 72.0 m/47.2 m = 1.53 or 4 sectors (4 x 22.5° = 90° or 108° - 45° = 63° to 108° + 45° = 153°)

A = 2336.4 m<sup>2</sup> (Ref. 6)  
 k = 3/(s/d)<sup>1.4</sup> = 3/(1.53)<sup>1.4</sup> = 1.65  
 σ<sub>y</sub> @ 72.0 m for F stability class = 3.43 m (Ref. 4)  
 σ<sub>z</sub> @ 72.0 m for F stability class = 1.72 m (Ref. 4)  
 u(5%) = 2.2 mph (1.0 m/sec) (Appendix 1, p. 11)  
 u(10%) = 3.1 mph (1.4 m/sec) (Appendix 1, p. 12)  
 u(20%) = 4.5 mph (2.0 m/sec) (Appendix 1, p. 13)  
 u(40%) = 6.7 mph (3.0 m/sec) (Appendix 1, p. 15)  
 F = 10,208/66332 = 0.16 (Appendix 1, p. 18)

**Short-Term X/Q Value for Unit 3 Intake (0 - 2 Hours)**

$$X/Q = [ (1.0 \text{ m/sec}) (3.14159275\dots) (3.43\text{m}) (1.72 \text{ m}) + (2336.4 \text{ m}^2) / (1.65 + 2) ]^{-1}$$

**X/Q = 1.52 E- 3 sec/m<sup>3</sup>**

STONE & WEBSTER ENGINEERING CORPORATION  
CALCULATION SHEET

5010.65

CALCULATION IDENTIFICATION NUMBER

JOB ORDER NO. 037037002	DISCIPLINE WM(B)	CALCULATION NO. 04 <i>Rebo</i>	OPTIONAL TASK CODE	PAGE 7 OF 10
----------------------------	---------------------	-----------------------------------	--------------------	-----------------

**Intermediate Period X/Q Value for Unit 3 Intake**

<u>Averaging Period</u>	<u>Occupancy Factor</u>	<u>Wind Speed Factor</u>	<u>Wind Direction Factor</u>	<u>X/Q (sec/m<sup>3</sup>)</u>
0 - 8 hours	1	1	1	1.52 E- 3
8 - 24 hours	1	2.2/3.1 = 0.71	0.75 + 0.16/4 = 0.79	8.53 E- 4
1 - 4 days	0.6	2.2/4.5 = 0.49	0.50 + 0.16/2 = 0.58	2.59 E- 4
4 - 30 days	0.4	2.2/6.7 = 0.33	0.16	3.21 E- 5

**2. Unit 3 Turbine Bldg. Vent to Unit 3 Control Room Air Intake**

s = 38.1 m (Ref. 7)

direction = 128 deg (Ref. 7)

d = 36 m (Ref. 7)

s/d = 38.1 m/36 m = 1.06 or 5 sectors (5 x 22.5° = 113° or 128° - 57° = 71° to 128° + 57° = 185°)

$k = 3/(s/d)^{1.4} = 3/(1.06)^{1.4} = 2.76$

A = 1239 m<sup>2</sup> (Ref. 7)

$\sigma_y$  @ 38.1m for F stability class = 1.93 m (Ref. 4)

$\sigma_z$  @ 38.1m for F stability class = 1.03 m (Ref. 4)

u(5%) = 2.2 mph (1.0 m/sec) (Appendix 2, P. 11)

u(10%) = 2.9 mph (1.3 m/sec) (Appendix 2, p. 12)

u(20%) = 4.0 mph (1.8 m/sec) (Appendix 2, p. 13)

u(40%) = 6.5 mph (2.9 m/sec) (Appendix 2, p. 15)

F = 12,724/66,332 = 0.19 (Appendix 2, p. 18)

**Short-Term X/Q Value for Unit 3 Intake (0 - 2 Hours)**

$X/Q = [ (1.0 \text{ m/sec}) (3.14159275...) (1.93\text{m}) (1.03 \text{ m}) + (1239 \text{ m}^2) / (2.76 + 2) ]^{-1}$

**X/Q = 3.75 E- 3 sec/m<sup>3</sup>**

**Intermediate Period X/Q Value for Unit 3 Intake**

<u>Averaging Period</u>	<u>Occupancy Factor</u>	<u>Wind Speed Factor</u>	<u>Wind Direction Factor</u>	<u>X/Q (sec/m<sup>3</sup>)</u>
0 - 8 hours	1	1	1	3.75 E- 3
8 - 24 hours	1	2.2/2.9 = 0.76	0.75 + 0.19/4 = 0.80	2.28 E- 3
1 - 4 days	0.6	2.2/4.0 = 0.55	0.50 + 0.19/2 = 0.60	7.43 E- 4
4 - 30 days	0.4	2.2/6.5 = 0.34	0.19	9.69 E- 5

**CONCLUSIONS**

The Unit 3 control room X/Qs are summarized in the body of the calculation. The Unit 3 control room air intake X/Q values are representative of the X/Q values for the center of the Unit 3 control room given that the distances and directions from the releases to these receptors are very similar. The Unit 3 control room air intake X/Q values are also conservative when applied to the Technical Support Center which is located at a farther distance from the releases than the control room.

STONE & WEBSTER ENGINEERING CORPORATION  
CALCULATION SHEET

5010.65

CALCULATION IDENTIFICATION NUMBER

JOB ORDER NO. 037037002	DISCIPLINE WM(B)	CALCULATION NO. 04 <i>two</i>	OPTIONAL TASK CODE	PAGE 8 OF 10
----------------------------	---------------------	----------------------------------	--------------------	-----------------

**REFERENCES**

1. Murphy, K.G. and K.M. Campe., "Nuclear Power Plant Control Room Ventilation System Design for Meeting General Design Criterion 19". Presented at the 13<sup>th</sup> AEC Air Cleaning Conference, August, 1974.
2. Millstone onsite meteorological data for the period 1974 - 1981 provided by H. L. Chamberlain, Jr. of Northeast Utilities, April 28, 1998. The data are hourly values represented by one 15-minute average value per hour. See Attachment 2 for transmittal letter.
3. Stone & Webster Calculation No. 12179.12-ENVR-W223, dated 11/29/82.
4. U. S. Nuclear Regulatory Commission, Subroutine "POLYN", Horizontal and Vertical Dispersion Coefficients as a Function of Downwind Distance (see Attachment 1 for F-stability values).
5. EN-200, Version 0, Level 0. SWEC computer code "Distribution of Two Parameters". Output is provided in Appendices 1 and 2.
6. Stone & Webster Calculation No. 12179.12-ENVR-W210, 11/23/82.
7. Stone & Webster Calculation No. 12179.12-ENVR-W228, 12/02/82.
8. Stone & Webster Drawing Nos. 12179-EA-1B-15 and 12179-EB-39L-14.

**ATTACHMENTS**

1. Subroutine "POLYN", Horizontal and Vertical Dispersion Coefficients as a Function of Downwind Distance (F-stability).
2. Millstone onsite meteorological data transmittal letter from H. L. Chamberlain to J. Creamer, April 28, 1998.

**APPENDICES (36 pages)**

EN-200 Wind Speed/Wind Direction Distribution Computer Output:

<u>Release/Receptor Combination</u>	<u>Wind Direction Range</u>	<u>Job No</u>
1. Unit 3 Containment to Unit 3 Control Room Intake	63 - 153 degrees	02236
2. Unit 3 Turbine Bldg. to Unit 3 Control Room Intake	71 - 185 degrees	00106

10 MAR 1981

DISPERSION COEFFICIENTS AS A FUNCTION OF DOWNWIND DISTANCE  
PASQUILL STABILITY CLASS (F)

PAGE 41

DOWNWIND DISTANCE (METERS)	STONE & WEBSTER	** **	** **	POLYN (LONG)	** **	** **	POLYN (DESERT)	** **	** **	POLYN (XOQDOQ)	** **
	SIGMA Y	SIGMA Z	** **	SIGMA Y	SIGMA Z	** **	SIGMA Y	SIGMA Z	** **	SIGMA Y	SIGMA Z
10.	0.4739	0.1971	**	0.4014	0.1395	**	2.4230	1.6073	**	0.5776	0.3454
20.	0.8969	0.4437	**	0.8020	0.3243	**	4.5718	1.9981	**	1.0802	0.6072
30.	1.3054	0.6928	**	1.2022	0.5313	**	6.6281	2.2694	**	1.5578	0.8446
40.	1.7048	0.9383	**	1.6022	0.7540	**	8.6265	2.4839	**	2.0200	1.0675
50.	2.0977	1.1786	**	2.0021	0.9893	**	10.5829	2.6642	**	2.4710	1.2801
60.	2.4855	1.4134	**	2.4019	1.2351	**	12.5064	2.8212	**	2.9133	1.4849
70.	2.8691	1.6427	**	2.8015	1.4900	**	14.4031	2.9611	**	3.3485	1.6834
80.	3.2490	1.8667	**	3.2011	1.7530	**	16.2771	3.0879	**	3.7776	1.8767
90.	3.6259	2.0857	**	3.6006	2.0232	**	18.1315	3.2043	**	4.2016	2.0655
100.	4.0000	2.3000	**	4.0000	2.3000	**	19.9696	3.3120	**	4.6210	2.2472
110.	4.3716	2.5098	**	4.3994	2.5829	**	21.7903	3.4126	**	5.0364	2.4369
120.	4.7409	2.7153	**	4.7987	2.7365	**	23.5981	3.5072	**	5.4481	2.6223
130.	5.1082	2.9169	**	5.1979	2.8894	**	25.3933	3.5964	**	5.8565	2.8037
140.	5.4736	3.1146	**	5.5971	3.0416	**	27.1769	3.6811	**	6.2619	2.9815
150.	5.8372	3.3088	**	5.9963	3.1930	**	28.9499	3.7617	**	6.6645	3.1560
160.	6.1991	3.4995	**	6.3954	3.3437	**	30.7129	3.8387	**	7.0644	3.3275
170.	6.5595	3.6870	**	6.7945	3.4937	**	32.4667	3.9125	**	7.4620	3.4962
180.	6.9184	3.8714	**	7.1936	3.6430	**	34.2119	3.9834	**	7.8573	3.6624
190.	7.2759	4.0528	**	7.5926	3.7916	**	35.9489	4.0516	**	8.2505	3.8261
200.	7.6321	4.2314	**	7.9916	3.9395	**	37.6782	4.1174	**	8.6417	3.9877
210.	7.9871	4.4073	**	8.3905	4.0867	**	39.4003	4.1809	**	9.0309	4.1472
220.	8.3409	4.5806	**	8.7895	4.2332	**	41.1156	4.2424	**	9.4184	4.3047
230.	8.6935	4.7514	**	9.1884	4.3790	**	42.8242	4.3021	**	9.8042	4.4603
240.	9.0451	4.9198	**	9.5872	4.5241	**	44.5267	4.3599	**	10.1884	4.6143
250.	9.3956	5.0860	**	9.9861	4.6685	**	46.2232	4.4162	**	10.5710	4.7665
260.	9.7451	5.2499	**	10.3845	4.8123	**	47.9140	4.4709	**	10.9521	4.9172
270.	10.0936	5.4117	**	10.6986	4.9553	**	49.5994	4.5242	**	11.3319	5.0664
280.	10.4412	5.5714	**	11.0542	5.0977	**	51.2795	4.5762	**	11.7102	5.2141
290.	10.7878	5.7292	**	11.4095	5.2395	**	52.9546	4.6269	**	12.0873	5.3605
300.	11.1337	5.8850	**	11.7643	5.3805	**	54.6248	4.6764	**	12.4631	5.5056
310.	11.4786	6.0390	**	12.1108	5.5209	**	56.2904	4.7248	**	12.8377	5.6494
320.	11.8228	6.1912	**	12.4729	5.6607	**	57.9515	4.7721	**	13.2111	5.7920
330.	12.1661	6.3416	**	12.8266	5.7997	**	59.6082	4.8185	**	13.5833	5.9335
340.	12.5087	6.4903	**	13.1799	5.9382	**	61.2607	4.8638	**	13.9546	6.0738
350.	12.8505	6.6374	**	13.5328	6.0759	**	62.9091	4.9083	**	14.3247	6.2131
360.	13.1916	6.7830	**	13.8854	6.2131	**	64.5535	4.9519	**	14.6938	6.3513
370.	13.5320	6.9269	**	14.2375	6.3496	**	66.1942	4.9947	**	15.0619	6.4886
380.	13.8718	7.0694	**	14.5893	6.4854	**	67.8311	5.0367	**	15.4291	6.6249
390.	14.2107	7.2104	**	14.9407	6.6206	**	69.4644	5.0780	**	15.7953	6.7603
400.	14.5491	7.3500	**	15.2917	6.7552	**	71.0942	5.1185	**	16.1606	6.8947
410.	14.8868	7.4882	**	15.6424	6.8892	**	72.7205	5.1583	**	16.5250	7.0283
420.	15.2239	7.6251	**	15.9927	7.0225	**	74.3436	5.1975	**	16.8886	7.1611
430.	15.5604	7.7607	**	16.3426	7.1552	**	75.9634	5.2360	**	17.2513	7.2930
440.	15.8963	7.8949	**	16.6921	7.2872	**	77.5800	5.2740	**	17.6132	7.4242
450.	16.2316	8.0280	**	17.0413	7.4187	**	79.1935	5.3113	**	17.9743	7.5545
460.	16.5663	8.1598	**	17.3901	7.5496	**	80.8041	5.3481	**	18.3347	7.6841
470.	16.9005	8.2904	**	17.7385	7.6798	**	82.4117	5.3843	**	18.6943	7.8130
480.	17.2340	8.4199	**	18.0865	7.8094	**	84.0164	5.4201	**	19.0531	7.9412
490.	17.5670	8.5482	**	18.4342	7.9384	**	85.6184	5.4553	**	19.4112	8.0687

"POLYN" Dispersion Coefficients

03763.7012  
 WH(B)-04  
 RW-0  
 P.9



**Northeast  
Utilities System**

107 Selden Street, Berlin, CT 06037

Northeast Utilities Service Company  
P.O. Box 270  
Hartford, CT 06141-0270  
(860) 665-5000

P.10  
03703.700  
VH(B)-04  
DU-0

April 28, 1998

Mr. Joseph Creamer  
Stone and Webster  
245 Summer Street, 7th Floor  
Boston, MA 02210

Dear Mr. Creamer:

Millstone Nuclear Power Station  
Meteorological Data

Accompanying this memo are four computer diskettes containing the meteorological data from 1974 through 1981, for your use in the Millstone Unit 3 X/Q calculations. Each diskette contains two years of data, as noted on the labels. The year of data is represented in each dataset name.

Each line of the datasets represents one hour of data. There is a nine character "time stamp" on each line; columns 1 and 2 are the year, columns 3 through 5 are the Julian day, and columns 6 through 9 are the time (military time, always on Eastern Standard Time). Columns 10 through 54 are, in order, the AT033, WS033, WD033, WS142, WD142, DT142, WS374, WD374, & DT374 (AT = air temperature, WS = wind speed, WD = wind direction, DT = delta-temperature, and numbers are instrument height). These are all in "F5.1" format. Missing data are represented by "999.0."

The data generated by our meteorological monitoring system consist of four fifteen-minute averages per hour. However, the attached datasets only contain one fifteen-minute average per hour. Historically, most of our analyses involving meteorological data, including Category 1 X/Q calculations, have been based on one fifteen-minute average representing an entire hour of data. It was found that this methodology introduced very small errors into the analyses results, compared to calculating an average of the available fifteen-minute averages for each hour.

If you have any questions, please call me, at (860) 665-3183.

Very truly yours,

H. L. Chamberlain, Jr.  
Environmental Services

Enclosures

```
1 //DISTRIB JOB (0031,3),'VIGEANT-SA',
  // MSGLEVEL=2,MSGCLASS=A
  //* RJETRAN.VIG7988.DATA(DISTRIB)
  /*JOBPARM ROOM=3
2 //METRDISK EXEC METRPROC
9 //DISK DD DISP=SHR,DSN=ENVIRONM.METDATA.MILSTONE.YR7481
12 //SYSIN DD * GENERATED STATEMENT
13 //DISTRIB EXEC PGH=DISTRB00,REGION=284K,TIME=1
14 //STEPLIB DD DSN=ENVIRONM.DISTRIB,DISP=SHR
15 //GO.FT06F001 DD DCB=PRINT1,SYSOUT=*
16 //GO.FT10F001 DD UNIT=DISK,DISP=(OLD,DELETE),DSN=&SAMPLE
17 //GO.FT05F001 DD *
18 //IMBLIST EXEC PGH=IMBLIST
19 //SYSPRINT DD SYSOUT=*
20 //SYSLIB DD DSN=ENVIRONM.DISTRIB,DISP=SHR
21 //SYSIN DD * GENERATED STATEMENT
```

01-MAY-98JOB02236

JOB02236

APPENDIX 1  
Distribution Program Output  
Unit 3 Containment Structure to Unit 3 Control Room Air Intake

P. 1  
03703.7002  
WMM(B)-04

*WMM*



```

STMT NO. MESSAGE
      2 IEF001I PROCEDURE METRPROC WAS EXPANDED USING SYSTEM LIBRARY SYS1.USER.PROCLIB
ICH70001I VIG7988 LAST ACCESS AT 12:52:23 ON THURSDAY, MAY 7, 1998
IEF236I ALLOC. FOR DISTRIB METRPROC METRDISK
IGD103I SMS ALLOCATED TO DDNAME STEPLIB
IEF237I JES2 ALLOCATED TO FT06F001
IEF237I JES2 ALLOCATED TO SYSPRINT
IGD103I SMS ALLOCATED TO DDNAME SYS010
IGD101I SMS ALLOCATED TO DDNAME (SYS011..).
      DSN (SYS98127.T125351.RA000.DISTRIB.SAMPLE.H01 )
      STORCLAS (TEMP) MGMTCLAS ( ) DATACLAS ( )
      VOL SER NOS= VIO
IEF237I JES2 ALLOCATED TO FT05F001
IEF142I DISTRIB METRPROC METRDISK - STEP WAS EXECUTED - COND CODE 0000
IGD104I ENVIRONM.METODOLOGY RETAINED, DDNAME=STEPLIB
IEF285I VIG7988.DISTRIB.JOB02236.D0000104.? SYSOUT
IEF285I VIG7988.DISTRIB.JOB02236.D0000105.? SYSOUT
IGD104I ENVIRONM.METDATA.HILSTONE.YR7481 RETAINED, DDNAME=SYS010
IGD106I SYS98127.T125351.RA000.DISTRIB.SAMPLE.H01 PASSED, DDNAME=SYS011
IEF285I VIG7988.DISTRIB.JOB02236.D0000101.? SYSIN
.....
.JOB - DISTRIB , SUBMITTER - VIGEANT-SA , FLOOR - 3 , READER TIME, DATE - 12.53.51, 05/07/98 V09 .
.STEP NUMBER - 1, STEP NAME - METRPROC, PROGRAM NAME - METHR01 , RAN FROM 12.53.52 TO 12.53.55 .
.ENDING CONDITION - RETURN CODE 0, REGION USED - 376K, PERFORMANCE GROUP - 20, SHAPS - 0 .
.PAGEINS - 0, PAGEOUTS - 0, VIO PAGEINS - 0, VIO PAGEOUTS - 0 .
.CPU TIME - .51 VECTOR TIME - .00 SECS, EXCPS -( 352 NON-VIO, 1,169 VIO), CPU UNITS - 1.88 SECS .
.SYSIN RECORDS - 3, OPENS - ( 0 TAPE, 0 TEMP, 0 PERM), COST = $3.13 .
.EXCPS/DDNAME - 9/STEPLIB 343/SYS010 1,169/SYS011 .
.....
IEF373I STEP/METRPROC/START 1998127.1253
IEF374I STEP/METRPROC/STOP 1998127.1253 CPU 0MIN 00.47SEC SRB 0MIN 00.02SEC VIRT 88K SYS 288K EXT 4K SYS 9956K
IEF236I ALLOC. FOR DISTRIB DISTRIB
IGD103I SMS ALLOCATED TO DDNAME STEPLIB
IEF237I JES2 ALLOCATED TO FT06F001
IGD103I SMS ALLOCATED TO DDNAME FT10F001
IEF237I JES2 ALLOCATED TO FT05F001
IEF142I DISTRIB DISTRIB - STEP WAS EXECUTED - COND CODE 0001
IGD104I ENVIRONM.DISTRIB RETAINED, DDNAME=STEPLIB
IEF285I VIG7988.DISTRIB.JOB02236.D0000106.? SYSOUT
IGD105I SYS98127.T125351.RA000.DISTRIB.SAMPLE.H01 DELETED, DDNAME=FT10F001
IEF285I VIG7988.DISTRIB.JOB02236.D0000102.? SYSIN
.....
.JOB - DISTRIB , SUBMITTER - VIGEANT-SA , FLOOR - 3 , READER TIME, DATE - 12.53.51, 05/07/98 V09 .
.STEP NUMBER - 2, STEP NAME - DISTRIB , PROGRAM NAME - DISTRB00, RAN FROM 12.53.55 TO 12.54.00 .
.ENDING CONDITION - RETURN CODE 1, REGION USED - 336K, PERFORMANCE GROUP - 20, SHAPS - 0 .
.PAGEINS - 0, PAGEOUTS - 0, VIO PAGEINS - 0, VIO PAGEOUTS - 0 .
.CPU TIME - 2.35 VECTOR TIME - .00 SECS, EXCPS -( 8 NON-VIO, 1,170 VIO), CPU UNITS - 3.41 SECS .
.SYSIN RECORDS - 16, OPENS - ( 0 TAPE, 0 TEMP, 0 PERM), COST = $5.68 .
.EXCPS/DDNAME - 8/STEPLIB 1,170/FT10F001 .
.....
IEF373I STEP/DISTRIB /START 1998127.1253
IEF374I STEP/DISTRIB /STOP 1998127.1254 CPU 0MIN 02.34SEC SRB 0MIN 00.01SEC VIRT 64K SYS 272K EXT 4K SYS 9964K
IEF236I ALLOC. FOR DISTRIB IMBLIST
IEF237I JES2 ALLOCATED TO SYSPRINT
IGD103I SMS ALLOCATED TO DDNAME SYSLIB
IEF237I JES2 ALLOCATED TO SYSIN
IEF142I DISTRIB IMBLIST - STEP WAS EXECUTED - COND CODE 0008
IEF285I VIG7988.DISTRIB.JOB02236.D0000107.? SYSOUT
IGD104I ENVIRONM.DISTRIB RETAINED, DDNAME=SYSLIB

```

APPENDIX 1  
 Distribution Program Output  
 Unit 3 Containment Structure to Unit 3 Control Room Air Intake

P. 2  
 03703.7002  
 WMM(B)-04  
 NCC-0

IEF285I VIG7988.DISTRIB.JOB02236.D0000103.?

SYSIN

```

.....
JOB - DISTRIB , SUBMITTER - VIGEANT-SA , FLOOR - 3 , READER TIME, DATE - 12.53.51, 05/07/98 V09
STEP NUMBER - 3, STEP NAME - IMBLIST , PROGRAM NAME - IMBLIST , RAN FROM 12.54.00 TO 12.54.00
ENDING CONDITION - RETURN CODE 8, REGION USED - 424K, PERFORMANCE GROUP - 20, SHAPS - 0
PAGEINS - 0, PAGEOUTS - 0, VIO PAGEINS - 0, VIO PAGEOUTS - 0
CPU TIME - .03 VECTOR TIME - .00 SECS, EXCPS -( 0 NON-VIO, 0 VIO), CPU UNITS - .03 SECS
SYSIN RECORDS - 1, OPENS - ( 0 TAPE, 0 TEMP, 0 PERM), COST = $0.05
.....

```

```

IEF373I STEP/IMBLIST /START 1998127.1254
IEF374I STEP/IMBLIST /STOP 1998127.1254 CPU 0MIN 00.03SEC SRB 0MIN 00.00SEC VIRT 156K SYS 268K EXT 4K SYS 9868K
IEF375I JOB/DISTRIB /START 1998127.1253
IEF376I JOB/DISTRIB /STOP 1998127.1254 CPU 0MIN 02.84SEC SRB 0MIN 00.03SEC
.....

```

```

.....
TOTAL CPU TIME - 2.89 SECS, TOTAL VECTOR TIME - .00 SECS, TOTAL CPU UNITS - 5.32 SECS
TOTAL EXCPS -( 360 NON-VIO, 2,339 VIO)
TOTAL JOB COST EXCLUDING PRINT CHARGES = $8.86 CHARGED TO AUTH = 0031 , JO/HO = 022685067
.....

```

APPENDIX 1  
 Distribution Program Output  
 Unit 3 Containment Structure to Unit 3 Control Room Air Intake

P. 3  
 03703.7002  
 WM(B)-04

*Handwritten initials*



STONE & WEBSTER ENGINEERING CORPORATION  
ENVIRONMENTAL ENGINEERING DIVISION

COMPUTER CODE IDENTIFICATION

PROGRAM NAME: SITE DATA RETREIVAL PROGAM  
VERSION OF PROGRAM: 00  
LINK EDIT DATE (JULIAN): 80.184  
DATE OF RUN (MO/DAY/YR): 5/07/98  
JOB NAME OF RUN: DISTRIB

LIBRARY REFERENCE NUMBER: EN-112  
LEVEL OF PROGRAM: 01  
LINK EDIT TIME (HRS.MINS.SECONDS): 14.21.36  
TIME OF RUN (MILITARY): 1253  
JOB02236

APPENDIX 1  
Distribution Program Output  
Unit 3 Containment Structure to Unit 3 Control Room Air Intake

P. 4  
03703.7002  
WM(B)-04

*W-0*

INPUT DATA TRACEBACK

DATA SUBMITTED ON DEVICE: 5

CARD#	1	2	3	4	5	6	7	8
1		2						
2	111	112						
3	74001		81365					

\*\*\*\*\* END OF INPUT ON DEVICE 5 \*\*\*\*\*

*ALD*

INPUT TO METOWER PROGRAM

2  
111 112  
74001 81365

EOF OF INPUT DATA REACHED

NUMBER OF CARDS SELECTED = 5844

NUMBER OF DAYS SELECTED = 2922

APPENDIX 1  
Distribution Program Output  
Unit 3 Containment Structure to Unit 3 Control Room Air Intake

P. 6  
03703.7002  
WM(B)-04

*MSD*



STONE & WEBSTER ENGINEERING CORPORATION  
ENVIRONMENTAL ENGINEERING DIVISION

COMPUTER CODE IDENTIFICATION

PROGRAM NAME: FREQ OF OCCUR OF TWO PARAMETERS  
VERSION OF PROGRAM: 00  
LOAD MODULE: ENVIRONM.DISTRIB  
LINK EDIT DATE (JULIAN): 81.182  
DATE OF RUN (MO/DAY/YR): 5/07/98  
JOB NAME OF RUN: DISTRIB

LIBRARY REFERENCE NUMBER: EN-200  
LEVEL OF PROGRAM: 00  
MEMBER (PGM): DISTRB00  
LINK EDIT TIME (HRS.MINS.SECONDS): 12.11.26  
TIME OF RUN (MILITARY): 1253  
JOB02236

APPENDIX 1  
Distribution Program Output  
Unit 3 Containment Structure to Unit 3 Control Room Air Intake

P. 7  
03703.7002  
WM(B)-04

*W-0*

INPUT DATA TRACEBACK

DATA SUBMITTED ON DEVICE: 5

```

CARD# 1-----2-----3-----4-----5-----6-----7-----8
1      2
2      MILLSTONE NUCLEAR POWER STATION 1974 - 1981 ONSITE DATA
3      33-FT WIND DIRECTION VS. 33-FT WIND SPEED DISTRIBUTION
4      WIND DIRECTION (DEGREES)          3      0 999
5      62 153 360
6      0
7      WIND SPEED      (MPH)      (TENTHS)      99      0 1000
8      5  6  7  8  9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24
9      25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44
10     45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60 61 62 63 64

CARD# 1-----2-----3-----4-----5-----6-----7-----8
11     65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80 81 82 83 84
12     85 86 87 88 89 90 91 92 93 94 95 96 97 98 99 100 110 120 130 140
13     1 999
14     74
15     7400181365      0      0
16     112      0.0      0.0 111      0.0      0.0

CARD# 1-----2-----3-----4-----5-----6-----7-----8
***** END OF INPUT ON DEVICE 5 *****
    
```

APPENDIX 1  
 Distribution Program Output  
 Unit 3 Containment Structure to Unit 3 Control Room Air Intake

P. 8  
 03703.7002  
 WM(B)-04

*AW-2*

\*\*\*\*\* SITE WEATHER DATA \*\*\*\*\*

FIRST YEAR = 1974, JSYR = 74001, JNYR = 81365, JMO1 = 0, JMO2 = 0

TOP PARAMETER CODE = 112    MULT = 1.00000    ADD = 0.0

SIDE PARAMETER CODE = 111    MULT = 1.00000    ADD = 0.0

FIRST DATE RETURNED = 74001

LAST DATE RETURNED = 81365

APPENDIX 1  
Distribution Program Output  
Unit 3 Containment Structure to Unit 3 Control Room Air Intake

P. 9  
03703.7002  
WM(B)-04

*AWD*



MILLSTONE NUCLEAR POWER STATION 1974 - 1981 ONSITE DATA  
 33-FT WIND DIRECTION VS. 33-FT WIND SPEED DISTRIBUTION

WIND SPEED (MPH) (TENTHS)	WIND DIRECTION (DEGREES)				TOTAL
	0- 62	63- 153	154- 360	361- 999	
0 - 5	0	0	0	87	87
PCT CLASS	0.0	0.0	0.0	100.00	100.00
PCT TOTAL	0.0	0.0	0.0	0.13	0.13
6 - 6	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
7 - 7	0	0	0	123	123
PCT CLASS	0.0	0.0	0.0	100.00	100.00
PCT TOTAL	0.0	0.0	0.0	0.19	0.19
8 - 8	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
9 - 9	0	0	0	237	237
PCT CLASS	0.0	0.0	0.0	100.00	100.00
PCT TOTAL	0.0	0.0	0.0	0.36	0.36
10 - 10	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
11 - 11	0	0	0	367	367
PCT CLASS	0.0	0.0	0.0	100.00	100.00
PCT TOTAL	0.0	0.0	0.0	0.55	0.55
12 - 12	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
13 - 13	147	109	265	14	535
PCT CLASS	27.48	20.37	49.53	2.62	100.00
PCT TOTAL	0.22	0.16	0.40	0.02	0.81
14 - 14	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
15 - 15	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0

APPENDIX 1  
 Distribution Program Output  
 Unit 3 Containment Structure to Unit 3 Control Room Air Intake

P. 10  
 03703.7002  
 WM(B)-04

*WMO*

WIND SPEED (MPH) (TENTHS)	WIND DIRECTION (DEGREES)				TOTAL
	0-62	63-153	154-360	361-999	
16 - 16	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
17 - 17	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
18 - 18	215	136	359	11	721
PCT CLASS	29.82	18.86	49.79	1.53	100.00
PCT TOTAL	0.32	0.21	0.54	0.02	1.09
19 - 19	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
20 - 20	241	139	428	13	821
PCT CLASS	29.35	16.93	52.13	1.58	100.00
PCT TOTAL	0.36	0.21	0.65	0.02	1.24
21 - 21	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
22 - 22	206	133	328	6	673
PCT CLASS	30.61	19.76	48.74	0.89	100.00
PCT TOTAL	0.31	0.20	0.49	0.01	1.01
23 - 23	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
24 - 24	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
25 - 25	269	165	553	11	998
PCT CLASS	26.95	16.53	55.41	1.10	100.00
PCT TOTAL	0.41	0.25	0.83	0.02	1.50
26 - 26	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
27 - 27	0	0	1	0	1
PCT CLASS	0.0	0.0	100.00	0.0	100.00
PCT TOTAL	0.0	0.0	0.00	0.0	0.00

63° → 153°  
 ← Cumulative Hours = 517  
 Total Hours = 10,208

APPENDIX 1  
 Distribution Program Output  
 Unit 3 Containment Structure to Unit 3 Control Room Air Intake

P. 11  
 03703.7002  
 WM(B)-04

*Handwritten mark*

WIND SPEED (MPH) (TENTHS)	WIND DIRECTION (DEGREES)				TOTAL
	0- 62	63- 153	154- 360	361- 999	
28 - 28	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
29 - 29	320	214	629	8	1171
PCT CLASS	27.33	18.27	53.71	0.68	100.00
PCT TOTAL	0.48	0.32	0.95	0.01	1.77
30 - 30	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
31 - 31	298	213	643	6	1160
PCT CLASS	25.69	18.36	55.43	0.52	100.00
PCT TOTAL	0.45	0.32	0.97	0.01	1.75
32 - 32	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
33 - 33	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
34 - 34	334	204	733	10	1281
PCT CLASS	26.07	15.93	57.22	0.78	100.00
PCT TOTAL	0.50	0.31	1.11	0.02	1.93
35 - 35	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
36 - 36	342	223	793	11	1369
PCT CLASS	24.98	16.29	57.93	0.80	100.00
PCT TOTAL	0.52	0.34	1.20	0.02	2.06
37 - 37	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
38 - 38	0	1	1	0	2
PCT CLASS	0.0	50.00	50.00	0.0	100.00
PCT TOTAL	0.0	0.00	0.00	0.0	0.00
39 - 39	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0

63° → 153°  
 ← Cumulative Hours = 1,109  
 Total Hours = 10,208  
 1,109/10,208 = 10.9%

*MLC*

WIND SPEED (MPH) (TENTHS)	WIND DIRECTION (DEGREES)				TOTAL
	0- 62	63- 153	154- 360	361- 999	
40 - 40	286	220	808	8	1322
PCT CLASS	21.63	16.64	61.12	0.61	100.00
PCT TOTAL	0.43	0.33	1.22	0.01	1.99
41 - 41	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
42 - 42	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
43 - 43	328	240	868	7	1443 ←
PCT CLASS	22.73	16.63	60.15	0.49	100.00
PCT TOTAL	0.49	0.36	1.31	0.01	2.18
44 - 44	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
45 - 45	211	141	579	7	938 ←
PCT CLASS	22.49	15.03	61.73	0.75	100.00
PCT TOTAL	0.32	0.21	0.87	0.01	1.41
46 - 46	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
47 - 47	331	211	918	9	1469
PCT CLASS	22.53	14.36	62.49	0.61	100.00
PCT TOTAL	0.50	0.32	1.38	0.01	2.21
48 - 48	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
49 - 49	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
50 - 50	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
51 - 51	297	245	870	9	1421
PCT CLASS	20.90	17.24	61.22	0.63	100.00
PCT TOTAL	0.45	0.37	1.31	0.01	2.14

63-153°  
 Cumulative Hours = 2,138  
 Total Hours = 10,208  
 $2,138 / 10,208 = 20.9\%$

APPENDIX 1  
 Distribution Program Output  
 Unit 3 Containment Structure to Unit 3 Control Room Air Intake

P. 13  
 03703.7002  
 WM(B)-04

*W-0*

WIND SPEED (MPH) (TENTHS)	WIND DIRECTION (DEGREES)				TOTAL
	0- 62	63- 153	154- 360	361- 999	
52 - 52	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
53 - 53	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
54 - 54	266	242	905	6	1419
PCT CLASS	18.75	17.05	63.78	0.42	100.00
PCT TOTAL	0.40	0.36	1.36	0.01	2.14
55 - 55	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
56 - 56	282	243	901	13	1439
PCT CLASS	19.60	16.89	62.61	0.90	100.00
PCT TOTAL	0.43	0.37	1.36	0.02	2.17
57 - 57	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
58 - 58	290	244	902	5	1441
PCT CLASS	20.12	16.93	62.60	0.35	100.00
PCT TOTAL	0.44	0.37	1.36	0.01	2.17
59 - 59	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
60 - 60	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
61 - 61	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
62 - 62	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
63 - 63	257	235	915	6	1413
PCT CLASS	18.19	16.63	64.76	0.42	100.00
PCT TOTAL	0.39	0.35	1.38	0.01	2.13

APPENDIX 1  
Distribution Program Output  
Unit 3 Containment Structure to Unit 3 Control Room Air Intake

P. 14  
03703.7002  
WM(B)-04

*W-0*

WIND SPEED (MPH) (TENTHS)	WIND DIRECTION (DEGREES)				TOTAL
	0- 62	63- 153	154- 360	361- 999	
64 - 64	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
65 - 65	263	236	971	8	1478
PCT CLASS	17.79	15.97	65.70	0.54	100.00
PCT TOTAL	0.40	0.36	1.46	0.01	2.23
66 - 66	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
67 - 67	187	171	651	5	1014
PCT CLASS	18.44	16.86	64.20	0.49	100.00
PCT TOTAL	0.28	0.26	0.98	0.01	1.53
68 - 68	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
69 - 69	248	255	977	10	1490
PCT CLASS	16.64	17.11	65.57	0.67	100.00
PCT TOTAL	0.37	0.38	1.47	0.02	2.25
70 - 70	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
71 - 71	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
72 - 72	0	2	0	0	2
PCT CLASS	0.0	100.00	0.0	0.0	100.00
PCT TOTAL	0.0	0.00	0.0	0.0	0.00
73 - 73	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
74 - 74	240	245	970	10	1465
PCT CLASS	16.38	16.72	66.21	0.68	100.00
PCT TOTAL	0.36	0.37	1.46	0.02	2.21
75 - 75	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0

63°-153° ← Cumulative Hours = 3,965  
 Total Hours = 10,208  
 3,965 / 10,208 = 38.8%

APPENDIX 1  
 Distribution Program Output  
 Unit 3 Containment Structure to Unit 3 Control Room Air Intake

P. 15  
 03703.7002  
 WMI(B)-04  
*WMI*

WIND SPEED (MPH) (TENTHS)	WIND DIRECTION (DEGREES)				TOTAL
	0- 62	63- 153	154- 360	361- 999	
76 - 76	226	229	969	8	1432
PCT CLASS	15.78	15.99	67.67	0.56	100.00
PCT TOTAL	0.34	0.35	1.46	0.01	2.16
77 - 77	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
78 - 78	244	213	885	8	1350
PCT CLASS	18.07	15.78	65.56	0.59	100.00
PCT TOTAL	0.37	0.32	1.33	0.01	2.04
79 - 79	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
80 - 80	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
81 - 81	189	228	912	8	1337
PCT CLASS	14.14	17.05	68.21	0.60	100.00
PCT TOTAL	0.28	0.34	1.37	0.01	2.02
82 - 82	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
83 - 83	0	2	2	0	4
PCT CLASS	0.0	50.00	50.00	0.0	100.00
PCT TOTAL	0.0	0.00	0.00	0.0	0.01
84 - 84	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
85 - 85	204	234	900	6	1344
PCT CLASS	15.18	17.41	66.96	0.45	100.00
PCT TOTAL	0.31	0.35	1.36	0.01	2.03
86 - 86	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
87 - 87	202	221	943	4	1370
PCT CLASS	14.74	16.13	68.83	0.29	100.00
PCT TOTAL	0.30	0.33	1.42	0.01	2.07

APPENDIX 1  
Distribution Program Output  
Unit 3 Containment Structure to Unit 3 Control Room Air Intake

P. 16  
03703.7002  
WM(B)-04

*NR-0*

WIND SPEED (MPH) (TENTHS)	WIND DIRECTION (DEGREES)				TOTAL
	0- 62	63- 153	154- 360	361- 999	
88 - 88	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
89 - 89	140	145	636	5	926
PCT CLASS	15.12	15.66	68.68	0.54	100.00
PCT TOTAL	0.21	0.22	0.96	0.01	1.40
90 - 90	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
91 - 91	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
92 - 92	182	177	871	5	1235
PCT CLASS	14.74	14.33	70.53	0.40	100.00
PCT TOTAL	0.27	0.27	1.31	0.01	1.86
93 - 93	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
94 - 94	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
95 - 95	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
96 - 96	193	201	880	6	1280
PCT CLASS	15.08	15.70	68.75	0.47	100.00
PCT TOTAL	0.29	0.30	1.33	0.01	1.93
97 - 97	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
98 - 98	184	191	937	7	1319
PCT CLASS	13.95	14.48	71.04	0.53	100.00
PCT TOTAL	0.28	0.29	1.41	0.01	1.99
99 - 99	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0

APPENDIX 1  
Distribution Program Output  
Unit 3 Containment Structure to Unit 3 Control Room Air Intake

P. 17  
03703.7002  
WM(B)-04

*AWD*



WIND SPEED (MPH) (TENTHS)	WIND DIRECTION (DEGREES)				TOTAL
	0- 62	63- 153	154- 360	361- 999	
100 - 100	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
101 - 110	614	643	3411	14	4682
PCT CLASS	13.11	13.73	72.85	0.30	100.00
PCT TOTAL	0.93	0.97	5.14	0.02	7.06
111 - 120	352	385	2128	8	2873
PCT CLASS	12.25	13.40	74.07	0.28	100.00
PCT TOTAL	0.53	0.58	3.21	0.01	4.33
121 - 130	373	517	2822	20	3732
PCT CLASS	9.99	13.85	75.62	0.54	100.00
PCT TOTAL	0.56	0.78	4.25	0.03	5.63
131 -1000	863	2355	12791	139	16148
PCT CLASS	5.34	14.58	79.21	0.86	100.00
PCT TOTAL	1.30	3.55	19.28	0.21	24.34
TOTAL	9824	<u>10208</u>	45055	1245	<u>66332</u>
PCT CLASS	14.81	15.39	67.92	1.88	100.00
PCT TOTAL	14.81	15.39	67.92	1.88	100.00

← Total Valid Observations

Total Hours for 63° → 153°

APPENDIX 1  
Distribution Program Output  
Unit 3 Containment Structure to Unit 3 Control Room Air Intake

P. 18  
03703.7002  
WM(B)-04  
*Ward*

01-MAY-98JOB00106

```
1 //DISTRIB JOB (0031,3),'VIGEANT-SA',
  // MSGLEVEL=2,MSGCLASS=A
  //* RJETRAN.VIG7988.DATA(DISTRIB)
  /*JOBPARM ROOM=3
2 //METRDISK EXEC METRPROC
9 //DISK DD DISP=SHR,DSN=ENVIRONM.METDATA.MILSTONE.YR7481
12 //SYSIN DD * GENERATED STATEMENT
13 //DISTRIB EXEC PGM=DISTRB00,REGION=284K,TIME=1
14 //STEPLIB DD DSN=ENVIRONM.DISTRIB,DISP=SHR
15 //GO.FT06F001 DD DCB=PRINT1,SYSOOT=*
16 //GO.FT10F001 DD UNIT=DISK,DISP=(OLD,DELETE),DSN=&SAMPLE
17 //GO.FT05F001 DD *
18 //IMBLIST EXEC PGM=IMBLIST
19 //SYSPRINT DD SYSOOT=*
20 //SYSLIB DD DSN=ENVIRONM.DISTRIB,DISP=SHR
21 //SYSIN DD * GENERATED STATEMENT
```

JOB00106

APPENDIX 2  
Distribution Program Output  
Unit 3 Turbine Bldg. Vent to Unit 3 Control Room Air Intake

P. 1  
03703.7002  
WM(B)-04

*W-3*

STMT NO. MESSAGE  
 2 IEF001I PROCEDURE METRPROC HAS EXPANDED USING SYSTEM LIBRARY SYS1.USER.PROCLIB  
 ICH70001I VIG7988 LAST ACCESS AT 15:43:00 ON FRIDAY, MAY 1, 1998  
 IEF236I ALLOC. FOR DISTRIB METRPROC METRDISK  
 IGD103I SMS ALLOCATED TO DDNAME STEPLIB  
 IEF237I JES2 ALLOCATED TO FT06F001  
 IEF237I JES2 ALLOCATED TO SYSPRINT  
 IGD103I SMS ALLOCATED TO DDNAME SYS010  
 IGD101I SMS ALLOCATED TO DDNAME (SYS011 )  
 DSN (SYS98121.T154342.RA000.DISTRIB.SAMPLE.H01 )  
 STORCLAS (TEMP) MGMTCLAS ( ) DATACLAS ( )  
 VOL SER NOS= VIO

IEF237I JES2 ALLOCATED TO FT05F001  
 IEF142I DISTRIB METRPROC METRDISK - STEP WAS EXECUTED - COND CODE 0000  
 IGD104I ENVIRONM.METOLGY RETAINED, DDNAME=STEPLIB  
 IEF285I VIG7988.DISTRIB.JOB00106.D0000104.? SYSOUT  
 IEF285I VIG7988.DISTRIB.JOB00106.D0000105.? SYSOUT  
 IGD104I ENVIRONM.METDATA.MILSTONE.YR7481 RETAINED, DDNAME=SYS010  
 IGD106I SYS98121.T154342.RA000.DISTRIB.SAMPLE.H01 PASSED, DDNAME=SYS011  
 IEF285I VIG7988.DISTRIB.JOB00106.D0000101.? SYSIN


.....  
 .JOB - DISTRIB , SUBMITTER - VIGEANT-SA , FLOOR - 3 , READER TIME, DATE - 15.43.41, 05/01/98 V09 .  
 .STEP NUMBER - 1, STEP NAME - METRPROC, PROGRAM NAME - METWR01 , RAN FROM 15.43.43 TO 15.43.45 .  
 .ENDING CONDITION - RETURN CODE 0, REGION USED - 380K, PERFORMANCE GROUP - 20, SHAPS - 0 .  
 .PAGEINS - 0, PAGEOUTS - 0, VIO PAGEINS - 0, VIO PAGEOUTS - 0 .  
 .CPU TIME - .49 VECTOR TIME - .00 SECS, EXCPS -( 352 NON-VIO, 1,169 VIO), CPU UNITS - 1.86 SECS .  
 .SYSIN RECORDS - 3, OPENS - ( 0 TAPE, 0 TEMP, 0 PERM), COST = \$3.10 .  
 .EXCPS/DDNAME - 9/STEPLIB 343/SYS010 1,169/SYS011 .  
 .....

IEF373I STEP/METRPROC/START 1998121.1543  
 IEF374I STEP/METRPROC/STOP 1998121.1543 CPU 0MIN 00.46SEC SRB 0MIN 00.02SEC VIRT 88K SYS 292K EXT 4K SYS 10132K  
 IEF236I ALLOC. FOR DISTRIB DISTRIB  
 IGD103I SMS ALLOCATED TO DDNAME STEPLIB  
 IEF237I JES2 ALLOCATED TO FT06F001  
 IGD103I SMS ALLOCATED TO DDNAME FT10F001  
 IEF237I JES2 ALLOCATED TO FT05F001  
 IEF142I DISTRIB DISTRIB - STEP WAS EXECUTED - COND CODE 0001  
 IGD104I ENVIRONM.DISTRIB RETAINED, DDNAME=STEPLIB  
 IEF285I VIG7988.DISTRIB.JOB00106.D0000106.? SYSOUT  
 IGD105I SYS98121.T154342.RA000.DISTRIB.SAMPLE.H01 DELETED, DDNAME=FT10F001  
 IEF285I VIG7988.DISTRIB.JOB00106.D0000102.? SYSIN

.....  
 .JOB - DISTRIB , SUBMITTER - VIGEANT-SA , FLOOR - 3 , READER TIME, DATE - 15.43.41, 05/01/98 V09 .  
 .STEP NUMBER - 2, STEP NAME - DISTRIB , PROGRAM NAME - DISTRB00, RAN FROM 15.43.45 TO 15.43.49 .  
 .ENDING CONDITION - RETURN CODE 1, REGION USED - 340K, PERFORMANCE GROUP - 20, SHAPS - 0 .  
 .PAGEINS - 0, PAGEOUTS - 0, VIO PAGEINS - 0, VIO PAGEOUTS - 0 .  
 .CPU TIME - 2.34 VECTOR TIME - .00 SECS, EXCPS -( 8 NON-VIO, 1,170 VIO), CPU UNITS - 3.40 SECS .  
 .SYSIN RECORDS - 16, OPENS - ( 0 TAPE, 0 TEMP, 0 PERM), COST = \$5.67 .  
 .EXCPS/DDNAME - 8/STEPLIB 1,170/FT10F001 .  
 .....

IEF373I STEP/DISTRIB /START 1998121.1543  
 IEF374I STEP/DISTRIB /STOP 1998121.1543 CPU 0MIN 02.33SEC SRB 0MIN 00.01SEC VIRT 64K SYS 276K EXT 4K SYS 10140K  
 IEF236I ALLOC. FOR DISTRIB IMBLIST  
 IEF237I JES2 ALLOCATED TO SYSPRINT  
 IGD103I SMS ALLOCATED TO DDNAME SYSLIB  
 IEF237I JES2 ALLOCATED TO SYSIN  
 IEF142I DISTRIB IMBLIST - STEP WAS EXECUTED - COND CODE 0008  
 IEF285I VIG7988.DISTRIB.JOB00106.D0000107.? SYSOUT  
 IGD104I ENVIRONM.DISTRIB RETAINED, DDNAME=SYSLIB

APPENDIX 2  
 Distribution Program Output  
 Unit 3 Turbine Bldg. Vent to Unit 3 Control Room Air Intake

P. 2  
 03703.7002  
 WM(B)-04  


IEF285I VIG7988.DISTRIB.JOB00106.D0000103.?

SYSIN

```
.....
.JOB - DISTRIB , SUBMITTER - VIGEANT-SA , FLOOR - 3 , READER TIME, DATE - 15.43.41, 05/01/98 V09 .
.STEP NUMBER - 3, STEP NAME - IMBLIST , PROGRAM NAME - IMBLIST , RAN FROM 15.43.49 TO 15.43.49 .
.ENDING CONDITION - RETURN CODE 8, REGION USED - 428K, PERFORMANCE GROUP - 20, SHAPS - 0 .
.PAGEINS - 0, PAGEOUTS - 0, VIO PAGEINS - 0, VIO PAGEOUTS - 0 .
.CPU TIME - .03 VECTOR TIME - .00 SECS, EXCPS -( 0 NON-VIO, 0 VIO), CPU UNITS - .03 SECS .
.SYSIN RECORDS - 1, OPENS - ( 0 TAPE, 0 TEMP, 0 PERM), COST = $0.05 .
.....
IEF373I STEP/IMBLIST /START 1998121.1543 .
IEF374I STEP/IMBLIST /STOP 1998121.1543 CPU 0MIN 00.03SEC SRB 0MIN 00.00SEC VIRT 156K SYS 272K EXT 4K SYS 10044K
IEF375I JOB/DISTRIB /START 1998121.1543
IEF376I JOB/DISTRIB /STOP 1998121.1543 CPU 0MIN 02.82SEC SRB 0MIN 00.03SEC
.....
.TOTAL CPU TIME - 2.86 SECS, TOTAL VECTOR TIME - .00 SECS, TOTAL CPU UNITS - 5.29 SECS .
.TOTAL EXCPS -( 360 NON-VIO, 2,339 VIO) .
.TOTAL JOB COST EXCLUDING PRINT CHARGES = $8.82 CHARGED TO AUTH = 0031 , JO/WD = 022685067
.....
```

APPENDIX 2  
Distribution Program Output  
Unit 3 Turbine Bldg. Vent to Unit 3 Control Room Air Intake

P. 3  
03703.7002  
WMM(B)-04  
*WMM*



STONE & WEBSTER ENGINEERING CORPORATION  
ENVIRONMENTAL ENGINEERING DIVISION

COMPUTER CODE IDENTIFICATION

PROGRAM NAME: SITE DATA RETREIVAL PROGAM  
VERSION OF PROGRAM: 00  
LINK EDIT DATE (JULIAN): 80.184  
DATE OF RUN (MO/DAY/YR): 5/01/98  
JOB NAME OF RUN: DISTRIB

LIBRARY REFERENCE NUMBER: EN-112  
LEVEL OF PROGRAM: 01  
LINK EDIT TIME (HRS.MINS.SECONDS): 14.21.36  
TIME OF RUN (MILITARY): 1543  
JOB00106

APPENDIX 2  
Distribution Program Output  
Unit 3 Turbine Bldg. Vent to Unit 3 Control Room Air Intake

P. 4  
03703.7002  
WM(E)-04

*RW*

INPUT DATA TRACEBACK

DATA SUBMITTED ON DEVICE: 5

```
CARD# 1-----2-----3-----4-----5-----6-----7-----8
      1      2
      2  111 112
      3 74001 81365
CARD# 1-----2-----3-----4-----5-----6-----7-----8
```

\*\*\*\*\* END OF INPUT ON DEVICE 5 \*\*\*\*\*

APPENDIX 2  
Distribution Program Output  
Unit 3 Turbine Bldg. Vent to Unit 3 Control Room Air Intake

P. 5  
03703.7002  
WM(B)-04

*WV*

INPUT TO METONER PROGRAM

2  
111 112  
74001 81365

EOF OF INPUT DATA REACHED

NUMBER OF CARDS SELECTED = 5844

NUMBER OF DAYS SELECTED = 2922

APPENDIX 2  
Distribution Program Output  
Unit 3 Turbine Bldg. Vent to Unit 3 Control Room Air Intake

P. 6  
03703.7002  
WM(B)-04

*W-0*



STONE & WEBSTER ENGINEERING CORPORATION  
ENVIRONMENTAL ENGINEERING DIVISION

COMPUTER CODE IDENTIFICATION

PROGRAM NAME: FREQ OF OCCUR OF TWO PARAMETERS  
VERSION OF PROGRAM: 00  
LOAD MODULE: ENVIRONM.DISTRIB  
LINK EDIT DATE (JULIAN): 81.182  
DATE OF RUN (MO/DAY/YR): 5/01/98  
JOB NAME OF RUN: DISTRIB

LIBRARY REFERENCE NUMBER: EN-200  
LEVEL OF PROGRAM: 00  
MEMBER (PGM): DISTRB00  
LINK EDIT TIME (HRS.MINS.SECONDS): 12.11.26  
TIME OF RUN (MILITARY): 1543  
JOB00106

APPENDIX 2  
Distribution Program Output  
Unit 3 Turbine Bldg. Vent to Unit 3 Control Room Air Intake

P. 7  
03703.7002  
WMM(B)-04

*WMM*



INPUT DATA TRACEBACK

DATA SUBMITTED ON DEVICE: 5

```
CARD# 1-----2-----3-----4-----5-----6-----7-----8
1      2
2      MILLSTONE NUCLEAR POWER STATION 1974 - 1981 ONSITE DATA
3      33-FT WIND DIRECTION VS. 33-FT WIND SPEED DISTRIBUTION
4      WIND DIRECTION (DEGREES)          3      0 999
5      70 185 360
6      0
7      WIND SPEED      (MPH)      (TENTHS)          99      0 1000
8      5  6  7  8  9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24
9      25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44
10     45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60 61 62 63 64
```

```
CARD# 1-----2-----3-----4-----5-----6-----7-----8
11     65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80 81 82 83 84
12     85 86 87 88 89 90 91 92 93 94 95 96 97 98 99 100 110 120 130 140
13     1 999
14     74
15     7400181365      0      0
16     112      0.0      0.0 111      0.0      0.0
```

```
CARD# 1-----2-----3-----4-----5-----6-----7-----8
***** END OF INPUT ON DEVICE 5 *****
```

APPENDIX 2  
Distribution Program Output  
Unit 3 Turbine Bldg. Vent to Unit 3 Control Room Air Intake

*W-0*

P. 8  
03703.7002  
WM(B)-04

\*\*\*\*\* SITE WEATHER DATA \*\*\*\*\*

FIRST YEAR = 1974, JSYR = 74001, JNYR = 81365, JM01 = 0, JM02 = 0

TOP PARAMETER CODE = 112      MULT = 1.00000      ADD = 0.0

SIDE PARAMETER CODE = 111      MULT = 1.00000      ADD = 0.0

FIRST DATE RETURNED = 74001

LAST DATE RETURNED = 81365

APPENDIX 2  
Distribution Program Output  
Unit 3 Turbine Bldg. Vent to Unit 3 Control Room Air Intake

P. 9  
03703.7002  
WMM(B)-04

*WMM*

MILLSTONE NUCLEAR POWER STATION 1974 - 1981 ONSITE DATA  
 33-FT WIND DIRECTION VS. 33-FT WIND SPEED DISTRIBUTION

WIND SPEED (MPH) (TENTHS)	WIND DIRECTION (DEGREES)				
	0- 70	71- 185	186- 360	361- 999	TOTAL
0 - 5	0	0	0	87	87
PCT CLASS	0.0	0.0	0.0	100.00	100.00
PCT TOTAL	0.0	0.0	0.0	0.13	0.13
6 - 6	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
7 - 7	0	0	0	123	123
PCT CLASS	0.0	0.0	0.0	100.00	100.00
PCT TOTAL	0.0	0.0	0.0	0.19	0.19
8 - 8	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
9 - 9	0	0	0	237	237
PCT CLASS	0.0	0.0	0.0	100.00	100.00
PCT TOTAL	0.0	0.0	0.0	0.36	0.36
10 - 10	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
11 - 11	0	0	0	367	367
PCT CLASS	0.0	0.0	0.0	100.00	100.00
PCT TOTAL	0.0	0.0	0.0	0.55	0.55
12 - 12	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
13 - 13	165	123	233	14	535
PCT CLASS	30.84	22.99	43.55	2.62	100.00
PCT TOTAL	0.25	0.19	0.35	0.02	0.81
14 - 14	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
15 - 15	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0

APPENDIX 2  
 Distribution Program Output  
 Unit 3 Turbine Bldg. Vent to Unit 3 Control Room Air Intake

P. 10  
 03703.7002  
 W/M(B)-04

*Handwritten mark*

WIND SPEED (MPH) (TENTHS)	WIND DIRECTION (DEGREES)				TOTAL
	0- 70	71- 185	186- 360	361- 999	
16 - 16	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
17 - 17	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
18 - 18	237	162	311	11	721
PCT CLASS	32.87	22.47	43.13	1.53	100.00
PCT TOTAL	0.36	0.24	0.47	0.02	1.09
19 - 19	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
20 - 20	258	201	349	13	821
PCT CLASS	31.43	24.48	42.51	1.58	100.00
PCT TOTAL	0.39	0.30	0.53	0.02	1.24
21 - 21	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
22 - 22	220	175	272	6	673
PCT CLASS	32.69	26.00	40.42	0.89	100.00
PCT TOTAL	0.33	0.26	0.41	0.01	1.01
23 - 23	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
24 - 24	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
25 - 25	292	232	463	11	998
PCT CLASS	29.26	23.25	46.39	1.10	100.00
PCT TOTAL	0.44	0.35	0.70	0.02	1.50
26 - 26	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
27 - 27	0	0	1	0	1
PCT CLASS	0.0	0.0	100.00	0.0	100.00
PCT TOTAL	0.0	0.0	0.00	0.0	0.00

71° → 185°  
 ← Cumulative Hours = 661  
 Total Hours = 12,724  
 661 / 12,724 = 5.2%

APPENDIX 2  
 Distribution Program Output  
 Unit 3 Turbine Bldg. Vent to Unit 3 Control Room Air Intake

P. 11  
 03703.7002  
 WM(B)-04  
 RUC

WIND SPEED (MPH) (TENTHS)	WIND DIRECTION (DEGREES)				TOTAL
	0- 70	71- 185	186- 360	361- 999	
28 - 28	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
<u>29 - 29</u>	346	303	514	8	1171
PCT CLASS	29.55	25.88	43.89	0.68	100.00
PCT TOTAL	0.52	0.46	0.77	0.01	1.77
30 - 30	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
31 - 31	315	309	530	6	1160
PCT CLASS	27.16	26.64	45.69	0.52	100.00
PCT TOTAL	0.47	0.47	0.80	0.01	1.75
32 - 32	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
33 - 33	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
34 - 34	352	309	610	10	1281
PCT CLASS	27.48	24.12	47.62	0.78	100.00
PCT TOTAL	0.53	0.47	0.92	0.02	1.93
35 - 35	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
36 - 36	366	298	694	11	1369
PCT CLASS	26.73	21.77	50.69	0.80	100.00
PCT TOTAL	0.55	0.45	1.05	0.02	2.06
37 - 37	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
38 - 38	0	1	1	0	2
PCT CLASS	0.0	50.00	50.00	0.0	100.00
PCT TOTAL	0.0	0.00	0.00	0.0	0.00
39 - 39	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0

71° → 185°  
 ← Cumulative Hours = 1,196  
 Total Hours = 12,724  
 1,196 / 12,724 = 9.4%

WMB

WIND SPEED (MPH) (TENTHS)	WIND DIRECTION (DEGREES)				TOTAL
	0- 70	71- 185	186- 360	361- 999	
40 - 40	304	309	701	8	1322
PCT CLASS	23.00	23.37	53.03	0.61	100.00
PCT TOTAL	0.46	0.47	1.06	0.01	1.99
41 - 41	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
42 - 42	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
43 - 43	347	334	755	7	1443
PCT CLASS	24.05	23.15	52.32	0.49	100.00
PCT TOTAL	0.52	0.50	1.14	0.01	2.18
44 - 44	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
45 - 45	219	209	503	7	938
PCT CLASS	23.35	22.28	53.62	0.75	100.00
PCT TOTAL	0.33	0.32	0.76	0.01	1.41
46 - 46	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
47 - 47	343	303	814	9	1469
PCT CLASS	23.35	20.63	55.41	0.61	100.00
PCT TOTAL	0.52	0.46	1.23	0.01	2.21
48 - 48	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
49 - 49	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
50 - 50	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
51 - 51	312	338	762	9	1421
PCT CLASS	21.96	23.79	53.62	0.63	100.00
PCT TOTAL	0.47	0.51	1.15	0.01	2.14

71° → 185°  
 ← Cumulative Hours = 2,422  
 Total Hours = 12,724  
 2,422 / 12,724 = 19.0%

APPENDIX 2  
 Distribution Program Output  
 Unit 3 Turbine Bldg. Vent to Unit 3 Control Room Air Intake

P. 13  
 03703.7002  
 WM(B)-04

*W-0*

WIND SPEED (MPH) (TENTHS)	WIND DIRECTION (DEGREES)				TOTAL
	0- 70	71- 185	186- 360	361- 999	
52 - 52	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
53 - 53	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
54 - 54	274	333	806	6	1419
PCT CLASS	19.31	23.47	56.80	0.42	100.00
PCT TOTAL	0.41	0.50	1.22	0.01	2.14
55 - 55	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
56 - 56	298	309	819	13	1439
PCT CLASS	20.71	21.47	56.91	0.90	100.00
PCT TOTAL	0.45	0.47	1.23	0.02	2.17
57 - 57	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
58 - 58	309	325	802	5	1441
PCT CLASS	21.44	22.55	55.66	0.35	100.00
PCT TOTAL	0.47	0.49	1.21	0.01	2.17
59 - 59	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
60 - 60	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
61 - 61	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
62 - 62	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
63 - 63	269	313	825	6	1413
PCT CLASS	19.04	22.15	58.39	0.42	100.00
PCT TOTAL	0.41	0.47	1.24	0.01	2.13

APPENDIX 2  
 Distribution Program Output  
 Unit 3 Turbine Bldg. Vent to Unit 3 Control Room Air Intake

P. 14  
 03703.7002  
 WM(B)-04

*W-0*

WIND SPEED (MPH) (TENTHS)	WIND DIRECTION (DEGREES)				TOTAL
	0- 70	71- 185	186- 360	361- 999	
64 - 64	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
<u>65 - 65</u>	274	308	888	8	1478
PCT CLASS	18.54	20.84	60.08	0.54	100.00
PCT TOTAL	0.41	0.46	1.34	0.01	2.23
66 - 66	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
67 - 67	194	210	605	5	1014
PCT CLASS	19.13	20.71	59.66	0.49	100.00
PCT TOTAL	0.29	0.32	0.91	0.01	1.53
68 - 68	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
69 - 69	263	317	900	10	1490
PCT CLASS	17.65	21.28	60.40	0.67	100.00
PCT TOTAL	0.40	0.48	1.36	0.02	2.25
70 - 70	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
71 - 71	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
72 - 72	0	2	0	0	2
PCT CLASS	0.0	100.00	0.0	0.0	100.00
PCT TOTAL	0.0	0.00	0.0	0.0	0.00
73 - 73	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
74 - 74	256	301	898	10	1465
PCT CLASS	17.47	20.55	61.30	0.68	100.00
PCT TOTAL	0.39	0.45	1.35	0.02	2.21
75 - 75	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0

← 71° → 185°  
 Cumulative Hours = 5,194  
 Total Hours = 12,724  
 5,194 / 12,724 = 40.8%

*Nur 1*



WIND SPEED (MPH) (TENTHS)	WIND DIRECTION (DEGREES)				TOTAL
	0- 70	71- 185	186- 360	361- 999	
76 - 76	248	259	917	8	1432
PCT CLASS	17.32	18.09	64.04	0.56	100.00
PCT TOTAL	0.37	0.39	1.38	0.01	2.16
77 - 77	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
78 - 78	263	266	813	8	1350
PCT CLASS	19.48	19.70	60.22	0.59	100.00
PCT TOTAL	0.40	0.40	1.23	0.01	2.04
79 - 79	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
80 - 80	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
81 - 81	204	269	856	8	1337
PCT CLASS	15.26	20.12	64.02	0.60	100.00
PCT TOTAL	0.31	0.41	1.29	0.01	2.02
82 - 82	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
83 - 83	0	2	2	0	4
PCT CLASS	0.0	50.00	50.00	0.0	100.00
PCT TOTAL	0.0	0.00	0.00	0.0	0.01
84 - 84	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
85 - 85	213	282	843	6	1344
PCT CLASS	15.85	20.98	62.72	0.45	100.00
PCT TOTAL	0.32	0.43	1.27	0.01	2.03
86 - 86	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
87 - 87	224	255	887	4	1370
PCT CLASS	16.35	18.61	64.74	0.29	100.00
PCT TOTAL	0.34	0.38	1.34	0.01	2.07

*WMM*

WIND SPEED (MPH) (TENTHS)	WIND DIRECTION (DEGREES)				TOTAL
	0- 70	71- 185	186- 360	361- 999	
88 - 88	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
89 - 89	150	175	596	5	926
PCT CLASS	16.20	18.90	64.36	0.54	100.00
PCT TOTAL	0.23	0.26	0.90	0.01	1.40
90 - 90	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
91 - 91	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
92 - 92	190	213	827	5	1235
PCT CLASS	15.38	17.25	66.96	0.40	100.00
PCT TOTAL	0.29	0.32	1.25	0.01	1.86
93 - 93	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
94 - 94	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
95 - 95	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
96 - 96	205	236	833	6	1280
PCT CLASS	16.02	18.44	65.08	0.47	100.00
PCT TOTAL	0.31	0.36	1.26	0.01	1.93
97 - 97	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
98 - 98	198	223	891	7	1319
PCT CLASS	15.01	16.91	67.55	0.53	100.00
PCT TOTAL	0.30	0.34	1.34	0.01	1.99
99 - 99	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0

APPENDIX 2  
Distribution Program Output  
Unit 3 Turbine Bldg. Vent to Unit 3 Control Room Air Intake

P. 17  
03703.7002  
WM(B)-04

*W-0*

WIND SPEED (MPH) (TENTHS)	WIND DIRECTION (DEGREES)				TOTAL
	0-70	71-185	186-360	361-999	
100 - 100	0	0	0	0	0
PCT CLASS	0.0	0.0	0.0	0.0	0.0
PCT TOTAL	0.0	0.0	0.0	0.0	0.0
101 - 110	654	767	3247	14	4682
PCT CLASS	13.94	16.38	69.35	0.30	100.00
PCT TOTAL	0.99	1.16	4.90	0.02	7.06
111 - 120	382	439	2044	8	2873
PCT CLASS	13.30	15.28	71.15	0.28	100.00
PCT TOTAL	0.58	0.66	3.08	0.01	4.33
121 - 130	421	569	2722	20	3732
PCT CLASS	11.28	15.25	72.94	0.54	100.00
PCT TOTAL	0.63	0.86	4.10	0.03	5.63
131 - 1000	975	2745	12289	139	16148
PCT CLASS	6.04	17.00	76.10	0.86	100.00
PCT TOTAL	1.47	4.14	18.53	0.21	24.34
TOTAL	10540	12724	41823	1245	66332
PCT CLASS	15.89	19.18	63.05	1.88	100.00
PCT TOTAL	15.89	19.18	63.05	1.88	100.00

Total Valid Observations (All Sectors)

Total Hours of Winds Between 71° → 185°

APPENDIX 2  
Distribution Program Output  
Unit 3 Turbine Bldg. Vent to Unit 3 Control Room Air Intake

P. 18  
03703.7002  
WM(B)-04

*WV-C*

Attachment 5

Millstone Nuclear Power Station, Unit No. 3

AFFIDAVIT from Stone & Webster Engineering Corp. to Withhold Proprietary  
Information

and

Edited Revision 1 of

ANALYSIS OF CONTAINMENT MIZING RATE DURING A DESIGN BASIS LOCA  
by Stone & Webster Engineering Corporation  
© Stone & Webster Engineering Corporation, 1999,2000

VIA TELECOPY AND NEXT-DAY DELIVERY

Mr. Raymond P. Necci  
Vice President – Nuclear Technical Services  
Northeast Utilities Service Company  
Millstone Nuclear Power Station  
P.O. Box 128  
Waterford, Connecticut 06385

July 5, 2000

SRE-MP3-0003

**SUBJECT: Request for Withholding from the Public Record  
Containment Mixing Model Derivation and Application  
MILLSTONE NUCLEAR POWER STATION - UNIT 3**

References: 1. *Analysis of Containment Mixing Rate During A Design Basis Accident by* Stone & Webster Engineering Corporation, Revision 4

Dear Mr. Necci:

With this letter, Stone & Webster transmits to ref. 1 to Northeast Utilities and requests that this document be withheld from public disclosure in accordance with 10 CFR Part 2, Subpart G, Section 2.790 a (4) and that it be transmitted to the NRC in confidence. We are requesting Northeast Utilities' cooperation in seeking an exemption from public records disclosure for this material, for commercial reasons.

The following information is provided to support classification of ref. 1 as proprietary or privileged commercial as contemplated in the above-noted regulation:

- In previous correspondence, Stone & Webster stated that an earlier revision of ref. 1 document contents cannot be released to third parties without authorization.
- The methodology described in ref. 1 provides the basis for increasing the effectiveness credit for containment spray system in the fission product cleanup function. In very restrictive cases, the model provides the basis for avoiding redesign of the spray system. This makes the Stone & Webster Mixing Model commercially "valuable" to our company.
- The proprietary information contained in this document is not available through public sources.
- The Stone & Webster Mixing Model was developed at an estimated cost to the company of \$250,000.

Stone & Webster Engineers and Constructors, Inc.

245 Summer Street  
Boston, Massachusetts 02210  
Phone: 617.589.5111  
Fax: 617.589.2156  
www.stoneweb.com

- The Stone & Webster Mixing Model constitutes a trade secret and an advancement in the state of the art, and therefore provides this company with a competitive advantage in obtaining and performing similar design projects. Making this model available to the public will forfeit this company's hard-earned competitive advantage.

If you have any questions or require any additional information, please contact Frank Elia at 617-589-7225.

Very truly yours,



James T. Callahan  
Senior Vice President

cc: F. Elia 245/6  
J. T. Creamer 245/7  
J. S. Lunde 245/6  
C. Zappile Chill/30R

**AFFIDAVIT OF JAMES CALLAHAN IN SUPPORT OF APPLICATION FOR WITHHOLDING  
PURSUANT TO 10 C.F.R. PART 2, SUBPART G, SECTION 2.790**

James T. Callahan, being duly sworn, does hereby depose and state:


1. I hold the position of Senior Vice President of Stone & Webster Engineering Corporation, and I am authorized to make the request for withholding accompanying this affidavit.
2. The work underlying the information in question was performed under my authority, and I am responsible for the engineering divisions (s) performing the work.
3. The information that we request be withheld appears in a letter dated July 5, 2000 from the undersigned to Mr. Raymond P. Necce of Northeast Utilities Service Company (letter number SRE-MP3-0003). It comprises this company's analysis of containment mixing rate during a design basis accident.
4. The analysis identified above constitutes a novel advance in the state of the art for such analysis, and as such constitutes a source of competitive advantage for our company in the competition and performance of such work in the industry.

Further affiant sayeth not.



James T. Callahan, Senior Vice President  
Stone & Webster Engineering Corporation

Signed and sworn before me this 5<sup>th</sup> day of July, 2000

  
Notary Public

SUSAN E. VIGORITO  
Notary Public

My Commission Expires October 18, 2002