


**James R. Lemons**  
Manager  
Nuclear Support Services

1650 Calvert Cliffs Parkway  
Lusby, Maryland 20657  
410 495-3693



**Constellation**  
Nuclear

**Calvert Cliffs  
Nuclear Power Plant**

*A Member of the  
Constellation Energy Group*

August 9, 2000

U. S. Nuclear Regulatory Commission  
Washington, DC 20555

**ATTENTION:** Document Control Desk

**SUBJECT:** Calvert Cliffs Nuclear Power Plant  
Unit No. 1; Docket No. 50-317  
Emergency Response Data System

---

The attached revision to the Emergency Response Data System (ERDS) Data Point Library for the Calvert Cliffs Nuclear Power Plant is provided pursuant to 10 CFR Part 50, Appendix E, Section VI.3.a.

The table below provides a brief summary of the changes:

Point Identifier	Unit	Description	Old Range	New Range
F131A	1	RCS Total Flow Channel A	-54.47:154.03% Flow	-53.46:151.16% Flow

The revised ERDS Data Point Library sheet is attached.

Should you have questions regarding this matter, we will be pleased to discuss them with you.

Very truly yours,

JRL/TWG/bjd

Attachment: As Stated

cc: R. S. Fleishman, Esquire  
J. E. Silberg, Esquire  
Director, Project Directorate I-1, NRC  
A. W. Dromerick, NRC  
J. R. Jolicoeur, NRC

H. J. Miller, NRC  
Resident Inspector, NRC  
R. I. McLean, DNR  
J. H. Walter, PSC

A026

## PWR Data Point Library Reference File

Report Date : 07-11-2000

Page : 5

<b>Date:</b>	07/11/2000
<b>Reactor Unit:</b>	CC1
<b>Data Feeder:</b>	CC11
<b>NRC ERDS Parameter:</b>	CORE FLOW
<b>Point ID:</b>	F131A
<b>Plant Specific Point Description:</b>	RCS TOTAL FLOW CH A
<b>Generic / Condition Description:</b>	TOTAL REACTOR COOLANT FLOW
<b>Analog / Digital:</b>	A
<b>ENGR Units / Digital States:</b>	% FLOW
<b>ENGR Units Conversion:</b>	100% RX COOLANT FLOW = 370,000 GPM
<b>Minimum Instrument Range:</b>	-53.46
<b>Maximum Instrument Range:</b>	151.16
<b>Zero Point Reference:</b>	N/A
<b>Reference Point Notes</b>	N/A
<b>Proc or Sens:</b>	S
<b>Number of Sensors:</b>	1
<b>How Processed:</b>	N/A
<b>Sensor Locations</b>	N/A
<b>Alarm / Trip Setpoints:</b>	N/A
<b>NI Detector Power</b>	
<b>Supply Cut-Off Power Level:</b>	N/A
<b>NI Detector Power</b>	
<b>Supply Turn-on Power Level:</b>	N/A
<b>Instrument Failure Mode:</b>	N/A
<b>Temperature Compensation for DP Transmitters:</b>	N
<b>Level Reference Leg:</b>	N/A
<b>Unique System Description:</b>	REACTOR COOLANT FLOW IS DETERMINED BY THE D/P ACROSS THE STEAM GENERATORS. WHERE TOTAL FLOW IS THE SUM OF BOTH LOOP FLOWS.