

Commonwealth Edison Company  
Quad Cities Generating Station  
22710 206th Avenue North  
Cordova, IL 61242-9740  
Tel 309-654-2241



August 11, 2000

SVP-00-128

U. S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, D.C. 20555

Quad Cities Nuclear Power Station, Units 1 and 2  
Facility Operating License Nos. DPR-29 and DPR-30  
NRC Docket Nos. 50-254 and 50-265

Subject: NRC Generic Letter 89-10, "Safety-Related Motor Operated Valve Testing and Surveillance," dated June 28, 1999, Commitment.

Reference: Letter from D. Taylor (ComEd) to USNRC, "Alternative Schedule for Generic Letter 89-10," NRC Docket Nos. 50-237/249, 50-254/265, 50-295/304, 50-373/374, 50-454/455 and 50-456/457, dated September 28, 1990.

During March 2000, a review of the Motor Operated Valve (MOV) program identified that the station was not trending MOV performance as committed to in item H of the referenced letter. The purpose of this letter is to inform the NRC of this deficiency and the corrective actions taken to address the error.

This deficiency occurred due to inadequate follow-up of the original commitment. The noted deficiency was entered into our corrective action program.


Since this discovery, the station has implemented a trending program for MOV performance. Additionally, action items have been created to ensure that procedures are written for the trending program and a trend report is generated on an annual basis.

A064

August 11, 2000  
U.S. Nuclear Regulatory Commission  
Page 2

Should you have any questions concerning this letter, please contact Mr. C.C. Peterson at (309) 654-2241, extension 3609.

Respectfully,

A handwritten signature in cursive script, appearing to read "Joel P. Dimmette, Jr.", with a large, sweeping flourish at the end.

Joel P. Dimmette, Jr.  
Site Vice President  
Quad Cities Nuclear Power Station

cc: Regional Administrator – NRC Region III  
NRC Senior Resident Inspector – Quad Cities Nuclear Power Station