

# WOLF CREEK NUCLEAR OPERATING CORPORATION

Britt T. McKinney  
Vice President Plant Operations and  
Plant Manager

AUG 11 2000

WO 00-0034


U. S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Mail Station P1-137  
Washington, D. C. 20555

Subject: Docket No. 50-482: July, 2000, Monthly  
Operating Report

Gentlemen:

Attached to this letter is the July, 2000, Monthly Operating Report for the Wolf Creek Generating Station. This submittal is being made in accordance with the requirements of Wolf Creek Generating Station Technical Specification 5.6.4, "Monthly Operating Reports." This submittal also follows the guidance of Generic Letter 97-02, "Revised Contents of the Monthly Operating Report." If you have questions regarding this report, please contact me at (316) 364-4112, or Mr. Tony Harris at (316) 364-4038.

Very truly yours,



Britt T. McKinney

BTM/jad

Attachment

cc: J. N. Donohew (NRC), w/a  
W. D. Johnson (NRC), w/a  
E. W. Merschoff (NRC), w/a  
Senior Resident Inspector (NRC), w/a

IE 24

**OPERATING DATA REPORT**

Report Number: 185

**DOCKET NO.:** 50-482  
**UNIT NAME:** Wolf Creek Generating Station  
**DATE:** August 8, 2000  
**COMPLETED BY:** K. W. Hall  
**TELEPHONE:** 316-364-8831, extension 8709

**REPORT MONTH: July, 2000**

1.	Design Electrical Rating (MWe - Net):	1170
2.	Maximum Dependable Capacity (MWe - Net):	1170

		This Month	Year to Date	Cumulative
3.	Number of Hours Reactor Critical:	744.0	5,111.0	110,856.2
4.	Number of Hours Generator On-Line:	744.0	5,111.0	109,833.4
5.	Unit Reserve Shutdown Hours:	0.0	0.0	339.8
6.	Net Electrical Energy Generated (MWH)	865,454	6,032,282	123,661,793

**UNIT SHUTDOWN AND POWER REDUCTIONS**

**DOCKET NO.:** 50-482  
**UNIT NAME:** Wolf Creek Generating Station  
**DATE:** August 8, 2000  
**COMPLETED BY:** K. W. Hall  
**TELEPHONE:** 316-364-8831 extension 8709

No	Date	Type	DURATION (Hours)	REASON (1)	METHOD OF SHUTTING DOWN THE REACTOR (2)	CORRECTIVE ACTIONS/COMMENTS
		F: FORCED S: SCHEDULED				
1	7/29/2000	F	15.75	A	1	Rose Hill transmission line lost due to a broken cross arm on structure 491. Structure repaired and reactor power restored.

**SUMMARY:** The unit operated at approximately 100% power July 1, 2000, through July 29, 2000, at 12:50 p.m. The unit commenced load reduction due to loss of off-site power transmission line (Rose Hill). Off-site power was still available through other transmission lines. At 6:35 p.m., on July 29, 2000, power was at 82%. At 9:05 p.m., on July 29, 2000, the unit commenced increasing turbine load after Rose Hill Line was repaired. Unit restored to 100% power at 4:35 a.m., July 30, 2000.

1) REASON: A: EQUIPMENT FAILURE (EXPLAIN)  
 B: MAINTENANCE OR TEST  
 C: REFUELING  
 D: REGULATORY RESTRICTION

E: OPERATOR TRAINING AND LICENSE EXAMINATION (2) METHOD:  
 F: ADMINISTRATIVE  
 G: OPERATIONAL ERROR (EXPLAIN)  
 H: OTHER (EXPLAIN)

1. MANUAL  
 2. MANUAL SCRAM  
 3. AUTOMATIC SCRAM  
 4. CONTINUATION  
 5. OTHER