



Duke Power
526 South Church Street
P.O. Box 1006
Charlotte, NC 28201-1006

August 14, 2000

U.S Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555

Subject: Duke Energy Corporation
Oconee Nuclear Station, Units 1, 2, and 3
Docket Numbers 50-269, 50-270 and 50-287
Monthly Performance and Operation Status-July, 2000

Please find attached information concerning the performance and operation status of the Oconee Nuclear Station for the month of July, 2000.

Any questions or comments July be directed to Roger A. Williams at (704) 382-5346.

Sincerely,


Terry Dimmery, Manager
Nuclear Business Support

Attachment
XC:

L. A. Reyes, Regional Administrator
USNRC, Region II

Dave LaBarge, Project Manager
USNRC, ONRR

INPO Records Center

Ms. Margaret Aucoin
Nuclear Assurance Corporation

Dottie Sherman, ANI Library
American Nuclear Insurers

Oconee NRC Inspector

JE 24

Document Control Desk
U.S. NRC - Oconee

bxc:

L. E. Nicholson (ON03RC)
RGC Site Licensing File
ELL (EC050)

Operating Data Report

Docket No.	<u>50-269</u>
Date	<u>August 14, 2000</u>
Completed By	<u>Roger Williams</u>
Telephone	<u>704-382-5346</u>

Operating Status

1. Unit Name: Oconee 1
2. Reporting Period: July 1, 2000 - July 31, 2000
3. Licensed Thermal Power (MWt): 2568
4. Nameplate Rating (Gross MWe): 934
5. Design Electrical Rating (Net MWe): 886
6. Maximum Dependable Capacity (Gross MWe): 886
7. Maximum Dependable Capacity (Net MWe): 846
8. If Changes Occured in Capacity Ratings (Items Number 3-7) Since Last Report, Give Reasons:

Notes: Year-to-date and cumulative capacity factors are calculated using a weighted average for maximum dependable capacity.

9. Power Level To Which Restricted, If Any (Net MWe): _____

10. Reason for Restrictions, If any: _____

	This Month	YTD	Cumulative
11. Hours in Reporting Period	744.0	5111.0	237072.0
12. Number of Hours Reactor was Critical	744.0	4729.5	184557.7
13. Reactor Reserve Shutdown Hours	0.0	0.0	0.0
14. Hours Generator On-Line	744.0	4707.7	181321.3
15. Unit Reserve Shutdown Hours	0.0	0.0	0.0
16. Gross Thermal Energy Generated (MWH)	1909976	12076175	447399029
17. Gross Electrical Energy Generated (MWH)	660749	4220170	154656260
18. Net Electrical Energy Generated (MWH)	630683	4033506	147027542
19. Unit Service Factor	100.0	92.1	76.5
20. Unit Availability Factor	100.0	92.1	76.5
21. Unit Capacity Factor (Using MDC Net)	100.2	93.3	72.6
22. Unit Capacity Factor (Using DER Net)	95.7	89.1	70.0
23. Unit Forced Outage Rate	0.0	7.9	9.9
24. Shutdown Scheduled Over Next 6 Months (Type, Date and Duration of Each)			

25. If ShutDown At End Of Report Period, Estimated Date of Startup

26. Units in Test Status (Prior to Commercial Operation)

	Forecast	Achieved
Initial Criticality	_____	_____
Initial Electricity	_____	_____
Commercial Operation	_____	_____

NRC Calculated from Generator Nameplate Data:
 1 037 937 KVA x 0.90 Pf=934 MW

UNIT SHUTDOWNS

DOCKET NO. 50-269

UNIT NAME: Oconee 1

DATE: August 14, 2000

COMPLETED BY: Roger Williams

TELEPHONE: 704-382-5346

REPORT MONTH: July, 2000

No.	Date:	Type F - Forced S - Scheduled	Duration Hours	(1) Reason	(2) Method of Shutdown R/X	Licensed Event Report No.	Cause and Corrective Action to Prevent Recurrence
			No	Outages	for the Month		

Summary:

(1) Reason

- A - Equipment failure (Explain)
- B - Maintenance or Test
- C - Refueling
- D - Regulatory restriction

- E - Operator Training/License Examination
- F - Administrative
- G - Operator Error (Explain)
- H - Other (Explain)

(2) Method

- 1 - Manual
- 2 - Manual Trip/Scram
- 3 - Automatic Trip/Scram
- 4 - Continuation
- 5 - Other (Explain)

MONTHLY REFUELING INFORMATION REQUEST

- 1. Facility name: Oconee Unit 1
- 2. Scheduled next refueling shutdown: November, 2000
- 3. Scheduled restart following refueling: December, 2000

THE PROJECT MANAGER HAS BEEN ADVISED BY SEPARATE COMMUNICATION OF ANY T.S. CHANGE OR LICENSE AMENDMENT. THEREFORE, QUESTIONS 4 THROUGH 6 WILL NO LONGER BE MAINTAINED IN THIS REPORT.

- 4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment?

If yes, what will these be?

If no, has reload design and core configuration been reviewed by Safety Review Committee regarding unreviewed safety questions?

- 5. Scheduled date(s) for submitting proposed licensing action and supporting information.
- 6. Important licensing considerations (new or different design or supplier, unreviewed design or performance analysis methods, significant changes in design or new operating procedures).
- 7. Number of Fuel assemblies (a) in the core: 177
 (b) in the spent fuel pool: 1022*
 (c) in the ISFSI: 1272****
- 8. Present licensed fuel pool capacity: 1312
Size of requested or planned increase: **
- 9. Projected date of last refueling which can be accommodated by present capacity: January 2005***

DUKE POWER COMPANY

DATE: August 14, 2000

Name of Contact: R. A. Williams

Phone: (704) - 382-5346

* Represents the combined total for Units 1 and 2

** On March 29, 1990, received a license for ISFSI which will store 2112 assemblies

*** We currently have 60 modules of which 49 modules are loaded.
Additional modules will be built on an as-needed basis.

**** Represents the combined total for Units 1, 2, and 3

Operating Data Report

Docket No.	50-270
Date	August 14, 2000
Completed By	Roger Williams
Telephone	704-382-5346

Operating Status

1. Unit Name: Oconee 2
2. Reporting Period: July 1, 2000 - July 31, 2000
3. Licensed Thermal Power (MWt): 2568
4. Nameplate Rating (Gross MWe): 934
5. Design Electrical Rating (Net Mwe): 886
6. Maximum Dependable Capacity (Gross MWe): 886
7. Maximum Dependable Capacity(Net MWe): 846
8. If Changes Occured in Capacity Ratings (Items Number 3-7) Since Last Report, Give Reasons:

Notes: Year-to-date and cumulative capacity factors are calculated using a weighted average for maximum dependable capacity.

-
9. Power Level To Which Restricted, If Any (Net MWe): _____
 10. Reason for Restrictions, If any: _____
-

	This Month	YTD	Cumulative
11. Hours in Reporting Period	744.0	5111.0	226992.0
12. Number of Hours Reactor was Critical	744.0	5111.0	181668.3
13. Reactor Reserve Shutdown Hours	0.0	0.0	0.0
14. Hours Generator On-Line	744.0	5111.0	179242.5
15. Unit Reserve Shutdown Hours	0.0	0.0	0.0
16. Gross Thermal Energy Generated (MWH)	1909976	25118740	453343546
17. Gross Electrical Energy Generated (MWH)	663274	4563076	151489419
18. Net Electrical Energy Generated (MWH)	634861	4374171	144306071
19. Unit Service Factor	100.0	100.0	79.0
20. Unit Availability Factor	100.0	100.0	79.0
21. Unit Capacity Factor (Using MDC Net)	100.9	101.2	74.4
22. Unit Capacity Factor (Using DER Net)	96.3	96.6	71.8
23. Unit Forced Outage Rate	0.0	0.0	9.4
24. Shutdown Scheduled Over Next 6 Months (Type, Date and Duration of Each)			

25. If ShutDown At End Of Report Period, Estimated Date of Startup
26. Units in Test Status (Prior to Commercial Operation)

	Forecast	Achieved
Initial Criticality	_____	_____
Initial Electricity	_____	_____
Commercial Operation	_____	_____

NRC Calculated from Generator Nameplate Data:
 1 037 937 KVA x 0.90 Pf=934 MW

UNIT SHUTDOWNS

DOCKET NO. 50-270

UNIT NAME: Oconee 2

DATE: August 14, 2000

COMPLETED BY: Roger Williams

TELEPHONE: 704-382-5346

REPORT MONTH: July, 2000

No.	Date:	Type F - Forced S - Scheduled	Duration Hours	(1) Reason	(2) Method of Shutdown R/X	Licensed Event Report No.	Cause and Corrective Action to Prevent Recurrence
			No	Outages	for the Month		

Summary:

(1) Reason

- A - Equipment failure (Explain)
- B - Maintenance or Test
- C - Refueling
- D - Regulatory restriction

- E - Operator Training/License Examination
- F - Administrative
- G - Operator Error (Explain)
- H - Other (Explain)

(2) Method

- 1 - Manual
- 2 - Manual Trip/Scram
- 3 - Automatic Trip/Scram
- 4 - Continuation
- 5 - Other (Explain)

Operating Data Report

Docket No.	50-287
Date	August 14, 2000
Completed By	Roger Williams
Telephone	704-382-5346

Operating Status

1. Unit Name: Oconee 3
2. Reporting Period: July 1, 2000 - July 31, 2000
3. Licensed Thermal Power (MWt): 2568
4. Nameplate Rating (Gross MWe): 934
5. Design Electrical Rating (Net MWe): 886
6. Maximum Dependable Capacity (Gross MWe): 886
7. Maximum Dependable Capacity (Net MWe): 846
8. If Changes Occured in Capacity Ratings (Items Number 3-7) Since Last Report, Give Reasons:

Notes: Year-to-date and cumulative capacity factors are calculated using a weighted average for maximum dependable capacity.

9. Power Level To Which Restricted, If Any (Net MWe): _____

10. Reason for Restrictions, If any: _____

	This Month	YTD	Cumulative
11. Hours in Reporting Period	744.0	5111.0	224639.0
12. Number of Hours Reactor was Critical	744.0	4221.7	176273.8
13. Reactor Reserve Shutdown Hours	0.0	0.0	0.0
14. Hours Generator On-Line	744.0	4057.7	173688.9
15. Unit Reserve Shutdown Hours	0.0	0.0	0.0
16. Gross Thermal Energy Generated (MWH)	1906278	35418681	458481583
17. Gross Electrical Energy Generated (MWH)	665768	3606355	149823482
18. Net Electrical Energy Generated (MWH)	636575	3441638	142903829
19. Unit Service Factor	100.0	79.4	77.3
20. Unit Availability Factor	100.0	79.4	77.3
21. Unit Capacity Factor (Using MDC Net)	101.1	79.6	74.5
22. Unit Capacity Factor (Using DER Net)	96.6	76.0	71.8
23. Unit Forced Outage Rate	0.0	2.8	9.8
24. Shutdown Scheduled Over Next 6 Months (Type, Date and Duration of Each)			

25. If Shut Down At End Of Report Period, Estimated Date of Startup

26. Units in Test Status (Prior to Commercial Operation)

	Forecast	Achieved
Initial Criticality	_____	_____
Initial Electricity	_____	_____
Commercial Operation	_____	_____

NRC Calculated from Generator Nameplate Data:
 1 037 937 KVA x 0.90 Pf=934 MW

UNIT SHUTDOWNS

DOCKET NO. 50-287

UNIT NAME: Oconee 3

DATE: August 14, 2000

COMPLETED BY: Roger Williams

TELEPHONE: 704-382-5346

REPORT MONTH: July, 2000

No.	Date:	Type F - Forced S - Scheduled	Duration Hours	(1) Reason	(2) Method of Shutdown R/X	Licensed Event Report No.	Cause and Corrective Action to Prevent Recurrence
			No	Outages	for the Month		

Summary:

(1) Reason

- A - Equipment failure (Explain)
- B - Maintenance or Test
- C - Refueling
- D - Regulatory restriction

- E - Operator Training/License Examination
- F - Administrative
- G - Operator Error (Explain)
- H - Other (Explain)

(2) Method

- 1 - Manual
- 2 - Manual Trip/Scram
- 3 - Automatic Trip/Scram
- 4 - Continuation
- 5 - Other (Explain)

OCONEE NUCLEAR STATION

MONTHLY OPERATING STATUS REPORT

JUNE 2000

1. Personnel Exposure -

The total station liquid release for JUNE has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.

The total station gaseous release for JUNE has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.