



**Pacific Gas and
Electric Company**

David H. Oatley
Vice President—Diablo Canyon
Operations and Plant Manager

Diablo Canyon Power Plant
P.O. Box 56
Avila Beach, CA 93424

805.545.6000

August 14, 2000

PG&E Letter DCL-00-111

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555-0001

Docket No. 50-275, DPR-80
Docket No. 50-323, DPR-82
Diablo Canyon Units 1 and 2
Monthly Operating Report for July 2000

Dear Commissioners and Staff:

Attached is the Monthly Operating Report for Diablo Canyon Power Plant, Units 1 and 2, for July 2000. This report is submitted in accordance with Section 5.6.4 of the Units 1 and 2 Technical Specifications and NRC Generic Letter 97-02.

Sincerely,

David H. Oatley

cc: Steven D. Bloom
Robert D. Glynn, Jr.
Kurt Larson
Barbara Lewis
Ellis W. Merschoff
David L. Proulx
Gregory M. Rueger
INPO Record Center

Enclosures

LMP/1713/R0209186

TE24

**JULY 2000, OPERATION SUMMARIES
DIABLO CANYON POWER PLANT
UNITS 1 AND 2**

Summary of Unit 1 Operation

Unit 1 remained in Mode 1 (Power Operation), at approximately 100 percent power during July 2000. There were no significant operational activities.

Summary of Unit 2 Operation

Unit 2 remained in Mode 1, at approximately 100 percent power during July 2000. There were no significant operational activities.

Actuations of Steam Generator Safety or Pressurizer Power Operated Relief Valves

There were no challenges to the steam generator safety valves or pressurizer power operated relief valves.

OPERATING DATA REPORT

DOCKET NO.: 50-275
UNIT NAME: Diablo Canyon Unit 1
DATE: 8/1/2000
COMPLETED BY: L. Parker
TELEPHONE: (805) 545-3386

REPORT MONTH: July 2000

1.	Design Electrical Rating (MWe - Net):	1086
2.	Maximum Dependable Capacity (MWe - Net):	1073

		This Month	YTD	Cumulative
3.	Number of Hours Reactor Critical:	744.0	4834.8	115897.6
4.	Number of Hours Generator On-Line:	744.0	4826.0	114682.9
5.	Unit Reserve Shutdown Hours:	0.0	0.0	0.0
6.	Net Electrical Energy Generated (MWH)	806298	5092487	117892478

UNIT SHUTDOWNS

DOCKET NO.: 50-275
 UNIT NAME: Diablo Canyon Unit 1
 DATE: 8/1/2000
 COMPLETED BY: L. Parker
 TELEPHONE: (805) 545-3386

REPORT MONTH: July 2000

NO.	DATE	TYPE F (Forced) S (Scheduled)	DURATION (HOURS)	REASON ¹	METHOD OF SHUTTING DOWN ²	CAUSE & CORRECTIVE ACTIONS COMMENTS
N/A						There were no shutdowns this month.

1. Reason

- A-Equipment Failure (Explain)
- B-Maintenance or Test
- C-Refueling
- D-Regulatory Restriction
- E-Operator Training/License Examination
- F- Administrative
- G-Operational Error (Explain)
- H-Other (Explain)

2. Method

- 1-Manual
- 2-Manual Trip/Scram
- 3-Automatic Trip/Scram
- 4-Continuation from Previous Month
- 5-Other

OPERATING DATA REPORT

DOCKET NO.: 50-323
UNIT NAME: Diablo Canyon Unit 2
DATE: 8/1/2000
COMPLETED BY: L. Parker
TELEPHONE: (805) 545-3386

REPORT MONTH: July 2000

1.	Design Electrical Rating (MWe - Net):	1119
2.	Maximum Dependable Capacity (MWe - Net):	1087

		This Month	YTD	Cumulative
3.	Number of Hours Reactor Critical:	744.0	5111.0	111088.5
4.	Number of Hours Generator On-Line:	744.0	5111.0	109741.6
5.	Unit Reserve Shutdown Hours:	0.0	0.0	0.0
6.	Net Electrical Energy Generated (MWH)	813435	5560920	115119938

UNIT SHUTDOWNS

DOCKET NO.: 50-323
 UNIT NAME: Diablo Canyon Unit 2
 DATE: 8/1/2000
 COMPLETED BY: L. Parker
 TELEPHONE: (805) 545-3386

REPORT MONTH: July 2000

NO.	DATE	TYPE F (Forced) S (Scheduled)	DURATION (HOURS)	REASON ¹	METHOD OF SHUTTING DOWN ²	CAUSE & CORRECTIVE ACTIONS COMMENTS
N/A						There were no shutdowns this month.

1. Reason

- A-Equipment Failure (Explain)
- B-Maintenance or Test
- C-Refueling
- D-Regulatory Restriction
- E-Operator Training/License Examination
- F- Administrative
- G-Operational Error (Explain)
- H-Other (Explain)

2. Method

- 1-Manual
- 2-Manual Trip/Scram
- 3-Automatic Trip/Scram
- 4-Continuation from Previous Month
- 5-Other