

**ENERGY  
NORTHWEST**

P.O. Box 968 ■ Richland, Washington 99352-0968

August 9, 2000  
GO2-00-138

Docket No. 50-397

U. S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, D. C. 20555

Gentlemen:

Subject: **WNP-2 OPERATING LICENSE NPF-21  
MONTHLY OPERATING REPORT  
JULY 2000**

Transmitted herewith is the Monthly Operating Report for the month of July 2000 as required by Technical Specification 5.6.4.

Respectfully,



G. O. Smith  
Vice President, Generation  
Mail Drop 927M

cc: EW Merschhoff - NRC RIV  
JS Cushing - NRR  
NRC Sr. Resident Inspector - 927N  
TC Poindexter - Winston & Strawn  
INPO  
ANI Library  
Utility Data Institute  
DL Williams - BPA / 1399

IE24

**OPERATING STATUS REPORT**  
for WNP-2

Date: August 1, 2000

---

1. Docket: 50-397
  2. Reporting Period: July 2000
  3. Utility Contact: **Bernice Kasko** (509) 377-4473
  4. Design Electrical Rating (Net MW<sub>e</sub>): 1153
  5. Maximum Dependable Capacity - summer (Net MW<sub>e</sub>): 1107
- |  | MONTH | YEAR | CUMULATIVE |
|--|-------|------|------------|
|--|-------|------|------------|
10. Challenges to safety/relief valves: None

## UNIT SHUTDOWNS

DOCKET NO.: 50-397  
 UNIT NAME: WNP-2  
 DATE: August 1, 2000  
 COMPLETED BY: B Kasko  
 TELEPHONE: (509) 377-4473

REPORT PERIOD: July, 2000

No.	Date	Type F: Forced S: Scheduled	Duration (Hours)	Reason (1)	Method (2)	Cause and Corrective Action To Prevent Recurrence
00-01	6/26/00	F	77.9	A	4	scram due to the erroneous indication of phase current mismatch in station electrical output due to a ground fault in a current transformer lead.

**SUMMARY:** Synchronized and connected main generator to grid at 05:54 July 4, 2000.  
 Achieved full reactor power on 6-July-2000

**(1) REASON**

A - Equipment Failure  
 B - Maintenance or Test  
 C - Refueling  
 D - Regulatory Restriction  
 E - Operator Training &  
     License Examination  
 F - Administration  
 G - Operational Error  
 H - Other

**(2) METHOD**

1 - Manual  
 2 - Manual Scram  
 3 - Auto Scram  
 4 - Continued  
 5 - Reduced Load  
 9 - Other