



August 16, 2000  
RC-00-0284

Document Control Desk  
U. S. Nuclear Regulatory Commission  
Washington, DC 20555

Gentlemen:

Subject: VIRGIL C. SUMMER NUCLEAR STATION  
DOCKET NO. 50/395  
OPERATING LICENSE NO. NPF-12  
SPECIAL REPORT 2000-03

Stephen A. Byrne  
Vice President  
Nuclear Operations  
803.345.4622

South Carolina Electric and Gas Company is submitting this Special Report pursuant to the requirements of Technical Specification 3.3.3.4, Action a.

On August 2, 2000, at 0500 hours, the Meteorological Site Number One 10-40 Meter Delta -T channel (IUR08503), 10-61 Meter Delta -T channel (IUR08505), 61 Meter Level Wind Direction Transmitter (IZT08503B), and 61 Meter Level Wind Speed Transmitter (IST08503A) were declared inoperable. These equipment failures occurred due to a lightning strike, and resulted in the equipment being out of service for greater than seven days.

The equipment was repaired and declared operable on August 11, 2000, at 2015 hours.

If you require further information, please contact Mr. Kelley Marsh at (803) 345-4796.

Very truly yours,

Stephen A. Byrne

RKM/SAB/mb

IE22

**NUCLEAR EXCELLENCE - A SUMMER TRADITION!**

South Carolina Electric & Gas Co  
Virgil C. Summer Nuclear Station  
P. O. Box 88  
Jenkinsville, South Carolina  
29065

803.345.4344  
803.345.5209  
www.scana.com

Document Control Desk  
SPR 2000-03  
RC-00-0284  
Page 2 of 2

c: J. L. Skolds  
T. G. Eppink  
R. J. White  
L. A. Reyes  
K. R. Cotton  
NRC Resident Inspector  
J. B. Knotts, Jr.  
INPO Records Center  
RTS (L-00-0991)  
File (818.08)  
DMS (RC-00-0284)