

August 25, 2000

Mr. W. R. McCollum, Jr.
Vice President, Oconee Site
Duke Energy Corporation
7800 Rochester Highway
Seneca, SC 29672

SUBJECT: REVISION TO TECHNICAL SPECIFICATION BASES B 3.8.3 - OCONEE
NUCLEAR STATION, UNITS 1, 2, AND 3

Dear Mr. McCollum:

By letter dated August 9, 2000, you informed the staff of a change to the Oconee Nuclear Station, Units 1, 2, and 3 Technical Specifications (TS) that only affects the Bases of TS 3.8.3, DC Sources - Operating. The change revises the Bases by adding the clarification that temporary alignment of both battery chargers to the same train of input power for testing or maintenance is allowed provided that both batteries meet the requirements for energizing their respective panelboards as stated in LCO B.3.8.8.

The purpose of this letter is to distribute the enclosed TS page and List of Effective Pages to the appropriate TS manual holders.

Sincerely,

/RA/

David E. LaBarge, Senior Project Manager, Section 1
Project Directorate II
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. 50-269, 50-270, and 50-287

Enclosure: Revised Bases Page and List of Effective Pages

cc w/encl: See next page

August 25, 2000

Mr. W. R. McCollum, Jr.
Vice President, Oconee Site
Duke Energy Corporation
7800 Rochester Highway
Seneca, SC 29672

SUBJECT: REVISION TO TECHNICAL SPECIFICATION BASES B 3.8.3 - OCONEE
NUCLEAR STATION, UNITS 1, 2, AND 3

Dear Mr. McCollum:

By letter dated August 9, 2000, you informed the staff of a change to the Oconee Nuclear Station, Units 1, 2, and 3 Technical Specifications (TS) that only affects the Bases of TS 3.8.3, DC Sources - Operating. The change revises the Bases by adding the clarification that temporary alignment of both battery chargers to the same train of input power for testing or maintenance is allowed provided that both batteries meet the requirements for energizing their respective panelboards as stated in LCO B.3.8.8.

The purpose of this letter is to distribute the enclosed revised TS page and List of Effective Pages to the appropriate TS manual holders.

Sincerely,
/RA/

David E. LaBarge, Senior Project Manager, Section 1
Project Directorate II
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. 50-269, 50-270, and 50-287

Enclosure: Revised Bases Page and List of Effective Pages

cc w/encl: See next page

Distribution:

PUBLIC
PDII-1 RF (paper copy)
RidsNrrDlpmLpdii
RidsNrrDlpmLpdii1
RidsNrrPMDLaBarge
RidsNrrLAHawes
RidsOgcRp
G. Hill (6 paper copies)
Document Name: G:\PDII-1\OCONEE\BAS CHG22 OCO.WPD

RidsNRRWBeckner
RidsAcrsAcnwmMail Center
RidsRegionIIMailCenter

To receive a copy of this document, indicate in the box:

"C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	PM:PDII/S1	C	LA:PDII/S1	SC:PDII/S1
NAME	DLaBarge:mw		CHawes	REmch
DATE	08/25/00		08/25/00	08/25/00

OFFICIAL RECORD COPY

Oconee Nuclear Station

cc:

Ms. Lisa F. Vaughn
Legal Department (PBO5E)
Duke Energy Corporation
422 South Church Street
Charlotte, North Carolina 28201-1006

Anne W. Cottingham, Esquire
Winston and Strawn
1400 L Street, NW
Washington, DC 20005

Mr. Rick N. Edwards
Framatome Technologies
Suite 525
1700 Rockville Pike
Rockville, Maryland 20852-1631

Manager, LIS
NUS Corporation
2650 McCormick Drive, 3rd Floor
Clearwater, Florida 34619-1035

Senior Resident Inspector
U. S. Nuclear Regulatory
Commission
7812B Rochester Highway
Seneca, South Carolina 29672

Virgil R. Autry, Director
Division of Radioactive Waste Management
Bureau of Land and Waste Management
Department of Health and Environmental
Control
2600 Bull Street
Columbia, South Carolina 29201-1708

Mr. L. E. Nicholson
Compliance Manager
Duke Energy Corporation
Oconee Nuclear Site
7800 Rochester Highway
Seneca, South Carolina 29672

Ms. Karen E. Long
Assistant Attorney General
North Carolina Department of
Justice
P. O. Box 629
Raleigh, North Carolina 27602

Mr. C. Jeffrey Thomas
Manager - Nuclear Regulatory
Licensing
Duke Energy Corporation
526 South Church Street
Charlotte, North Carolina 28201-1006

Mr. Richard M. Fry, Director
Division of Radiation Protection
North Carolina Department of
Environment, Health, and
Natural Resources
3825 Barrett Drive
Raleigh, North Carolina 27609-7721

Mr. Steven P. Shaver
Senior Sales Engineer
Westinghouse Electric Company
5929 Carnegie Blvd.
Suite 500
Charlotte, North Carolina 28209