

CONFIRMATORY ANALYSIS:

ANO-2 Design Basis Accident Containment Response

Prepared for

U.S. Nuclear Regulatory Commission
Rockville, Maryland

Prepared by

D. V. Rao
M. T. Leonard
Probabilistic Risk and Hazard Analysis Group
Technology and Safety Assessment Division
Los Alamos National Laboratory
Los Alamos, New Mexico

August 2000

CONTENTS

1. INTRODUCTION	1
1.1. Background.....	1
1.2. Objective and Scope of Confirmatory Analysis	1
2. APPROACH	2
2.1. Containment Geometry and Structures	2
2.2. Engineered Safety Features	2
2.3. Mass/Energy Sources	3
2.4. Other Boundary Conditions	4
3. RESULTS OF CONFIRMATORY ANALYSIS.....	5
3.1. Large-Break Loss-of-Coolant Accident.....	5
3.1.1. Modeling Variables.....	5
3.1.2. Baseline Results	8
3.1.3. Sensitivity to Key Modeling Parameters	9
3.1.4. Summary of Loss-of-Coolant Accident Results.....	12
3.2. Main Steam Line Break	15
3.2.1. Modeling Variables.....	15
3.2.2. Baseline Results	15
3.2.3. Sensitivity to Key Modeling Parameters	17
3.2.4. Summary of Main Steam Line Break Results	17
4. DISCUSSION OF RESULTS.....	20
5. CONCLUSIONS	20
REFERENCES.....	20
APPENDIX A: MELCOR INPUT DATA.....	A-1
APPENDIX B: CHANGES IN INPUT DATA BETWEEN THE ORIGINAL LICENSEE SUBMITTAL (NOVEMBER 1999) AND THE SUPPLEMENT (JUNE 2000).....	B-1

CONFIRMATORY ANALYSIS: ANO-2 Design Basis Accident Containment Response

1. INTRODUCTION

Entergy Operations, Inc., the licensee for Arkansas Nuclear One, Unit 2 (ANO-2), has requested US Nuclear Regulatory Commission (NRC) approval of a license amendment associated with the ANO-2 Replacement Steam Generator Project (Entergy 1999). The amendment addresses the containment's post-accident response resulting from the new steam generators that will be installed beginning with operating Cycle 15. The pivotal element of the license amendment request is an increase in the containment design pressure from 54 to 59 psig. The licensee has determined the increased containment design pressure to be an unreviewed safety question (USQ) in compliance with 10 CFR 50.59, which requires NRC review and approval before implementation.

The licensee submitted structural response analyses that support the higher containment design pressure. The licensee also updated the calculations of peak containment pressure during established design-basis events that demonstrate the peak pressures to be lower than the revised design pressure of the containment. These calculations were performed with computer programs that have been approved by the NRC. However, because of the importance to safety of an intact containment following an accident and because the results of a computer calculation depend to a large extent on the detailed modeling and assumptions used in it, independent confirmatory calculations were performed to verify the licensee's conclusions. The confirmatory calculations are described here.

After the calculations described in the main body of this report were completed, the licensee submitted a supplement to their amendment request (Entergy 2000). The supplement described corrections to two assumptions in computer model input. Other changes in plant input and modeling assumptions also were made to "offset the effects of these corrections." Additional confirmatory calculations were performed to examine these changes, which are described in Appendix B.

1.1. Background

Corrosion-related phenomena have degraded the ANO-2 heat-transfer capability and therefore the net thermal power generated by plant to the extent that the licensee has decided to replace the original steam generators with new ones. The replacement steam generators have larger primary and secondary inventories than the original steam generators. From a safety analysis perspective, the larger coolant inventories represent an increase in the stored energy available for release to the containment during a design-basis loss of coolant accident (LOCA). In addition, the licensee plans to increase the power level of ANO-2 from 2815 MWt to 3026 MWt.

These changes in plant characteristics result in an increase in the containment pressure associated with the postulated accidents that are part of the ANO-2 licensing basis, with peak pressures exceeding the current design pressure for several scenarios. In particular, peak pressure for the design-basis events that determine the bounding structural loads on the containment were identified in the amendment request to be 57.7 psig. The licensee rounded this value to 58 psig for defining the peak containment accident pressure (1 psi below the new design pressure of 59 psig).

1.2. Objective and Scope of Confirmatory Analysis

The objective of the analysis described here is to provide independent calculations of the peak pressure and temperature inside the ANO-2 containment associated with design-basis LOCA and main steam line break (MSLB) accident scenarios. Differences in results from those submitted by the licensee, if any, are identified and explained.

2. APPROACH

Calculations of containment response to design-basis accident (DBA) scenarios were performed using the MELCOR 1.8.4 computer code. MELCOR provides a robust framework for calculating nonequilibrium thermodynamic behavior in the containment and heat transfer to bounding structures, including the effects of engineered safeguard systems. Further, MELCOR provides the requisite flexibility to examine the effects of alternative assumptions and modeling uncertainties on calculated results. The convenience afforded by MELCOR for this purpose is the primary reason for using it in lieu of the CONTAIN computer code (Murata 1997). Recent comparative analysis performed by Sandia National Laboratories has shown that the two codes generate sufficiently similar results for the current objectives (Gauntt 1999). Potential deficiencies in containment wall condensation modeling identified by the MELCOR peer review are mitigated by the fact that wall heat-transfer coefficients were specified through user input in the current analysis (Boyack 1992). A listing of the ANO-2 MELCOR model is given in Appendix A.

2.1. Containment Geometry and Structures

The free volume within the ANO-2 containment is represented by a single thermodynamic control volume. Treatment of the entire containment free volume as a single (iso-thermal, uniformly mixed) control volume is consistent with the vendor analysis. More detailed subcompartment analysis was not practical because geometric information needed to subdivide the containment volume was absent. The containment sump is not represented as a distinct thermodynamic control volume. Water that falls to the containment floor from operation of containment sprays or drains from films on structure surfaces collects in the sump. Alternatively, in the LOCA simulations, water is sourced directly to the sump during the reflood/post-reflood periods, which accounts for discharge from the reactor coolant system (RCS). In all cases, a nonequilibrium thermodynamic solution to the control volume conservation equations allows the sump water to have a different temperature from the atmosphere. Mass transfer between the sump water and the containment atmosphere (i.e., evaporation or condensation) is modeled. For the LOCA simulations, the volume of the reactor vessel and other RCS internals is not represented in the model, which is consistent with the conservative assumptions applied in the licensee analysis.

A total of 20 one-dimensional heat structures was defined to model the effects of heat transfer between the containment atmosphere and surfaces such as the containment walls, floors, and equipment. These structures directly mimic those described in Table 6.2-8D of the licensee submittal. Heat transfer between these surfaces and the atmosphere or sump water was modeled using specified values for surface coefficients. Values for surface coefficients were derived from guidance provided in NUREG-0800. Surface coefficients were treated as an uncertain parameter in the current analysis, and the effects of alternative, credible values are examined in the results described in Sec. 3.

2.2. Engineered Safety Features

Containment heat removal by the operation of containment air coolers and containment sprays was modeled based on information provided in the licensee submittal. Air cooler performance was modeled by a simple tabular function of heat removal rate as a function of inlet (containment atmosphere) temperature. Performance data were taken from Table 6.2-8I in the licensee submittal. Heat removal rate is also a weak function of service water (SW) temperature. This effect was not modeled explicitly in the current analysis, and the effects of changing SW temperature were examined through sensitivity analysis (see Sec. 3). One of two trains of containment air coolers was assumed to operate in the LOCA and MSLB analyses.

Containment spray operation was modeled using the Spray Package in MELCOR. Spray flow rates in the injection mode and recirculation modes were modeled as defined in Tables 6.2-8F and 6.2-9A of the licensee submittal (i.e., 1875 gal./min and 2000 gal./min, respectively). In the LOCA simulations, switch-over of suction from the refueling water tank (RWT) to the containment sump was specified to occur at the time derived from the licensee analysis (2707.62 s). An independent calculation of time to switchover

was not possible because of the absence of information regarding the depletion of the RWT inventory by emergency coolant system (ECS) operation. The change in spray droplet size accompanying the increase in flow rate from injection to recirculation spray was modeled as specified in the submittal. One of two trains of containment spray was assumed to operate in the LOCA and MSLB analyses.

Actuation of either system was modeled explicitly, including the appropriate containment pressure signals and delay times.

2.3. Mass/Energy Sources

Mass and energy sources to the containment were developed from data provided in the licensee submittal. In the current analysis, mass and energy sources associated with the discharge of steam and/or water to the containment were defined in terms of integral quantities (i.e., cumulative mass or energy as a function of time). These quantities were taken directly from Tables 6.2-8B and 6.2-9B in the licensee submittal for the LOCA and MSLB scenarios, respectively.

Two additional sources of energy to the containment atmosphere are represented in the LOCA analysis. One is the release of sensible heat from RCS structures. Three elements of the energy source were defined.

- Residual energy associated with the pressurizer
- Residual stored energy associated with the RCS loop and the steam generator
- Residual energy associated with the reactor vessel upper head and its miscellaneous hardware

The total quantities of energy involved are given in Table 6.2-8B of the licensee submittal, but neither the rates nor the time periods over which these energies are released are described. In the baseline analysis described in Sec. 3, it is assumed that these quantities of energy are added to the containment atmosphere at an even rate over a period of 1 h.¹ A sensitivity calculation was performed to examine the extent to which the results might change if more rapid energy release rates are assumed.

The second additional source of energy to the containment atmosphere in the LOCA simulations is decay heat. The energy source associated with decay heat was specified as the product of the rated core power and a normalized decay heat curve developed from Branch Technical Position ASB 9-2 (shown in Fig. 6.2-11 of the licensee submittal). Two values of rated core power were examined here, the current power level of 2815 MWt and the proposed up-rate level of 3026 MWt. In either case, long-term containment response was calculated assuming that the decay heat corresponding to 102% of rated power is added directly to the containment atmosphere.

Sources of mass and energy to the containment from each of these sources (with the single exception of decay heat) are shown in Fig. 2.1 in the form of cumulative quantities. The sources are more diverse in the LOCA scenario than in the MSLB scenario, but the total amount of mass/energy imparted to the atmosphere is very similar in both cases.

¹The time at which energy release begins differs among the three sources as described in Sec. 6.2.1.1.3.1.1.1 of the licensee submittal.




Fig. 2.1. Cumulative Mass/Energy Source to Containment (LOCA on the Left, MSLB on the Right).

2.4 Other Boundary Conditions

The current ANO-2 technical specifications allow containment leakage up to 0.1% of the containment volume per day. However, the containment was assumed to be leak tight in the current analysis. A sensitivity calculation was performed to examine the effect of leakage on containment peak pressure.

3. RESULTS OF CONFIRMATORY ANALYSIS

The results of the confirmatory analysis of the LOCA are described in Sec. 3.1. The results of calculations for the DBA MSLB are described in Sec. 3.2.

3.1. Large-Break Loss-of-Coolant Accident

The limiting conditions for the large-break LOCA in terms of emergency safety feature (ESF) availability and operating conditions were evaluated and defined in the licensee submittal (e.g., the number of available trains of ESF systems). These conditions were adopted for our analyses without change. For the limited DBA, a baseline calculation was established that applies the general modeling guidelines outlined in the Standard Review Plan (SRP). These guidelines also were followed in the licensee analysis. Several additional calculations were performed to evaluate the extent to which peak containment pressure is sensitive to model input concerning key boundary conditions and modeling assumptions.

A description of the modeling assumptions used in the baseline calculations and subsequent sensitivity calculations is given in Sec. 3.1.1. Key results from the baseline calculation are described in Sec. 3.1.2, and the results of the sensitivity calculations are described in Sec. 3.1.3. A summary of all the calculated results is given in Sec. 3.1.4.

3.1.1. Modeling Variables

The parameters that were varied in these calculations are summarized in Table 3.1 and discussed below.

Rated Power. The licensee plans to submit a separate amendment request addressing a power up-rate from the current value of 2815 MW_t to 3026 MW_t. Nevertheless, the analyses supporting the current amendment request were based on an assumption that the up-rate will occur. The decay heat level used in the confirmatory calculations also was based on a rated power of 3026 MW_t. A sensitivity calculation was performed with the rated power reduced to the currently approved level to approximate the effect of this change on containment pressure².

Table 3.1. Variables in the LOCA Calculations.

<i>Variable</i>	<i>SRP Baseline</i>	<i>Sens1</i>	<i>Sens2</i>	<i>Sens3</i>	<i>Sens4</i>	<i>Sens5</i>	<i>Sens6</i>	<i>Sens7</i>	<i>Sens8</i>
Rated Power (MW)	3026	3026	2815	3026	3026	3026	3026	3026	3026
Service Water Temp (°F)	110	120	110	110	110	110	120	120	120
RCS Sensible Heat Addition Time (min)	60	60	60	10	60	60	60	60	60
Heat Structure Film	Yes	Yes	Yes	Yes	No	Yes	No	No	No
Structure Surface Coefficient	Tagami & Uchida	Tagami & Uchida	Tagami & Uchida	Tagami & Uchida	Tagami & Uchida	Tagami decays to 5.0*	Tagami decays to 5.0	Tagami decays to 5.0	Tagami decays to 5.0
Steel/Concrete Gap Conductance*	100.	100.	100.	100.	100.	100.	100,000	100.	100.
Containment Leakage (vol-%/day)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1

²This approach does not account for differences in energy stored in reactor fuel.

Service Water Temperature. In the licensee analysis, containment heat removal through the air coolers was calculated using a model that accounts for time-dependent changes in SW temperature and therefore cooler performance. The results of their analysis indicate that SW temperature increases linearly from an initial value of ~100°F to ~120°F over a period of 1 day (refer to Fig. 6.2-8B in the submittal). This time period is very long in comparison to the period of interest to the present analysis. Consequently, a simpler, conservative approach was taken. In the confirmatory calculations; the SW temperature was assumed to remain constant. In the baseline calculation, SW temperature was assumed to be 110°F (i.e., the average value calculated in the licensee's analysis). Sensitivity calculations also were performed assuming a constant SW temperature of 120°F.

RCS Sensible Heat Addition. As described above, the time period over which stored energy in the RCS and steam generator structures is released to the containment atmosphere is not specified in the submittal. A 1-h release period was assumed in the baseline calculation. A sensitivity calculation was performed assuming a 10-min release period.

Heat Structure Films. In the COPATTA analysis performed by the licensee, condensate on containment structures is transferred to the sump immediately upon formation. The effects of film development and drainage were not taken into account. In the baseline confirmatory calculation, condensate films were allowed to develop and gradually drain to the sump as allowed in the default MELCOR models. However, the effects of film conductance on structure heat transfer were examined in sensitivity calculations in which the maximum film thickness was set to 10⁻⁶ mm (i.e., no film).

Heat Structure Surface Coefficient. Specific guidelines are not provided in the SRP for modeling condensing heat transfer on containment structures to calculate peak (maximum) containment pressure. However, a correlation by Tagami for the blowdown period of a LOCA and data by Uchida for the reflood and post-reflood periods are recognized standards for this purpose. These coefficients were used in the baseline confirmatory analysis as follows.

- Blowdown period (0–14.9 s): A linear ramp from an initial value of 8 Btu/h-ft²-°F to a maximum value defined by the Tagami correlation.

$$h_{\text{Tagami}} = 72.5 (Q/V t_p)^{0.62} \quad (1)$$

where

- h_{max} = maximum blowdown coefficient
- Q = primary coolant energy (Btu) (3.00E8 Btu including residual energy stored in the pressurizer)
- V = net free containment volume (ft³) (1.778E6 ft³)
- t_p = time interval to end of blowdown (s) (14.9 s)

- Reflood and post-reflood (14.9 s onward): An exponential transition to the Uchida correlation as follows.

$$h_{\text{longterm}} = h_{\text{Uchida}} + (h_{\text{Tagami}} - h_{\text{Uchida}}) \exp\{-0.025(t-t_p)\} \quad (2)$$

where h_{Uchida} = a function of the air-to-steam mass ratio in the containment atmosphere.³

³Data for the Uchida coefficients are taken directly from Branch Technical Position CSB 6-1 (Rev. 2).

Time-dependent values for the atmosphere air-steam mass ratio and the Uchida surface coefficient are calculated as part of the MELCOR model for the baseline LOCA calculation as shown in Fig. 3.1. A peak value of approx. 325 Btu/h-ft²-°F (~1850 W/m²-K) results from this approach.

The blended Tagami/Uchida coefficients are used in several of the calculations listed in Table 3.1. However, an alternate conservative approach also was taken; namely, the time-dependent values from the Uchida correlation in Eq. (2) were replaced by a single, long-term asymptotic value of 5 Btu/h-ft²-°F (~28 W/m²-K). The resulting alternative transition from the Tagami peak value also is shown in Fig. 3.1. These values are used in several of the sensitivity calculations.

Steel/Concrete Gap Conductance. An argument is posed in the licensee submittal and is examined in one sensitivity calculation. The DBA calculation results presented in the submittal assume that an air gap of 0.01 ft (0.12 in.) separates the steel containment liner from the outer concrete shell. This gap is assumed to have an average conductance of 100 Btu/h-ft²-°F. This value also was used in most of the confirmatory calculations. However, a value of 100,000 Btu/h-ft²-°F was used in a sensitivity calculation to represent near-perfect contact between the steel liner and concrete wall. This calculation was performed to confirm the statement made in the submittal that "by introducing an interface conductance of 100 Btu/hr-ft²-°F on the lined concrete heat sinks instead of assuming perfect contact, the peak containment pressure increases less than one per cent."⁴

Containment Leakage. The final parameter examined in the sensitivity calculations was containment leak rate. All calculations except one assumed that the containment pressure boundary is leak tight. The




Fig. 3.1. Structure Heat-Transfer Coefficients (LOCA Calculations).

⁴Statement in Entergy report Sec. 6.2.1.1.3.1.2.1 (1999).

effects of the maximum allowable leak rate⁵ on the calculated peak pressure were examined in a sensitivity calculation.

3.1.2. Baseline Results

The times of key events obtained from the baseline LOCA calculation are compared with the licensee results in Table 3.2. The prompt increase in containment pressure associated with RCS blowdown results in containment air cooler and containment spray actuation signals within 1 s of the pipe break. ESF operation begins 52 s after the containment pressure high (CPH) actuation signal for the air coolers, and 53.6 s after the containment pressure high-high (CPHH) signal for containment sprays⁶.

As indicated in Fig. 3.2, differences in calculated containment pressure signature following RCS blowdown lead to differences in the predicted peak pressure and the time at which it occurs. The qualitative trends in baseline confirmatory calculation and the licensee result are similar, but several quantitative details differ. The peak pressure immediately following RCS blowdown is approximately 5 psi higher in the MELCOR baseline calculation than the COPATTA result. More importantly, the subsequent rise in containment pressure resulting from mass/energy addition during reactor vessel reflood and from the residual energy released from RCS structures (refer to Fig. 2.1) is much smaller in the baseline calculation than in the licensee calculation. The peak pressures predicted in the two calculations are 57.7 psig (COPATTA) and 53.3 psig (MELCOR baseline). Potential causes for this difference are examined in the sensitivity calculations described in Sec. 3.1.2.

The containment temperature responses in the two calculations are compared in Fig. 3.3. Temperature signatures are shown for the containment atmosphere as well as for water in the sump. Again, the qualitative trends are very similar. Differences in the quantitative results, particularly peak temperature, are not as noteworthy as those for containment pressure. The peak temperature calculated in the MELCOR baseline analysis is 278.6 °F compared with 291°F in the licensee analysis.

Table 3.2. Calculated Time of Key Events (Baseline LOCA).

Event	Time (s) Licensee Calculations	Time (s) Baseline Confirmatory Calculation
Pipe rupture, mass/energy release to containment begins	0.0	0.0
CPH signal received—containment air cooler actuation set point	0.5	0.46
CPHH signal received— containment spray set point	1.0	0.90
End of blowdown period	14.9	14.9
Containment air coolers begin operation	52.5	52.5
Containment sprays begin operation	54.6	54.5
Containment reaches peak temperature	54.6	3616.
Containment reaches peak pressure	149.0	13.0
Switchover to spray recirculation	2707.62	2707.62
End of analysis	2.60x10 ⁶	1.0x10 ⁶

⁵The hole allowing 0.1% volume/day leakage is sized assuming that the containment is pressurized with air to the proposed new design pressure (59 psig).

⁶The delay times are specified in the submittal.




Fig. 3.2. Containment Pressure (LOCA Baseline Calculation).

3.1.3. Sensitivity to Key Modeling Parameters

The modeling variables examined in the sensitivity calculations were described in Sec. 3.1.1. The results of the sensitivity calculations are described below.

Sensitivity cases 3, 4, and 5 (see Table 2.1) examined the modeling parameters that influence peak containment pressure following reactor vessel reflood, in particular, the following.

1. A faster rate at which residual stored energy in the RCS is assumed to be released
2. Neglecting the development and drainage of condensate films on heat structures
3. Reduced post-reflood structure heat-transfer coefficients

The containment pressure signatures generated in these three sensitivity calculations are compared with the MELCOR baseline and licensee results in Fig. 3.4.

The pressure signature for the case in which liquid films on the containment structures are neglected (i.e., condensate is transported to the sump immediately as it forms) is nearly identical to that for the baseline calculation. Changes in the other two parameters result in a noticeable change in the pressure history.




Fig. 3.3. Containment Temperature (LOCA Baseline Calculation).




Fig. 3.4. Containment Pressure (Sensitivity Cases 3, 4, and 5).

Accelerating the release of residual RCS energy is not shown to increase the peak pressure, but it slows the subsequent rate at which the containment depressurizes. Reducing the post-reflood containment structure surface coefficients generates a noticeable increase in peak pressure. The peak pressure for sensitivity case 5 is 58.4 psig, approximately 0.7 psi higher than the licensee result.

Sensitivity cases 3 and 5 also change the calculated peak containment temperature. As shown in Fig. 3.5, a sharp increase in temperature occurs in the two sensitivity calculations; this is caused by an imbalance between energy addition rates to the containment atmosphere and heat removal rates by ESF operation and structure surface heat transfer.

Sensitivity cases 1 and 2 examined modeling parameters that influence containment response in the intermediate period following switchover to spray recirculation, in particular, the following.

1. Degrading containment air cooler performance by assuming higher service water temperature
2. Reducing decay heat by assuming a reduced (i.e., the current) core rated power

The results from these cases are shown in Fig. 3.6. Neither case significantly alters the calculated containment pressure signature before switchover to spray recirculation, but the secondary peak in pressure that occurs roughly 5 h (18,000 s) into the accident is reduced slightly at lower decay heat levels and is increased slightly with degraded air cooler performance.




Fig. 3.5 Containment Temperature (Sensitivity Cases 3, 4, and 5).




Fig. 3.6. Containment Pressure (Sensitivity Cases 1 and 2).

From these sensitivity calculations (and the results of sensitivity case 7),⁷ bounding modeling assumptions were identified within the general SRP guidance. In particular, using the "alternate transition" to the Uchida correlation generated a bounding value for peak containment pressure and temperature. Assumptions regarding the other parameters were found to be of secondary importance. The range of containment pressure and temperature signatures generated by the alternative modeling assumptions examined here is summarized in Figs. 3.7 and 3.8, respectively.

As discussed in Sec. 3.1.1, two final sensitivity calculations were performed to measure the effect of containment leakage and perfect contact between the containment liner and concrete wall. The results of these calculations are shown in comparison with the bounding case in Fig. 3.9. Accounting for containment leakage (at a maximum rate corresponding to the Technical Specification limit of 0.1%/day is shown to have no effect on the containment pressure signature. On the other hand, perfect contact between the liner and the concrete wall reduces the peak pressure by approximately 4%, a larger margin than that mentioned in the submittal.

3.1.4. Summary of Loss-of-Coolant Accident Results

The results of the containment response analysis for the ANO-2 LOCA are summarized in Table 3.3. Peak pressures are shown to span a range of $\pm 4\%$ and peak temperatures span a range of $\pm 7\%$ of the mean values on this table.

⁷The calculated peak pressure from sensitivity case 7 is 58.2 psig; the peak temperature is 324°F.




Fig. 3.7. Range of Containment Pressure Signatures in the Confirmatory Analysis.




Fig. 3.8. Range of Containment Temperature Signatures in the Confirmatory Analysis.




Fig. 3.9. Reduction in Containment Pressure from Bounding Case Resulting from Design Basis Leakage and Perfect Contact Between Steel Liner and Concrete Wall.

Table 3.3. Summary of Key Results: LOCA.

Variable	SRP Baseline	Sens1	Sens2	Sens3	Sens4	Sens5	Sens6	Sens7	Sens8
Peak Containment Pressure (psig)	53.3	53.3	53.3	53.3	53.3	58.4	55.2	58.2	58.2
Time at which Peak Occurs (s)	13.0	13.0	13.0	13.0	13.0	148.5	133.4	148.5	148.5
Peak Containment Temperature (°F)	278.6	280.5	278.6	300.6	278.8	323.1	311.0	324.2	324.2
Time at which Peak Occurs (s)	3616.	3616.	13.0	615.5	3616.	480.5	445.5	468.5	468.5

Alternatively, the peak pressure and temperature resulting from the confirmatory analysis can be characterized as follows.

	Confirmatory Analysis	Licensee Analysis
Peak Pressure (psig)	55.9 ± 2.5	57.7
Peak Temperature (°F)	301.4 ± 22.8	291

3.2 Main Steam Line Break

The confirmatory MSLB analysis is simpler than the LOCA analysis in several ways. The sources of mass and energy to the containment were limited to the discharge of secondary coolant from the faulted steam generator. Energy transferred from the RCS across the faulted steam generator tubes was assumed to be accounted for properly in the licensee's SGNIII and RELAP5 analyses.⁸ Heat transfer to the containment heat structure was addressed directly through data correlated by Uchida; transitions from one family of surface coefficients to another were not needed. Finally, the RCS inventory is not depleted during an MSLB. Consequently, ECS operation is not required and sufficient RWT inventory is available to operate the containment sprays in injection mode throughout the time period of interest to this analysis.

One effect of these simplifications from the LOCA analysis is fewer parameters to examine through sensitivity calculations. Lessons learned from the LOCA calculations described in Sec. 3.1 also narrowed the list of candidate parameters to examine for the MSLB analysis.

3.2.1. Modeling Variables

The baseline modeling approach for the MSLB analysis was the same as that described in Sec. 3.1.1 for the baseline LOCA calculation with one exception. Heat transfer to containment structures is modeling data by Uchida as tabulated in Branch Technical Position CSB 6-1 (Rev. 2). Sensitivity calculations were performed to examine the effects of two variables, thickness of condensate film on structure surfaces and structure surface coefficients. The baseline calculation is described in Sec. 3.2.2; the sensitivity results are described in Sec. 3.2.3.

3.2.2. Baseline Results

The calculated times of key events in the MSLB sequence are compared with licensee results in Table 3.4. The times at which containment air cooler and spray actuation is initiated are in good agreement. However, the times at which peak pressure and temperatures occur differ for reasons described below.

The calculated containment pressure response for the baseline MSLB analysis is shown in comparison with the licensee result in Fig. 3.10. As in the baseline LOCA calculation, the qualitative pressure

Table 3.4. Calculated Time of Key events (Baseline MSLB).

Event	Time (s) Licensee Calculations	Time (s) Baseline Confirmatory Calculation
MSLB at 0% power, mass/energy release to containment begins	0.0	0.0
CPH signal received—containment air cooler actuation set point	3.2	3.2
CPHH signal received—containment spray set point	7.0	7.3
Containment air coolers begin operation	33.2	33.2
Containment spray begins operation	45.6	45.9
Containment reaches peak temperature	45.6	20.3
Containment reaches peak pressure	196.6	178.1
End of analysis	400.0	400.0

⁸A described in Sec. 6.2.1.1.3.2.1 of the submittal.

signatures are similar, but important quantitative differences are evident. First, the peak pressure in the MELCOR baseline calculation is significantly lower than the licensee result (50.0 vs 57.7 psig). The knee in the ascending pressure history is less evident in the MELCOR result than in the COPATTA result and occurs at a different time. The reasons for the difference in peak pressure are examined in the next section. The knee in the ascending pressure history occurs when superheat in the containment atmosphere is eliminated through operation of ESF systems. However, as indicated in Fig. 3.11, the amount of atmosphere superheat reflected in the MELCOR baseline calculation is ~120°F less than that in the COPATTA calculation. Consequently, the atmosphere returns to saturation conditions sooner in the MELCOR calculation; the knee is smaller and occurs earlier.

Altering the modeling assumptions associated with structure heat transfer as described below can eliminate these differences in results.




Fig. 3.10. Containment Pressure (MSLB Baseline Calculation).




Fig. 3.11 Containment Temperatures (MSLB Baseline Calculation).

3.2.3. Sensitivity to Key Modeling Parameters

Two sensitivity calculations were performed to identify possible explanations for the differences in results described above. In the first sensitivity case, the thickness of liquid films on containment structures was set to 10^{-6} mm, effectively forcing condensate to be transported to the sump immediately upon formation. As described in Sec. 3.1.1, this nonstandard approach to containment modeling in MELCOR was taken to mimic a similar assumption made in the licensee's COPATTA analysis. The second case examined the effect of reduced structure surface heat-transfer coefficients. The basic formulation of the Uchida correlation was not changed in this sensitivity case. However, the magnitude of the resulting surface coefficients was decreased arbitrarily by a factor of 10.

The resulting containment pressure signatures are shown in comparison with the baseline result and the licensee's result in Fig. 3.12. Ignoring the presence of condensate films on containment structures is shown to have no effect on the baseline results. However, the results of the second sensitivity case show excellent agreement with the licensee analysis. A similar improvement in the calculated atmosphere temperature response is shown in Fig. 3.13.

3.2.4. Summary of Main Steam Line Break Results

The calculated results for the MSLB analysis are summarized in Table 3.5. The baseline results that result from the application of the SRP modeling assumptions (particularly values for surface heat-transfer coefficients) are shown to be approximately 16% lower than those presented in the ANO-2 license amendment request. A peak pressure consistent with the licensee analysis can be obtained by electing the conservative modeling approach of reducing the Uchida heat-transfer coefficients by a factor of 10.




Fig. 3.12 Containment Pressure (MSLB Sensitivity Calculations).




Fig. 3.13 Containment Temperatures (MSLB Sensitivity Calculations).

Table 3.5. Summary of Key Results: MSLB.

<i>Variable</i>	<i>SRP Baseline</i>	<i>Sens1</i>	<i>Sens2</i>	<i>Licensee Results</i>
Peak Containment Pressure (psig)	51.4	51.3	57.8	57.7
Time at which Peak Occurs (sec)	178.1	178.1	186.1	196.6
Peak Containment Temperature (F)	286.4	283.8	360.0	398.
Time at which Peak Occurs (sec)	20.3	19.4	37.0	45.6

4. DISCUSSION OF RESULTS

Confirmatory calculations of containment response to two DBA events in ANO-2 were performed using modeling assumptions consistent with guidance outlined in the SRP. In both cases, the confirmatory analysis generated peak containment pressures and temperatures lower than those presented by the licensee in their license amendment request. The difference in peak pressures is roughly 5% for the large LOCA scenario and is considerably larger for the MSLB scenario (~16%). Several sensitivity calculations were performed to identify plausible reasons for these differences. Among the parameters that were varied in these calculations, containment structure heat-transfer coefficients clearly stand out as having the single largest influence on results.⁹ In the analysis of both DBA events, calculations of peak pressures consistent with those presented by the licensee could be replicated by applying surface coefficients significantly lower than those suggested in the SRP.

Although differences in results can be eliminated through more conservative modeling of surface heat transfer, this does not necessarily identify the root cause of the differences in the results. Alternative explanations may be possible but can only be investigated effectively through a cooperative effort with the licensee.

5. CONCLUSIONS

The licensee analysis of DBAs in the ANO-2 containment was performed in two sequential steps: (1) generate mass/energy sources to the containment resulting from a postulated DBA and (2) calculate the resulting containment thermodynamic response. The confirmatory analysis described here focused exclusively on the second step.

The confirmatory analysis of containment response clearly indicates that the peak containment pressure and temperature during a design-basis LOCA or MSLB event are no greater than the proposed containment design pressure of 59 psig.

REFERENCES

- | | |
|--------------|--|
| Boyack 1992 | B. E. Boyack et al., "MELCOR Peer Review," Los Alamos National Laboratory report LA-12240 (March 1992). |
| Entergy 1999 | Proposed License Amendment (No. 16) to License No. NPF-6, Entergy Operations, Inc., Arkansas Nuclear One, Unit Two, Docket 50-368, an Attachment to 2CAN119903 (November 3, 1999). |
| Entergy 2000 | Supplement to Proposed Technical Specification Change Request Supporting the ANO-2 Containment Building Design Pressure Increase to 59 Psig, 2CAN060014 (June 29, 2000). |
| Gauntt 2000 | R. O. Gauntt et al., "MELCOR/CONTAIN Parity Assessment Report," Sandia National Laboratories, Modeling & Analysis Department, report (January 24, 2000). |

⁹It is important to note that variations in the tabulated mass and energy sources to the containment presented in the license amendment request were not examined.

Murata 1997 K. K. Murata et al., "Code Manual for CONTAIN 2.0: A Computer Code for Nuclear Reactor Containment Analysis," US Nuclear Regulatory Commission/Sandia National Laboratories report NUREG/CR-6533, SAND97-17359 (June 1997).

APPENDIX A

MELCOR Input Data

ANO-2 Design-Basis Accident Containment Response Analysis

July 2000

```

*****
** ANO-2 DBA CONTAINMENT ANALYSIS
**
** MELCOR CALCULATION CONTROL INPUT
**
** Reference: Entergy Letter 2CAN119903, dated Nov. 3, 1999
*****
*
*eor* MELGEN
*
TITLE 'ANO-2 1-CELL CONTAINMENT'
*
OUTPUTFILE ANO-2.GOU
DIAGFILE ANO-2.GDI
RESTARTFILE ANO-2.RST
*
NCG001 O2 4
NCG002 N2 5
*
TSTART -10.
*
CRTOUT
*
***** GEOMETRIC DATA *****
r*i*f geom.dat
*
***** MATERIAL PROPS *****
r*i*f MP.dat
*
***** MASS/ENERGY SOURCE *****
** Sources as integral quantities (via TF)
r*i*f DEDLSint.dat
**r*i*f MSLBint.dat
r*i*f decay-ht.dat
*
***** SPRAY OPERATION *****
r*i*f SPRAY.dat
*
***** FAN COOLER OPERATION *****
r*i*f FAN.dat
*
**** LICENSEE HEAT TRANSFER COEFFICIENTS ****
r*i*f HTC.dat
** ALSO: need to activate sensitivity coefficients in
** MELCOR input below to zero out pool surface
** heat transfer
*****
***** TRACK PEAK VALUES
*
** Peak Pressure
cf50100 new-gt-old L-GT 2 1.0 0.0 * TRUE if p .gt. old max
cf50101 .TRUE.
cf50110 1.4504E-4 -14.7 CVH-P.100 * current pressure (psig)
cf50111 1.0 0.0 cfvalu.502 * previous peak
*
cf50200 Peak-P L-A-IFTE 3 1.0 0.0 * Peak containment pressure
cf50210 1.0 0.0 cfvalu.501 * if new .gt. old
cf50211 1.4504E-4 -14.7 CVH-P.100 * then peak is current value (psig)
cf50212 1.0 0.0 cfvalu.502 * else peak is old value
*
cf50300 Time-at-Peak L-A-IFTE 3 1.0 0.0 * Time peak pressure occurs
cf50310 1.0 0.0 cfvalu.501 * if new .gt. old
cf50311 1.0 0.0 TIME * record time of peak
cf50312 1.0 0.0 cfvalu.503 * else time unchanged
*
** Peak Temperature
cf50400 new-gt-old L-GT 2 1.0 0.0 * TRUE if p .gt. old max
cf50401 .TRUE.

```

```

cf50410 1.8 -460. CVH-TVAP.100 * current temperature (F)
cf50411 1.0 0.0 cfvalu.505 * previous peak
*
cf50500 Peak-T L-A-IFTE 3 1.0 0.0 * Peak containment atm temperature
cf50510 1.0 0.0 cfvalu.504 * if new .gt. old
cf50511 1.8 -460. CVH-TVAP.100 * then peak is current value (F)
cf50512 1.0 0.0 cfvalu.505 * else peak is old value
*
cf50600 Time-at-Peak L-A-IFTE 3 1.0 0.0 * Time peak temp occurs
cf50610 1.0 0.0 cfvalu.504 * if new .gt. old
cf50611 1.0 0.0 TIME * record time of peak
cf50612 1.0 0.0 cfvalu.506 * else time unchanged
*
*
*****
*
*
***** TIME ADVANCEMENT *****
*
*eor* MELCOR
*
TITLE 'ANO-2 1-CELL CONTAINMENT'
CRTOUT
OUTPUTFILE ANO-2.OUT
DIAGFILE ANO-2.DIA
RESTARTFILE ANO-2.RST
MESSAGEFILE ANO-2.MES
PLOTFILE ANO-2.PTF
*
CPULEFT 20.0
CPULIM 1.00E+06
RESTART -1
TEND 100000. * LOCA
* TEND 400. * MSLB
*
*
TIME DTMAX DTMIN DTEDT DTPLT DTRST
TIME1 -10.0 0.1 1.00E-08 10.0 0.1 3600.0
TIME2 -1.0 0.001 1.00E-08 5.0 0.1 3600.0
TIME3 1.0 0.001 1.00E-08 15.0 0.5 3600.0
TIME4 15.0 0.01 1.00E-08 600.0 1.0 3600.0
TIME5 150.0 0.1 1.00E-08 600.0 2.0 3600.0
TIME6 200.0 1.0 1.00E-08 3600.0 5.0 3600.0
TIME7 2000.0 2.0 1.00E-08 36000.0 10.0 36000.0
TIME8 10000.0 5.0 1.00E-08 36000.0 60.0 36000.0
**
** Sensitivity coefficients to zero out pool (sump) surface heat transfer
** (for cases where NUREG-0800 HTC values are being used)
**
SC00001 4407 0.0 2 * reset 4407(2) to 0.0
SC00002 4407 0.0 3 * reset 4407(3) to 0.0
SC00003 4407 0.0 4 * reset 4407(5) to 0.0
SC00004 4407 0.0 5 * reset 4407(6) to 0.0
SC00005 4407 0.0 7 * reset 4407(9) to 0.0
*
*
** Heat Structure maximum liquid film thickness
*SC00007 4251 1.E-9 2 * change default value of 0.0005 m
*

```

 ** ANO-2 DBA CONTAINMENT ANALYSIS
 **
 ** Geometric configuration data
 **

** Reference: Entergy Letter 2CAN119903, dated Nov. 3, 1999

***** CONTROL VOLUMES *****

CVTYPE01 'contain'
 CVTYPE08 'RWT'
 CVTYPE09 'environ'

CV10000	'containment'	2	1	1	* Non-Equilibrium thermo
CV10001	0	0			
CV100A0	3				
CV100B1	0.0	0.0			
CV100B2	52.2732	43848.6			* cylinder free vol
CV100B3	63.5508	50347.3			* total free volume (1.778E6 ft^3 [Table 6.2-7])
CV100A1	VPOL	0.0			
CV100A2	PVOL	110315.2			* 16.0 psia [Table 6.2-8F]
*CV100A2	PVOL	508139.4			* new design pressure: 59 psig
CV100A3	TATM	333.3			* 140 F
CV100A4	RHUM	0.			* [Table 6.2-8F]
CV100A5	MLFR.4	0.21			
CV100A6	MLFR.5	0.79			

***** FLOW PATHS *****

FL99900	'leakage'	100	999	1.	1.
*FL99901	0.881E-5	1.0	1.0		* 0.1% vol/day @ design pres.
FL99901	0.881E-5	1.0	0.0		* Open fraction = 0.0 DBA leakage [Table 6.2-8F]
FL99902	3	0	0	0	
FL99903	0.0	0.0	1.0	1.0	
FL99904	0.	0.			
FL999S0	0.881E-5	1.0	0.00164		

***** HEAT STRUCTURES *****

** [Table 6.2-8D]

HS10001000	12	1	0		* 12 nodes / rectangular geom
HS10001001	'Type B wall-dome'				
HS10001002	0.0	1.0			* base at basemat / vertical
HS10001100	-1	1	0.0		* specify node locations (ref=0.0)
HS10001101	0.0001524	4			* 0.0005 ft
HS10001102	0.0065024	7			* +0.0208333 ft
HS10001103	0.0095504	9			* +0.01 ft
HS10001104	1.1525504	12			* +3.75 ft
HS10001200	-1				* specify region mat'ls
HS10001201	'TYPE-B COATING'		3		
HS10001202	'CARBON STEEL'		6		
HS10001203	'AIR'		8		
HS10001204	'CONCRETE'		11		
HS10001300	0	-1			

HS10001400	1	100	EXT	1.	1.	* Convective bndry to CV100
HS10001500	5208.	10.		63.5		* 56,059 ft^2 / assume L=10m
HS10001600	1	999	EXT	1.	1.	* Convective bndry to CV999
HS10001700	5208.	10.		63.5		* ignore curvature
*						
HS10002000	12	1	0			* 12 nodes / rectangular geom
HS10002001	'Type C wall'					
HS10002002	0.0	1.0				* base on basemat / vertical
HS10002100	-1	1	0.0			* specify node locations (ref=0.0)
HS10002101	0.0002286	4				* 0.00075 ft
HS10002102	0.0065786	7				* +0.0208333 ft
HS10002103	0.0096266	9				* +0.01 ft
HS10002104	1.1526266	12				* +3.75 ft
HS10002200	-1					* specify region mat'ls
HS10002201	'TYPE-B COATING'		3			
HS10002202	'CARBON STEEL'		6			
HS10002203	'AIR'		8			
HS10002204	'CONCRETE'		11			
HS10002300	0	-1				
HS10002400	1	100	EXT	1.	1.	* Convective bndry to CV100
HS10002500	1861.	10.		52.27		* 20,035 ft^2 / assume L=10m
HS10002600	1	999	EXT	1.	1.	* Convective bndry to CV999
HS10002700	1861.	10.		52.27		* ignore curvature
*						
HS10003000	10	1	0			* 10 nodes / rectangular geom
HS10003001	'Refueling Canal'					
HS10003002	25.0	1.0				* base at mid-level / vertical
HS10003100	-1	1	0.0			* specify node locations (ref=0.0)
HS10003101	0.0063500	4				* +0.0208333 ft
HS10003102	0.0093980	7				* +0.01 ft
HS10003103	1.1523980	10				* +3.75 ft
HS10003200	-1					* specify region mat'ls
HS10003201	'STAINLESS STEEL'		3			
HS10003202	'AIR'		6			
HS10003203	'CONCRETE'		9			
HS10003300	0	-1				
HS10003400	1	100	EXT	1.	1.	* Convective bndry to CV100
HS10003500	1672.	1.	10.			* 18,000 ft^2 / assume L=1m
HS10003600	0	-100	EXT	1.	1.	* Insulated bndy
*						
HS10004000	7	1	0			* 7 nodes / rectangular geom
HS10004001	'Thick Steel'					
HS10004002	10.0	1.0				* base off basemat / vertical
HS10004100	-1	1	0.0			* specify node locations (ref=0.0)
HS10004101	0.0001524	4				* 0.0005 ft
HS10004102	0.0065024	7				* +0.0208333 ft
HS10004200	-1					* specify region mat'ls
HS10004201	'TYPE-C COATING'		3			
HS10004202	'CARBON STEEL'		6			
HS10004300	0	-1				
HS10004400	1	100	EXT	1.	1.	* Convective bndry to CV100
HS10004500	3235.	1.	1.			* 34,824 ft^2 / assume L=1m
HS10004600	0	-100	EXT	1.	1.	* Insulated bndy
*						
HS10005000	7	1	0			* 7 nodes / rectangular geom
HS10005001	'Thin Steel'					
HS10005002	10.0	1.0				* base off basemat / vertical
HS10005100	-1	1	0.0			* specify node locations (ref=0.0)
HS10005101	0.00015240	4				* 0.0005 ft
HS10005102	0.00253365	7				* +0.0078125 ft
HS10005200	-1					* specify region mat'ls
HS10005201	'TYPE-C COATING'		3			
HS10005202	'CARBON STEEL'		6			
HS10005300	0	-1				
HS10005400	1	100	EXT	1.	1.	* Convective bndry to CV100
HS10005500	4153.	1.	1.			* 44700 ft^2 / assume L=1m
HS10005600	0	-100	EXT	1.	1.	* Insulated bndy
*						

HS10006000	7	1	0						* 7 nodes / rectangular geom
HS10006001	'Elevated Floors'								
HS10006002	25.0	0.0							* base at mid-height / horizontal
HS10006100	-1	1	0.0						* specify node locations (ref=0.0)
HS10006101	0.0032513	4							* 0.010667 ft
HS10006102	0.337312	7							* +1.096 ft
HS10006200	-1								* specify region mat'ls
HS10006201	'TYPE-C COATING'								3
HS10006202	'CONCRETE'								6
HS10006300	0	-1							
HS10006400	0	-100	EXT	1.	1.				* Insulated bndy
HS10006600	1	100	EXT	1.	1.				* Convective bndry to CV100
HS10006700	1068.	1.	1.						* 11,500 ft^2 / assume L=1m
*									
HS10007000	7	1	0						* 7 nodes / rectangular geom
HS10007001	'Base slab-sump'								
HS10007002	0.0	0.0							* base at basemat / horizontal
HS10007100	-1	1	0.0						* specify node locations (ref=0.0)
HS10007101	0.0032513	4							* 0.010667 ft
HS10007102	0.46045	7							* +1.5 ft
HS10007200	-1								* specify region mat'ls
HS10007201	'TYPE-C COATING'								3
HS10007202	'CONCRETE'								6
HS10007300	0	-1							
HS10007400	0	-100	EXT	1.	1.				* Insulated bndy
HS10007600	1	100	EXT	1.	1.				* Convective bndry to CV100
HS10007700	864.0	1.	1.						* 9,300 ft^2 / assum L=1m
*									
HS10008000	4	1	0						* 4 nodes / rectangular geom
HS10008001	'Unlined Walls'								
HS10008002	10.0	1.0							* base off basemat / vertical
HS10008100	-1	1	0.0						* specify node locations (ref=0.0)
HS10008101	0.6096	4							* 2.0 ft
HS10008200	-1								* specify region mat'ls
HS10008201	'CONCRETE'								3
HS10008300	0	-1							
HS10008400	1	100	EXT	1.	1.				* Convective bndry to CV100
HS10008500	3956.	1.	1.						* 42,584 ft^2 / assume L=1m
HS10008600	0	-100	EXT	1.	1.				* Insulated bndy
*									
HS10009000	7	1	0						* 7 nodes / rectangular geom
HS10009001	'Uninsulated Walls'								
HS10009002	10.0	1.0							* base off basemat / vertical
HS10009100	-1	1	0.0						* specify node locations (ref=0.0)
HS10009101	0.0016635	4							* 0.005458 ft
HS10009102	0.6112635	7							* +2.0 ft
HS10009200	-1								* specify region mat'ls
HS10009201	'TYPE-C COATING'								3
HS10009202	'CONCRETE'								6
HS10009300	0	-1							
HS10009400	1	100	EXT	1.	1.				* Convective bndry to CV100
HS10009500	1218.5	1.	1.						* 13,116 ft^2 / assume L=1m
HS10009600	0	-100	EXT	1.	1.				* Insulated bndy
*									
HS10010000	7	1	0						* 7 nodes / rectangular geom
HS10010001	'Polar Crane Rail'								
HS10010002	26.0	0.0							* base at springline / horizontal
HS10010100	-1	1	0.0						* specify node locations (ref=0.0)
HS10010101	0.0001524	4							* 0.0005 ft
HS10010102	0.0192024	7							* +0.0625 ft
HS10010200	-1								* specify region mat'ls
HS10010201	'TYPE-D COATING'								3
HS10010202	'CARBON STEEL'								6
HS10010300	0	-1							
HS10010400	0	-100	EXT	1.	1.				* Insulated bndy
HS10010600	1	100	EXT	1.	1.				* Convective bndry to CV100
HS10010700	793.8	1.	1.						* 8,542 ft^2 / assume L=1m
*									

HS10011000	7	1	0						* 7 nodes / rectangular geom
HS10011001	'Trolley Steel'								
HS10011002	10.0	0.0							* base off basemat / horizontal
HS10011100	-1	1	0.0						* specify node locations (ref=0.0)
HS10011101	0.0002804	4							* 0.00092 ft
HS10011102	0.0050596	7							* +0.01568 ft
HS10011200	-1								* specify region mat'ls
HS10011201	'TYPE-D COATING'								3
HS10011202	'CARBON STEEL'								6
HS10011300	0	-1							
HS10011400	0	-100	EXT	1.	1.				* Insulated bndy
HS10011600	1	100	EXT	1.	1.				* Convective bndry to CV100
HS10011700	3750.6	1.	1.						* 40,371 ft^2 / assume L=1m
*									
HS10012000	7	1	0						* 7 nodes / rectangular geom
HS10012001	'Box Girders'								
HS10012002	10.0	1.0							* base off basemat / vertical
HS10012100	-1	1	0.0						* specify node locations (ref=0.0)
HS10012101	0.0002804	4							* 0.00092 ft
HS10012102	0.0098054	7							* +0.03125 ft
HS10012200	-1								* specify region mat'ls
HS10012201	'TYPE-D COATING'								3
HS10012202	'CARBON STEEL'								6
HS10012300	0	-1							
HS10012400	1	100	EXT	1.	1.				* Convective bndry to CV100
HS10012500	557.8	1.	1.						* 6,020 ft^2 / assume L=1m
HS10012600	0	-100	EXT	1.	1.				* Insulated bndy
*									
HS10013000	4	1	0						* 4 nodes / rectangular geom
HS10013001	'Elevator'								
HS10013002	10.0	1.0							* base off basemat / vertical
HS10013100	-1	1	0.0						* specify node locations (ref=0.0)
HS10013101	0.0008129	4							* 0.002667 ft
HS10013200	-1								* specify region mat'ls
HS10013201	'CARBON STEEL'								3
HS10013300	0	-1							
HS10013400	1	100	EXT	1.	1.				* Convective bndry to CV100
HS10013500	660.5	1.	1.						* 7,110 ft^2 / assume L=1m
HS10013600	0	-100	EXT	1.	1.				* Insulated bndy
*									
HS10014000	7	1	0						* 7 nodes / rectangular geom
HS10014001	'MS Piping'								
HS10014002	10.0	0.0							* base off basemat / horizontal
HS10014100	-1	1	0.0						* specify node locations (ref=0.0)
HS10014101	0.0001524	4							* 0.0005 ft
HS10014102	0.0016026	7							* +0.05208 ft
HS10014200	-1								* specify region mat'ls
HS10014201	'TYPE-C COATING'								3
HS10014202	'CARBON STEEL'								6
HS10014300	0	-1							
HS10014400	0	-100	EXT	1.	1.				* Insulated bndy
HS10014600	1	100	EXT	1.	1.				* Convective bndry to CV100
HS10014700	427.4	1.	1.						* 4,600 ft^2 / assume L=1m
*									
HS10015000	4	1	0						* 4 nodes / rectangular geom
HS10015001	'Spray-Hdr + H2-Rec'								
HS10015002	10.0	0.0							* base off basemat / horizontal
HS10015100	-1	1	0.0						* specify node locations (ref=0.0)
HS10015101	0.003048	4							* 0.01 ft
HS10015200	-1								* specify region mat'ls
HS10015201	'STAINLESS STEEL'								3
HS10015300	0	-1							
HS10015400	0	-100	EXT	1.	1.				* Insulated bndy
HS10015600	1	100	EXT	1.	1.				* Convective bndry to CV100
HS10015700	195.2	1.	1.						* 2,101 ft^2 / assume L=1m
*									
HS10016000	4	1	0						* 4 nodes / rectangular geom
HS10016001	'Cable Trays'								

```

HS10016002 10.0 0.0 * base off basemat / horizontal
HS10016100 -1 1 0.0 * specify node locations (ref=0.0)
HS10016101 0.001054 4 * 0.003458 ft
HS10016200 -1 * specify region mat'ls
HS10016201 'CARBON STEEL' 3
HS10016300 0 -1
HS10016400 0 -100 EXT 1. 1. * Insulated bndy
HS10016600 1 100 EXT 1. 1. * Convective bndry to CV100
HS10016700 1079.5 1. 1. * 11,620 ft^2 / assume L=1m
*
HS10017000 4 1 0 * 4 nodes / rectangular geom
HS10017001 'Conduit'
HS10017002 10.0 0.0 * base off basemat / horizontal
HS10017100 -1 1 0.0 * specify node locations (ref=0.0)
HS10017101 0.0031826 4 * 0.0104417 ft
HS10017200 -1 * specify region mat'ls
HS10017201 'CONDUIT' 3
HS10017300 0 -1
HS10017400 0 -100 EXT 1. 1. * Insulated bndy
HS10017600 1 100 EXT 1. 1. * Convective bndry to CV100
HS10017700 421.9 1. 1. * 4,541 ft^2 / assume L=1m
*
HS10018000 4 1 0 * 4 nodes / rectangular geom
HS10018001 'Refueling Apparatus'
HS10018002 10.0 0.0 * base off basemat / horizontal
HS10018100 -1 1 0.0 * specify node locations (ref=0.0)
HS10018101 0.009525 4 * 0.03125 ft
HS10018200 -1 * specify region mat'ls
HS10018201 'STAINLESS STEEL' 3
HS10018300 0 -1
HS10018400 0 -100 EXT 1. 1. * Insulated bndy
HS10018600 1 100 EXT 1. 1. * Convective bndry to CV100
HS10018700 192.8 1. 1. * 2,075 ft^2 / assume L=1m
*
HS10019000 4 1 0 * 4 nodes / rectangular geom
HS10019001 'HVAC ducts'
HS10019002 10.0 0.0 * base off basemat / horizontal
HS10019100 -1 1 0.0 * specify node locations (ref=0.0)
HS10019101 0.0020472 4 * 0.0067167 ft
HS10019200 -1 * specify region mat'ls
HS10019201 'CARBON STEEL' 3
HS10019300 0 -1
HS10019400 0 -100 EXT 1. 1. * Insulated bndy
HS10019600 1 100 EXT 1. 1. * Convective bndry to CV100
HS10019700 2108. 1. 1. * 22,690 ft^2 / assume L=1m
*
HS10020000 7 1 0 * 7 nodes / rectangular geom
HS10020001 'SITS'
HS10020002 10.0 1.0 * base off basemat / vertical
HS10020100 -1 1 0.0 * specify node locations (ref=0.0)
HS10020101 0.0001524 4 * 0.0005 ft
HS10020102 0.0467563 7 * +0.1529 ft
HS10020200 -1 * specify region mat'ls
HS10020201 'TYPE-C COATING' 3
HS10020202 'CARBON STEEL' 6
HS10020300 0 -1
HS10020400 1 100 EXT 1. 1. * Convective bndry to CV100
HS10020500 352.7 1. 1. * 3,796 ft^2 / assume L=1m
HS10020600 0 -100 EXT 1. 1. * Insulated bndy
*

```

```

*****
** ANO-2 DBA CONTAINMENT ANALYSIS
**
** Decay heat addition
**
** Reference: Entergy Letter 2CAN119903, dated Nov. 3, 1999
*****
* Long-term decay heat addition [curve based on Figure 6.2-11]
*
*****
cv100c7 ae 352 3 * cf352 for energy source rate
for atm (W)
*
cf35000 FAN-CLR-RATE TAB-FUN 1 3026.E+06 0.0 * 3026E6 MW (new rated power)
*cf35000 FAN-CLR-RATE TAB-FUN 1 2815.E+06 0.0 * 2815E6 MW (current rated
power)
*
cf35003 350
cf35010 1.0 0.0 TIME * f(time)
*
tf35000 'DECAY HEAT' 21 1.0 0.0 * fraction of full power
tf35010 -1.0E6 0.0
tf35011 0.0 0.0
tf35012 1.0 0.065
tf35013 3.0 0.060
tf35014 10.0 0.050
tf35015 40.0 0.040
tf35016 100.0 0.035
tf35017 150.0 0.031
tf35018 170.0 0.037
tf35019 400.0 0.030
tf35020 1000.0 0.025
tf35021 2000.0 0.020
tf35022 3000.0 0.017
tf35023 4000.0 0.016
tf35024 10000.0 0.012
tf35025 20000.0 0.0094
tf35026 30000.0 0.0085
tf35027 40000.0 0.0076
tf35028 50000.0 0.0070
tf35029 100000.0 0.006
tf35030 300000.0 0.004
*
cf35100 long-term L-GT 2 1.0 0.0
cf35110 1.0 0.0 TIME
cf35111 0.0 152.51 TIME * start of long term cooldown
*
cf35200 lower-bound L-A-IFTE 3 1.02 0.0 * 102% power
cf35210 1.0 0.0 cfvalu.351 * if long-term cooldown starts
cf35211 1.0 0.0 cfvalu.350 * add decay heat to containment
cf35212 0.0 0.0 time * otherwise wait
*

```

 ** ANO-2 DBA CONTAINMENT ANALYSIS
 **
 ** ANO-2 Material Properties for Heat Structures
 **
 ** Reference: Entergy Letter 2CAN119903, dated Nov. 3, 1999

* Add properties for the following materials
 * 1. TYPE-B COATING
 * 2. TYPE-C COATING
 * 3. TYPE-D COATING
 * 4. AIR (as a 'structure')
 * 5. CARBON STEEL
 * 6. CONDUIT
 *

***** Heat capacity (rho*Cp) and
 ***** Conductivity from [Table 6.2-8E]
 * Densities derived separately (to convert rho*Cp to units req'd by MELCOR
 *

MATERIAL 1 IS TYPE-B COATING

MPMAT00100 'TYPE-B COATING'
 MPMAT00101 RHO 1
 MPMAT00102 CPS 2
 MPMAT00103 THC 3
 *

* Density
 TF00100 'RHO B-COATING' 1 1.00 0.0 * representative values for coating
 TF00110 300.0 2100. * spec. grav.: 1.7 - 2.5 [CDI report]
 * assume mean value of 2.1 (~130 lb/ft³)
 *

* Specific Heat
 TF00200 'CPS B-COATING' 1 1.00 0.0
 TF00210 300.0 0.9581 * 30 Btu/ft³-F / rho
 * (2012.0 kW/m³-K) / rho
 *

* Conductivity
 TF00300 'THC B-COATING' 1 1.00 0.0
 TF00310 300.0 1.55889 * 0.9 Btu/hr-ft-F
 *

MATERIAL 2 IS TYPE-C COATING

MPMAT00200 'TYPE-C COATING'
 MPMAT00201 RHO 4
 MPMAT00202 CPS 5
 MPMAT00203 THC 6
 *

* Density
 TF00400 'RHO C-COATING' 1 1.00 0.0 * same as above
 TF00410 300.0 2100.
 *

* Specific Heat
 TF00500 'CPS C-COATING' 1 1.00 0.0
 TF00510 300.0 0.9587 * 33 Btu/ft³-F / rho
 * (2013.2 kW/m³-K) / rho
 *

* Conductivity
 TF00600 'THC C-COATING' 1 1.00 0.0
 TF00610 300.0 0.17321 * 0.1 Btu/hr-ft-F
 *

MATERIAL 3 IS TYPE-D COATING

MPMAT00300 'TYPE-D COATING'
 MPMAT00301 RHO 7MPMAT00302 CPS 8
 MPMAT00303 THC 9
 *

* Density
 TF00700 'RHO D-COATING' 1 1.00 0.0 * same as above

TF00710 300.0 2100.

*
 * Specific Heat
 TF00800 'CPS D-COATING' 1 1.00 0.0
 TF00810 300.0 0.9581 * 30 Btu/ft³-F / rho
 * (2012.0 kW/m³-K) / rho
 *

* Conductivity
 TF00900 'THC D-COATING' 1 1.00 0.0
 TF00910 300.0 12.81754 * 7.4 Btu/hr-ft-F
 *

MATERIAL 4 IS AIR

MPMAT00400 'AIR'
 MPMAT00401 RHO 10
 MPMAT00402 CPS 11
 MPMAT00403 THC 12
 *

* Density
 TF01000 'RHO AIR' 1 1.00 0.0 * same as above
 TF01010 300.0 1.23
 *

* Specific Heat
 TF01100 'CPS AIR' 1 1.00 0.0
 TF01110 300.0 0.92683 * 0.017 Btu/ft³-F / rho
 * (1.140 kW/m³-K) / rho
 *

* Conductivity
 TF01200 'THC AIR' 1 1.00 0.0
 TF01210 300.0 1.7321 * 1.0 Btu/hr-ft-F
 *

MATERIAL 5 IS CARBON STEEL

MPMAT00500 'CARBON STEEL'
 MPMAT00501 RHO 13
 MPMAT00502 CPS 14
 MPMAT00503 THC 15
 *

* Density
 TF01300 'RHO CS' 1 1.00 0.0 * same as above
 TF01310 300.0 7850. * representative value from Mark's Hdbk
 *

* Specific Heat
 TF01400 'CPS CS' 1 1.00 0.0
 TF01410 300.0 0.4613 * 54. Btu/ft³-F / rho
 * (3621.2 kW/m³-K) / rho
 *

* Conductivity
 TF01500 'THC CS' 1 1.00 0.0
 TF01510 300.0 43.3 * 25. Btu/hr-ft-F
 *

MATERIAL 6 IS CONDUIT

MPMAT00600 'CONDUIT'
 MPMAT00601 RHO 16
 MPMAT00602 CPS 17
 MPMAT00603 THC 18
 *

* Density
 TF01600 'RHO CONDUIT' 1 1.00 0.0 * same as above
 TF01610 300.0 7850. * representative CS value from Mark's Hdbk
 *

* Specific Heat
 TF01700 'CPS CONDUIT' 1 1.00 0.0
 TF01710 300.0 0.3588 * 42. Btu/ft³-F / rho
 * (2816.5 kW/m³-K) / rho
 *

* Conductivity
 TF01800 'THC CONDUIT' 1 1.00 0.0
 TF01810 300.0 107.4 * 62. Btu/hr-ft-F
 *

```

*****
** ANO-2 DBA CONTAINMENT ANALYSIS
**
** Containment Spray Operation
**
** Reference: Entergy Letter 2CAN119903, dated Nov. 3, 1999
*****
* Sprays actuate on cont-p high-high (25.7 psia), delay time of 53.6 sec
* [Table 6.2-8F]
*
*****
* trip logic
*
cf20000 CPHH-sig L-GT 2 1.0 0.0
cf20005 latch
cf20006 2 'CPHH signal'
cf20010 1.0 0.0 cvh-p.100
cf20011 0.0 177193.8 time * 25.7 psia
*
cf20100 spr-sig-time TRIP 1 1.0 0.0
cf20110 1.0 0.0 cfvalu.200
*
cf20200 inj-spray-on L-GT 2 1.0 0.0
cf20206 2 'Containment Spray Starts (1-pump)'
cf20210 1.0 0.0 cfvalu.201
cf20211 0.0 53.6 time * LOCA delay time=53.6 sec
*cf20211 0.0 38.6 time * MSLB delay time=38.6 sec
*
cf20300 rec-spray-on L-GT 2 1.0 0.0
cf20306 2 'Switchover to Cont. Spray Recirc'
cf20310 1.0 0.0 time
cf20311 0.0 2708. time * LOCA switchover time
*cf20311 0.0 1.0E10 time * MSLB switchover time
*
cf20400 not-recirc L-NOT 1 1.0 0.0
cf20410 1.0 0.0 cfvalu.203
*
cf20500 inj-true L-AND 2 1.0 0.0
cf20510 1.0 0.0 cfvalu.202
cf20511 1.0 0.0 cfvalu.204
*
cf20600 inj-true L-L-IFTE 3 1.0 0.0
cf20601 .false.
cf20610 1.0 0.0 cfvalu.205 * If injection should be on
cf20611 1.0 0.0 cfvalu.290 * CF is true
cf20612 1.0 0.0 cfvalu.291 * Else CF is false
*
*****
cf21000 RWT-invent divide 2 264.173 0.0 * convert m^3 to gal
cf21010 1.0 0.0 cvh-rhop.901 * pool density
cf21011 1.0 0.0 cvh-mass.1.901 * pool mass
*
cf22000 Spray-temp L-A-IFTE 3 1.0 0.0
cf22010 1.0 0.0 cfvalu.203 * If sprays switchover
cf22011 1.0 0.0 cvh-tliq.100 * spray temp = sump temp
cf22012 1.0 0.0 cvh-tliq.901 * else: spray temp = RWT temp
*
cf23000 Spray-flow L-A-IFTE 3 1.0 0.0
cf23010 1.0 0.0 cfvalu.203 * If sprays switchover
cf23011 0.0 0.1262 time * spray flow = 2000
gpm/pump
cf23012 0.0 0.1183 time * else: spray flow = 1875
gpm/pump
*
*****
cf29000 always-T L-GT 2 1.0 0.0
cf29010 0.0 1.0 time

```

```

cf29011 0.0 0.0 time
*
cf29100 always-F L-GT 2 1.0 0.0
cf29110 0.0 0.0 time
cf29111 0.0 1.0 time
*
*****
* Spray-01 (injection) performance specs
*
SPRSR0100 SPRY-INJ 100 31.7 206 901 1 0. 52. * spray into CV100
* 104 ft ave fall height [Sec.
6.2.3.2.1]
*
* trip on/off with cf204
* source from CV901
* injection spray stops if RWT
is depleted
SPRSR0101 322.22 0.1262 220 230 * 120F / 2000 gpm per pump
[Table 6.2-8]
* spray temp (K) defined by
cf220
* spray flow (m^3/s) defined by
cf230
SPRSR0102 0.000925 1.0 * 925 micron drop size during
inj. mode
*
*****
* Spray-02 (recirculation) performance specs
*
SPRSR0200 SPRY-REC 100 31.7 203 100 1 0. 52. * spray into CV100
* 104 ft ave fall height [Sec.
6.2.3.2.1]
*
* trip on w/ cf203
* source from CV100
* injection spray stops if sump
is depleted
SPRSR0201 322.22 0.1183 220 230 * (120F) / 1875 gpm per pump
[Table 6.2-8]
* spray temp (K) defined by
cf220
* spray flow (m^3/s) defined by
cf230
SPRSR0202 0.000880 1.0 * 880 micron during recirc
*
*****
SPRSUMP0 100 * sump in CV100 for both
*
*****
cv90100 'RWT' 2 1 8
cv90101 0 0
cv901A0 3
cv901B1 0.0 0.0
cv901B2 52.2 1514.16 * total tank vol 53,472 ft^3 (400,000 gal) [Table 6.2-
8]
cv901A1 VPOL 1453.59 * max coolant inventory 384,000 gal [Table 6.2-8A]
cv901A2 PVOL 101352.1 * 14.7 psia [Table 6.2-8]
cv901A3 TATM 322.2 * 120 F [Table 6.2-8A]
cv901A4 MLFR.4 0.21
cv901A5 MLFR.5 0.79
*
.

```

```

*****
** ANO-2 DBA CONTAINMENT ANALYSIS
**
** Containment Fan Cooler Operation
**
** Reference: Entergy Letter 2CAN119903, dated Nov. 3, 1999
*****
* Fan Coolers actuate on cont-p high (20.7 psia), delay time of 52 sec
* [Table 6.2-8F]
*
*****
* trip logic
*
cf30000 CPH-sig L-GT 2 1.0 0.0
cf30005 latch
cf30006 2 'CPH signal'
cf30010 1.0 0.0 cvh-p.100
cf30011 0.0 142720.3 time * 20.7 psia
*
cf30100 fan-sig-time TRIP 1 1.0 0.0
cf30110 1.0 0.0 cfvalu.300
*
cf30200 fan-clr-on L-GT 2 1.0 0.0
cf30206 2 'Fan Coolers Starts (2/4 fans)'
cf30210 1.0 0.0 cfvalu.301
cf30211 0.0 52.0 time * LOCA delay time=52.0 sec
*cf30211 0.0 30.0 time * MSLB delay time=30.0 sec
*
*****
* heat removal per train
*
cv100c6 ae 310 3 * cf310 for energy source rate for
atm (W)
*
cf30400 test-TSAT L-GT 2 1.0 0.0
cf30410 1.0 0.0 CVH-TSAT(A).100
cf30411 0.0 308.34 TIME * 95F
*
cf30500 lower-bound L-A-IFTE 3 1.0 0.0 * set lower bound to Tsat to cover
cf30510 1.0 0.0 cfvalu.304 * initial (zero steam) conditions
cf30511 1.0 0.0 cvh-tsat(a).100
cf30512 0.0 308.33 time
*
cf30600 FAN-CLR-RATE TAB-FUN 1 2.0 0.0 * Mult=2.0
* (1 'group' consisting of 2
fans)[sec. 9.4.5.3]
cf30603 306
cf30610 1.8 -460. CVH-TSAT(A).100 * convert to deg-F for table look-
up
*
* reference t(sat) at P(steam)
*
tf30600 'FAN-CLR-RATE' 6 0.293 0.0 * convert output from Btu/hr to W
* table in deg-F & Btu/hr
* negative values for heat removal
*
*tf30610 95. 0.0 * constant 95F service water
*tf30611 105. -1.35E6
*tf30612 150. -1.05E7
*tf30613 180. -2.01E7
*tf30614 230. -4.21E7
*tf30615 286. -6.98E7
*
tf30610 110. 0.0 * constant 110F service water
tf30611 120. -1.62E6
tf30612 150. -7.96E6
tf30613 180. -1.71E7
tf30614 230. -3.80E7

```

```

tf30615 286. -6.47E7
*
*tf30610 120. 0.0 * constant 120F service water
*tf30611 130. -1.78E6
*tf30612 150. -6.15E6
*tf30613 180. -1.49E7
*tf30614 230. -3.51E7
*tf30615 286. -6.12E7
*
cf31000 fan-clr-rate L-A-IFTE 3 1.0 0.0 *
cf31010 1.0 0.0 cfvalu.302 *
cf31011 1.0 0.0 cfvalu.306
cf31012 0.0 0.0 time
*

```

```

*****
** ANO-2 DBA CONTAINMENT ANALYSIS
**
** Heat transfer coefficient used in licensee analysis
**
** Reference: Entergy Letter 2CAN119903, dated Nov. 3, 1999
*****
allowreplace
*
** sump liquid to containment atm
** (set to zero via sensitivity coeff in melCOR input
*
** sump and floor to sump liquid
tf90200 'HTC-2' 1 5.68 0.0 * convert Btu/hr-ft2-F to W/m^2-K
tf90210 0.0 0.4 * 0.4 Btu/hr-ft^2-F
*
** heat sink surfaces exposed to outside air
tf90300 'HTC-3' 1 5.68 0.0 * convert Btu/hr-ft2-F to W/m^2-K
tf90310 0.0 2.0 * 2.0 Btu/hr-ft^2-F
*
* Heat structures affected by change:
HS10001600 4903 999 EXT 1. 1. * Convective bndry to CV999
HS10002600 4903 999 EXT 1. 1. * Convective bndry to CV999
HS10007600 4902 100 EXT 1. 1. * Convective bndry to CV100
*
** wall condensation
** (per NUREG-0800, 6.2.1.5)
**
** BLOWDOWN (Tagami)
** linear increase from 8 Btu/hr-ft2-F to h(max)
** between t=0 and end of blowdown.
**
** h(Tagami) = 72.5*(Q/Vt)^0.62
** where Q = integrated energy release to containment (Btu)
** V = net free containment volume (ft3)
** t(p) = time interval to end of blowdown (sec)
**
** V = 1.778E+06 ft3
** for DBA LOCA: Q = 2.885E+08 Btu blowdown atm energy
** = 3.000E+08 (including prz stored energy)
** t(p) = 14.90 sec end of blowdown
** h(Tagami) = 318.636 Btu/hr-ft2-F
** = 326.456 (including prz stored energy)
**
cf90000 time>0 L-GT 2 1.0 0.0 * TRUE if blowdown has begun
cf90010 1.0 0.0 TIME * (steam mass.ne.zero)
cf90011 0.0 1.0 TIME
*
cf90100 ramp DIVIDE 2 1.0 0.0
cf90102 3 0.0 1.0 * min / max
cf90110 0.0 14.9 TIME
cf90111 1.0 0.0 TIME * t/t(p)
*
cf90200 H-blow EQUALS 1 1.0 0.0 * Blowdown HTC (Btu/hr-ft2-F)
cf90202 3 8.0 326.456 * min / max (blowdown only)
cf90210 318.456 8.0 cfvalu.901 * linear ramp from 8 to h(max)
*
cf90300 M-air ADD 2 1.0 0.0 * add mass of O2+N2
cf90310 1.0 0.0 CVH-MASS.4.100
cf90311 1.0 0.0 CVH-MASS.5.100
*
cf90400 steam L-A-IFTE 3 1.0 0.0
cf90401 0.0
cf90410 1.0 0.0 cfvalu.900 * If blowdown has started
cf90411 1.0 0.0 CVH-MASS.3.100 * evaluate real mass ratio
cf90412 0.0 1.0E-6 TIME * else define small, non-zero steam mass
*

```

```

cf90500 Fix-MR EQUALS 1 1.0 0.0 * Define Uchida (long-term HTC = 5.0)
cf90510 0.0 35.0 TIME
*
*cf90500 M-ratio DIVIDE 2 1.0 0.0 * mass air/mass steam
*cf90501 50.
*cf90502 3 0.1 50. * min / max
*cf90510 1.0 0.0 cfvalu.904 * mass of steam in containment
*cf90511 1.0 0.0 cfvalu.903 * mass of air in containment
*
cf90600 H-stag TAB-FUN 1 1.0 0.0 * long-term post-blowdown (Uchida)
cf90603 906 * use tf906
cf90610 1.0 0.0 cfvalu.905 * indep variable is M-ratio (cf905)
*
tf90600 Uchida 15 1.0 0.0 * Uchida data
* M-ratio HTC
tf90610 0.1 280.0
tf90611 0.5 140.0
tf90612 0.8 98.0
tf90613 1.3 63.0
tf90614 1.8 46.0
tf90615 2.3 37.0
tf90616 3.0 29.0
tf90617 4.0 24.0
tf90618 5.0 21.0
tf90619 7.0 17.0
tf90620 10. 14.0
tf90621 14. 10.0
tf90622 18. 9.0
tf90623 20. 8.0
tf90624 50. 2.0
*
cf90700 save MIN 2 1.0 0.0 * prevent overflow of CF909
cf90710 1.0 0.0 TIME
cf90711 0.0 300.0 TIME
*
cf90800 expon EQUALS 1 1.0 0.0 * delta-t [dt]
cf90810 1.0 -14.90 cfvalu.907
*
cf90900 e-term EXP 1 1.0 0.0
cf90910 -0.025 0.0 cfvalu.908 * exp(-0.025*dt)
*
cf91000 h-diff ADD 2 1.0 0.0
cf91010 1.0 0.0 cfvalu.902 * h(max)
cf91011 -1.0 0.0 cfvalu.906 * - h(stag)
*
cf91100 adder MULTIPLY 2 1.0 0.0
cf91110 1.0 0.0 cfvalu.910 * (h(max)-h(stag))
cf91111 1.0 0.0 cfvalu.909 * *exp(-0.025*dt)
*
cf91200 h-long ADD 2 1.0 0.0
cf91210 1.0 0.0 cfvalu.906 * h(stag)+
cf91211 1.0 0.0 cfvalu.911 * (h(max)-h(stag))*exp(-0.025*dt)
*
cf91300 Uchida max 2 1.0 0.0 * ensure positive value
cf91310 1.0 0.0 cfvalu.912
cf91311 0.0 0.0 time
*
cf91500 time L-GT 2 1.0 0.0 * True if blowdown is over
cf91510 1.0 0.0 TIME
cf91511 0.0 14.90 TIME
*
cf91600 alt-decay MULTIPLY 2 1.0 0.0 * simple decay of Tagami h(max)
cf91610 1.0 0.0 cfvalu.902
cf91611 1.0 0.0 cfvalu.909
*
cf92000 HTC L-A-IFTE 3 5.68 0.0 * convert Btu/hr-ft2-F to W/m2-K
cf92001 0.0
cf92010 1.0 0.0 cfvalu.915 * If blowdown is over

```

cf92011	1.0	0.0	cfvalu.913	* transition to Uchida (LOCA)
cf92012	1.0	0.0	cfvalu.902	* else ramp to Tagami peak (LOCA)
*cf92011	1.0	0.0	cfvalu.902	* stay at Tagami peak (LOCA)
*cf92011	1.0	0.0	cfvalu.906	* use Uchida (MSLB)
*cf92012	1.0	0.0	cfvalu.906	* else use Uchida (MSLB)

* Replace default HTC to CF920

HS10001400	6920	100	EXT	1.	1.
HS10002400	6920	100	EXT	1.	1.
HS10003400	6920	100	EXT	1.	1.
HS10004400	6920	100	EXT	1.	1.
HS10005400	6920	100	EXT	1.	1.
HS10006600	6920	100	EXT	1.	1.
HS10008400	6920	100	EXT	1.	1.
HS10009400	6920	100	EXT	1.	1.
HS10010600	6920	100	EXT	1.	1.
HS10011600	6920	100	EXT	1.	1.
HS10012400	6920	100	EXT	1.	1.
HS10013400	6920	100	EXT	1.	1.
HS10014600	6920	100	EXT	1.	1.
HS10015600	6920	100	EXT	1.	1.
HS10016600	6920	100	EXT	1.	1.
HS10017600	6920	100	EXT	1.	1.
HS10018600	6920	100	EXT	1.	1.
HS10019600	6920	100	EXT	1.	1.
HS10020400	6920	100	EXT	1.	1.

 ** ANO-2 DBA CONTAINMENT ANALYSIS
 **
 ** CONTAINMENT SOURCE TABLES
 **
 ** Reference: Entergy Letter 2CAN119903, dated Nov. 3, 1999

* DEDLS mass/energy source as integral quantities [Table 6.2-8B]
 *

	src-type	iestyp	iesflg	
cv100c1	mass.3	110	1	* cf110 for integral mass source for atm
cv100c2	ae	120	1	* cf120 for integral energy source for atm
cv100c3	mass.1	130	1	* cf130 for integral mass source for pool
cv100c4	pe	140	1	* cf140 for integral energy source for pool
cv100c5	ae	160	1	* cf150 for misc stored energy sources

 * atmosphere mass

cf10100	BLODWN-MASS-A	TAB-FUN	1	1.0	0.0
cf10103	101				
cf10110	1.0	0.0	TIME		

cf10200	REFLD-MASS-A	TAB-FUN	1	1.0	0.0
cf10203	102				
cf10210	1.0	0.0	TIME		

tf10100	'BLODWN-MASS-A'	50	0.4536	0.0	* convert lbm to kg
tf10110	-1.0	0.0			
tf10111	0.0	0.0			
tf10112	0.01	7.950E2			
tf10113	0.02	1.536E3			
tf10114	0.03	2.276E3			
tf10115	0.04	3.027E3			
tf10116	0.05	3.787E3			
tf10117	0.06	4.546E3			
tf10118	0.07	5.300E3			
tf10119	0.08	6.053E3			
tf10120	0.09	6.796E3			
tf10121	0.10	7.675E3			
tf10122	0.15	1.314E4			
tf10123	0.20	1.868E4			
tf10124	0.25	2.419E4			
tf10125	0.30	2.969E4			
tf10126	0.35	3.512E4			
tf10127	0.40	4.048E4			
tf10128	0.45	4.581E4			
tf10129	0.50	5.111E4			
tf10130	0.60	6.153E4			
tf10131	0.70	7.185E4			
tf10132	0.80	8.193E4			
tf10133	0.90	9.167E4			
tf10134	1.00	1.013E5			
tf10135	1.5	1.456E5			
tf10136	2.0	1.844E5			
tf10137	2.5	2.188E5			
tf10138	3.0	2.486E5			
tf10139	3.5	2.755E5			
tf10140	4.0	2.999E5			
tf10141	5.0	3.147E5			
tf10142	6.0	3.763E5			
tf10143	7.0	4.028E5			
tf10144	8.0	4.213E5			
tf10145	9.0	4.314E5			
tf10146	10.0	4.388E5			
tf10147	11.0	4.501E5			
tf10148	12.0	4.620E5			

tf10149	13.0	4.712E5
tf10150	14.0	4.763E5
tf10151	14.1	4.766E5
tf10152	14.2	4.769E5
tf10153	14.3	4.772E5
tf10154	14.4	4.774E5
tf10155	14.5	4.776E5
tf10156	14.6	4.777E5
tf10157	14.7	4.778E5
tf10158	14.8	4.779E5
tf10159	14.9	4.779E5

tf10200	'REFLD-MASS-A'	52	0.4536	0.0	* convert lbm to kg
tf10210	0.0	0.0			
tf10211	14.91	0.0			
tf10212	15.00	1.253E1			
tf10213	19.00	1.866E3			
tf10214	20.80	3.442E3			
tf10215	20.81	3.446E3			
tf10216	22.90	4.396E3			
tf10217	26.80	6.171E3			
tf10218	30.70	7.945E3			
tf10219	34.60	9.711E3			
tf10220	38.50	1.147E4			
tf10221	42.40	1.321E4			
tf10222	46.40	1.498E4			
tf10223	50.30	1.669E4			
tf10224	54.20	1.838E4			
tf10225	58.10	2.005E4			
tf10226	62.00	2.171E4			
tf10227	65.90	2.335E4			
tf10228	69.80	2.498E4			
tf10229	73.59	2.654E4			
tf10230	73.60	2.654E4			
tf10231	78.60	3.052E4			
tf10232	83.60	3.425E4			
tf10233	88.60	3.774E4			
tf10234	93.60	4.109E4			
tf10235	98.60	4.426E4			
tf10236	103.50	4.723E4			
tf10237	108.50	5.016E4			
tf10238	113.50	5.299E4			
tf10239	118.50	5.573E4			
tf10240	123.50	5.834E4			
tf10241	128.40	6.079E4			
tf10242	133.40	6.319E4			
tf10243	138.40	6.545E4			
tf10244	143.40	6.760E4			
tf10245	148.30	6.960E4			
tf10246	148.40	6.964E4			
tf10247	148.50	6.969E4			
tf10248	148.60	6.971E4			
tf10249	148.70	6.974E4			
tf10250	148.80	6.975E4			
tf10251	148.90	6.976E4			
tf10252	149.30	6.977E4			
tf10253	149.60	6.978E4			
tf10254	149.90	6.980E4			
tf10255	150.20	6.981E4			
tf10256	150.60	6.982E4			
tf10257	151.00	6.984E4			
tf10258	151.50	6.986E4			
tf10259	152.00	6.988E4			
tf10260	152.50	6.990E4			
tf10261	152.51	6.990E4			

cf11000	ATM-MASS-SRC	ADD	2	1.0	0.0
cf11001	0.0				

```

cf11010 1.0 0.0 CFVALU.101
cf11011 1.0 0.0 CFVALU.102
*
*****
* atmosphere energy
*****
cf11100 BLODWN-ENRG-A TAB-FUN 1 1.0 0.0
cf11103 111
cf11110 1.0 0.0 TIME
*
cf11200 REFLD-ENRG-A TAB-FUN 1 1.0 0.0
cf11203 112
cf11210 1.0 0.0 TIME
*
tf11100 'BLODWN-ENRG-A' 50 1055. 0.0 * convert Btu to J
tf11110 -1.0 0.0
tf11111 0.0 0.0
tf11112 0.01 4.377E5
tf11113 0.02 8.447E5
tf11114 0.03 1.251E6
tf11115 0.04 1.664E6
tf11116 0.05 2.081E6
tf11117 0.06 2.498E6
tf11118 0.07 2.912E6
tf11119 0.08 3.325E6
tf11120 0.09 3.734E6
tf11121 0.10 4.217E6
tf11122 0.15 7.233E6
tf11123 0.20 1.029E7
tf11124 0.25 1.334E7
tf11125 0.30 1.639E7
tf11126 0.35 1.939E7
tf11127 0.40 2.236E7
tf11128 0.45 2.530E7
tf11129 0.50 2.823E7
tf11130 0.60 3.400E7
tf11131 0.70 3.971E7
tf11132 0.80 4.528E7
tf11133 0.90 5.068E7
tf11134 1.00 5.603E7
tf11135 1.5 8.080E7
tf11136 2.0 1.030E8
tf11137 2.5 1.229E8
tf11138 3.0 1.404E8
tf11139 3.5 1.566E8
tf11140 4.0 1.716E8
tf11141 5.0 1.980E8
tf11142 6.0 2.208E8
tf11143 7.0 2.398E8
tf11144 8.0 2.549E8
tf11145 9.0 2.641E8
tf11146 10.0 2.703E8
tf11147 11.0 2.770E8
tf11148 12.0 2.825E8
tf11149 13.0 2.861E8
tf11150 14.0 2.879E8
tf11151 14.1 2.881E8
tf11152 14.2 2.882E8
tf11153 14.3 2.882E8
tf11154 14.4 2.883E8
tf11155 14.5 2.884E8
tf11156 14.6 2.884E8
tf11157 14.7 2.885E8
tf11158 14.8 2.885E8
tf11159 14.9 2.885E8
*
tf11200 'REFLD-ENRG-A' 52 1055. 0.0 * convert Btu to J
tf11210 0.0 0.0

```

```

tf11211 14.91 0.0
tf11212 15.0 1.634E4
tf11213 19.0 2.423E6
tf11214 20.80 4.451E6
tf11215 20.81 4.457E6
tf11216 22.90 5.671E6
tf11217 26.80 7.930E6
tf11218 30.70 1.017E7
tf11219 34.60 1.240E7
tf11220 38.50 1.462E7
tf11221 42.40 1.680E7
tf11222 46.40 1.902E7
tf11223 50.30 2.116E7
tf11224 54.20 2.328E7
tf11225 58.10 2.538E7
tf11226 62.00 2.745E7
tf11227 65.90 2.949E7
tf11228 69.80 3.151E7
tf11229 73.59 3.346E7
tf11230 73.60 3.346E7
tf11231 78.60 3.840E7
tf11232 83.60 4.304E7
tf11233 88.60 4.740E7
tf11234 93.60 5.154E7
tf11235 98.60 5.548E7
tf11236 103.50 5.918E7
tf11237 108.50 6.282E7
tf11238 113.50 6.634E7
tf11239 118.50 6.966E7
tf11240 123.50 7.280E7
tf11241 128.40 7.572E7
tf11242 133.40 7.855E7
tf11243 138.40 8.122E7
tf11244 143.40 8.376E7
tf11245 148.30 8.613E7
tf11246 148.40 8.617E7
tf11247 148.50 8.623E7
tf11248 148.60 8.626E7
tf11249 148.70 8.629E7
tf11250 148.80 8.631E7
tf11251 148.90 8.632E7
tf11252 149.30 8.634E7
tf11253 149.60 8.635E7
tf11254 149.90 8.637E7
tf11255 150.20 8.638E7
tf11256 150.60 8.640E7
tf11257 151.00 8.642E7
tf11258 151.50 8.645E7
tf11259 152.00 8.647E7
tf11260 152.50 8.650E7
tf11261 152.51 8.650E7
*
cf12000 ATM-ENRG-SRC ADD 2 1.0 0.0
cf12001 0.0
cf12010 1.0 0.0 CFVALU.111
cf12011 1.0 0.0 CFVALU.112
*
*****
* pool mass
*****
cf13000 REFLD-MASS-P TAB-FUN 1 1.0 0.0
cf13003 130
cf13010 1.0 0.0 TIME
*
tf13000 'REFLD-MASS-P' 24 0.4536 0.0 * convert lbm to kg
tf13010 0.0 0.0
tf13011 14.91 0.0
tf13012 20.79 0.0

```

tf13013	20.80	6.269E+01
tf13014	22.80	1.165E+04
tf13015	25.80	2.730E+04
tf13016	27.80	3.709E+04
tf13017	31.90	5.481E+04
tf13018	35.90	7.026E+04
tf13019	41.90	9.010E+04
tf13020	45.90	1.021E+05
tf13021	51.90	1.176E+05
tf13022	55.90	1.269E+05
tf13023	61.90	1.390E+05
tf13024	65.90	1.483E+05
tf13025	71.90	1.556E+05
tf13026	73.90	1.556E+05
tf13027	114.90	1.556E+05
tf13028	115.00	1.556E+05
tf13029	120.00	1.559E+05
tf13030	130.00	1.566E+05
tf13031	140.00	1.578E+05
tf13032	148.30	1.590E+05
tf13033	152.51	1.590E+05

*

* pool energy

cf14000	REFLD-ENRG-P	TAB-FUN	1	1.0	0.0
cf14003	140				
cf14010	1.0	0.0	TIME		

tf14000	'REFLD-ENRG-P'	24	1055.	0.0	* convert Btu to J
tf14010	0.0	0.0			
tf14011	14.91	0.000E+00			
tf14012	20.79	0.000E+00			
tf14013	20.80	6.371E+03			
tf14014	22.80	1.198E+06			
tf14015	25.80	2.833E+06			
tf14016	27.80	3.885E+06			
tf14017	31.90	5.776E+06			
tf14018	35.90	7.476E+06			
tf14019	41.90	9.726E+06			
tf14020	45.90	1.111E+07			
tf14021	51.90	1.297E+07			
tf14022	55.90	1.412E+07			
tf14023	61.90	1.568E+07			
tf14024	65.90	1.662E+07			
tf14025	71.90	1.790E+07			
tf14026	73.90	1.790E+07			
tf14027	114.90	1.790E+07			
tf14028	115.00	1.790E+07			
tf14029	120.00	1.796E+07			
tf14030	130.00	1.817E+07			
tf14031	140.00	1.849E+07			
tf14032	148.30	1.884E+07			
tf14033	152.51	1.884E+07			

*

* Misc stored energy sources

cf15000	MISC-ENRGY1	TAB-FUN	1	1.0	0.0
cf15003	150				
cf15010	1.0	0.0	TIME		

tf15000	'MISC-ENRGY1'	3	1055.	0.0	* convert Btu to J
tf15010	0.0	0.0			
tf15011	14.90	0.000E+00			
tf15012	3614.90	1.150E+07			* assume 1-hour release time
*tf15012	614.90	1.150E+07			* assume 10-minute release time

cf15100	MISC-ENRGY2	TAB-FUN	1	1.0	0.0
cf15103	151				
cf15110	1.0	0.0	TIME		

tf15100	'MISC-ENRGY2'	3	1055.	0.0	* convert Btu to J
tf15110	0.0	0.0			
tf15111	152.51	0.000E+00			
tf15112	3752.51	7.500E+07			* and assume 1-hour release time
*tf15112	752.51	7.500E+07			* and assume 10-minute release time

cf16000	MISC-ENERGY	ADD	2	1.0	0.0
cf16001	0.0				
cf16010	1.0	0.0	CFVALU.150		
cf16011	1.0	0.0	CFVALU.151		

```

*****
** ANO-2 DBA CONTAINMENT ANALYSIS
**
** CONTAINMENT SOURCE TABLES
**
** Reference: Entergy Letter 2CAN119903, dated Nov. 3, 1999
*****
* MSLB mass/energy source as integral quantities [Table 6.2-9B]
*
*      src-type  iestyp  iesflg
cv100c1  mass.3   110     1      * cf110 for integral mass source for atm
cv100c2  ae       120     1      * cf120 for integral energy source for atm
*
*****
* atmosphere mass
*****
cf10100  MSLB-MASS-1  TAB-FUN  1  1.0  0.0
cf10103  101
cf10110  1.0      0.0      TIME
*
cf10200  MSLB-MASS-2  TAB-FUN  1  1.0  0.0
cf10203  102
cf10210  1.0      0.0      TIME
*
cf10300  MSLB-MASS-3  TAB-FUN  1  1.0  0.0
cf10303  103
cf10310  1.0      0.0      TIME
*
cf10400  MSLB-MASS-4  TAB-FUN  1  1.0  0.0
cf10403  104
cf10410  1.0      0.0      TIME
*
cf10500  MSLB-MASS-5  TAB-FUN  1  1.0  0.0
cf10503  105
cf10510  1.0      0.0      TIME
*
tf10100  'MSLB-MASS-1'  90  0.4536  0.0  * convert lbm to kg
tf10110      0.00      0.00000E+00
tf10111      0.09      3.92334E+02
tf10112      0.19      8.26279E+02
tf10113      0.29      1.25851E+03
tf10114      0.39      1.68913E+03
tf10115      0.49      2.11817E+03
tf10116      0.59      2.54568E+03
tf10117      0.69      2.97168E+03
tf10118      0.79      3.39626E+03
tf10119      0.89      3.81940E+03
tf10120      0.99      4.24115E+03
tf10121      1.09      4.66155E+03
tf10122      1.19      5.08060E+03
tf10123      1.29      5.49836E+03
tf10124      1.39      5.91484E+03
tf10125      1.49      6.33005E+03
tf10126      1.59      6.74403E+03
tf10127      1.69      7.15678E+03
tf10128      1.79      7.56834E+03
tf10129      1.89      7.97872E+03
tf10130      1.99      8.38794E+03
tf10131      2.09      8.79603E+03
tf10132      2.19      9.20297E+03
tf10133      2.29      9.60882E+03
tf10134      2.39      1.00136E+04
tf10135      2.49      1.04173E+04
tf10136      2.59      1.08199E+04
tf10137      2.69      1.12215E+04
tf10138      2.79      1.16219E+04
tf10139      2.89      1.20214E+04

```

```

tf10140      2.99      1.24197E+04
tf10141      3.09      1.28171E+04
tf10142      3.19      1.32134E+04
tf10143      3.29      1.36086E+04
tf10144      3.39      1.40029E+04
tf10145      3.49      1.43962E+04
tf10146      3.59      1.47885E+04
tf10147      3.69      1.51799E+04
tf10148      3.79      1.55703E+04
tf10149      3.89      1.59598E+04
tf10150      3.99      1.63483E+04
tf10151      4.09      1.67339E+04
tf10152      4.19      1.71226E+04
tf10153      4.29      1.75084E+04
tf10154      4.39      1.78933E+04
tf10155      4.49      1.82774E+04
tf10156      4.59      1.86606E+04
tf10157      4.69      1.90429E+04
tf10158      4.79      1.94244E+04
tf10159      4.89      1.98050E+04
tf10160      4.99      2.01849E+04
tf10161      5.09      2.05639E+04
tf10162      5.19      2.09422E+04
tf10163      5.29      2.13196E+04
tf10164      5.39      2.16962E+04
tf10165      5.49      2.20721E+04
tf10166      5.59      2.24472E+04
tf10167      5.69      2.28216E+04
tf10168      5.79      2.31952E+04
tf10169      5.89      2.35681E+04
tf10170      5.99      2.39403E+04
tf10171      6.09      2.43117E+04
tf10172      6.19      2.46825E+04
tf10173      6.29      2.50525E+04
tf10174      6.39      2.54217E+04
tf10175      6.49      2.57871E+04
tf10176      6.59      2.61497E+04
tf10177      6.69      2.65108E+04
tf10178      6.79      2.68704E+04
tf10179      6.89      2.72287E+04
tf10180      6.99      2.75855E+04
tf10181      7.09      2.79411E+04
tf10182      7.19      2.82953E+04
tf10183      7.29      2.86482E+04
tf10184      7.39      2.89998E+04
tf10185      7.49      2.93502E+04
tf10186      7.59      2.96993E+04
tf10187      7.69      3.00472E+04
tf10188      7.79      3.03940E+04
tf10189      7.89      3.07395E+04
tf10190      7.99      3.10839E+04
tf10191      8.09      3.14271E+04
tf10192      8.19      3.17692E+04
tf10193      8.29      3.21101E+04
tf10194      8.39      3.24500E+04
tf10195      8.49      3.27888E+04
tf10196      8.59      3.31265E+04
tf10197      8.69      3.34631E+04
tf10198      8.79      3.37987E+04
tf10199      8.7900001  0.00000E+00
*
tf10200  'MSLB-MASS-2'  90  0.4536  0.0  * convert lbm to kg
tf10210      8.7899999  0.00000E+00
tf10211      8.7900001  3.37987E+04
tf10212      8.89      3.41332E+04
tf10213      8.99      3.44668E+04
tf10214      9.09      3.47993E+04
tf10215      9.19      3.51308E+04

```

tf10216	9.29	3.54613E+04
tf10217	9.39	3.57909E+04
tf10218	9.49	3.61195E+04
tf10219	9.59	3.64471E+04
tf10220	9.69	3.67738E+04
tf10221	9.79	3.70996E+04
tf10222	9.89	3.74244E+04
tf10223	9.99	3.77484E+04
tf10224	10.09	3.80714E+04
tf10225	10.19	3.83935E+04
tf10226	10.29	3.87148E+04
tf10227	10.39	3.90351E+04
tf10228	10.49	3.93546E+04
tf10229	10.59	3.96732E+04
tf10230	10.69	3.99910E+04
tf10231	10.79	4.03079E+04
tf10232	10.89	4.06239E+04
tf10233	10.99	4.09391E+04
tf10234	11.09	4.12535E+04
tf10235	11.19	4.15670E+04
tf10236	11.29	4.18798E+04
tf10237	11.39	4.21917E+04
tf10238	11.49	4.25028E+04
tf10239	11.59	4.28131E+04
tf10240	11.69	4.31226E+04
tf10241	11.79	4.34313E+04
tf10242	11.89	4.37392E+04
tf10243	11.99	4.40464E+04
tf10244	12.09	4.43528E+04
tf10245	12.19	4.46584E+04
tf10246	12.29	4.49632E+04
tf10247	12.39	4.52673E+04
tf10248	12.49	4.55707E+04
tf10249	12.59	4.58733E+04
tf10250	12.69	4.61751E+04
tf10251	12.79	4.64763E+04
tf10252	12.89	4.67767E+04
tf10253	12.99	4.70763E+04
tf10254	13.09	4.73753E+04
tf10255	13.19	4.76735E+04
tf10256	13.29	4.79710E+04
tf10257	13.39	4.82679E+04
tf10258	13.49	4.85640E+04
tf10259	13.59	4.88590E+04
tf10260	13.69	4.91512E+04
tf10261	13.79	4.94425E+04
tf10262	13.89	4.97327E+04
tf10263	13.99	5.00220E+04
tf10264	14.09	5.03103E+04
tf10265	14.19	5.05976E+04
tf10266	14.29	5.08839E+04
tf10267	14.39	5.11694E+04
tf10268	14.49	5.14538E+04
tf10269	14.59	5.17374E+04
tf10270	14.69	5.20200E+04
tf10271	14.79	5.23017E+04
tf10272	14.89	5.25825E+04
tf10273	14.99	5.28624E+04
tf10274	15.09	5.31415E+04
tf10275	15.19	5.34196E+04
tf10276	15.29	5.36969E+04
tf10277	15.39	5.39733E+04
tf10278	15.49	5.42489E+04
tf10279	15.59	5.45236E+04
tf10280	15.69	5.47975E+04
tf10281	15.79	5.50706E+04
tf10282	15.89	5.53429E+04
tf10283	15.99	5.56144E+04

tf10284	16.09	5.58852E+04
tf10285	16.19	5.61551E+04
tf10286	16.29	5.64244E+04
tf10287	16.39	5.66928E+04
tf10288	16.49	5.69606E+04
tf10289	16.59	5.72276E+04
tf10290	16.69	5.74938E+04
tf10291	16.79	5.77593E+04
tf10292	16.89	5.80241E+04
tf10293	16.99	5.82882E+04
tf10294	17.09	5.85516E+04
tf10295	17.19	5.88143E+04
tf10296	17.29	5.90763E+04
tf10297	17.39	5.93376E+04
tf10298	17.49	5.95982E+04
tf10299	17.4900001	0.00000E+00
*		
tf10300	'MSLB-MASS-3'	90 0.4536 0.0 * convert lbm to kg
tf10310	17.4899999	0.00000E+00
tf10311	17.49	5.95982E+04
tf10312	17.59	5.98581E+04
tf10313	17.69	6.01174E+04
tf10314	17.79	6.03760E+04
tf10315	17.89	6.06339E+04
tf10316	17.99	6.08912E+04
tf10317	18.09	6.11478E+04
tf10318	18.19	6.14038E+04
tf10319	18.29	6.16591E+04
tf10320	18.39	6.19138E+04
tf10321	18.49	6.21678E+04
tf10322	18.59	6.24213E+04
tf10323	18.69	6.26741E+04
tf10324	18.79	6.29262E+04
tf10325	18.89	6.31778E+04
tf10326	18.99	6.34288E+04
tf10327	19.09	6.36792E+04
tf10328	19.19	6.39289E+04
tf10329	19.29	6.41781E+04
tf10330	19.39	6.44267E+04
tf10331	19.49	6.46747E+04
tf10332	19.59	6.49221E+04
tf10333	19.69	6.51689E+04
tf10334	19.79	6.54152E+04
tf10335	19.89	6.56609E+04
tf10336	19.99	6.59060E+04
tf10337	20.38	6.68811E+04
tf10338	20.78	6.78474E+04
tf10339	21.18	6.88053E+04
tf10340	21.58	6.97550E+04
tf10341	21.98	7.06966E+04
tf10342	22.38	7.16305E+04
tf10343	22.78	7.25569E+04
tf10344	23.18	7.34763E+04
tf10345	23.58	7.43887E+04
tf10346	23.98	7.52943E+04
tf10347	24.38	7.61933E+04
tf10348	24.78	7.70859E+04
tf10349	25.18	7.79721E+04
tf10350	25.58	7.88522E+04
tf10351	25.98	7.97263E+04
tf10352	26.38	8.05945E+04
tf10353	26.78	8.14569E+04
tf10354	27.18	8.23137E+04
tf10355	27.58	8.31650E+04
tf10356	27.98	8.40110E+04
tf10357	28.38	8.48517E+04
tf10358	28.78	8.56873E+04
tf10359	29.18	8.65186E+04

tf10360	29.58	8.73456E+04
tf10361	29.98	8.81685E+04
tf10362	30.38	8.89872E+04
tf10363	30.78	8.98018E+04
tf10364	31.18	9.06124E+04
tf10365	31.58	9.14191E+04
tf10366	31.98	9.22218E+04
tf10367	32.38	9.30208E+04
tf10368	32.78	9.38159E+04
tf10369	33.18	9.46073E+04
tf10370	33.58	9.53951E+04
tf10371	33.98	9.61792E+04
tf10372	34.38	9.69597E+04
tf10373	34.78	9.77367E+04
tf10374	35.18	9.85103E+04
tf10375	35.58	9.92806E+04
tf10376	35.98	1.00048E+05
tf10377	36.38	1.00811E+05
tf10378	36.78	1.01572E+05
tf10379	37.18	1.02330E+05
tf10380	37.58	1.03084E+05
tf10381	37.98	1.03835E+05
tf10382	38.38	1.04584E+05
tf10383	38.78	1.05329E+05
tf10384	39.18	1.06071E+05
tf10385	39.58	1.06810E+05
tf10386	39.98	1.07547E+05
tf10387	40.38	1.08280E+05
tf10388	40.78	1.09011E+05
tf10389	41.18	1.09739E+05
tf10390	41.58	1.10464E+05
tf10391	41.98	1.11186E+05
tf10392	42.38	1.11906E+05
tf10393	42.78	1.12623E+05
tf10394	43.18	1.13337E+05
tf10395	43.58	1.14049E+05
tf10396	43.98	1.14758E+05
tf10397	44.38	1.15464E+05
tf10398	44.78	1.16168E+05
tf10399	44.7800001	0.00000E+00
*		
tf10400	'MSLB-MASS-4'	90 0.4536 0.0 * convert lbm to kg
tf10410	44.7799999	0.00000E+00
tf10411	44.78	1.16168E+05
tf10412	45.18	1.16869E+05
tf10413	45.58	1.18264E+05
tf10414	46.38	1.18958E+05
tf10415	46.78	1.19649E+05
tf10416	47.18	1.20338E+05
tf10417	47.58	1.21025E+05
tf10418	47.98	1.21709E+05
tf10419	48.38	1.22390E+05
tf10420	48.78	1.23070E+05
tf10421	49.18	1.23747E+05
tf10422	49.58	1.24421E+05
tf10423	49.98	1.25093E+05
tf10424	51.98	1.28421E+05
tf10425	53.98	1.31693E+05
tf10426	55.98	1.34911E+05
tf10427	57.98	1.38078E+05
tf10428	59.98	1.41193E+05
tf10429	61.98	1.44257E+05
tf10430	63.98	1.47271E+05
tf10431	65.98	1.50234E+05
tf10432	67.98	1.53148E+05
tf10433	69.98	1.56013E+05
tf10434	71.98	1.58831E+05
tf10435	73.98	1.61602E+05

tf10436	75.98	1.64327E+05
tf10437	77.98	1.67009E+05
tf10438	79.98	1.69648E+05
tf10439	81.98	1.72244E+05
tf10440	83.98	1.74799E+05
tf10441	85.98	1.77314E+05
tf10442	87.98	1.79790E+05
tf10443	89.98	1.82228E+05
tf10444	91.98	1.84628E+05
tf10445	93.98	1.86992E+05
tf10446	95.98	1.89320E+05
tf10447	97.98	1.91613E+05
tf10448	99.98	1.93872E+05
tf10449	101.98	1.96097E+05
tf10450	103.98	1.98289E+05
tf10451	105.98	2.00448E+05
tf10452	107.98	2.02575E+05
tf10453	109.98	2.04670E+05
tf10454	111.98	2.06734E+05
tf10455	113.98	2.08768E+05
tf10456	115.98	2.10773E+05
tf10457	117.98	2.12748E+05
tf10458	119.98	2.14695E+05
tf10459	121.98	2.16614E+05
tf10460	123.98	2.18505E+05
tf10461	125.98	2.20370E+05
tf10462	127.98	2.22208E+05
tf10463	129.98	2.24021E+05
tf10464	131.98	2.25808E+05
tf10465	133.98	2.27567E+05
tf10466	135.98	2.29299E+05
tf10467	137.98	2.31000E+05
tf10468	139.98	2.32672E+05
tf10469	141.98	2.34314E+05
tf10470	143.98	2.35926E+05
tf10471	145.98	2.37508E+05
tf10472	147.98	2.39060E+05
tf10473	149.98	2.40583E+05
tf10474	153.98	2.43536E+05
tf10475	157.98	2.46367E+05
tf10476	161.98	2.49073E+05
tf10477	165.98	2.51651E+05
tf10478	169.98	2.54091E+05
tf10479	173.98	2.56386E+05
tf10480	177.98	2.58526E+05
tf10481	181.98	2.60501E+05
tf10482	185.98	2.62301E+05
tf10483	189.98	2.63922E+05
tf10484	193.98	2.65275E+05
tf10485	197.98	2.66296E+05
tf10486	201.98	2.67085E+05
tf10487	205.98	2.67708E+05
tf10488	209.98	2.68219E+05
tf10489	213.98	2.68638E+05
tf10490	217.98	2.69004E+05
tf10491	221.98	2.69093E+05
tf10492	225.98	2.69155E+05
tf10493	229.98	2.69217E+05
tf10494	233.98	2.69279E+05
tf10495	237.98	2.69340E+05
tf10496	241.98	2.69401E+05
tf10497	245.98	2.69462E+05
tf10498	249.98	2.69523E+05
tf10499	249.9800001	0.00000E+00
*		
tf10500	'MSLB-MASS-5'	40 0.4536 0.0 * convert lbm to kg
tf10510	249.9799999	0.00000E+00
tf10511	249.98	2.69523E+05

tf10512	253.98	2.69584E+05				cf11510	1.0	0.0	TIME	
tf10513	257.98	2.69645E+05				*				
tf10514	261.98	2.69706E+05				tf11100	'MSLB-ENRG-1'	90	1055.	0.0 * convert Btu to J
tf10515	265.98	2.69766E+05				tf11110	0.00	0.00000E+00		
tf10516	269.98	2.69827E+05				tf11111	0.09	4.66320E+05		
tf10517	273.98	2.69887E+05				tf11112	0.19	9.82183E+05		
tf10518	277.98	2.69948E+05				tf11113	0.29	1.49608E+06		
tf10519	281.98	2.70008E+05				tf11114	0.39	2.00814E+06		
tf10520	285.98	2.70068E+05				tf11115	0.49	2.51839E+06		
tf10521	289.98	2.70128E+05				tf11116	0.59	3.02687E+06		
tf10522	293.98	2.70189E+05				tf11117	0.69	3.53363E+06		
tf10523	297.98	2.70249E+05				tf11118	0.79	4.03875E+06		
tf10524	301.98	2.70309E+05				tf11119	0.89	4.54223E+06		
tf10525	305.98	2.70369E+05				tf11120	0.99	5.04410E+06		
tf10526	309.98	2.70429E+05				tf11121	1.09	5.54442E+06		
tf10527	313.98	2.70490E+05				tf11122	1.19	6.04319E+06		
tf10528	317.98	2.70550E+05				tf11123	1.29	6.54047E+06		
tf10529	321.98	2.70610E+05				tf11124	1.39	7.03628E+06		
tf10530	325.98	2.70670E+05				tf11125	1.49	7.53062E+06		
tf10531	329.98	2.70729E+05				tf11126	1.59	8.02355E+06		
tf10532	333.98	2.70789E+05				tf11127	1.69	8.51505E+06		
tf10533	337.98	2.70849E+05				tf11128	1.79	9.00519E+06		
tf10534	341.98	2.70909E+05				tf11129	1.89	9.49396E+06		
tf10535	345.98	2.70969E+05				tf11130	1.99	9.98141E+06		
tf10536	349.98	2.71029E+05				tf11131	2.09	1.04675E+07		
tf10537	353.98	2.71088E+05				tf11132	2.19	1.09523E+07		
tf10538	357.98	2.71148E+05				tf11133	2.29	1.14359E+07		
tf10539	361.98	2.71208E+05				tf11134	2.39	1.19182E+07		
tf10540	365.98	2.71267E+05				tf11135	2.49	1.23992E+07		
tf10541	369.98	2.71327E+05				tf11136	2.59	1.28790E+07		
tf10542	373.98	2.71386E+05				tf11137	2.69	1.33576E+07		
tf10543	377.98	2.71445E+05				tf11138	2.79	1.38350E+07		
tf10544	381.98	2.71505E+05				tf11139	2.89	1.43111E+07		
tf10545	385.98	2.71564E+05				tf11140	2.99	1.47860E+07		
tf10546	389.98	2.71623E+05				tf11141	3.09	1.52597E+07		
tf10547	393.98	2.71683E+05				tf11142	3.19	1.57322E+07		
tf10548	397.98	2.71742E+05				tf11143	3.29	1.62035E+07		
tf10549	400.00	2.71772E+05				tf11144	3.39	1.66737E+07		
*						tf11145	3.49	1.71427E+07		
cf11000	ATM-MASS-SRC	ADD	5	1.0	0.0	tf11146	3.59	1.76106E+07		
cf11001	0.0					tf11147	3.69	1.80773E+07		
cf11010	1.0	0.0	CFVALU.101			tf11148	3.79	1.85430E+07		
cf11011	1.0	0.0	CFVALU.102			tf11149	3.89	1.90076E+07		
cf11012	1.0	0.0	CFVALU.103			tf11150	3.99	1.94711E+07		
cf11013	1.0	0.0	CFVALU.104			tf11151	4.09	1.99335E+07		
cf11014	1.0	0.0	CFVALU.105			tf11152	4.19	2.03949E+07		
*						tf11153	4.29	2.08552E+07		
*****						tf11154	4.39	2.13145E+07		
* atmosphere energy						tf11155	4.49	2.17728E+07		
*****						tf11156	4.59	2.22301E+07		
cf11100	MSLB-ENRG-1	TAB-FUN	1	1.0	0.0	tf11157	4.69	2.26864E+07		
cf11103	111					tf11158	4.79	2.31417E+07		
cf11110	1.0	0.0	TIME			tf11159	4.89	2.35960E+07		
*						tf11160	4.99	2.40494E+07		
cf11200	MSLB-ENRG-2	TAB-FUN	1	1.0	0.0	tf11161	5.09	2.45019E+07		
cf11203	112					tf11162	5.19	2.49534E+07		
cf11210	1.0	0.0	TIME			tf11163	5.29	2.54040E+07		
*						tf11164	5.39	2.58537E+07		
cf11300	MSLB-ENRG-3	TAB-FUN	1	1.0	0.0	tf11165	5.49	2.63025E+07		
cf11303	113					tf11166	5.59	2.67504E+07		
cf11310	1.0	0.0	TIME			tf11167	5.69	2.71974E+07		
*						tf11168	5.79	2.76436E+07		
cf11400	MSLB-ENRG-4	TAB-FUN	1	1.0	0.0	tf11169	5.89	2.80889E+07		
cf11403	114					tf11170	5.99	2.85334E+07		
cf11410	1.0	0.0	TIME			tf11171	6.09	2.89770E+07		
*						tf11172	6.19	2.94199E+07		
cf11500	MSLB-ENRG-5	TAB-FUN	1	1.0	0.0	tf11173	6.29	2.98619E+07		
cf11503	115					tf11174	6.39	3.03029E+07		

tf11175	6.49	3.07394E+07	
tf11176	6.59	3.11728E+07	
tf11177	6.69	3.16043E+07	
tf11178	6.79	3.20341E+07	
tf11179	6.89	3.24623E+07	
tf11180	6.99	3.28899E+07	
tf11181	7.09	3.33140E+07	
tf11182	7.19	3.37375E+07	
tf11183	7.29	3.41595E+07	
tf11184	7.39	3.45800E+07	
tf11185	7.49	3.49990E+07	
tf11186	7.59	3.54166E+07	
tf11187	7.69	3.58328E+07	
tf11188	7.79	3.62475E+07	
tf11189	7.89	3.66609E+07	
tf11190	7.99	3.70729E+07	
tf11191	8.09	3.74835E+07	
tf11192	8.19	3.78929E+07	
tf11193	8.29	3.83009E+07	
tf11194	8.39	3.87076E+07	
tf11195	8.49	3.91131E+07	
tf11196	8.59	3.95173E+07	
tf11197	8.69	3.99202E+07	
tf11198	8.79	4.03219E+07	
tf11199	8.7900001	0.00000E+00	
*			
tf11200	'MSLB-ENRG-2'	90 1055. 0.0	* convert Btu to J
tf11210	8.7899999	0.00000E+00	
tf11211	8.7900001	4.03219E+07	
tf11212	8.89	4.07225E+07	
tf11213	8.99	4.11218E+07	
tf11214	9.09	4.15199E+07	
tf11215	9.19	4.19169E+07	
tf11216	9.29	4.23127E+07	
tf11217	9.39	4.27073E+07	
tf11218	9.49	4.31008E+07	
tf11219	9.59	4.34933E+07	
tf11220	9.69	4.38846E+07	
tf11221	9.79	4.42748E+07	
tf11222	9.89	4.46639E+07	
tf11223	9.99	4.50519E+07	
tf11224	10.09	4.54389E+07	
tf11225	10.19	4.58248E+07	
tf11226	10.29	4.62097E+07	
tf11227	10.39	4.65936E+07	
tf11228	10.49	4.69764E+07	
tf11229	10.59	4.73582E+07	
tf11230	10.69	4.77390E+07	
tf11231	10.79	4.81188E+07	
tf11232	10.89	4.84976E+07	
tf11233	10.99	4.88753E+07	
tf11234	11.09	4.92521E+07	
tf11235	11.19	4.96279E+07	
tf11236	11.29	5.00028E+07	
tf11237	11.39	5.03767E+07	
tf11238	11.49	5.07497E+07	
tf11239	11.59	5.11217E+07	
tf11240	11.69	5.14928E+07	
tf11241	11.79	5.18629E+07	
tf11242	11.89	5.22322E+07	
tf11243	11.99	5.26005E+07	
tf11244	12.09	5.29679E+07	
tf11245	12.19	5.33344E+07	
tf11246	12.29	5.36999E+07	
tf11247	12.39	5.40646E+07	
tf11248	12.49	5.44285E+07	
tf11249	12.59	5.47914E+07	
tf11250	12.69	5.51533E+07	

tf11251	12.79	5.53147E+07	
tf11252	12.89	5.56750E+07	
tf11253	12.99	5.60345E+07	
tf11254	13.09	5.63931E+07	
tf11255	13.19	5.67509E+07	
tf11256	13.29	5.71078E+07	
tf11257	13.39	5.74639E+07	
tf11258	13.49	5.78192E+07	
tf11259	13.59	5.81732E+07	
tf11260	13.69	5.85238E+07	
tf11261	13.79	5.88733E+07	
tf11262	13.89	5.92216E+07	
tf11263	13.99	5.95687E+07	
tf11264	14.09	6.00147E+07	
tf11265	14.19	6.04595E+07	
tf11266	14.29	6.08032E+07	
tf11267	14.39	6.11458E+07	
tf11268	14.49	6.14873E+07	
tf11269	14.59	6.18276E+07	
tf11270	14.69	6.21669E+07	
tf11271	14.79	6.25051E+07	
tf11272	14.89	6.28422E+07	
tf11273	14.99	6.31783E+07	
tf11274	15.09	6.35133E+07	
tf11275	15.19	6.38473E+07	
tf11276	15.29	6.41803E+07	
tf11277	15.39	6.45122E+07	
tf11278	15.49	6.48431E+07	
tf11279	15.59	6.51730E+07	
tf11280	15.69	6.55020E+07	
tf11281	15.79	6.58300E+07	
tf11282	15.89	6.61570E+07	
tf11283	15.99	6.64831E+07	
tf11284	16.09	6.68083E+07	
tf11285	16.19	6.71326E+07	
tf11286	16.29	6.74560E+07	
tf11287	16.39	6.77785E+07	
tf11288	16.49	6.81002E+07	
tf11289	16.59	6.84209E+07	
tf11290	16.69	6.87408E+07	
tf11291	16.79	6.90598E+07	
tf11292	16.89	6.93780E+07	
tf11293	16.99	6.96953E+07	
tf11294	17.09	7.00117E+07	
tf11295	17.19	7.03274E+07	
tf11296	17.29	7.06422E+07	
tf11297	17.39	7.09562E+07	
tf11298	17.49	7.12694E+07	
tf11299	17.4900001	0.00000E+00	
*			
tf11300	'MSLB-ENRG-3'	90 1055. 0.0	* convert Btu to J
tf11310	17.4899999	0.00000E+00	
tf11311	17.49	7.12694E+07	
tf11312	17.59	7.15817E+07	
tf11313	17.69	7.18933E+07	
tf11314	17.79	7.22041E+07	
tf11315	17.89	7.25141E+07	
tf11316	17.99	7.28233E+07	
tf11317	18.09	7.31318E+07	
tf11318	18.19	7.34394E+07	
tf11319	18.29	7.37463E+07	
tf11320	18.39	7.40525E+07	
tf11321	18.49	7.43578E+07	
tf11322	18.59	7.46625E+07	
tf11323	18.69	7.49664E+07	
tf11324	18.79	7.52695E+07	
tf11325	18.89	7.55720E+07	
tf11326	18.99	7.58737E+07	

tf11327	19.09	7.61747E+07
tf11328	19.19	7.64750E+07
tf11329	19.29	7.67746E+07
tf11330	19.39	7.70734E+07
tf11331	19.49	7.73716E+07
tf11332	19.59	7.76691E+07
tf11333	19.69	7.79659E+07
tf11334	19.79	7.82620E+07
tf11335	19.89	7.85575E+07
tf11336	19.99	7.88522E+07
tf11337	20.38	8.00248E+07
tf11338	20.78	8.11870E+07
tf11339	21.18	8.23391E+07
tf11340	21.58	8.34814E+07
tf11341	21.98	8.46142E+07
tf11342	22.38	8.57376E+07
tf11343	22.78	8.68522E+07
tf11344	23.18	8.79584E+07
tf11345	23.58	8.90563E+07
tf11346	23.98	9.01460E+07
tf11347	24.38	9.12279E+07
tf11348	24.78	9.23021E+07
tf11349	25.18	9.33687E+07
tf11350	25.58	9.44279E+07
tf11351	25.98	9.54800E+07
tf11352	26.38	9.65250E+07
tf11353	26.78	9.75631E+07
tf11354	27.18	9.85945E+07
tf11355	27.58	9.96193E+07
tf11356	27.98	1.00638E+08
tf11357	28.38	1.01650E+08
tf11358	28.78	1.02656E+08
tf11359	29.18	1.03657E+08
tf11360	29.58	1.04653E+08
tf11361	29.98	1.05643E+08
tf11362	30.38	1.06629E+08
tf11363	30.78	1.07610E+08
tf11364	31.18	1.08586E+08
tf11365	31.58	1.09557E+08
tf11366	31.98	1.10524E+08
tf11367	32.38	1.11486E+08
tf11368	32.78	1.12444E+08
tf11369	33.18	1.13397E+08
tf11370	33.58	1.14345E+08
tf11371	33.98	1.15290E+08
tf11372	34.38	1.16230E+08
tf11373	34.78	1.17165E+08
tf11374	35.18	1.18097E+08
tf11375	35.58	1.19025E+08
tf11376	35.98	1.19949E+08
tf11377	36.38	1.20869E+08
tf11378	36.78	1.21785E+08
tf11379	37.18	1.22697E+08
tf11380	37.58	1.23606E+08
tf11381	37.98	1.24511E+08
tf11382	38.38	1.25412E+08
tf11383	38.78	1.26309E+08
tf11384	39.18	1.27204E+08
tf11385	39.58	1.28094E+08
tf11386	39.98	1.28981E+08
tf11387	40.38	1.29865E+08
tf11388	40.78	1.30745E+08
tf11389	41.18	1.31622E+08
tf11390	41.58	1.32495E+08
tf11391	41.98	1.33365E+08
tf11392	42.38	1.34232E+08
tf11393	42.78	1.35095E+08
tf11394	43.18	1.35956E+08

tf11395	43.58	1.36813E+08
tf11396	43.98	1.37667E+08
tf11397	44.38	1.38518E+08
tf11398	44.78	1.39366E+08
tf11399	44.7800001	0.00000E+00
*		
tf11400	'MSLB-ENRG-4'	90 1055. 0.0 * convert Btu to J
tf11410	44.7799999	0.00000E+00
tf11411	44.78	1.39366E+08
tf11412	45.18	1.40211E+08
tf11413	45.98	1.41891E+08
tf11414	46.38	1.42727E+08
tf11415	46.78	1.43559E+08
tf11416	47.18	1.44389E+08
tf11417	47.58	1.45216E+08
tf11418	47.98	1.46040E+08
tf11419	48.38	1.46861E+08
tf11420	48.78	1.47679E+08
tf11421	49.18	1.48495E+08
tf11422	49.58	1.49307E+08
tf11423	49.98	1.50117E+08
tf11424	51.98	1.54125E+08
tf11425	53.98	1.58066E+08
tf11426	55.98	1.61943E+08
tf11427	57.98	1.65758E+08
tf11428	59.98	1.69510E+08
tf11429	61.98	1.73200E+08
tf11430	63.98	1.76830E+08
tf11431	65.98	1.80399E+08
tf11432	67.98	1.83908E+08
tf11433	69.98	1.87358E+08
tf11434	71.98	1.90751E+08
tf11435	73.98	1.94087E+08
tf11436	75.98	1.97369E+08
tf11437	77.98	2.00597E+08
tf11438	79.98	2.03774E+08
tf11439	81.98	2.06899E+08
tf11440	83.98	2.09974E+08
tf11441	85.98	2.13001E+08
tf11442	87.98	2.15980E+08
tf11443	89.98	2.18914E+08
tf11444	91.98	2.21801E+08
tf11445	93.98	2.24645E+08
tf11446	95.98	2.27445E+08
tf11447	97.98	2.30203E+08
tf11448	99.98	2.32920E+08
tf11449	101.98	2.35596E+08
tf11450	103.98	2.38231E+08
tf11451	105.98	2.40827E+08
tf11452	107.98	2.43383E+08
tf11453	109.98	2.45902E+08
tf11454	111.98	2.48383E+08
tf11455	113.98	2.50827E+08
tf11456	115.98	2.53235E+08
tf11457	117.98	2.55608E+08
tf11458	119.98	2.57946E+08
tf11459	121.98	2.60251E+08
tf11460	123.98	2.62522E+08
tf11461	125.98	2.64761E+08
tf11462	127.98	2.66968E+08
tf11463	129.98	2.69144E+08
tf11464	131.98	2.71288E+08
tf11465	133.98	2.73400E+08
tf11466	135.98	2.75477E+08
tf11467	137.98	2.77518E+08
tf11468	139.98	2.79523E+08
tf11469	141.98	2.81492E+08
tf11470	143.98	2.83424E+08

tf11471	145.98	2.85320E+08
tf11472	147.98	2.87181E+08
tf11473	149.98	2.89004E+08
tf11474	153.98	2.92542E+08
tf11475	157.98	2.95930E+08
tf11476	161.98	2.99167E+08
tf11477	165.98	3.02250E+08
tf11478	169.98	3.05165E+08
tf11479	173.98	3.07903E+08
tf11480	177.98	3.10455E+08
tf11481	181.98	3.12807E+08
tf11482	185.98	3.14949E+08
tf11483	189.98	3.16873E+08
tf11484	193.98	3.18477E+08
tf11485	197.98	3.19686E+08
tf11486	201.98	3.20619E+08
tf11487	205.98	3.21355E+08
tf11488	209.98	3.21958E+08
tf11489	213.98	3.22453E+08
tf11490	217.98	3.22890E+08
tf11491	221.98	3.22998E+08
tf11492	225.98	3.23074E+08
tf11493	229.98	3.23150E+08
tf11494	233.98	3.23225E+08
tf11495	237.98	3.23300E+08
tf11496	241.98	3.23375E+08
tf11497	245.98	3.23450E+08
tf11498	249.98	3.23524E+08
tf11499	249.980001	0.00000E+00

tf11500	'MSLB-ENRG-4'	40	1055.	0.0	* convert Btu to J
tf11510	249.9799999	0.00000E+00			
tf11511	249.98	3.23524E+08			
tf11512	253.98	3.23599E+08			
tf11513	257.98	3.23673E+08			
tf11514	261.98	3.23747E+08			
tf11515	265.98	3.23821E+08			
tf11516	269.98	3.23895E+08			
tf11517	273.98	3.23969E+08			
tf11518	277.98	3.24043E+08			
tf11519	281.98	3.24117E+08			
tf11520	285.98	3.24191E+08			
tf11521	289.98	3.24264E+08			
tf11522	293.98	3.24338E+08			
tf11523	297.98	3.24411E+08			
tf11524	301.98	3.24485E+08			
tf11525	305.98	3.24559E+08			
tf11526	309.98	3.24632E+08			
tf11527	313.98	3.24706E+08			
tf11528	317.98	3.24779E+08			
tf11529	321.98	3.24853E+08			
tf11530	325.98	3.24926E+08			
tf11531	329.98	3.24999E+08			
tf11532	333.98	3.25073E+08			
tf11533	337.98	3.25146E+08			
tf11534	341.98	3.25219E+08			
tf11535	345.98	3.25292E+08			
tf11536	349.98	3.25366E+08			
tf11537	353.98	3.25439E+08			
tf11538	357.98	3.25512E+08			
tf11539	361.98	3.25585E+08			
tf11540	365.98	3.25658E+08			
tf11541	369.98	3.25731E+08			
tf11542	373.98	3.25803E+08			
tf11543	377.98	3.25876E+08			
tf11544	381.98	3.25949E+08			
tf11545	385.98	3.26022E+08			
tf11546	389.98	3.26094E+08			

tf11547	393.98	3.26167E+08
tf11548	397.98	3.26240E+08
tf11549	400.00	3.26276E+08

*					
cf12000	ATM-ENRG-SRC	ADD	5	1.0	0.0
cf12001	0.0				
cf12010	1.0	0.0	CFVALU.111		
cf12011	1.0	0.0	CFVALU.112		
cf12012	1.0	0.0	CFVALU.113		
cf12013	1.0	0.0	CFVALU.114		
cf12014	1.0	0.0	CFVALU.115		
*					

APPENDIX B

Changes in Input Data Between the Original Licensee Submittal (November 1999) and the Supplement (June 2000)

1. BACKGROUND

The confirmatory calculations described in the main body of this report were performed using data submitted by the licensee in an Amendment Request dated November 1999 (Entergy 1999). After the calculations were completed, the licensee submitted a supplement to their Amendment Request. In the supplement, the licensee stated

corrections were made to two key input assumptions used in the computer code to perform the containment analysis. A correction was made regarding the surface area assumed for an existing containment heat sink. A second correction was made regarding the time required to fill the containment spray headers, and thus the containment spray system response time. (Entergy 2000)

In particular, the surface area associated with the "Refueling Canal" heat sink was reduced from 18,000 ft² to 8000 ft². The delay time between receipt of the high-high containment pressure signal and the beginning of containment spray flow was changed from 53.6 s to 60.0 s.

The licensee also modified proposed changes to the ANO-2 Technical Specifications regarding the region of acceptable operation. The only change that affected the confirmatory calculations related to containment maximum pressure, which was changed to a 15.5 psia for all allowed values of containment atmosphere temperature.

Finally, the licensee modified the method for modeling condensation heat/mass transfer on containment structures in two areas. First, the list of structural heat sinks included in the ANO-2 containment model was expanded to include several new items. A total of 20 new heat sinks was identified, most of which were composed of relatively thin steel but involved small surface area. Water-filled piping in the Safety Injection System and the Fire Water System also was added as new heat sinks.

The second modification involved a change to COPATTA modeling assumptions regarding condensate heat/mass transfer. The original assumption was that condensate is transported instantaneously to the containment sump (i.e., the formation and drainage of liquid films are ignored). In the revised analysis, the licensee adopted an assumption allowed under NRC guidance for environmental qualification of safety-related electrical equipment (NRC 1979). Specifically, 8% of the condensate formed on heat sinks was assumed to remain in the containment atmosphere rather than drain to the containment sump while the containment atmosphere is superheated. This amount purportedly represents the latent heat equivalent of the atmosphere superheat absorbed by draining condensate films.

2. REVISED CONFIRMATORY CALCULATIONS

Each of the changes described above was made in the ANO-2 model used for the confirmatory calculations except the one related to condensate heat/mass transfer. The proposed adjustments to accident initial conditions, the safety system actuation criteria, and the list of containment heat sinks appeared reasonable and were accommodated in the confirmatory analysis model easily. However, the original confirmatory analysis (described in the main report) clearly indicated that heat transfer to draining liquid condensate films had an insignificant effect on peak containment temperature and pressure (refer to the baseline and sensitivity case 4 results). Further, heat/mass transfer between draining liquid films and the containment atmosphere is included in the confirmatory analysis model (i.e., MELCOR). Consequently,

a priori assumptions defining the partitioning of the condensate between the sump and atmosphere are not necessary.

Revised confirmatory calculations were made for the LOCA baseline accident scenario as well as the scenario that generated the bounding containment pressure response (sensitivity case 5). Calculated containment pressure and temperature signatures are compared in Figs. B-1 and B-2, respectively.

In both cases, the changes made to the ANO-2 model resulted in very small changes to the calculated results. Peak pressures were found to be less than 1 psi lower than those generated in the original analysis; peak temperatures (during the post-reflood period) increased by 1°F.

3. CONCLUSIONS

The modifications made to the ANO-2 containment analysis described in the supplement to the licensee's Amendment Request do not alter key calculated results or conclusions drawn from the analysis described in the main body of this report.

REFERENCES

- | | |
|--------------|--|
| Entergy 1999 | Proposed License Amendment (No. 16) to License No. NPF-6, Entergy Operations, Inc., Arkansas Nuclear One, Unit Two, Docket 50-368, an Attachment to 2CAN119903 (November 3, 1999). |
| Entergy 2000 | Supplement to Proposed Technical Specification Change Request Supporting the ANO-2 Containment Building Design Pressure Increase to 59 Psig, 2CAN060014 (June 29, 2000). |
| NRC 1979 | "Interim Staff Position on Environmental Qualification of Safety-Related Electrical Equipment," US Nuclear Regulatory Commission report NUREG-0588 (December 1979). |




Fig. B-1. Containment Pressure—Original vs Revised Confirmatory Calculations.




Fig. B-2. Containment Temperature—Original vs Revised Confirmatory Calculations.