

August 29, 2000

Mr. S. E. Scace - Director  
Nuclear Oversight and Regulatory Affairs  
c/o Mr. David A. Smith  
Northeast Nuclear Energy Company  
P. O. Box 128  
Waterford, CT 06385

SUBJECT: COMPLETION OF LICENSING ACTION FOR GENERIC LETTER 99-02,  
"LABORATORY TESTING OF NUCLEAR-GRADE ACTIVATED CHARCOAL" -  
MILLSTONE NUCLEAR POWER STATION, UNIT NO. 3 (TAC NO. MA5813)

Dear Mr. Scace:

On June 3, 1999, the U.S. Nuclear Regulatory Commission (NRC) issued Generic Letter (GL) 99-02, "Laboratory Testing of Nuclear-Grade Activated Charcoal," to all holders of operating licenses for nuclear power reactors, except those who have permanently ceased operations and have certified that fuel has been permanently removed from the reactor vessel.

The purpose of the GL was to:

- (1) Alert addressees that the NRC has determined that testing nuclear-grade activated charcoal to standards other than American Society for Testing and Materials (ASTM) D3803-1989, "Standard Test Method for Nuclear-Grade Activated Carbon," does not provide assurance for complying with the current licensing basis as it relates to the dose limits of General Design Criterion (GDC) 19 of Appendix A to Part 50 of Title 10 of the *Code of Federal Regulations* (10 CFR) and Subpart A of 10 CFR Part 100.
- (2) Request that all addressees determine whether their Technical Specifications (TS) reference ASTM D3803-1989 for charcoal filter laboratory testing. Addressees whose TS do not reference ASTM D3803-1989 should either amend their TS to reference ASTM D3803-1989 or propose an alternative test protocol and provide the information discussed in the requested actions.
- (3) Alert addressees to the staff's intent to exercise enforcement discretion under certain conditions.
- (4) Request that all addressees send the NRC written responses on the implementation of the actions requested in this GL.

In GL 99-02, the NRC staff established the following four groups of plants:

- (1) plants in compliance with their TS that test in accordance with ASTM D3803-1989.

- (2) plants in compliance with their TS that test in accordance with a test protocol other than ASTM D3803-1989.
- (3) plants not in compliance with their TS that test in accordance with ASTM D3803-1989.
- (4) plants not in compliance with their TS that test in accordance with a test protocol other than ASTM D3803-1989.

In response to GL 99-02, you provided a letter dated November 29, 1999, for Millstone, Unit 3. Associated with your response was a request for a license amendment to change your TS to provide for testing as described in the GL. The NRC staff has reviewed your response and has concluded that you have provided requested information and a TS change request in accordance with the GL. In addition, you have committed to test in accordance with ASTM D3803-1989 until your TS amendment is issued. Therefore, we consider GL 99-02 to be closed for your facility. The TS change will be reviewed as a separate, plant-specific action under TAC NO. MA7231. We thank you for your prompt and complete response.

If you have any questions regarding this matter, please contact me at 301-415-1484.

Sincerely,

***/RA/***

Victor Nerses, Sr. Project Manager, Section 2  
Project Directorate I  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket No. 50-423

cc: See next page

- (2) plants in compliance with their TS that test in accordance with a test protocol other than ASTM D3803-1989.
- (3) plants not in compliance with their TS that test in accordance with ASTM D3803-1989.
- (4) plants not in compliance with their TS that test in accordance with a test protocol other than ASTM D3803-1989.

In response to GL 99-02, you provided a letter dated November 29, 1999, for Millstone, Unit 3. Associated with your response was a request for a license amendment to change your TS to provide for testing as described in the GL. The NRC staff has reviewed your response and has concluded that you have provided requested information and a TS change request in accordance with the GL. In addition, you have committed to test in accordance with ASTM D3803-1989 until your TS amendment is issued. Therefore, we consider GL 99-02 to be closed for your facility. The TS change will be reviewed as a separate, plant-specific action under TAC NO. MA7231. We thank you for your prompt and complete response.

If you have any questions regarding this matter, please contact me at 301-415-1484.

Sincerely,

***/RA/***

Victor Nerses, Sr. Project Manager, Section 2  
 Project Directorate I  
 Division of Licensing Project Management  
 Office of Nuclear Reactor Regulation

Docket No. 50-423

cc: See next page

**DISTRIBUTION:**

File Center  
 PUBLIC  
 PDI-2 Reading  
 RidsNrrDlpmLpdi (E.Adensam)  
 RidsNrrDlpmLpdi2 (J.Clifford)  
 RidsNrrLATClark  
 RidsNrrPMVNerses  
 RidsNrrLABMozafari  
 JSegala  
 JHannon  
 EWeiss  
 RidsOgcRp  
 RidsAcrsAcnsMailCenter

JLinville, RI  
 RUrban, RI

**TO RECEIVE A COPY, WRITE A "C" IN THE BOX.**

OFFICE	PDI-2/PM	PDI-2/LA	LPM	SC: SPLB	PDI-2/SC
NAME	VNerses:lcc	TClark	BMozafari	EWeiss	JClifford
DATE	3/29/00	3/29/00	3/31/00	8/23/00	8/25/00

DOCUMENT NAME: C:\GL99-02A5813.WPD

OFFICIAL RECORD COPY

Millstone Nuclear Power Station  
Unit 3

cc:

Ms. L. M. Cuoco  
Senior Nuclear Counsel  
Northeast Utilities Service Company  
P. O. Box 270  
Hartford, CT 06141-0270

Edward L. Wilds, Jr., Ph.D.  
Director, Division of Radiation  
Department of Environmental Protection  
79 Elm Street  
Hartford, CT 06106-5127

Regional Administrator, Region I  
U.S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, PA 19406

First Selectmen  
Town of Waterford  
15 Rope Ferry Road  
Waterford, CT 06385

Mr. M. H. Brothers  
Vice President - Nuclear Operations  
Northeast Nuclear Energy Company  
P.O. Box 128  
Waterford, CT 06385

Mr. M. R. Scully, Executive Director  
Connecticut Municipal Electric  
Energy Cooperative  
30 Stott Avenue  
Norwich, CT 06360

Mr. J. T. Carlin  
Vice President - Human Services - Nuclear  
Northeast Nuclear Energy Company  
P. O. Box 128  
Waterford, CT 06385

Mr. F. C. Rothen  
Vice President - Nuclear Operations  
Northeast Nuclear Energy Company  
P. O. Box 128  
Waterford, CT 06385

Ernest C. Hadley, Esquire  
1040 B Main Street  
P.O. Box 549  
West Wareham, MA 02576

Ms. Cynthia Arcate, Vice President  
Generation Investments  
New England Power Company  
25 Research Drive  
Westborough, MA 01582

Deborah Katz, President  
Citizens Awareness Network  
P.O. Box 83  
Shelburne Falls, MA 03170

Mr. Allan Johanson, Assistant Director  
Office of Policy and Management  
Policy Development & Planning Division  
450 Capitol Avenue - MS# 52ERN  
P. O. Box 341441  
Hartford, CT 06134-1441

Ms. Terry Concannon  
Co-Chair  
Nuclear Energy Advisory Council  
41 South Buckboard Lane  
Marlborough, CT 06447

Mr. R. P. Necci  
Vice President - Nuclear Technical Services  
Northeast Nuclear Energy Company  
P. O. Box 128  
Waterford, CT 06385

Millstone Nuclear Power Station  
Unit 3

cc:

Mr. Evan W. Woollacott  
Co-Chair  
Nuclear Energy Advisory Council  
128 Terry's Plain Road  
Simsbury, CT 06070

Mr. John W. Beck, President  
Little Harbor Consultants, Inc.  
Millstone - ITPOP Project Office  
P.O. Box 0630  
Niantic, CT 06357-0630

Mr. L. J. Olivier  
Senior Vice President and  
Chief Nuclear Officer - Millstone  
Northeast Nuclear Energy Company  
P.O. Box 128  
Waterford, CT 06385

Mr. C. J. Schwarz  
Station Director  
Northeast Nuclear Energy Company  
P.O. Box 128  
Waterford, CT 06385

Senior Resident Inspector  
Millstone Nuclear Power Station  
c/o U.S. Nuclear Regulatory Commission  
P. O. Box 513  
Niantic, CT 06357

Nicholas J. Scobbo, Jr., Esquire  
Ferriter, Scobbo, Caruso, & Rodophele, P.C.  
75 State Street, 7th Floor  
Boston, MA 02108-1807

Mr. G. D. Hicks  
Director - Nuclear Training Services  
Northeast Nuclear Energy Company  
P.O. Box 128  
Waterford, CT 06385

Citizens Regulatory Commission  
ATTN: Ms. Geri Winslow  
P. O. Box 199  
Waterford, CT 06385

Mr. William D. Meinert  
Nuclear Engineer  
Massachusetts Municipal Wholesale  
Electric Company  
P.O. Box 426  
Ludlow, MA 01056

Mr. B. D. Kenyon  
President and Chief Executive Officer-  
NNECO  
Northeast Nuclear Energy Company  
P.O. Box 128  
Waterford, CT 06385

Mr. D. B. Amerine  
Vice President - Engineering Services  
Northeast Nuclear Energy Company  
P. O. Box 128  
Waterford, CT 06385

Mr. D. A. Smith  
Manager - Regulatory Affairs  
Northeast Nuclear Energy Company  
P. O. Box 128  
Waterford, CT 06385

Ms. Nancy Burton  
147 Cross Highway  
Redding Ridge, CT 00870