

Commonwealth Edison Company
LaSalle Generating Station
2601 North 21st Road
Marseilles, IL 61341-9757
Tel 815-357-6761



August 30, 2000

**United States Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555**

**LaSalle County Station, Units 1 and 2
Facility Operating License Nos. NPF-11 and NPF-18
NRC Docket Nos. 50-373 and 50-374**

Subject: Supplement to LaSalle County Station Relief Request PR-12

**Reference: Letter from C.G. Pardee (Commonwealth Edison
(ComEd) Company) to U.S. Nuclear Regulatory Commission,
"Revision to LaSalle County Station Relief Request PR-12,"
dated August 11, 2000.**

**During an evaluation for implementation of the proposed relief request, we
identified that the Component Identification section of the relief request
attached to the referenced letter is incorrect. The component numbers
should be as follows:**

**From valve 1HG002B to valve 2HG002A
From valve 1HG002A to valve 2HG002B
From valve 1HG009 to valve 2HG006B
From valve 1HG006B to valve 2HG009**

**In addition, Figure PR-12.1 showed the check valves associated with the
crosstie piping in the incorrect relative locations. A corrected copy of
Figure PR-12.1 is attached, showing the proper relative location of the check
valves. The outboard primary containment isolation valves listed above form
the boundary between the accessible and inaccessible Hydrogen
Recombiner System piping.**


A047

August 30, 2000
U.S. Nuclear Regulatory Commission
Page 2

This request for relief supplements the referenced request for relief (see referenced letter) and does not change the basis for the relief request.

Should you have any questions concerning this letter, please contact Mr. Frank A. Spangenberg, III, Regulatory Assurance Manager, at (815) 357-6761, extension 2383.

Respectfully,



Charles G. Pardee
Site Vice President
LaSalle County Station

Attachment

cc: Regional Administrator - NRC Region III
NRC Senior Resident Inspector - LaSalle County Station

ATTACHMENT
RELIEF REQUEST PR-12
REVISION 1
(Page 3 of 3)

Figure PR-12.1

