1-NHY-650002



DETAIL 'A'



DETAIL "D"



SECT A-A



DETAIL "C"
12" INLET/OUTLET NOZZLES



ELEVATION VIEW



DETAIL "E"



RHR VAULT LOCATION PLAN
PLAN AT EL. (-) 31'-10"



DETAIL 'B' ~ SKIRT & DRAIN ATTACHMENT

NOTES:
1. DRAWING NOT TO SCALE.
2. MANUFACTURER: JOSEPH OAT JOB NO. J-2267-4
3. MANUFACTURER DRAWINGS: 5618; 5620; 5622; 5627; 5628.
4. WESTINGHOUSE P.O. NAH-546-CAZ 215357
5. WESTINGHOUSE SHOP ORDER 210.
6. 52 STUDS SA-193-B7 1⅛" DIA.-8UN X 19" LG.
7. NUTS SA-194 2H
8. SHELL MATERIAL SA-240/t-304

FOR INFORMATION ONLY

REV	DATE	DSGN	DRWN	CHKD	QA	LDE	DESCRIPTION
0	1/28/81	MPW	JM	[illegible]	[illegible]	[illegible]	ORIGINAL ISSUE

New Hampshire Yankee

SEABROOK STATION

RESIDUAL HEAT EXCHANGER
1-RH-E-9B
ISI EQUIPMENT WELDS

1-NHY-650002

REF. DRAWING NO.	REV	TITLE
FP-58251	02	RESIDUAL HEAT EXCHANGER

D-3