



August 31, 2000  
NMP1L 1533

U. S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, DC 20555

RE: Nine Mile Point Unit 1  
Docket No. 50-220  
DPR-63

**Subject:** *Supplement to Special Report, dated May 26, 2000 (NMP1L 1517)*

Gentlemen:

In Niagara Mohawk Power Corporation's (NMPC's) Special Report of May 26, 2000 (NMP1L 1517), NMPC indicated that the Containment Hydrogen Monitoring System Channel #11 and Channel #12 recorders would be upgraded or replaced by August 31, 2000. The purpose of this letter is to inform you that NMPC is changing the completion date for replacing the recorders.

NMPC had intended to replace the recorders with the plant online. Further review of the activities involved indicated that the replacement should be done during plant shut down because of the potential adverse consequences of modifying the Control Room panel online. The replacement of the Containment Hydrogen Monitoring System Channel #11 and Channel #12 recorders will be completed by the end of Refueling Outage 16. Refueling Outage 16 is currently scheduled to start in March 2001.

Very truly yours,

A handwritten signature in black ink, appearing to read "L. Hopkins".

Lawrence A. Hopkins  
Plant Manager - NMP1

LAH/KLE/jlb

xc: Mr. H. J. Miller, Regional Administrator, Region I  
Mr. G. K. Hunegs, NRC Senior Resident Inspector  
Records Management

IE22