DWG NO 0-ABVAC-01

FROM CONTAINMENT PURGE SYSTEM EXHAUST
38" DIA.
LAUNDRY FACILITY DRYERS EXHAUST
FROM RADWASTE BUILDING EXHAUST
FROM CONTAINMENT PURGE SYSTEM EXHAUST
1" SS TUBING
RdD 6304
RD 14
FT 6584
FE 6584
STACK
SN 3400
PX 3407A
FROM UNIT 4 SFP & NEW FUEL STORAGE AREA VENTILATION
ELECTRICAL PENETRATION ROOM
ELECTRICAL EQUIPMENT ROOM
DECON ROOM
FD-15A
PX 3408A
MO-3420
V8A
AUXILIARY BLDG EXHAUST FANS
PX 3408B
MO-3419
V8B
FAN ROOM
FROM WASTE GAS RELEASE HEADER
dPI 1407
dPI 1405
MO-3410
MO-3409
PX 1484
48x30
RHR HX ROOM UNIT 4
PIPE AND VALVE ROOM UNIT 4
1,045 CFM
RHR PUMP ROOM UNIT 4
PIPEWAYS UNIT 4
5,375 CFM
CONTAINMENT SPRAY PUMP ROOM UNIT 4
SAMPLE ROOM UNIT 4
PASS ROOM
46x20
24x12
48x22
46x12
SEAL WATER HEAT EXCH ROOM UNIT 4
NON-REGEN. HEAT EXCH ROOM UNIT 4
CHARGING PUMP ROOM UNIT 4
PX 1490
LAUNDRY ROOM
5x8
12x16
12x16
dPI 6122
F-31
SUPPLY AIR
O.A.
AUXILIARY BLDG SUPPLY FAN
V10
AUXILIARY BLDG ROOF
V11
AUXILIARY BLDG SUPPLY FAN
HP
INSTRUMENT LAB
HP NOTE 2
RADIOACTIVE LAB
EXHAUST HOOD FAN
AIR EXHAUST
GAS ANALYZER ROOM
PX 3408A
PX 1488
MO-3408
GAS DECAY TANKS ROOM
GAS DECAY TANKS ROOM
BORIC ACID EVAP ROOM
BORIC ACID EVAP ROOM
HOLD UP TANK ROOM NO. 1
MO-3406
MO-3423
MO-3407
18x18
ELECTRICAL PENETRATION ROOM
FD-19A
HOLD UP TANK ROOM NO. 2
NON DUCTED PATH
HOLD UP TANK ROOM NO. 3
40x30
GAS STRIPPER ROOM
GAS STRIPPER ROOM
205 CFM
BASEMENT
TANK ROOM
PUMP ROOM
PIPE WAYS UNIT 3
SAMPLE ROOM UNIT 3
CONCENTRATE HOLDING TANK ROOM
30x30
30x25
CONTAINMENT SPRAY PUMPS ROOM UNIT 3
PIPE AND VALVE ROOM UNIT 3
960 CFM
24x12
RHR HX ROOM UNIT 3
BORIC ACID TANKS & PUMPS ROOM
RHR PUMP ROOM UNIT 3
RHR PUMP ROOM UNIT 3
40x30
4,930 CFM
26x20
26x16
20x16
10x12
ION EXCHANGE ROOM
ION EXCHANGE ROOM
DEBORATING ROOM
MONITOR TANK ROOM
CHARGING PUMP ROOM UNIT 3
NON REGENERATIVE HX ROOM UNIT 3
SEAL WATER HX ROOM UNIT 3
SAFETY INJECTION PUMP ROOM

D-002

NOTES:
1. FOR GENERAL NOTES & LEGEND SEE DWG NO. 0-NOTES-01.

FPL

AUXILIARY BUILDING VENTILLATION

FLORIDA POWER & LIGHT
TURKEY POINT NUCLEAR UNITS 3 & 4
LICENSE RENEWAL BOUNDARY DRAWING

DRAWING NUMBER	REVISION
0-ABVAC-01	0

0ABVAC01.DWG