DWG NO 3-BA-01

OUTSIDE CONTAINMENT
INSIDE CONTAINMENT

FROM BREATHING AIR SYSTEM COMPRESSORS

BA-3-112 | BA-3-113 | T.C. | I.F. | 2 1/2" | PdS 6165 | L.O. | SV-3-6165 | S | FROM INSTRUMENT AIR | CV-3-6165 | DB | LR | BA-3-114 | 1" | T.C.

2 1/2x2 | P-30 | 2 1/2x2 | 2 1/2" | LR | BB | BA-3-201 | I.F. | BA-3-202 | T.C. | BA-3-203

PX 3410 | BA-3-207 | L.C. | BA-3-208 | PI 6187 | BA-3-209 | BA-3-266

BA-3-204 | I.F. | PCV-3-6180 | I.F. | BA-3-206 | PC 6180 | BA-3-205 | RV-3-6242

BA-3-267

BA-3-210 | I.F. | BA-3-211 | PI 3-6171 | BA-3-212 | STEAM GEN C STATION EL 62'-0"

BA-3-213 | I.F. | BA-3-214 | PI 3-6172 | BA-3-215 | REACTOR COOLANT PUMP C MOTOR STATION EL 34'-6"

BA-3-216 | I.F. | BA-3-217 | PI 3-6170 | BA-3-218 | STEAM GEN C STATION EL 18'-0"

BA-3-219 | I.F. | BA-3-220 | PI 3-6168 | BA-3-221 | FLUX MAPPING STATION EL 34'-6"

BA-3-222 | I.F. | BA-3-223 | PI 3-6167 | BA-3-224 | STEAM GEN B STATION EL 62'-0"

BA-3-225 | I.F. | BA-3-226 | PI 3-6169 | BA-3-227 | REACTOR COOLANT PUMP B MOTOR STATION EL 34'-6"

BA-3-228 | I.F. | BA-3-229 | PI 3-6176 | BA-3-230 | STEAM GEN B STATION EL 18'-0"

BA-3-231 | I.F. | BA-3-232 | PI 3-6173 | BA-3-233 | STEAM GEN LEVEL INDICATION STATION EL 34'-6"

BA-3-234 | I.F. | BA-3-235 | PI 3-6177 | BA-3-236 | PRESSURIZER STATION EL 62'-0"

BA-3-237 | I.F. | BA-3-238 | PI 3-6174 | BA-3-239 | STEAM GEN A STATION EL 18'-0"

BA-3-240 | I.F. | BA-3-241 | PI 3-6178 | BA-3-242 | REACTOR COOLANT PUMP A MOTOR STATION EL 34'-6"

BA-3-243 | I.F. | BA-3-244 | PI 3-6175 | BA-3-245 | FUEL TRANSFER CANAL EL 62'-0"

BA-3-246 | I.F. | BA-3-247 | PI 3-6179 | BA-3-248 | STEAM GEN A STATION EL 62'-0"

D-012

NOTES:

1. FOR GENERAL NOTES & LEGEND SEE DWG NO. 0-NOTES-01.

FPL

BREATHING AIR

FLORIDA POWER & LIGHT
TURKEY POINT NUCLEAR UNIT 3
LICENSE RENEWAL BOUNDARY DRAWING

DRAWING NUMBER	REVISION
3-BA-01	0

3BA01.DWG