DWG NO 4-CCW-04

OUTSIDE CONTAINMENT | INSIDE CONTAINMENT

TO CCW RETURN HEADERS TRAIN A & B 4-CCW-02 (C-8)

FROM CCW SUPPLY HEADERS TRAIN A & B 4-CCW-02 (A-8)

FROM 40-1716 3-IA-09 (D-7)

FROM INSTRUMENT AIR

EXCESS LETDOWN HX 4E202 4-CVCS-03

4V1C NORMAL CONTAINMENT COOLER 4-E/NCC-01

4V1D NORMAL CONTAINMENT COOLER 4-E/NCC-01

4V2B CRDM COOLER 4-E/NCC-01

4V1B NORMAL CONTAINMENT COOLER 4-E/NCC-01

4V2A CRDM COOLER 4-E/NCC-01

4V1A NORMAL CONTAINMENT COOLER 4-E/NCC-01

UPPER & THRUST BRG OIL COOLER

LOWER BEARING OIL COOLER

△ P ACROSS THERMAL BARRIER 25 PSID
△ T ABOUT 22°F

THERMAL BARRIER COOLING COIL

REACTOR COOLANT PUMP 4P200B 4-RCS-03

REACTOR COOLANT PUMP 4P200C 4-RCS-03

REACTOR COOLANT PUMP 4P200A 4-RCS-03

PRISHIELD COOLER A1 | PRISHIELD COOLER B1 | PRISHIELD COOLER A2 | PRISHIELD COOLER B2

PRIMARY SHIELD COOLERS (ABANDONED IN PLACE)

OUTSIDE THE SCOPE OF LICENSE RENEWAL

NOTES:

1. FOR GENERAL NOTES & LEGEND SEE DWG 0-NOTES-01.
2. ALL PIPING INSIDE CONTAINMENT DEPICTED ON THIS DRAWING ARE WITHIN THE SEISMIC/Q-BOUNDARY AND ARE SAFETY RELATED.
3. ALL SAFETY-RELATED PIPING AND ASSOCIATED COMPONENTS DEPICTED ON THIS DRAWING ARE WITHIN THE SCOPE OF LICENSE RENEWAL UNLESS NOTED OTHERWISE.

D-025

FPL

COMPONENT COOLING WATER

FLORIDA POWER & LIGHT
TURKEY POINT NUCLEAR UNIT 4
LICENSE RENEWAL BOUNDARY DRAWING

DRAWING NUMBER	REVISION
4-CCW-04	0

4CCW04.DWG