



September 7, 2000
RC-00-0302

Document Control Desk
U. S. Nuclear Regulatory Commission
Washington, DC 20555

Gentlemen:

Subject: VIRGIL C. SUMMER NUCLEAR STATION
DOCKET NO. 50/395
OPERATING LICENSE NO. NPF-12
SPECIAL REPORT 2000-04

Stephen A. Byrne
Vice President
Nuclear Operations
803.345.4622

South Carolina Electric and Gas Company is submitting this Special Report pursuant to the requirements of Technical Specification 3.3.3.4, Action a.

On August 22, 2000, at 1805 hours, the Meteorological Site Number One 10 and 61 Meter Level Wind Speed and Direction Transmitters were declared inoperable due to indication errors. This equipment degradation resulted from electronic noise. Extensive troubleshooting eventually located the problem and capacitors were installed to remove the noise from the circuitry. The equipment was returned to an operable status on August 31, 2000 at 1705 hours.

If you require further information, please contact Mr. Charles McKinney at (803) 345-4723.

Very truly yours,

Stephen A. Byrne

CJM/SAB

c: N. Lorick
T. G. Eppink
R. J. White
L. A. Reyes
K. R. Cotton
NRC Resident Inspector

J. B. Knotts, Jr.
INPO Records Center
RTS (O-C-00-1093)
File (818.08)
DMS (RC-00-0302)

JE22

NUCLEAR EXCELLENCE – A SUMMER TRADITION!

South Carolina Electric & Gas Co.
Virgil C. Summer Nuclear Station
P. O. Box 88
Jenkinsville, South Carolina
29065

803.345.5209
803.635.1461