

September 15, 2000

Mr. H. L. Sumner, Jr.
Vice President - Nuclear
Hatch Project
Southern Nuclear Operating
Company, Inc.
Post Office Box 1295
Birmingham, Alabama 35201-1295

SUBJECT: CORRECTION TO AMENDMENT NO. 211 - EDWIN I. HATCH NUCLEAR
PLANT, UNIT 1 (TAC NO. M99073)

Dear Mr. Sumner:

On June 2, 1998, the Commission issued Amendment No. 211 to Facility Operating License No. DPR-57 for the Edwin I. Hatch Nuclear Plant, Unit 1, in response to your application dated May 30, 1997, as supplemented by letter dated April 1, 1998. The amendment revises the Technical Specifications (TS) requirements to reflect a design modification that changes the power sources to valves associated with the low pressure coolant injection mode of the residual heat removal system.

It was recently discovered that TS page 3.8-20 was issued with a typographical error. The marked up copy of that page, which was submitted with the May 30, 1997, application, stated in the parenthesis in TS 3.8.2.f, "either a Unit 2 DG or the swing DG". Section 2.3 of the staff Safety Evaluation enclosed with the June 2, 1998, amendment stated "LCO 3.8.2.f requires that either one of the Unit 2 DGs or the swing DG be operable." However, the amendment was incorrectly issued with "Unit 1 DG" instead of "Unit 2 DG" in the parenthesis of TS 3.8.2.f. Enclosed is a corrected TS page 3.8-20.

We regret any inconvenience this may have caused you.

Sincerely,

/RA/

Leonard N. Olshan, Senior Project Manager, Section 1
Project Directorate II
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-321

Enclosure: As stated

September 15, 2000

Mr. H. L. Sumner, Jr.
Vice President - Nuclear
Hatch Project
Southern Nuclear Operating
Company, Inc.
Post Office Box 1295
Birmingham, Alabama 35201-1295

SUBJECT: CORRECTION TO AMENDMENT NO. 211 - EDWIN I. HATCH NUCLEAR
PLANT, UNIT 1 (TAC NO. M99073)

Dear Mr. Sumner:

On June 2, 1998, the Commission issued Amendment No. 211 to Facility Operating License No. DPR-57 for the Edwin I. Hatch Nuclear Plant, Unit 1, in response to your application dated May 30, 1997, as supplemented by letter dated April 1, 1998. The amendment revises the Technical Specifications (TS) requirements to reflect a design modification that changes the power sources to valves associated with the low pressure coolant injection mode of the residual heat removal system.

It was recently discovered that TS page 3.8-20 was issued with a typographical error. The marked up copy of that page, which was submitted with the May 30, 1997, application, stated in the parenthesis in TS 3.8.2.f, "either a Unit 2 DG or the swing DG". Section 2.3 of the staff Safety Evaluation enclosed with the June 2, 1998, amendment stated "LCO 3.8.2.f requires that either one of the Unit 2 DGs or the swing DG be operable." However, the amendment was incorrectly issued with "Unit 1 DG" instead of "Unit 2 DG" in the parenthesis of TS 3.8.2.f. Enclosed is a corrected TS page 3.8-20.

We regret any inconvenience this may have caused you.

Sincerely,

/RA/

Leonard N. Olshan, Senior Project Manager, Section 1
Project Directorate II
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-321

Enclosure: As stated

<u>Distribution:</u>	OChopra	RidsOgcRp
PUBLIC	RidsAcrsAcnwMailCenter	SCahill, RII
PD II-1 Rdg.	RidsRgn2MailCenter	RidsNrrPMLOlshan
RidsNrrDlpmLpdii1	RidsNrrDlpmLpdii	RidsNrrDripRtsb (WBeckner)
RidsNrrLACHawes	GHill (2) (paper copies)	

OFFICE	PDI-1/PM	PDI-1/LA	PDI-1/SC
NAME	LOlshan:cn	CHawes	REmch
DATE	9/15/00	9/14/00	9/15/00

DOCUMENT NAME: C:\corr211.wpd

OFFICIAL RECORD COPY

Edwin I. Hatch Nuclear Plant

cc:

Mr. Ernest L. Blake, Jr.
Shaw, Pittman, Potts
and Trowbridge
2300 N Street, NW.
Washington, DC 20037

Mr. D. M. Crowe
Manager, Licensing
Southern Nuclear Operating
Company, Inc.
P. O. Box 1295
Birmingham, Alabama 35201-1295

Resident Inspector
Plant Hatch
11030 Hatch Parkway N.
Baxley, Georgia 31531

Mr. Charles H. Badger
Office of Planning and Budget
Room 610
270 Washington Street, SW.
Atlanta, Georgia 30334

Harold Reheis, Director
Department of Natural Resources
205 Butler Street, SE., Suite 1252
Atlanta, Georgia 30334

Steven M. Jackson
Senior Engineer - Power Supply
Municipal Electric Authority
of Georgia
1470 Riveredge Parkway, NW
Atlanta, Georgia 30328-4684

Charles A. Patrizia, Esquire
Paul, Hastings, Janofsky & Walker
10th Floor
1299 Pennsylvania Avenue
Washington, DC 20004-9500

Chairman
Appling County Commissioners
County Courthouse
Baxley, Georgia 31513

Mr. J. D. Woodard
Executive Vice President
Southern Nuclear Operating
Company, Inc.
P. O. Box 1295
Birmingham, Alabama 35201-1295

Mr. P. W. Wells
General Manager, Edwin I. Hatch
Nuclear Plant
Southern Nuclear Operating
Company, Inc.
U.S. Highway 1 North
P. O. Box 2010
Baxley, Georgia 31515

Mr. L. M. Bergen
Resident Manager
Oglethorpe Power Corporation
Edwin I. Hatch Nuclear Plant
P. O. Box 2010
Baxley, Georgia 31515