TABLE 3.7-6 (Continued)

AREA TEMPERATURE MONITORING

<u>AREA</u>	TEMPERATURE LIMIT (°F)
7. FUEL BUILDING	
FB-02, Fuel Pool Pump Cubicles, El 24'6"	≤ 119
FB-03, General Area, El 52'4"	≤ 108
8. <u>FUEL OIL VAULT</u>	
FV-01, Diesel Fuel Oil Vault	≤ 95
9. HYDROGEN RECOMBINER BUILDING	
HR-01, Recombiner Skid Area, El 24'6"	≤ 125
HR-02, Controls Area, El 24'6"	< 110
HR-03, Sampling Area, El 24'6"	≤ 110
HR-04, HVAC Area, El 37'6"	≤ 110.
10. MAIN STEAM VALVE BUILDING	
MS-01, Areas above El. 58'0"	≤ 140
MS-02, Areas below El. 58'0"	≤ 140
11. TURBINE BUILDING	
TB-01, Entire Building	≤ 115
12. <u>TUNNEL</u>	
TN-02, Pipe Tunnel-Auxiliary, Fuel and ESF Building	≤ 112
13. <u>YARD</u>	
YD-01, Yard	≤ 115

DF04