



**Duke Power Company**  
A Duke Energy Company  
Energy Center  
P.O. Box 1006  
Charlotte, NC 28201-1006

September 12, 2000

U.S Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, D.C. 20555

Subject: Duke Energy Corporation  
Oconee Nuclear Station, Units 1, 2, and 3  
Docket Numbers 50-269, 50-270 and 50-287  
Monthly Performance and Operation Status-August, 2000

Please find attached information concerning the performance and operation status of the Oconee Nuclear Station for the month of August, 2000.

Any questions or comments August be directed to Roger A. Williams at (704) 382-5346.

Sincerely,

Terry Dimmery, Manager  
Nuclear Business Support

Attachment  
XC:

L. A. Reyes, Regional Administrator  
USNRC, Region II

Dave LaBarge, Project Manager  
USNRC, ONRR

INPO Records Center

Ms. Margaret Aucoin  
Nuclear Assurance Corporation

Dottie Sherman, ANI Library  
American Nuclear Insurers

Oconee NRC Inspector

IE 24

Document Control Desk  
U.S. NRC - Oconee

bxc:

L. E. Nicholson (ON03RC)  
RGC Site Licensing File  
ELL (EC050)

# Operating Data Report

Docket No.	50-269
Date	September 12, 2000
Completed By	Roger Williams
Telephone	704-382-5346

## Operating Status

1. Unit Name: Oconee 1
2. Reporting Period: August 1, 2000 - August 31, 2000
3. Licensed Thermal Power (MWt): 2568
4. Nameplate Rating (Gross MWe): 934
5. Design Electrical Rating (Net Mwe): 886
6. Maximum Dependable Capacity (Gross MWe): 886
7. Maximum Dependable Capacity (Net MWe): 846
8. If Changes Occured in Capacity Ratings (Items Number 3-7) Since Last Report, Give Reasons:

**Notes: Year-to-date and cumulative capacity factors are calculated using a weighted average for maximum dependable capacity.**

---

9. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

10. Reason for Restrictions, If any: \_\_\_\_\_

---

	This Month	YTD	Cumulative
11. Hours in Reporting Period	744.0	5855.0	237816.0
12. Number of Hours Reactor was Critical	744.0	5473.5	185301.7
13. Reactor Reserve Shutdown Hours	0.0	0.0	0.0
14. Hours Generator On-Line	744.0	5451.7	182065.3
15. Unit Reserve Shutdown Hours	0.0	0.0	0.0
16. Gross Thermal Energy Generated (MWH)	1909359	13985534	449308388
17. Gross Electrical Energy Generated (MWH)	655025	4875195	155311285
18. Net Electrical Energy Generated (MWH)	625152	4658658	147652694
19. Unit Service Factor	100.0	93.1	76.6
20. Unit Availability Factor	100.0	93.1	76.6
21. Unit Capacity Factor (Using MDC Net)	99.3	94.1	72.7
22. Unit Capacity Factor (Using DER Net)	94.8	89.8	70.1
23. Unit Forced Outage Rate	0.0	6.9	9.8
24. Shutdown Scheduled Over Next 6 Months (Type, Date and Duration of Each)			

25. If ShutDown At End Of Report Period, Estimated Date of Startup

26. Units in Test Status (Prior to Commercial Operation)

	Forecast	Achieved
Initial Criticality	_____	_____
Initial Electricity	_____	_____
Commercial Operation	_____	_____

NRC Calculated from Generator Nameplate Data:  
 1 037 937 KVA x 0.90 Pf=934 MW

## UNIT SHUTDOWNS

**DOCKET NO.** 50-269

**UNIT NAME:** Oconee 1

**DATE:** September 12, 2000

**COMPLETED BY:** Roger Williams

**TELEPHONE:** 704-382-5346

**REPORT MONTH:** August, 2000

No.	Date:	Type F - Forced S - Scheduled	Duration Hours	(1) Reason	(2) Method of Shutdown R/X	Licensed Event Report No.	Cause and Corrective Action to Prevent Recurrence
			<b>No</b>	<b>Outages</b>	<b>for the Month</b>		

**Summary:**

**(1) Reason**

- A - Equipment failure (Explain)
- B - Maintenance or Test
- C - Refueling
- D - Regulatory restriction
- E - Operator Training/License Examination
- F - Administrative
- G - Operator Error (Explain)
- H - Other (Explain)

**(2) Method**

- 1 - Manual
- 2 - Manual Trip/Scram
- 3 - Automatic Trip/Scram
- 4 - Continuation
- 5 - Other (Explain)

MONTHLY REFUELING INFORMATION REQUEST

1. Facility name: Oconee Unit 1
2. Scheduled next refueling shutdown: November, 2000
3. Scheduled restart following refueling: December, 2000

THE PROJECT MANAGER HAS BEEN ADVISED BY SEPARATE COMMUNICATION OF ANY T.S. CHANGE OR LICENSE AMENDMENT. THEREFORE, QUESTIONS 4 THROUGH 6 WILL NO LONGER BE MAINTAINED IN THIS REPORT.

4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment?

If yes, what will these be?

If no, has reload design and core configuration been reviewed by Safety Review Committee regarding unreviewed safety questions?

5. Scheduled date(s) for submitting proposed licensing action and supporting information.
6. Important licensing considerations (new or different design or supplier, unreviewed design or performance analysis methods, significant changes in design or new operating procedures).
7. Number of Fuel assemblies           (a)     in the core: 177  
   (b)     in the spent fuel pool: 998\*  
   (c)     in the ISFSI: 1296\*\*\*\*
8. Present licensed fuel pool capacity: 1312  
Size of requested or planned increase: \*\*
9. Projected date of last refueling which can be accommodated by present capacity: January 2005\*\*\*

DUKE POWER COMPANY

DATE: September 12, 2000

Name of Contact:

R. A. Williams

Phone: (704) - 382-5346

\* Represents the combined total for Units 1 and 2

\*\* On March 29, 1990, received a license for ISFSI which will store 2112 assemblies

\*\*\* We currently have 60 modules of which 49 modules are loaded.  
Additional modules will be built on an as-needed basis.

\*\*\*\* Represents the combined total for Units 1, 2, and 3

# Operating Data Report

Docket No.	<u>50-270</u>
Date	<u>September 12, 2000</u>
Completed By	<u>Roger Williams</u>
Telephone	<u>704-382-5346</u>

## Operating Status

1. Unit Name: Oconee 2
2. Reporting Period: August 1, 2000 - August 31, 2000
3. Licensed Thermal Power (MWt): 2568
4. Nameplate Rating (Gross MWe): 934
5. Design Electrical Rating (Net Mwe): 886
6. Maximum Dependable Capacity (Gross MWe): 886
7. Maximum Dependable Capacity(Net MWe): 846
8. If Changes Occured in Capacity Ratings (Items Number 3-7) Since Last Report, Give Reasons:

**Notes: Year-to-date and cumulative capacity factors are calculated using a weighted average for maximum dependable capacity.**

- 
9. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_
  10. Reason for Restrictions, If any: \_\_\_\_\_
- 

	This Month	YTD	Cumulative
11. Hours in Reporting Period	744.0	5855.0	227736.0
12. Number of Hours Reactor was Critical	744.0	5855.0	182412.3
13. Reactor Reserve Shutdown Hours	0.0	0.0	0.0
14. Hours Generator On-Line	744.0	5855.0	179986.5
15. Unit Reserve Shutdown Hours	0.0	0.0	0.0
16. Gross Thermal Energy Generated (MWH)	1909359	28937458	457162264
17. Gross Electrical Energy Generated (MWH)	656753	5219829	152146172
18. Net Electrical Energy Generated (MWH)	627819	5001990	144933890
19. Unit Service Factor	100.0	100.0	79.0
20. Unit Availability Factor	100.0	100.0	79.0
21. Unit Capacity Factor (Using MDC Net)	99.7	101.0	74.5
22. Unit Capacity Factor (Using DER Net)	95.2	96.4	71.8
23. Unit Forced Outage Rate	0.0	0.0	9.4
24. Shutdown Scheduled Over Next 6 Months (Type, Date and Duration of Each)			

25. If ShutDown At End Of Report Period, Estimated Date of Startup
26. Units in Test Status (Prior to Commercial Operation)

	Forecast	Achieved
Initial Criticality	_____	_____
Initial Electricity	_____	_____
Commercial Operation	_____	_____

NRC Calculated from Generator Nameplate Data:  
 1 037 937 KVA x 0.90 Pf=934 MW

**UNIT SHUTDOWNS**

**DOCKET NO.** 50-270  
**UNIT NAME:** Oconee 2  
**DATE:** September 12, 2000  
**COMPLETED BY:** Roger Williams  
**TELEPHONE:** 704-382-5346

**REPORT MONTH:** August, 2000

No.	Date:	Type F - Forced S - Scheduled	Duration Hours	(1) Reason	(2) Method of Shutdown R/X	Licensed Event Report No.	Cause and Corrective Action to Prevent Recurrence
			<b>No</b>	<b>Outages</b>	<b>for the Month</b>		

**Summary:**

**(1) Reason**

- A - Equipment failure (Explain)
- B - Maintenance or Test
- C - Refueling
- D - Regulatory restriction
- E - Operator Training/License Examination
- F - Administrative
- G - Operator Error (Explain)
- H - Other (Explain)

**(2) Method**

- 1 - Manual
- 2 - Manual Trip/Scram
- 3 - Automatic Trip/Scram
- 4 - Continuation
- 5 - Other (Explain)



# Operating Data Report

Docket No.	<u>50-287</u>
Date	<u>September 12, 2000</u>
Completed By	<u>Roger Williams</u>
Telephone	<u>704-382-5346</u>

## Operating Status

1. Unit Name: Oconee 3
2. Reporting Period: August 1, 2000 - August 31, 2000
3. Licensed Thermal Power (MWt): 2568
4. Nameplate Rating (Gross MWe): 934
5. Design Electrical Rating (Net MWe): 886
6. Maximum Dependable Capacity (Gross MWe): 886
7. Maximum Dependable Capacity (Net MWe): 846
8. If Changes Occured in Capacity Ratings (Items Number 3-7) Since Last Report, Give Reasons:

**Notes: Year-to-date and cumulative capacity factors are calculated using a weighted average for maximum dependable capacity.**

---

9. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

10. Reason for Restrictions, If any: \_\_\_\_\_

---

	This Month	YTD	Cumulative
11. Hours in Reporting Period	744.0	5855.0	225383.0
12. Number of Hours Reactor was Critical	744.0	4965.7	177017.8
13. Reactor Reserve Shutdown Hours	0.0	0.0	0.0
14. Hours Generator On-Line	744.0	4801.7	174432.9
15. Unit Reserve Shutdown Hours	0.0	0.0	0.0
16. Gross Thermal Energy Generated (MWH)	1910592	41147991	464210893
17. Gross Electrical Energy Generated (MWH)	658552	4264907	150482034
18. Net Electrical Energy Generated (MWH)	629370	4071008	143533199
19. Unit Service Factor	100.0	82.0	77.4
20. Unit Availability Factor	100.0	82.0	77.4
21. Unit Capacity Factor (Using MDC Net)	100.0	82.2	74.6
22. Unit Capacity Factor (Using DER Net)	95.5	78.5	71.9
23. Unit Forced Outage Rate	0.0	2.4	9.8
24. Shutdown Scheduled Over Next 6 Months (Type, Date and Duration of Each)			

25. If ShutDown At End Of Report Period, Estimated Date of Startup

26. Units in Test Status (Prior to Commercial Operation)

	Forecast	Achieved
Initial Criticality	_____	_____
Initial Electricity	_____	_____
Commercial Operation	_____	_____

NRC Calculated from Generator Nameplate Data:  
 1 037 937 KVA x 0.90 Pf=934 MW

### UNIT SHUTDOWNS

DOCKET NO. 50-287

UNIT NAME: Oconee 3

DATE: September 12, 2000

COMPLETED BY: Roger Williams

TELEPHONE: 704-382-5346

REPORT MONTH: August, 2000

No.	Date:	Type F - Forced S - Scheduled	Duration Hours	(1) Reason	(2) Method of Shutdown R/X	Licensed Event Report No.	Cause and Corrective Action to Prevent Recurrence
			<b>No</b>	<b>Outages</b>	<b>for the Month</b>		

**Summary:**

**(1) Reason**

- A - Equipment failure (Explain)
- B - Maintenance or Test
- C - Refueling
- D - Regulatory restriction
- E - Operator Training/License Examination
- F - Administrative
- G - Operator Error (Explain)
- H - Other (Explain)

**(2) Method**

- 1 - Manual
- 2 - Manual Trip/Scram
- 3 - Automatic Trip/Scram
- 4 - Continuation
- 5 - Other (Explain)



OCONEE NUCLEAR STATION

MONTHLY OPERATING STATUS REPORT

JULY 2000

1. Personnel Exposure -

The total station liquid release for JULY has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.

The total station gaseous release for JULY has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.