



Monticello Nuclear Generating Plant
2807 West County Road 75
Monticello, MN 55362-9637

Operated by Nuclear Management
Company LLC

September 8, 2000

US Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

MONTICELLO NUCLEAR GENERATING PLANT
Docket No. 50-263 License No. DPR-22

Submittal of Monticello Monthly Operating Report for August 2000

In accordance with Monticello Technical Specification 6.7.A.3, the report of operating statistics for the Monticello Nuclear Generating Plant for the month of August is provided.

Please contact Marcus H. Voth, Project Manager – Licensing at (763) 271-5116 if you require further information.

M H Voth

Marcus H. Voth
Project Manager - Licensing
Nuclear Energy Engineering Dept.

c: Regional Administrator – III, NRC
NRR Project Manager, NRC
Sr Resident Inspector, NRC
Minnesota Dept. of Commerce
J E Silberg

JE24

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-263
 UNIT Monticello
 DATE 9-1-0
 COMPLETED BY H. H. Paustian
 TELEPHONE 612/295-5151

MONTH OF August

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)	DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
1	568.	17	572.
2	566.	18	573.
3	572.	19	573.
4	564.	20	574.
5	570.	21	575.
6	571.	22	574.
7	568.	23	574.
8	567.	24	574.
9	571.	25	571.
10	566.	26	562.
11	565.	27	242.
12	568.	28	-8.
13	567.	29	-8.
14	566.	30	-8.
15	566.	31	-9.
16	572.		

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

NARRATIVE SUMMARY OF OPERATING EXPERIENCE

DOCKET NO. 50-263
DATE 9-1-0
COMPLETED BY H. H. Paustian
TELEPHONE 612/295-5151

MONTH AUG

08-01-00
to Power operation.
08-27-00

08-27-00 Shutdown to repair 345kv high side disconnect bolted
to connection overheating problem.
08-31-00

Note: Power operation defined as essentially 100% of rated power except for weekend load drops for specified surveillance testing.

