

FENOC

FirstEnergy Nuclear Operating Company

50-440

Perry Nuclear Power Plant
10 Center Road
Perry, Ohio 44081

John K. Wood
Vice President, Nuclear

440-280-5224
Fax: 440-280-8029

September 14, 2000
PY-CEI/LCDU-0059L

Attention: Robert Shelby, Mentor Waste Facility
Lake County Department of Utilities
P.O. Box 490
Painesville, Ohio 44077-0490

Ladies and Gentlemen:

Enclosed are the results of an isotopic analysis performed for industrial wastewater from the Perry Nuclear Power Plant. No radioactive material attributable to the Perry Nuclear Power Plant was detected.

If you have questions or require additional information, please contact Ms. Donna Benz at (440) 280-5514.

Very truly yours,



DGB:sc

Enclosures

cc: NRC Region III
NRC Resident Inspector Office
NRC Project Manager
NRC Document Control Desk (Docket No. 50-440)

COO1

Note: **NOTE**

Sample Approval Screen

System Name: **ENVIRONMEN** Desc: **Environmental Sample**
MPL Number: **SEWAGE** Desc: **Sewage Lift Station**
Reason/Freq: **Q** Desc: **Quarterly**
Mode Number: **6** Desc: **At All Times**
Sample ID : **290515** Date Collected: **10:15:00 9/06/00**

Approval Status: (AC -Accepted, Reject samples at the rejection screen)

Status: **PV**

Isotopic by Gamma Spectroscopy

Limit:

0.00 to 0.00

0.00E+00 uCi/ml

MCA: **1002**

NOTE: A numeric result of zero indicates 'None Detected'