CONTAINMENT SYSTEMS

1 1

ت . .

SURVEILLANCE REQUIREMENTS (Continued)

- b. At least once per 24* months or (1) after any structural maintenance on the EEFA filter or charcoal adsorber nousings, or (2) following painting, fire, or chemical release in any ventilation zone communicating with the subsystem by:
 - Verifying that the subsystem satisfies the in-place penetration and bypass leakage testing acceptance criteria of less than 0.05% and uses the test procedure guidance in Regulatory Positions C.5.a, C.3.c and C.5.d of Regulatory Guide 1.52, Revision 2, March 1978, and the system flow rate is 5764 cfm + 10%.

..

- 2. Verifying within 31 days after removal that a laboratory analysis of a representative carbon sample obtained in accordance with Regulatory Position C.6.b of Regulatory Guide 1.52, Revision 2, March 1978, shows the methyl iodide penetration of less than 0.5% when tested in accordance with ASTM D3803-1989 at a temperature of 30°C (86°F', at a relative humidity of 70% and at a face velocity of 66 fpm.
- 3. Verify that when the fan is running the subsystem flowrate is 2000 cfm minimum from each reactor enclosure (Zones I and II) and 2200 cfm minimum from the refueling area (Zone III) when tested in accordance with ANSI N510-1990.
- 4. Verify that the pressure drop across the refueling area to SGTS prefilter is less than 0.25 inches water gage while operating at a flow rate of 2400 cfm = 10%.
- c. After every 720 hours of charcoal adsorber operation by verifying within 31 pays after removal that a laboratory analysis of a representative carbon sample obtained in accordance with Regulatory Position 0.6.b of Regulatory Guide 1.52, Revision 2, March 1978, snows the methyl lodide penetration of less than 0.5% when tested in accordance with ASTM D3803-1989 at a temperature of 30°C (86°F), at a relative numidaty of 70% and at a face velocity of 66 fpm.
- d. At least ince per 24 months by:
 - Verifying that the pressure drop across the combined HEPA filters and charcoal adsorber banks is less than 9.1 inches water gauge while operating the filter train at a flow rate of 8400 cfm ± 10%.

*Surveillance interval is an exception to the guidance provided in Regulatory Guide 1.52, Revision 2, March 1978.

LINERICK - UNIT 1

3/4 6-53

Amendment No: 6, 33, 71, 122,144

÷. 000

ويتدوي فيلامهم المعالي

46007

CONTAINMENT SYSTEMS

SURVEILLANCE REQUIREMENTS (Continued)

- b. At least once per 24* months or (1) after any structural maintenance on the REPA filter or charcoal adsorber housings, or (2) following painting, fire, or chemical release in any ventilation zone communicating with the subsystem by:
 - Verifying that the subsystem satisfies the in-place penetration and bypass leakage testing acceptance criteria of less than 0.05% and uses the test procedure guidance in Regulatory Positions C.5.a, C.5.c and C.5.d of Regulatory Guide 1.52, Revision 2, March 1978, and the system flow rate is 5764 cfm ± 10%.
 - 2. Verifying within 31 days after removal that a laboratory analysis of a representative carbon sample obtained in accordance with Regulatory Position C.6.b of Regulatory Guide 1.52, Revision 2, March 1978, snows the methyl iodide penetration of less than 0.5% when tested in accordance with ASTM D3803-1989 at a temperature of 30° C (86°F), at a relative humidity of 70% and at a face velocity of 66 fpm.
 - 3. Verify that when the fam is running the subsystem flowrate is 2800 cfm minimum from each reactor enclosure (Zones I and II) and 2200 cfm minimum from the refueling area (Zone III) when tested in accordance with ANSI N510-1980.
 - 4. Verify that the pressure drop across the refueling area to SGTS prefilter is less than 0.25 inches water gage while operating at a flow rate of 2400 cfm \pm 10%.
- c. After every 720 hours of charcoal adsorber operation by verifying within 31 days after removal that a laboratory analysis of a representative carbon sample obtained in accordance with Regulatory Position C.6.b of Regulatory Guide 1.52, Revision 2, March 1978, shows the methyl iodide penetration of less than 0.5% when tested in accordance with ASTM D3803-1989 at a temperature of 30°C (56°F), at a relative humidity of 70% and at a face velocity of 66 fpm.
- d. At least once per 24 months by:
 - Verifying that the pressure drop across the combined HEPA filters and charcoal adsorber banks is less than 9.1 inches water gauge while operating the filter train at a flow rate of 8400 cfm ± 10%.

*Surveillance interval is an exception to the guidance provided in Regulatory Guide 1.52, Revision 2, March 1976.

LINERICK - UNIT 2

2/4 6-53 Amendment No: 34, 86, 106